

LICENSEE EVENT REPORT

CONTROL BLOCK: _____ (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | J | S | G | S | I | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | _____ | 5

7 8 9 | LICENSEE CODE 14 15 | LICENSE NUMBER 25 26 | LICENSE TYPE 30 57 | CAT 58 80

CON'T

0 1 | L | 6 | 0 | 5 | 0 | 0 | 0 | 2 | 7 | 2 | 7 | 0 | 8 | 1 | 8 | 8 | 2 | 8 | 0 | 9 | 0 | 8 | 8 | 2 | 9

7 8 | REPORT SOURCE 60 61 | DOCKET NUMBER 68 69 | EVENT DATE 74 75 | REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 1830 hours, August 18, 1982, the operator received alarms on the Radiation

0 3 | Monitoring System (RMS). An attempt was made to clear the alarms by advancing the

0 4 | filter paper, however, the alarms did not clear. The Radiation Monitoring System,

0 5 | Channels 1R11A, 1R12A, and 1R12B were declared inoperable and Action Statement

0 6 | 3.3.3.1b Actions 20 and 22 were entered at 1830 hours.

0 7 | _____

0 8 | _____

0 9 | C | I | 11 | B | 12 | X | X | X | X | X | X | X | 14 | X | 15 | Z | 16 |

7 8 | SYSTEM CODE 9 10 | CAUSE CODE 11 | CAUSE SUBCODE 12 | COMPONENT CODE 13 | COMP. SUBCODE 14 | VALVE SUBCODE 15 |

17 | 8 | 2 | 21 | 0 | 6 | 5 | 24 | 0 | 3 | 28 | L | 30 | 0 | 32 |

7 8 | LER/RO REPORT NUMBER 21 22 | SEQUENTIAL REPORT NO. 24 26 | OCCURRENCE CODE 28 29 | REPORT TYPE 30 | REVISION NO. 32 |

A | 18 | Z | 19 | Z | 20 | Z | 21 | 0 | 0 | 0 | 0 | 37 | Y | 23 | N | 24 | Z | 25 | Z | 9 | 9 | 9 | 26

7 8 9 | ACTION TAKEN 33 34 | FUTURE ACTION 35 | EFFECT ON PLANT 36 | SHUTDOWN METHOD 37 | HOURS 40 | ATTACHMENT SUBMITTED 41 | NPRD-4 FORM SUB. 42 | PRIME COMP. SUPPLIER 43 | COMPONENT MANUFACTURER 44 45 46 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | The cause of this occurrence was a torn filter paper which jammed in the unit. The

1 1 | filter paper was replaced and the RMS was tested satisfactorily. At 2200 hours,

1 2 | August 18, 1982, the RMS, Channels 1R11A, 1R12A and 1R12B were declared operable and

1 3 | Action Statement 3.3.3.1b Actions 20 and 22 were terminated.

1 4 | _____

1 5 | E | 28 | 1 | 0 | 0 | 29 | N/A | 30 | A | 31 | Operational Surveillance | 32

7 8 9 | FACILITY STATUS 28 | % POWER 29 | OTHER STATUS 30 | METHOD OF DISCOVERY 31 | DISCOVERY DESCRIPTION 32 |

1 6 | Z | 33 | Z | 34 | N/A | 35 | N/A | 36

7 8 9 | ACTIVITY CONTENT 33 | RELEASED OF RELEASE 34 | AMOUNT OF ACTIVITY 35 | LOCATION OF RELEASE 36 |

1 7 | 0 | 0 | 0 | 37 | Z | 38 | N/A | 39

7 8 9 | PERSONNEL EXPOSURES NUMBER 37 | TYPE 38 | DESCRIPTION 39 |

1 8 | 0 | 0 | 0 | 40 | N/A | 41

7 8 9 | PERSONNEL INJURIES NUMBER 40 | DESCRIPTION 41 |

1 9 | Z | 42 | N/A | 43

7 8 9 | LOSS OF OR DAMAGE TO FACILITY TYPE 42 | DESCRIPTION 43 |

2 0 | N | 44 | N/A | 45

7 8 9 | ISSUED DESCRIPTION 44 | PUBLICITY 45 |

8209240333 820908
PDR ADOCK 05000272
S PDR

NRC USE ONLY

NAME OF PREPARER: R. Heller

PHONE: 609/935-6000 Ext 3078