



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555  
September 7, 1990

Docket No. 50-282  
and 50-306

MEMORANDUM FOR: File

FROM: Dominic DiIanni, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III,  
IV, V & Special Projects  
Office of Nuclear Reactor Regulation

SUBJECT: STATUS OF RESOLVED GENERIC SAFETY ISSUE IMPLEMENTATION  
REQUIREMENTS AT PRAIRIE ISLAND NUCLEAR GENERATING PLANT  
UNITS NOS. 1 AND 2

The current status of resolved Generic Safety Issue (GSI) Implementation Requirements at the Prairie Island facilities are summarized in the enclosures to this memorandum.

Enclosure 1 contains a copy of the information provided by the licensee in its response to Generic Letter 90-04.

Enclosure 2 is a status summary for each GSI applicable to this facility. This status summary is based upon the licensee's response to the Generic Letter, discussions with the licensee and cognizant staff and my review of available NRC records and information.

Those items considered to be incomplete are listed below together with my assessment of the significance of that status and of the licensee's plans for completion.


<u>GSI/(MPA NO.)</u>	<u>TITLE</u>	<u>STATUS</u>
51/L913	Improving the reliability of Open-Cycle Service Water Systems GL 89-13	Target completion date 05/91 was found acceptable.
75/L003	Item 2.2.2 (GL 83-28) Vendor Interface for Safety-Related Components	Licensee will respond by 09/90. This schedule is acceptable.

9009130052 XA  
LPP

99/LE17

RCS/RHR Suction Line Valve  
Interlock on PWRs

Unit No. 1 complete,  
Unit No. 2 target date  
9/90 was found acceptable.



Dominic DiIanni, Project Manager  
Project Directorate III-1  
Division of Reactor Projects - III,  
IV, V & Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:  
As stated