

VIRGINIA ELECTRIC AND POWER COMPANY

SURRY POWER STATION

MONTHLY OPERATING REPORT

REPORT NO. 82-07

JULY, 1982

APPROVED BY:

A handwritten signature in cursive script, appearing to read "J. Wilson", is written over a horizontal line.

Station Manager

<u>Section</u>	<u>Page</u>
Operating Data Report - Unit #1	1
Operating Data Report - Unit #2	2
Unit Shutdowns and Power Reductions - Unit #1	3
Unit Shutdowns and Power Reductions - Unit #2	4
Load Reductions Due to Environmental Restrictions - Unit #1	5
Load Reductions Due to Environmental Restrictions - Unit #2	6
Average Daily Unit Power Level - Unit #1	7
Average Daily Unit Power Level - Unit #2	8
Summary of Operating Experience	9
Amendments to Facility License or Technical Specifications	12
Facility Changes Requiring NRC Approval	13
Facility Changes That Did Not Require NRC Approval	13
Tests and Experiments Requiring NRC Approval	15
Tests and Experiments That Did Not Require NRC Approval	15
Other Changes, Tests and Experiments	16
Chemistry Report	17
Description of All Instances Where Thermal Discharge Limits Were Exceeded	18
Fuel Handling	20
Procedure Revisions That Changed the Operating Mode Described in the FSAR	21
Description of Periodic Tests Which Were Not Completed Within the Time Limits Specified in Technical Specifications	22
Inservice Inspection	23
Reportable Occurrences Pertaining to Any Outage or Power Reductions	24
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #1 - Mechanical Maintenance	25
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #2 - Mechanical Maintenance	27

<u>Section</u>	<u>Page</u>
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #1 - Electrical Maintenance	29
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #2 - Electrical Maintenance	31
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #1 - Instrument Maintenance	33
Maintenance of Safety Related Systems During Outage or Reduced Power Periods - Unit #2 - Instrument Maintenance	35
Health Physics Summary	37
Procedure Deviations reviewed by Station Nuclear Safety and Operating Committee after Time Limits Specified in T. S.	38

OPERATING DATA REPORT

DOCKET NO. 50-280
 DATE 06 AUG 82
 COMPLETED BY SUE D. DUNN
 TELEPHONE 804-357-3184

OPERATING STATUS

1. UNIT NAME SURRY UNIT 1
 2. REPORTING PERIOD 70182 TO 73182
 3. LICENSED THERMAL POWER (MWT) 2441
 4. NAMEPLATE RATING (GROSS MWE) 847.5 | NOTES |
 5. DESIGN ELECTRICAL RATING (NET MWE) 788
 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE) 811
 7. MAXIMUM DEPENDABLE CAPACITY (NET MWE) 775
 8. IF CHANGES OCCUR IN CAPACITY RATINGS N/A
 (ITEMS 3 THROUGH 7) SINCE LAST
 REPORT, GIVE REASONS

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY N/A
 (NET MWE)
 10. REASONS FOR RESTRICTIONS, IF ANY N/A

THIS MONTH YR-TO-DATE CUMULATIVE

11. HOURS IN REPORTING PERIOD	744.0	5087.0	84215.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	736.6	4637.1	50671.6
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	3731.5
14. HOURS GENERATOR ON-LINE	725.7	4569.3	49644.1
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	3736.2
16. GROSS THERMAL ENERGY GENERATED (MWH)	1751564.0	10857907.0	115191173.4
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	543530.0	3419760.0	37238973.0
18. NET ELECTRICAL ENERGY GENERATED (MWH)	514302.0	3242167.0	35319403.0
19. UNIT SERVICE FACTOR	97.5 %	89.8 %	58.9 %
20. UNIT AVAILABILITY FACTOR	97.5 %	89.8 %	63.4 %
21. UNIT CAPACITY FACTOR (USING MDC NET)	89.2 %	82.2 %	54.1 %
22. UNIT CAPACITY FACTOR (USING DER NET)	87.7 %	80.9 %	53.2 %
23. UNIT FORCED OUTAGE RATE	2.5 %	4.2 %	23.9 %
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH)	FALL MAINTENANCE - 10-01-82- 14 Days		

25. IF SHUT DOWN AT END OF REPORT PERIOD,
 ESTIMATE DATE OF STARTUP

26. UNITS IN TEST STATUS FORECAST ACHIEVED
 (PRIOR TO COMMERCIAL OPERATION)

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

OPERATING DATA REPORT

DOCKET NO. 50-281
 DATE 06 AUG 82
 COMPLETED BY C.J. COSTELLO
 TELEPHONE 804-357-3184

OPERATING STATUS

1. UNIT NAME SURRY UNIT 2
 2. REPORTING PERIOD 70182 TO 73182
 3. LICENSED THERMAL POWER (MWT) 2441
 4. NAMEPLATE RATING (GROSS MWE) 847.5 |NOTES|
 5. DESIGN ELECTRICAL RATING (NET MWE) 788
 6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE) 811
 7. MAXIMUM DEPENDABLE CAPACITY (NET MWE) 775
 8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS N/A

9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE) N/A
 10. REASONS FOR RESTRICTIONS, IF ANY N/A

THIS MONTH YR-TO-DATE CUMULATIVE

11. HOURS IN REPORTING PERIOD	744.0	5087.0	81095.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	744.0	4532.1	49392.8
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
14. HOURS GENERATOR ON-LINE	744.0	4461.2	48572.9
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	0.0
16. GROSS THERMAL ENERGY GENERATED (MWH)	1805997.5	10042177.5	113339463.4
17. GROSS ELECTRICAL ENERGY GENERATED (MWH)	580480.0	3223905.0	36901084.0
18. NET ELECTRICAL ENERGY GENERATED (MWH)	550489.0	3043453.0	34972168.0
19. UNIT SERVICE FACTOR	100.0 %	87.7 %	59.9 %
20. UNIT AVAILABILITY FACTOR	100.0 %	87.7 %	59.9 %
21. UNIT CAPACITY FACTOR (USING MDC NET)	95.5 %	77.2 %	55.6 %
22. UNIT CAPACITY FACTOR (USING DER NET)	93.9 %	75.9 %	54.7 %
23. UNIT FORCED OUTAGE RATE	0.0	3.7 %	16.2 %
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH)	FALL MAINTENANCE - 11-05-82--10 Days		

25. IF SHUT DOWN AT END OF REPORT PERIOD, ESTIMATE DATE OF STARTUP

26. UNITS IN TEST STATUS FORECAST ACHIEVED
 (PRIOR TO COMMERCIAL OPERATION)

INITIAL CRITICALITY
 INITIAL ELECTRICITY
 COMMERCIAL OPERATION

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH July 1982

DOCKET NO. 50-280
 UNIT NAME Surry 1
 DATE August 9, 1982
 COMPLETED BY Vivian H. Jones
 TELEPHONE (804) 357-3184 ext. 477

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
82-19	07-13-82	F	18.3	G	3	82-02/03L-0			"B" Reactor trip bypass breaker was not racked in properly prior to Instrument Dept. testing of Train "B" Reactor Trip signals. This caused a Reactor Trip. Operators have been reinstructed on proper procedures for racking in reactor trip bypass breakers and verifying proper insertion of breaker in cubicle.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance of Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

UNIT SHUTDOWNS AND POWER REDUCTIONS

DOCKET NO. 50-281
 UNIT NAME Surry 2
 DATE August 9, 1982
 COMPLETED BY Vivian H. Jones
 TELEPHONE (804) 357-3184 ext. 477

REPORT MONTH July 82

No.	Date	Type ¹	Duration (Hours)	Reason ²	Method of Shutting Down Reactor ³	Licensee Event Report #	System Code ⁴	Component Code ⁵	Cause & Corrective Action to Prevent Recurrence
82-33	7-6-82	S	0.0	F					Reduced power to load follow on orders of the System Operator.

¹
 F: Forced
 S: Scheduled

²
 Reason:
 A-Equipment Failure (Explain)
 B-Maintenance or Test
 C-Refueling
 D-Regulatory Restriction
 E-Operator Training & License Examination
 F-Administrative
 G-Operational Error (Explain)
 H-Other (Explain)

³
 Method:
 1-Manual
 2-Manual Scram.
 3-Automatic Scram.
 4-Other (Explain)

⁴
 Exhibit G - Instructions for Preparation of Data Entry Sheets for Licensee Event Report (LER) File (NUREG-0161)

⁵
 Exhibit I - Same Source

LOAD REDUCTIONS DUE TO ENVIRONMENTAL RESTRICTIONSUNIT NO. 1MONTH: July, 1982

<u>DATE</u>	<u>TIME</u>	<u>HOURS</u>	<u>LOAD, MW</u>	<u>REDUCTIONS, MW</u>	<u>MWH</u>	<u>REASON</u>
NONE DURING THIS REPORTING PERIOD.						
MONTHLY TOTAL						

LOAD REDUCTIONS DUE TO ENVIRONMENTAL RESTRICTIONS

UNIT NO. 2

MONTH: July, 1982

<u>DATE</u>	<u>TIME</u>	<u>HOURS</u>	<u>LOAD, MW</u>	<u>REDUCTIONS, MW</u>	<u>MWH</u>	<u>REASON</u>
NONE DURING THIS REPORTING PERIOD.						
MONTHLY TOTAL						

DOCKET NO 50-280
 UNIT SURRY I
 DATE 8-1-82
 COMPLETED BY G J COSTELLO

AVERAGE DAILY UNIT POWER LEVEL

MONTH: JULY 82

DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	730.1	17	718.8
2	718.8	18	720.5
3	723.6	19	730.1
4	725.2	20	717.6
5	729.6	21	716.0
6	730.0	22	717.4
7	729.0	23	717.9
8	718.9	24	713.1
9	707.7	25	711.4
10	723.7	26	709.6
11	726.5	27	705.8
12	725.3	28	706.4
13	420.5	29	710.6
14	228.4	30	705.8
15	670.9	31	713.5
16	718.2		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWE-NET FOR EACH DAY IN THE REPORTING MONTH. THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT BY USING MAXIMUM DEPENDABLE CAPACITY FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER EXCEEDS THE 100 % LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.

DOCKET NO 50-281
 UNIT SUPRY II
 DATE 8-1-82
 COMPLETED BY G J COSTELLO

AVERAGE DAILY UNIT POWER LEVEL

MONTH: JULY 82

DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)	DAY	AVERAGE DAILY POWER LEVEL (MWE-NET)
1	746.3	17	741.1
2	745.5	18	742.3
3	745.4	19	746.3
4	745.6	20	734.6
5	748.1	21	740.2
6	708.6	22	739.4
7	744.8	23	738.5
8	743.0	24	735.8
9	743.1	25	726.0
10	747.2	26	735.0
11	746.6	27	738.4
12	742.6	28	738.7
13	741.7	29	732.3
14	740.0	30	740.5
15	740.3	31	744.6
16	740.1		

DAILY UNIT POWER LEVEL FORM INSTRUCTIONS

ON THIS FORM, LIST THE AVERAGE DAILY UNIT POWER LEVEL IN MWE-NET FOR EACH DAY IN THE REPORTING MONTH. THESE FIGURES WILL BE USED TO PLOT A GRAPH FOR EACH REPORTING MONTH. NOTE THAT BY USING MAXIMUM DEPENDABLE CAPACITY FOR THE NET ELECTRICAL RATING OF THE UNIT, THERE MAY BE OCCASIONS WHEN THE DAILY AVERAGE POWER EXCEEDS THE 100 % LINE (OR THE RESTRICTED POWER LEVEL LINE). IN SUCH CASES, THE AVERAGE DAILY UNIT POWER OUTPUT SHEET SHOULD BE FOOTNOTED TO EXPLAIN THE APPARENT ANOMALY.

SUMMARY OF OPERATING EXPERIENCEJuly, 1982

Listed below in chronological sequence by unit is a summary of operating experiences for this month which required load reductions or resulted in significant non-load related incidents.

UNIT ONE

- July 1 This reporting period begins with the unit at 100% power.
- July 2 1154 - Turbine runback to 92% power on Overttemperature ΔT signal. The runback signal was a result of OT ΔT setpoint reduction due to reduced primary pressure. The primary pressure reduction was a result of a problem encountered with a pressurizer spray valve.
- 1220 - Started power increase at 3% per hour.
- 1715 - The unit reached 100% power.
- July 13 1400 - The reactor tripped as a result of instrument department testing of the "B" Train Reactor Trip signals with the "B" Reactor Trip Bypass Breaker improperly racked into the breaker cubicle.
- 1612 - The reactor is critical.
- 1828 - Chemist reported dose equivalent I-131 was greater than 10 microcuries per cc. Started six hours clock for having unit shutdown and cooled down to less 500°F.
- 2253 - The reactor was manually shutdown.
- 2330 - The reactor coolant system was less than 500°F.
- July 14 0145 - Chemist reported dose equivalent. I-131 was less than 10 microcuries per cc.
- 0405 - The reactor was critical.
- 0819 - The generator was placed on the line.
- 0842 - Stopped power increase at 35% power to verify secondary chemistry was in specification.
- 0900 - Secondary chemistry is in specification. Started increasing power at 3% per hour.
- July 15 1335 - The unit reached 100% power.

- July 21 2200 - The supply breaker for the 2G Screenwell Transformer tripped de-energizing four (4) of the seven (7) operating circulating water pumps. Power was reduced to 95% to allow throttling the circulating water flow through the main condenser.
- 2210 - Cross-tied the 1G and 2G buses and restarted the circulating water pumps fed from the 2G bus.
- 2220 - Started increasing power at 3% per hour.
- July 22 0100 - The unit reached 100% power.
- July 31 This reporting period ends with the unit at 100% power.

UNIT TWO

- July 1 This reporting period begins with the unit at 100% power.
- July 6 0100 - Start power reduction at 150 MWe per hour to load follow on orders of the system operator.
- 0236 - Stopped load decrease at 69% power on orders of the system operator.
- 0438 - Started load increase on orders of the system operator.
- 0700 - The unit reached 100% power.
- July 20 1745 - Both RWST temperature indicators indicate 46°F. Started 6 hour clock for hot shutdown based on exceeding maximum RWST temperature of 45°F.
- 1932 - Started power decrease at 150 MWe per hour.
- 2033 - Both RWST temperature indicators indicate 45°F. Stopped power decrease at 89% power.
- 2108 - Started increasing power.
- 2215 - The unit reached 100% power.
- July 21 2210 - Decreased load 25 MWe due to loss of four (4) of seven (7) operating circulating water pumps.
- 2239 - Increased power to 100%.

- July 25 2115 - Decreased power 15 MWe due to vacuum problems encountered while cleaning condenser waterboxes.
- July 26 0518 - Increased power to 100%.
- July 31 This reporting period ends with the Unit at 100% power.

AMENDMENTS TO FACILITY LICENSE OR TECHNICAL SPECIFICATIONSJuly, 1982

The Nuclear Regulatory Commission, on June 17, 1982, issued Amendment Nos. 1 and 2 respectively. The changes have been designated as Technical Specification change No. 88.

These amendments revise the Technical Specifications to limit control rod misalignment to no more than + 12 steps indicated positions. This change is consistent with the Standard Technical Specifications.

Also, on page 3.16-2, a typographical error was corrected from 2 hours to 24 hours.

Accordingly, the paragraph 3.B of the Operating License for Unit 1 and 2, respectively, is amended as follows:

(Unit 1) "B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 78, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications."

(Unit 2) "B. Technical Specifications

The Technical Specifications contained in Appendix A, as revised through Amendment No. 79, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications."

FACILITY CHANGES REQUIRING
NRC APPROVAL

July, 1982

None during this reporting period.

FACILITY CHANGES THAT
DID NOT REQUIRE NRC APPROVAL

July, 1982

		<u>Unit</u>
D/C 80-76	<u>Process Vent</u>	1 & 2
	This design change improves the performance and reliability of the process vent system. This was accomplished by the installation of a moisture trap on the inlet to the process vent to prevent water ingress to the filter media.	
	<u>Summary of Safety Analysis</u>	
	The modification will not create any safety problems. It will remove the water entering the system through the system input and give an indication in the control room if water enters the filter banks.	
D/C 81-19	<u>Machine Shop Replacement Facility</u>	1 & 2
	D/C 81-19E Machine Shop Replacement Facility - Electrical Systems and D/C 81-19F Machine Shop Replacement Facility - Electrical Power Supply were implemented.	
	<u>Summary of Safety Analysis</u>	
	The addition of the Machine Shop Replacement Facility does not minimize the safety of operating units or effect the operation of safety related equipment.	
D/C 81-30	<u>Surry Main Switchyard and Gas Turbine Area Fire Protection</u>	1 & 2
	This design change provides a water supply and fire fighting equipment to the gas turbine area, material storage area and switchyard area.	

Summary of Safety Analysis

The modification will not reduce the safety of operating units, and fire protection capabilities to safety-related equipment will be maintained.

D/C 81-109 Steam Line to Auxiliary Boiler Drum Heater

1 & 2

This design change provides a tie in from the Building Heating System to supply the new Auxiliary Boiler Drum Heating Units. A steam heating element was installed in the lower drum of each of two Auxiliary Boilers during their recent retubing. The elements provide heat to the boiler during periods when the boilers are idle in order to reduce boiler startup time and reduce boiler corrosion.

Summary of Safety Analysis

The addition of the steam line from the heating steam system to the Auxiliary Boiler drum heating element does not affect the operation of any safety-related equipment.

TESTS AND EXPERIMENTS REQUIRING
NRC APPROVAL

July, 1982

None during this reporting period.

TESTS AND EXPERIMENTS THAT
DID NOT REQUIRE NRC APPROVAL

July, 1982

<u>Special Test No.</u>	<u>Unit</u>	<u>Title</u>	<u>Completed</u>
ST-52	1	RCS Flow Measurement Data	07-01-82
ST-89	2	Flow Coastdown Measurement	07-22-82
ST-90	2	S/G Water Level, Stability and Control Demonstration	07-22-82
ST-105	2	S/G Water Level, Stability and Control Demonstration	07-22-82
ST-106	1	Containment Sump Penetrations No. 66 and No. 69	07-22-82
ST-109	1	Engineered Safety Features Functional Test	07-22-82
ST-115	1	Chemical and Volume Control System Hot Functional Testing	07-22-82
ST-120	1	S/G Water Level, Stability and Control Demonstration	07-22-82
ST-134	1	S/G Moisture Carryover Measurement	07-22-82

OTHER CHANGES, TESTS AND EXPERIMENTSJuly, 1982

None during this reporting period.

17
SURREY POWER STATION

CHEMISTRY REPORT

July 19 82

T.S. 6.6.3.d

PRIMARY COOLANT ANALYSIS	UNIT NO. 1			UNIT NO. 2		
	MAXIMUM	MINIMUM	AVERAGE	MAXIMUM	MINIMUM	AVERAGE
Gross Radioact., $\mu\text{Ci/ml}$	(A) Eo 6.64	(A) Eo 2.02	(A) Eo 3.35	E-1 4.86	E-1 1.64	E-1 2.62
Suspended Solids, ppm	0.1	0.1	0.1	0.1	0.1	0.1
Gross Tritium, $\mu\text{Ci/ml}$	E-1 1.31	E-1 1.19	E-1 1.25	E-1 2.22	E-1 2.08	E-1 2.15
Iodine-131, $\mu\text{Ci/ml}$	(A) Eo 6.72	(A) E-2 9.22	(A) E-1 4.77	E-3 4.21	E-3 1.23	E-3 2.06
I-131/I-133	1.5026	.8830	1.1499	1.8776	.4451	.9087
Hydrogen, cc/kg	(C) 54.8	25.7	32.6	(C) 58.0	20.1	33.2
Lithium, ppm	1.45	(B) .54	.85	1.35	1.05	1.24
Boron-10, ppm +	101.53	71.15	79.32	138.96	127.40	133.17
Oxygen-16, ppm	.000	.000	.000	.000	.000	.000
Chloride, ppm	<.05	<.05	<.05	<.05	<.05	<.05
pH @ 25°C	6.96	6.47	6.77	6.69	6.56	6.62

+ Boron-10 = Total Boron x 0.196

NON-RADIOACTIVE CHEMICAL (D)
RELEASES, POUNDS
T.S. 4.13.A.6

Phosphate _____ - _____	Boron _____ 890
Sulfate _____ - _____	Chromate _____ 0.0
50% NaOH _____ - _____	Chlorine _____ - _____

REMARKS: (A) Activity levels indicate possible failed fuel (B) Two separate LiOH additions made (7-8-82) & (7-22-82) (C) Hydrogen levels too high-recommended reduce pressure on the VCT - Unit #1 Rx trip 7-13-82 - unit startup 7-14-82 (D) The levels of these chemicals should create no adverse environmental impact.

DESCRIPTION OF ALL INSTANCES WHERE
THERMAL DISCHARGE LIMITS WERE EXCEEDED

July, 1982

Due to the impairment of the circulating water system on the following days, the thermal discharge limits were exceeded as noted.

July 1, 1982	Exceeded 15 ^o F	ΔT across station*
July 2, 1982	Exceeded 15 ^o F	ΔT across station
July 3, 1982	Exceeded 15 ^o F	ΔT across station*
July 5, 1982	Exceeded 15 ^o F	ΔT across station*
July 6, 1982	Exceeded 15 ^o F	ΔT across station*
July 7, 1982	Exceeded 15 ^o F	ΔT across station
July 8, 1982	Exceeded 15 ^o F	ΔT across station
July 9, 1982	Exceeded 17.5 ^o F	ΔT across station*
July 10, 1982	Exceeded 15 ^o F	ΔT across station*
July 12, 1982	Exceeded 15 ^o F	ΔT across station
July 13, 1982	Exceeded 15 ^o F	ΔT across station*
July 14, 1982	Exceeded 15 ^o F	ΔT across station*
July 15, 1982	Exceeded 17.5 ^o F	ΔT across station*
July 16, 1982	Exceeded 15 ^o F	ΔT across station*
July 17, 1982	Exceeded 17.5 ^o F	ΔT across station
July 18, 1982	Exceeded 17.5 ^o F	ΔT across station*
July 19, 1982	Exceeded 15 ^o F	ΔT across station*
July 20, 1982	Exceeded 15 ^o F	ΔT across station
July 21, 1982	Exceeded 15 ^o F	ΔT across station
July 22, 1982	Exceeded 15 ^o F	ΔT across station
July 23, 1982	Exceeded 17.5 ^o F	ΔT across station
July 24, 1982	Exceeded 17.5 ^o F	ΔT across station*
July 25, 1982	Exceeded 17.5 ^o F	ΔT across station
July 26, 1982	Exceeded 15 ^o F	ΔT across station*

July 27, 1982	Exceeded 17.5 ^o F	ΔT across station
July 28, 1982	Exceeded 17.5 ^o F	ΔT across station
July 29, 1982	Exceeded 15 ^o F	ΔT across station*
July 30, 1982	Exceeded 15 ^o F	ΔT across station*

*Indicates dates where station ΔT was less than or equal to 15.0^oF across station for some time during the day.

The ΔT excursions were allowable under Technical Specification 4.14.B.2. There were no reported instances of adverse environmental impact.

The temperature change at the station discharge exceeded 3^oF per hour on July 13, 1982, due to a Unit 1 reactor trip. This event was allowable in accordance with Technical Specification 4.14.B.1. There were no reported instances of adverse environmental impact.

The temperature change at the station discharge exceeded 3^oF per hour on July 21, 1982, due to a loss of four (4) of seven (7) operating circulating water pumps. The four (4) circulating water pumps were temporarily out of service due to an electrical malfunction. This event was reported in accordance with Technical Specification 4.14.C.1.

FUEL HANDLING

July, 1982

Units One and Two

None during this reporting period.

PROCEDURE REVISIONS THAT CHANGED THE
OPERATING MODE DESCRIBED IN THE FSAR

July, 1982

None during this reporting period.

DESCRIPTION OF PERIODIC TESTS WHICH WERE NOT
COMPLETED WITHIN THE TIME LIMITS
SPECIFIED IN TECHNICAL SPECIFICATIONS

July, 1982

None during this reporting period.

INSERVICE INSPECTION

July, 1982

No Inservice Inspections were performed on Units One or Two.

REPORTABLE OCCURRENCES PERTAINING TO
ANY OUTAGE OR POWER REDUCTIONS

July, 1982

None during this reporting period.

Maintenance of Safety Related Systems During
Outage or Reduced Power Periods

UNIT #1

Mechanical Maintenance

LEPT-KZCH

UNITY
(MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

RETSRVC DT	SYS	COMP	MARKNO	SUMMARY	WKFEE	U	MR	TCTI\NTM
07/15/82	CR	PUMP	1-CH-P-1B	EXCESSIVE BEARING VIBRATION	REPLACED INBOARD BEARING	1	203130700	986
07/15/82	FW	VALVE	ECV-FW-1498	VALVE PERFORMS ERRATICALLY	REPLACED DIAPHRAM	1	203151932	43
07/15/82	CR	PUMP	1-CH-P-1B	REMOVE OIL COOLER	PLUGGED TUBE	1	207052250	120

DEPT TOTAL								1147

Maintenance of Safety Related Systems During
Outage or Reduced Power Periods

UNIT #2

Mechanical Maintenance

LEPT-NECH

UNIT2
(MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

RTSEKVDI	SYS	COMP	MARKNO	SUMMARY	WKPERF	U	MR	TOTWATN
07/06/82	IA	COMPRESS	2-IA-C-4A	COMPRESSOR WILL NOT LOAD UP	CHECK AT SYSTEM	2	206121410	645

DEPT TOTAL								

Maintenance of Safety Related Systems During
Outage or Reduced Power Periods

UNIT #1

Electrical Maintenance

DEPT=ELEC

UNITS
(MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

DATE/TIME	SYS	COMP	MARKNO	SUMMARY	WKFERR	U	MR	TOTIWTM
07/13/82	EE	BREAKER	1-H1-221	TYRAP PLUG IN TERMINAL STRIPS	TYRAPPED STRIPS	1	207091430	5
07/13/82	EE	BREAKER	1-J1-2143	TYRAP PLUG IN TERMINAL STRIPS	TYRAPPED STRIPS	1	207091431	5
07/13/82	EE	BREAKER	1-H1-231	TYRAP PLUG IN TERMINAL STRIPS	TYRAPPED STRIPS	1	207091432	5
07/13/82	EE	BREAKER	1-J1-211	TYRAP PLUG IN TERMINAL STRIPS	TYRAPPED STRIPS	1	207091433	5
07/14/82	KP	B RX TRI	B	INSPECT B RX TRIP BYPASS	TESTED SAT	1	207131540	17

DEPT TOTAL								37

Maintenance of Safety Related Systems During
Outage or Reduced Power Periods

UNIT #2

Electrical Maintenance

Maintenance of Safety Related Systems During
Outage or Reduced Power Periods

July, 1982

None during this reporting period.

Maintenance of Safety Related Systems During
Outage or Reduced Power Periods

UNIT #1

Instrument Maintenance

LEPT=INST

Unit 1
(MAINTENANCE OF SAFETY RELATED SYSTEMS DURING OUTAGE OR REDUCED POWER PERIODS)

RTSERVDT	SYS	COMP	MARKNO	SUMMARY	WKPERF	U	MR	TOTWNTM
07/15/82	CV	INSTR	FY-CV-150	DORS NOT INDICATE CORRECTLY INDICATE	REPLACE NOZZLE AND TRANSMITTER	1	205052345	469
07/15/82	CC	INSTR	FT-CC-110B	CALIBRATE TRANSMITTER	RECALIBRATE TRANSX	1	207050640	162
DRT TOTAL								631

Maintenance of Safety Related Systems During
Outage or Reduced Power Periods

UNIT #2

Instrument Maintenance

Maintenance of Safety Related Systems During
Outage or Reduced Power Periods

July, 1982

None during this reporting period.

37
HEALTH PHYSICS

July, 1982

There was no single release of radioactivity or radiation exposure specifically associated with an outage that accounted for more than 10% of the allowable annual values in 10CFR20.

PROCEDURE DEVIATIONS REVIEWED BY STATION NUCLEAR
SAFETY AND OPERATING COMMITTEE AFTER TIME LIMITS
SPECIFIED IN TECHNICAL SPECIFICATIONS

July, 1982

<u>Procedure No.</u>	<u>Unit</u>	<u>Title</u>	<u>Date Deviated</u>	<u>Date SNSOC Reviewed</u>
PT-18.2	2	Safety Injection System Tests	12-22-81	07-22-82
PT-17.2	1	Containment Inside Recirculation Spray Pumps Tests	07-09-82	07-30-82