

March 30, 1994

Docket No. 50-245

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M88265)

The Commission has issued the enclosed Amendment No. 73 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated November 22, 1993, as supplemented March 4, 1994.

The amendment revises the Technical Specifications by clarifying the operability requirements relative to the design function of the scram discharge volume - water level high rod block. In addition, Northeast Nuclear Energy Company is adding a statement which defines operability and surveillance requirements for the rod block functions while the reactor mode selector switch is in the REFUEL or SHUTDOWN positions.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

James W. Andersen, Acting Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

9404060194 940330
PDR ADOCK 05000245
P PDR

Enclosures:

- 1. Amendment No. 73 to DPR-21
- 2. Safety Evaluation

cc w/enclosures:

See next page

040030

DISTRIBUTION:

Docket File JWermiel
NRC & Local PDRs SNorris
PDI-4 Plant JAndersen
SVarga OGC
JCalvo DHagan
GHill (2) OC/LFDCB
LDoerflein, RGI

NRC FILE CENTER COPY

*SEE PREVIOUS CONCURRENCE

OFFICE	LA:PDI-4	PM:PDI-4	OTSB*	HICB*	D:PDI-4	OGC
NAME	SNorris	JAndersen:bp	CGrimes	JWermiel	JStoltz	RBackman
DATE	3/18/94	3/19/94	2/4/94	1/10/94	3/9/94	3/16/94

OFFICIAL RECORD COPY

Document Name: G:\ANDERSEN\88265.AMD

JFO

March 30, 1994

Docket No. 50-245

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M88265)

The Commission has issued the enclosed Amendment No. 73 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated November 22, 1993, as supplemented March 4, 1994.

The amendment revises the Technical Specifications by clarifying the operability requirements relative to the design function of the scram discharge volume - water level high rod block. In addition, Northeast Nuclear Energy Company is adding a statement which defines operability and surveillance requirements for the rod block functions while the reactor mode selector switch is in the REFUEL or SHUTDOWN positions.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Original signed by:

James W. Andersen, Acting Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 73 to DPR-21
2. Safety Evaluation

cc w/enclosures:
See next page

DISTRIBUTION:

Docket File	JWermiel	
NRC & Local PDRs	SNorris	CGrimes
PDI-4 Plant	JAndersen	ACRS (10)
SVarga	OGC	OPA
JCalvo	DHagan	OC/LFDCB
	GHill (2)	LDoerflein, RGI

*SEE PREVIOUS CONCURRENCE

OFFICE	LA:PDI-4	PM:PDI-4	OTSB*	HICB*	D:PDI-4	OGC
NAME	SNorris	JAndersen: <i>JA</i>	CGrimes	JWermiel	JStolz	R Bachman
DATE	3/8/94	3/9/94	2/4/94	1/10/94	3/9/94	3/16/94

OFFICIAL RECORD COPY

Document Name: G:\ANDERSEN\88265.AMD



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

March 30, 1994

Docket No. 50-245

Mr. John F. Opeka
Executive Vice President, Nuclear
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Opeka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. M88265)

The Commission has issued the enclosed Amendment No. 73 to Facility Operating License No. DPR-21 for Millstone Nuclear Power Station, Unit 1, in response to your application dated November 22, 1993, as supplemented March 4, 1994.

The amendment revises the Technical Specifications by clarifying the operability requirements relative to the design function of the scram discharge volume - water level high rod block. In addition, Northeast Nuclear Energy Company is adding a statement which defines operability and surveillance requirements for the rod block functions while the reactor mode selector switch is in the REFUEL or SHUTDOWN positions.

A copy of the related Safety Evaluation is also enclosed. The notice of issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

A handwritten signature in black ink, appearing to be "JW Andersen", written over a circular stamp or mark.

James W. Andersen, Acting Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 73 to DPR-21
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. John F. Opeka
Northeast Nuclear Energy Company

Millstone Nuclear Power Station
Unit 1

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Director
Nuclear Planning, Licensing & Budgeting
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

J. P. Stetz, Vice President
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
362 Injun Hollow Road
East Hampton, Connecticut 06424-3099

J. M. Solymossy, Director
Nuclear Quality and Assessment Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin T. A. McCarthy, Director
Monitoring and Radiation Division
Department of Environmental Protection
79 Elm Street
Hartford, Connecticut 06106-5127

Regional Administrator
Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Allan Johanson, Assistant Director
Office of Policy and Management
Policy Development and Planning Division
80 Washington Street
Hartford, Connecticut 06106

First Selectmen
Town of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

S. E. Scace, Vice President
Nuclear Operations Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

P. D. Swetland, Resident Inspector
Millstone Nuclear Power Station
c/o U.S. Nuclear Regulatory Commission
Post Office Box 513
Niantic, Connecticut 06357

H. F. Haynes, Nuclear Unit Director
Millstone Unit No. 1
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Donald B. Miller, Jr.
Senior Vice President
Millstone Station
Northeast Nuclear Energy Company
Post Office Box 128
Waterford, Connecticut 06385

Nicholas S. Reynolds
Winston & Strawn
1400 L Street, NW
Washington, DC 20005-3502