

SEP 18 1990

LICENSEE: Texas Utilities Electric Company (TU Electric)  
FACILITY: Comanche Peak Steam Electric Station (CPSES), Units 1 & 2  
SUBJECT: SUMMARY OF MEETING ON CLASS 1E CABLE AND RACEWAY SEPARATION

A meeting was held on September 6, 1990, to discuss TU Electric's proposed changes to the Class 1E cable and raceway separation criteria. A list of attendees and a copy of the handout used by TU Electric in their presentation are provided as Enclosures 1 and 2, respectively.

The details of the proposed separation criteria changes are contained in TU Electric's letter dated June 28, 1990, and reiterated in the enclosed handout. The revised separation criteria are intended to significantly reduce the related amount of inspection and rework time on Unit 2 and are based on tests performed by Wyle Laboratories. Most of the discussion at the meeting focused on the expected impact on the completion of Unit 2, and on past acceptance by the NRC of this approach to the separation criteria.

The meeting ended with the staff concluding that its review would factor in the appropriateness of the Wyle Laboratories test data, with emphasis on the applicability of the staff's acceptance of this approach at other commercial nuclear power plants as compared to the CPSES proposal.

Original Signed By:

Mel B. Fields, Project Manager  
Project Directorate IV-2  
Division of Reactor Projects III,  
IV, V and Special Projects  
Office of Nuclear Reactor Regulation

Enclosures:

- 1. List of Attendees
- 2. Presentation Slides

cc w/enclosures:  
See next page

DISTRIBUTION

**Docket File**  
NRC PDR  
Local PDR  
F. Miraglia  
J. Partlow  
PDIV-2 R/F  
PDIV-2 Plant File  
C. Grimes  
M. Fields  
E. Peyton  
OGC  
E. Jordan  
ACRS (10)  
M. Slosson  
NRC Participants

OFC	: PDIV-2/LA	: PDIV-2/PM	: PDIV-2/D	:	:	:
NAME	: <sup>esp</sup> E. Peyton	: MF <sup>MS</sup> Fields: jc	: CGrimes <sup>CG</sup>	:	:	:
DATE	: 09/17/90	: 09/17/90	: 09/17/90	:	:	:

OFFICIAL RECORD COPY  
Document Name: TU ELECTRIC MEETING SUMMARY

cc w/ enclosures:

Senior Resident Inspector  
U.S. Nuclear Regulatory Commission  
P. O. Box 1029  
Granbury, Texas 76048

Regional Administrator, Region IV  
U.S. Nuclear Regulatory Commission  
611 Ryan Plaza Drive, Suite 1000  
Arlington, Texas 76011

Ms. Billie Pirner Garde, Esq.  
Robinson, Robinson, et al  
103 East College Avenue  
Appleton, Wisconsin 54911

Mrs. Juanita Ellis, President  
Citizens Association for Sound Energy  
1426 South Polk  
Dallas, Texas 75224

E. F. Ottney  
P. O. Box 1777  
Glen Rose, Texas 76043

Mr. Roger D. Walker  
Manager, Nuclear Licensing  
Texas Utilities Electric Company  
400 North Olive Street, L.B. 81  
Dallas, Texas 75201

Texas Utilities Electric Company  
c/o Bethesda Licensing  
3 Metro Center, Suite 610  
Bethesda, Maryland 20814

William A. Burchette, Esq.  
Counsel for Tex-La Electric  
Cooperative of Texas  
Heron, Burchette, Ruckert & Rothwell  
1025 Thomas Jefferson Street, N.W.  
Washington, D.C. 20007

GDS Associates, Inc.  
Suite 720  
1850 Parkway Place  
Marietta, Georgia 30067-8237

Jack R. Newman, Esq.  
Newman & Holtzinger  
1615 L Street, N.W.  
Suite 1000  
Washington, D.C. 20036

Chief, Texas Bureau of Radiation Control  
Texas Department of Health  
1100 West 49th Street  
Austin, Texas 78756

Honorable George Crump  
County Judge  
Glen Rose, Texas 76043

Mr. William J. Cahill, Jr.  
Executive Vice President  
TU Electric  
400 North Olive Street, L.B. 81  
Dallas, Texas 75201

ENCLOSURE 1

NRC/TU ELECTRIC MEETING

CLASS 1E CABLE AND RACEWAY SEPARATION

FOR COMANCHE PEAK, UNITS 1 & 2

September 6, 1990

<u>NAME</u>	<u>ORGANIZATION</u>
M. Fields	NRR/NRC
F. Ashe	NRR/NRC
R. Walker	TU Electric
T. Hicks	STS Inc.
E. LaVigne	Stone & Webster Engineering Corp.
D. Leach	Stone & Webster Engineering Corp.
I. Ahmad	TU Electric
J. LaMarca	TU Electric

**CPSES**  
**CABLE AND RACEWAY**  
**SEPARATION CRITERIA**

**INDEPENDENCE OF ELECTRICAL SYSTEMS  
IS ACHIEVED THROUGH:**

- **PHYSICAL SEPARATION**
- **ELECTRICAL SEPARATION**

**THE COMANCHE PEAK PHYSICAL SEPARATION  
DESIGN IS BASED ON IEEE-384-1974 AND THE  
GUIDANCE PROVIDED IN R.G. 1.75 REV. 1  
COMPLIMENTED BY:**

- **SEPARATE SAFETY CLASS STRUCTURES**
- **FIRE HAZARDS ANALYSIS (DBD-ME-001)**
- **FIRE SAFE SHUTDOWN ANALYSIS (DBD-ME-020)**
- **SEISMIC/NON SEISMIC SYSTEM INTERACTIONS  
PROGRAM (DBD-ME-005)**
- **PIPE BREAK POSTULATIONS & EFFECTS (DBD-ME-007)**
- **MISSILE POSTULATION & EFFECTS (DBD-ME-105)**
- **CONTROL OF HEAVY LOADS (DBD-ME-006)**
- **COMMODITY CLEARANCE (CPES-S-1021)**

**THE COMBINED EFFECT OF THESE PROGRAMS  
ASSURE THAT:**

- **CLASS 1E CIRCUITS AND EQUIPMENT ARE REVIEWED  
FOR EXPOSURE TO POTENTIAL HAZARDS**
- **PROTECTION COMMENSURATE WITH THE POTENTIAL  
HAZARD IS PROVIDED**
- **DAMAGE POTENTIAL IS LIMITED TO FAILURES OR FAULTS  
INTERNAL TO ELECTRICAL EQUIPMENT OR CIRCUITS**

**WHEN DAMAGE POTENTIAL IS LIMITED TO FAILURES  
OR FAULTS INTERNAL TO THE ELECTRICAL EQUIPMENT  
OR CIRCUITS, IEEE 384-1974 PROVIDES FOR PHYSICAL  
SEPARATION BY:**

- **SPATIAL DISTANCE**
- **COMBINATION OF SPATIAL DISTANCE AND  
BARRIERS OR ENCLOSURES**
- **ANALYSIS OF CABLE INSTALLATION**




6

## SEPARATION CRITERIA IEEE-384-1974


- **3 FEET HORIZONTAL, 5 FEET VERTICAL (PARA 5.1.4)  
GENERAL PLANT AREA FOR OPEN VENTILATED TRAYS**
  
- **1 INCH VERTICAL BETWEEN TRAYS**
  - **WITH ONE BARRIER** (FIGURE 2)
  - **BOTTOM TRAY WITH COVER & TOP TRAY SOLID BOTTOM** (FIGURE 2)
  - **WITH ONE BARRIER AT TRAY CROSSING** (FIGURE 4)
  - **BOTTOM TRAY WITH COVER AT TRAY CROSSING** (FIGURE 5)
  
- **1 INCH HORIZONTAL BETWEEN TRAYS (FIGURE 3)**
  - **WITH ONE BARRIER**
  - **BETWEEN ENCLOSED TRAYS**
  
- **LESSER SEPARATION DISTANCE CAN BE ESTABLISHED BY ANALYSIS OF  
INSTALLATION BASED ON TEST (PARA. 5.1.1.2)**

**AN EXAMPLE OF PHYSICAL SEPARATION UTILIZING SPATIAL DISTANCE IN THE GENERAL PLANT AREA IS:**




**ALL TRAYS ARE  
OPEN LADDER TYPE  
TRAYS**

**AN EXAMPLE OF PHYSICAL SEPARATION UTILIZING SPATIAL DISTANCE IN THE CABLE SPREADING AREA IS:**




**ALL TRAYS ARE  
OPEN LADDER TYPE  
TRAYS**

**AN EXAMPLE OF PHYSICAL SEPARATION UTILIZING A  
COMBINATION OF SPATIAL DISTANCE AND BARRIERS  
OR ENCLOSURES FOR HORIZONTAL SEPARATION:**



**ENCLOSED RACEWAY**

**AN EXAMPLE OF PHYSICAL SEPARATION UTILIZING  
A COMBINATION OF SPATIAL DISTANCE AND BARRIERS  
OR ENCLOSURES BASED ON TESTS AND ANALYSIS IS:**



**CPSES SEPARATION CRITERIA MEETS  
THE REQUIREMENTS OF:**

- **IEEE 384-1974**
- **REG. GUIDE 1.75 REV. 1**

## **JUSTIFICATION FOR CRITERIA CHANGE**

- **UNIT 1 LESSONS LEARNED**
  
- **SIMPLER AND MORE CONSISTANT CRITERIA**
  - **EASIER TO TRAIN WALKDOWN PERSONNEL**
  - **EASIER TO TRAIN INSTALLERS**
  - **EASIER TO TRAIN QC**
  - **EASIER TO INSURE COMPLIANCE**
  - **MEETS ALL ASPECTS OF RG 1.75 AND IEEE 384-74**

## **EXTENT OF CRITERIA CHANGES**

- **POWER TRAY TO TRAY/CABLE  
(FROM 2 BARRIERS AND 1 INCH TO 1 BARRIER AND 1 INCH)**
  
- **CLASS IE CONDUIT ABOVE TRAY/CABLE  
(FROM 2 BARRIERS AND 1 INCH TO 1 BARRIER AND 1 INCH)**



## **WYLE TEST REPORT #17666-02**

- **TEST CONDUCTED FOR BEAVER VALLEY UNIT #2**
- **CONFIGURATIONS #1 & 2 ESTABLISH 0" AS ADEQUATE SEPARATION BETWEEN CABLES WHEN EITHER FAULT OR TARGET CABLE IS WRAPPED WITH SILTEMP WRAP.**
- **CONFIGURATIONS #3 & 4 ESTABLISH THAT SOLID/VENTILATED TRAY COVERS PROVIDE ADEQUATE PROTECTION WITHOUT ADDITIONAL SPACE FOR FAULTS INSIDE OR OUTSIDE THE TRAY**
- **CONFIGURATION #6 ESTABLISHES THAT 1" SPACE BETWEEN A CONDUIT AND TRAY IS ADEQUATE SEPARATION FOR ANY CONFIGURATION. SINCE THERE WAS NO TRAY COVER INSTALLED, IT IS CONCLUDED THAT 1" SEPARATION BETWEEN CONDUIT AND CABLE IS ALSO ADEQUATE.**

## **CPSES CRITERIA**

- **1" SEPARATION BETWEEN CONDUIT AND CABLE/TRAY**
- **1" SEPARATION WITH ONE CABLE WRAPPED IN SILTEMP**
- **TRAY COVER AND 1" SPACE**

## **EXTENT OF CRITERIA CHANGES**

- **POWER TRAY TO TRAY/CABLE  
(FROM 2 BARRIERS AND 1 INCH TO 1 BARRIER AND 1 INCH)**
- **CLASS IE CONDUIT ABOVE TRAY/CABLE  
(FROM 2 BARRIERS AND 1 INCH TO 1 BARRIER AND 1 INCH)**

## WYLE TEST REPORT #47906-02

- TEST CONDUCTED FOR NINE MILE POINT UNIT #2
- CONFIGURATION #5, ESTABLISH 1/4" AIR AS ADEQUATE SEPARATION:  
BETWEEN CONDUITS  
BETWEEN CABLE AND CONDUIT

## **CRITERIA CHANGE PRECEDENT**

- **BEAVER VALLEY**
  - **POWER TRAY TO TRAY/CABLE  
TRAY COVER AND 1" SPACE**
  - **CLASS 1E CONDUIT TO TRAY, 1" SPACE**

## **UNIT 1 IMPACT**

- **EXISTING INSTALLATION IN UNIT 1 WILL NOT BE ALTERED DUE TO THE CRITERIA CHANGE**
- **DBD'S AND SPECIFICATIONS WILL BE REVISED**
- **DM'S WILL USE THIS REVISED CRITERIA FOR FUTURE INSTALLATIONS AND ACCEPTANCE**

## **UNIT 2 IMPACT**

- **SYSTEMS INSTALLED UTILIZING EXISTING CRITERIA ARE:**
  - 98% OF THE TRAY SYSTEM**
  - 85% OF THE CONDUIT SYSTEM**
  - 85% OF THE CABLE SYSTEMS**
  
- **DBD'S AND SPECIFICATIONS HAVE BEEN REVISED.**
  
- **UNIT 2 WILL USE THE REVISED CRITERIA FOR SEPARATION INSTALLATION AND ACCEPTANCE.**

## SUMMARY

21

- RG1.75 AND IEEE 384-1974 REQUIREMENTS ARE MET
- CHANGES IMPACT ONLY LIMITED NUMBER OF CONFIGURATIONS
- NO IMPACT TO EXISTING UNIT 1 AND UNIT 2 INSTALLATIONS
- ENSURES COMPLIANCE AND TRAINING OF PERSONNEL WILL BE SIMPLER

18



## SUMMARY

- **RG1.75 AND IEEE 384-1974 REQUIREMENTS ARE MET**
- **CHANGES IMPACT ONLY LIMITED NUMBER OF CONFIGURATIONS**
- **NO IMPACT TO EXISTING UNIT 1 AND UNIT 2 INSTALLATIONS**
- **ENSURES COMPLIANCE AND TRAINING OF PERSONNEL WILL BE SIMPLER**