

APPENDIX A
NOTICE OF VIOLATION

Public Service Company of New Hampshire
P. O. Box 330
Manchester, New Hampshire 03105

Docket No. 50-443
License No. NPF-56

As a result of the inspection conducted at the Seabrook Generating Station on August 20-24, 1990, and in accordance with the NRC Enforcement Policy (10 CFR 2, Appendix C), the following violation was identified:

Technical Specification 6.11.2 requires that areas accessible to personnel with radiation levels greater than 1000 mR/hr at 18 inches be provided with locked doors to prevent unauthorized entry into the area.

Contrary to the above, the north door to the Demineralizer Alley, located on the 7' elevation of the Primary Auxiliary Building, was not locked during the period July 31, 1990, (9:48 a.m.) through August 1, 1990, (7:30 a.m.) and radiation levels, accessible to personnel, up to 1,500 mR/hr at 18 inches were present in the Demineralizer Alley.

The above example constitutes a Severity Level IV violation (Supplement IV).

Pursuant to the provisions of 10 CFR 2.201, Public Service Company of New Hampshire is hereby required to submit to this office within thirty days of the date of the letter which transmitted this Notice, a written statement or explanation in reply, including: (1) the corrective steps which have been taken and the results achieved; (2) corrective steps which will be taken to avoid further violations; and (3) the date when full compliance will be achieved. Where good cause is shown, consideration will be given to extending this response time.

"OFFICIAL RECORD COPY"

9009240201 900910
PDR ADOCK 05000443
R PDC