

March 30, 1994

Mr. Jerry W. Yelverton
Vice President, Operations ANO
Entergy Operations, Inc.
Route 3 Box 137G
Russellville, Arkansas 72801

Dear Mr. Yelverton:

SUBJECT: SATISFACTORY RESPONSE TO GENERIC LETTER 89-19 FOR ARKANSAS NUCLEAR ONE, UNIT 1 (TAC NO. M74906)

Your response to Generic Letter 89-19, Steam Generator Overfill Protection, for Arkansas Nuclear One, Unit 1 has been reviewed by NRC staff and is satisfactory. Based on your submittals dated March 19, 1990, and May 29, 1992, the staff concluded that an automatic steam generator overfill protection system for Unit 1 is not justified in terms of the installation cost versus the safety benefit. The associated Safety Evaluation is enclosed. This concludes actions required by Generic Letter 89-19 and closes out the associated NRC technical assignment control (TAC) number M74906.

Sincerely,

ORIGINAL SIGNED BY:

George Kalman, Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

9404060264 940330
PDR ADOCK 05000313
P PDR

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

DISTRIBUTION:

Docket File	NRC & LPDRs	PD4-1 r/f	JWermiel
JRoe	EAdensam	WBeckner	
PNoonan	GKalman	OGC	
ACRS (10)	ABeach, RIV	SRhow	

OFC	LA/PD4-1 <i>JW</i>	PM/PD4-1	D/PD4-1 <i>WDB</i>
NAME	PNoonan	GKalman/vw	WBeckner
DATE	3/30/94	3/30/94	3/30/94
COPY	YES/NO	YES/NO	YES/NO

OFFICIAL RECORD COPY Document Name: AR131194.LTR

040010

NRC FILE CENTER COPY



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555-0001

March 30, 1994

Docket No. 50-313

Mr. Jerry W. Yelverton
Vice President, Operations AND
Energy Operations, Inc.
Route 3 Box 137G
Russellville, Arkansas 72801

Dear Mr. Yelverton:

SUBJECT: SATISFACTORY RESPONSE TO GENERIC LETTER 89-19 FOR ARKANSAS NUCLEAR ONE, UNIT 1 (TAC NO. M74906)

Your response to Generic Letter 89-19, Steam Generator Overfill Protection, for Arkansas Nuclear One, Unit 1 has been reviewed by NRC staff and is satisfactory. Based on your submittals dated March 19, 1990, and May 29, 1992, the staff concluded that an automatic steam generator overfill protection system for Unit 1 is not justified in terms of the installation cost versus the safety benefit. The associated Safety Evaluation is enclosed. This concludes actions required by Generic Letter 89-19 and closes out the associated NRC technical assignment control (TAC) number M74906.

Sincerely,

A handwritten signature in cursive script that reads "George Kalman".

George Kalman, Project Manager
Project Directorate IV-1
Division of Reactor Projects - III/IV/V
Office of Nuclear Reactor Regulation

Enclosure:
Safety Evaluation

cc w/enclosure:
See next page

Mr. Jerry W. Yelverton
Entergy Operations, Inc.

Arkansas Nuclear One, Unit 1

cc:

Mr. Harry W. Keiser, Executive Vice
President & Chief Operating Officer
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Mr. Jerrold G. Dewease
Vice President, Operations Support
Entergy Operations, Inc.
P. O. Box 31995
Jackson, Mississippi 39286

Mr. Charles B. Brinkman, Manager
Washington Nuclear Operations
ABB Combustion Engineering
Nuclear Power
12300 Twinbrook Parkway, Suite 330
Rockville, Maryland 20852

Mr. Robert B. McGehee
Wise, Carter, Child & Caraway
P. O. Box 651
Jackson, Mississippi 39286

Mr. Nicholas S. Reynolds
Winston & Strawn
1400 L Street, N.W.
Washington, D.C. 20005-3502

Admiral Kinnaird R. McKee, USN (Ret)
214 South Morris Street
Oxford, Maryland 21654

Mr. Robert B. Borsum
Licensing Representative
B&W Nuclear Technologies
1700 Rockville Pike, Suite 525
Rockville, Maryland 20852

Senior Resident Inspector
U.S. Nuclear Regulatory Commission
P. O. Box 310
London, Arkansas 72847

Regional Administrator, Region IV
U.S. Nuclear Regulatory Commission
611 Ryan Plaza Drive, Suite 1000
Arlington, Texas 76011

Honorable C. Doug Lunningham
County Judge of Pope County
Pope County Courthouse
Russellville, Arkansas 72801

Ms. Greta Dicus, Director
Division of Radiation Control
and Emergency Management
Arkansas Department of Health
4815 West Markham Street
Little Rock, Arkansas 72205-3867