

Docket file



UNITED STATES
NUCLEAR REGULATORY COMMISSION

WASHINGTON, D.C. 20555-0001

March 30, 1994

Docket No. 50-219

Mr. John J. Barton
Vice President and Director
GPU Nuclear Corporation
Oyster Creek Nuclear Generating Station
Post Office eBox 388
Forked River, New Jersey 08731

Dear Mr. Barton:

SUBJECT: GENERIC LETTER (GL) 92-01, REVISION 1, "REACTOR VESSEL STRUCTURAL INTEGRITY," GPU NUCLEAR CORPORATION (GPUN), (TAC NO. M83490)

By letters dated June 30, 1992, and September 7, 1993, GPU Nuclear Corporation (GPUN) provided its response to GL 92-01, Revision 1. The NRC staff has completed its review of your responses. Based on its review, the staff has determined that GPUN has provided the information requested in GL 92-01.

The GL is part of the staff's program to evaluate reactor vessel integrity for Pressurized Water Reactors (PWRs) and Boiling Water Reactors (BWRs). The information provided in response to GL 92-01, including previously docketed information, is being used to confirm that licensees satisfy the requirements and commitments necessary to ensure reactor vessel integrity for their facilities.

A substantial amount of information was provided in response to GL 92-01, Revision 1. These data have been entered into a computerized data base designated Reactor Vessel Integrity Database (RVID). The RVID contains the following tables: A pressurized thermal shock (PTS) table for PWRs, a pressure-temperature limit table for BWRs and an upper-shelf energy (USE) table for PWRs and BWRs. Enclosure 1 provides the PTS and/or pressure temperature table(s), Enclosure 2 provides the USE table for your facility, and Enclosure 3 provides a key for the nomenclature used in the tables. The tables include the data necessary to perform USE, pressure-temperature limit, and RT_{pts} evaluations. These data were taken from your responses to GL 92-01 and previously docketed information. The information in the RVID for your facility will be considered accurate at this point in time and will be used in the staff's assessments related to vessel structural integrity. References to the specific source of the data are provided in the tables.

As a result of our GL 92-01 review, the NRC staff has identified one open issue for your plant. The initial RT_{ndt} values determined by General Electric's (GE) initial methodology have not been validated and the BWR Owners Group report, GE-NE-523-109-0893, entitled, "Basis for GE RT_{ndt} Estimation Method," did not resolve the issue. GE is in the process of validating its

9404060283 940330
PDR ADDCK 05000219
P PDR

040016

NRC FILE CENTER COPY

DFOI

methodology for resolving the initial RT_{NDT} determination issue and will document the results in a topical report. The BWR Owners Group is obtaining approval from its members to provide the GE topical report to the NRC staff for its review and approval. We request that you submit within 30 days a commitment to the BWR Owners Group effort or a schedule for a plant-specific analysis to resolve this issue. Further, we request that you provide confirmation of the plant-specific applicability of the topical report, NEDO-32205, Revision 1, (as specified in Appendix B of that report) and submit a request for approval of the topical report as the basis for demonstrating compliance with 10 CFR Part 50, Appendix G, Paragraph IV.A.1. We further request that you verify that the information you have provided for your facility has been accurately entered in the data base. If no comments are made in your response to the last request, the staff will use the information in the tables for future NRC assessments of your reactor pressure vessel.

Once you have (1) confirmed the applicability of the topical report, NEDO-32205, Revision 1, to your plant, (2) submitted the request for approval, and (3) provided your commitment to the BWR Owners Group effort or a satisfactory schedule for providing a plant-specific analysis, the staff will consider your actions related to GL 92-01, Revision 1, to be complete. Plant-specific licensing action(s) will be initiated to resolve these issues.

The information requested by this letter is within the scope of the overall burden estimated in GL 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)." The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,
Original signed by:

Alexander W. Dromerick, Sr. Project Manager
Project Directorate, I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Pressure-Temperature Limits Table
 - 2. Upper-Shelf Energy Table
 - 3. Nomenclature Key
- cc w/enclosures:
See next page

DISTRIBUTION:

Docket File	SNorris
PDR & Local PDRs	ADromerick
PDI-4 Plant	OGC
SVarga	ACRS (10)
JCalvo	JRogge, RGI
DMcDonald	SSheng

OFFICE:	LA:PDI-4	PM:PDI-4	D:PDI-4		
NAME:	SNorris	ADromerick:bp	JStolz		
DATE:	3/29/94	3/29/94	3/30/94		

March 30, 1994

methodology for resolving the initial RT_{NDT} determination issue and will document the results in a topical report. The BWR Owners Group is obtaining approval from its members to provide the GE topical report to the NRC staff for its review and approval. We request that you submit within 30 days a commitment to the BWR Owners Group effort or a schedule for a plant-specific analysis to resolve this issue. Further, we request that you provide confirmation of the plant-specific applicability of the topical report, NEDO-32205, Revision 1, (as specified in Appendix B of that report) and submit a request for approval of the topical report as the basis for demonstrating compliance with 10 CFR Part 50, Appendix G, Paragraph IV.A.1. We further request that you verify that the information you have provided for your facility has been accurately entered in the data base. If no comments are made in your response to the last request, the staff will use the information in the tables for future NRC assessments of your reactor pressure vessel.

Once you have (1) confirmed the applicability of the topical report, NEDO-32205, Revision 1, to your plant, (2) submitted the request for approval, and (3) provided your commitment to the BWR Owners Group effort or a satisfactory schedule for providing a plant-specific analysis, the staff will consider your actions related to GL 92-01, Revision 1, to be complete. Plant-specific licensing action(s) will be initiated to resolve these issues.

The information requested by this letter is within the scope of the overall burden estimated in GL 92-01, Revision 1, "Reactor Vessel Structural Integrity, 10 CFR 50.54(f)." The estimated average number of burden hours is 200 person hours for each addressee's response. This estimate pertains only to the identified response-related matters and does not include the time required to implement actions required by the regulations. This action is covered by the Office of Management and Budget Clearance Number 3150-0011, which expires June 30, 1994.

Sincerely,



Alexander W. Dromerick, Sr. Project Manager
Project Directorate, I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Pressure-Temperature Limits Table
2. Upper-Shelf Energy Table
3. Nomenclature Key

cc w/enclosures:
See next page

Mr. John J. Barton
Vice President and Director

Oyster Creek Nuclear
Generating Station

cc:

Ernest L. Blake, Jr., Esquire
Shaw, Pittman, Potts & Trowbridge
2300 N Street, NW.
Washington, DC 20037

Resident Inspector
c/o U.S. Nuclear Regulatory Commission
Post Office Box 445
Forked River, New Jersey 08731

Regional Administrator, Region I
U.S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Kent Tosch, Chief
New Jersey Department of
Environmental Protection
Bureau of Nuclear Engineering
CN 415
Trenton, New Jersey 08625

BWR Licensing Manager
GPU Nuclear Corporation
1 Upper Pond Road
Parsippany, New Jersey 07054

Mayor
Lacey Township
818 West Lacey Road
Forked River, New Jersey 08731

Licensing Manager
Oyster Creek Nuclear Generating Station
Mail Stop: Site Emergency Bldg.
Post Office Box 388
Forked River, New Jersey 08731

Summary File for Pressure-Temperature Limits

Plant Name	Beltline Ident.	Heat No. Ident.	ID Neut. Fluence at EOL/EFPY	IRT _{max}	Method of Determin. IRT _{max}	Chemistry Factor	Method of Determin. CF	%Cu	%Ni
Oyster Creek EOL: 12/15/2004	Lower Shell G-307-1	T1937-2	3.62E18	30°F	Plant specific	79.45	Table	0.17	0.11
	Lower Shell G-308-1	T1937-1	3.62E18	21°F	Plant specific	79.45	Table	0.17	0.11
	Lower Shell G-307-5	P2076-2	3.62E18	3°F	Plant specific	173.85	Table	0.27	0.53
	Lower-int. Shell G-8-6	P2150-1	3.62E18	31°F	Plant specific	138.2	Table	0.20	0.51
	Lower-int. Shell G-8-7	P2161-1	3.62E18	17°F	Plant specific	139.4	Table	0.21	0.48
	Lower-int. Shell G-8-8	P2136-2	3.62E18	8°F	Plant specific	120.7	Table	0.18	0.46
	Lower Shell Axial Welds 2-564A/C	86054B	3.62E18	-50°F	Plant specific	168	Table	0.35	0.20
	Lower-int. Shell Axial Welds 2-564D/F	86054B	3.62E18	-8°F ¹	plant specific	168	Table	0.35	0.20
	Lower to Lower-int. Shell Circ. Weld 3-564	1248	3.62E18	-50°F	Plant specific	112	Table	0.22	0.20

References for Oyster Creek

The Ni value for weld 1248 is from September 7, 1993 letter to NRC (Response to GL 92-01 RAI).

Cu, and fluence data are from June 16, 1992, letter from A. W. Dromerick (USNRC) to Distribution (USNRC), subject: Summary of Meeting regarding Reactor Vessel Upper Shelf Energy Analysis for the Oyster Creek Nuclear Generating Plant

Ni, P, S; and IRT data are from January 11, 1991, letter from J. J. Berton (GPLN) to USNRC Document Control Desk, subject: Oyster Creek Nuclear Generating Station, Technical Specification Change Request No. 194. Margin values for plates must be increased to account for σ calculated by the licensee.

¹Additional information required to confirm value.

Summary File for Upper Shelf Energy

Plant Name	Beltline Ident.	Heat No.	Material Type	1/4T USE at EOL/EFY	1/4T Neutron Fluence at EOL/EFY	Unirrad. USE	Method of Determin. Unirrad. USE
Oyster Creek EOL: 12/15/2004	Lower Shell G-307-1	T1937-2	A 302B-1	53	2.36E18	64	65%
	Lower Shell G-308-1	T1937-1	A 302B-1	EMA ²	2.36E18 ²	60	65%
	Lower Shell G-307-5	P2076-2	A 302B-1	EMA ²	2.36E18	62	65%
	Lower-int. Shell G-8-6	P2150-1	A 302B-1	EMA ²	2.36E18	53	65%
	Lower-int. Shell G-8-7	P2161-1	A 302B-1	EMA ²	2.36E18	51	65%
	Lower-int. Shell G-8-8	P2136-2	A 302B-1	53	2.36E18	65	65%
	Lower Shell Axial Welds 2-564A/C	86054B	Arcos B-5, SAW	EMA ²	2.36E18	EMA ²	
	Lower-int. Shell Axial Welds 2-564D/F	86054B	Arcos B-5, SAW	EMA ²	2.36E18	EMA ²	
	Lower to Lower-int. Shell Circ. Weld 3-564	1248	Arcos B-5, SAW	EMA ²	2.36E18	EMA ²	
<u>References for Oyster Creek</u>							
<p>USE, Cu, and fluence data are from June 16, 1992, letter from A. W. Dromerick (USMRC) to Distribution (USMRC), subject: Summary of Meeting regarding Reactor Vessel Upper Shelf Energy Analysis for the Oyster Creek Nuclear Generating Plant</p>							

²Licensee must confirm applicability of Topical Report NEDO-32205, Rev. 1

PRESSURE-TEMPERATURE LIMIT TABLES AND USE TABLES FOR ALL BWR PLANTSNOMENCLATURE

Pressure-Temperature Limits Table

- Column 1: Plant name and date of expiration of license.
 Column 2: Beltline material location identification.
 Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process, (T) indicates tandem wire was used in the SAW process.
 Column 4: End-of-life (EOL) neutron fluence at vessel inner wall; cited directly from inner diameter (ID) value or calculated by using Regulatory Guide (RG) 1.99, Revision 2 neutron fluence attenuation methodology from the quarter thickness (T/4) value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).
 Column 5: Unirradiated reference temperature.
 Column 6: Method of determining unirradiated reference temperature (IRT).

Plant-Specific

This indicates that the IRT was determined from tests on material removed from the same heat of the beltline material.

MTEB 5-2

This indicates that the unirradiated reference temperature was determined from following MTEB 5-2 guidelines for cases where the IRT was not determined using American Society of Mechanical Engineers Boiler and Pressure Vessel Code, Section III, NB-2331, methodology.

Generic

This indicates that the unirradiated reference temperature was determined from the mean value of tests on material of similar types.

- Column 7: Chemistry factor for irradiated reference temperature evaluation.
 Column 8: Method of determining chemistry factor

Table

This indicates that the chemistry factor was determined from the chemistry factor tables in RG 1.99, Revision 2.

Calculated

This indicates that the chemistry factor was determined from surveillance data via procedures described in RG 1.99, Revision 2.

Column 9: Copper content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no copper data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Column 10: Nickel content; cited directly from licensee value except when more than one value was reported. (Staff used the average value in the latter case.)

No Data

This indicates that no nickel data has been reported and the default value in RG 1.99, Revision 2, will be used by the staff.

Upper Shelf Energy Table

- Column 1: Plant name and date of expiration of license.
Column 2: Beltline material location identification.
Column 3: Beltline material heat number; for some welds that a single-wire or tandem-wire process has been reported, (S) indicates single wire was used in the SAW process. (T) indicates tandem wire was used in the SAW process.
Column 4: Material type; plate types include A 533B-1, A 302B, A 302B Mod., and forging A 508-2; weld types include SAW welds using Linde 80, 0091, 124, 1092, ARCOS-B5 flux, Rotterdam welds using Graw Lo, SMIT 89, LW 320, and SAF 89 flux, and SMAW welds using no flux.
Column 5: EOL upper-shelf energy (USE) at T/4; calculated by using the EOL fluence and either the copper value or the surveillance data. (Both methods are described in RG 1.99, Revision 2.)

EMA

This indicates that the USE issue may be covered by the approved equivalent margins analysis in the BWR Owners Group Topical Report: NEDO-32205, Revision 1.

- Column 6: EOL neutron fluence at T/4 from vessel inner wall; cited directly from T/4 value or calculated by using RG 1.99, Revision 2 neutron fluence attenuation methodology from the ID value reported in the latest submittal (GL 92-01, PTS, or P/T limits submittals).

Column 7: Unirradiated USE.

EMA

This indicates that the USE issue may be covered by the approved equivalent margins analysis in the BWR Owners Group Topical Report: NEDO-32205, Revision 1.

Column 8: Method of determining unirradiated USE

Direct

For plates, this indicates that the unirradiated USE was from a transverse specimen. For welds, this indicates that the unirradiated USE was from test date.

65%

This indicates that the unirradiated USE was 65% of the USE from a longitudinal specimen.

Generic

This indicates that the unirradiated USE was reported by the licensee from other plants with similar materials to the beltline material.

NRC generic

This indicates that the unirradiated USE was derived by the staff from other plants with similar materials to the beltline material.

10, 30, 40, or 50 °F

This indicates that the unirradiated USE was derived from Charpy test conducted at 10, 30, 40, or 50 °F.

Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having the same weld wire heat number.

Equiv. to Surv. Weld

This indicates that the unirradiated USE was from the surveillance weld having different weld wire heat number.

Sister Plant

This indicates that the unirradiated USE was derived by using the reported value from other plants with the same weld wire heat number.

Blank

indicates that there is insufficient data to determine the unirradiated USE. These licensees will utilize Topical Report NEDO-32205, Revision 1 to demonstrate USE compliance to Appendix G, 10 CFR Part 50.