

HEATUP AND COOLDOWN LIMIT CURVES  
FOR NORMAL OPERATION

BRAIDWOOD UNIT 2  
(CAPSULE U)

N. K. Ray  
J. M. Chicots

February 1991

Work Performed Under Shop Order BMVP-106

Prepared by Westinghouse Electric Corporation  
for the Commonwealth Edison Company

Approved by:

*T. A. Meyer*

T. A. Meyer, Manager

Structural Reliability and Life Optimization

WESTINGHOUSE ELECTRIC CORPORATION  
Nuclear and Advanced Technology Division  
P.O. Box 2728  
Pittsburgh, Pennsylvania 15230-2728

© 1991 Westinghouse Electric Corp.

9404070173 940330  
PDR ADDCK 05000456  
P PDR

## TABLE OF CONTENTS

<u>Section</u>	<u>Title</u>	<u>Page</u>
1	INTRODUCTION	1
2	FRACTURE TOUGHNESS PROPERTIES	1
3	CRITERIA FOR ALLOWABLE PRESSURE-TEMPERATURE RELATIONSHIPS	2
4	HEATUP AND COOLDOWN LIMIT CURVES	5
5	ADJUSTED REFERENCE TEMPERATURE	6
6	REFERENCES	13

## LIST OF ILLUSTRATIONS

<u>Figure</u>	<u>Title</u>	<u>Page</u>
1	Braidwood Unit 2 Reactor Coolant System Heatup Limitations (Heat up rate up to 100°F/hr) Applicable for the First 16 EFPY (Without Margins For Instrumentation Errors)	11
2	Braidwood Unit 2 Reactor Coolant System Cooldown (Cooldown rates up to 100°F/hr) Limitations Applicable for the First 16 EFPY (Without Margins For Instrumentation Errors)	12

## LIST OF TABLES

<u>Table</u>	<u>Title</u>	<u>Page</u>
1	Braidwood Unit 2 Reactor Vessel Toughness Table (Unirradiated)	8
2	Summary of Adjusted Reference Temperature (ART) at 1/4T and 3/4T Location	9
3	Calculation of Adjusted Reference Temperatures for Limiting Braidwood Unit 2 Reactor Vessel Material - Circumferential Weld	10

# HEATUP AND COOLDOWN LIMIT CUR. FOR NORMAL OPERATION

## 1. INTRODUCTION

Heatup and cooldown limit curves are calculated using the most limiting value of  $RT_{NDT}$  (reference nil-ductility temperature) for the reactor vessel. The most limiting  $RT_{NDT}$  of the material in the core region of the reactor vessel is determined by using the preservice reactor vessel material fracture toughness properties and estimating the radiation-induced  $\Delta RT_{NDT}$ .  $RT_{NDT}$  is designated as the higher of either the drop weight nil-ductility transition temperature (NDTT) or the temperature at which the material exhibits at least 50 ft-lb of impact energy and 35-mil lateral expansion (normal to the major working direction) minus 60°F.

$RT_{NDT}$  increases as the material is exposed to fast-neutron radiation. Therefore, to find the most limiting  $RT_{NDT}$  at any time period in the reactor's life,  $\Delta RT_{NDT}$  due to the radiation exposure associated with that time period must be added to the original unirradiated  $RT_{NDT}$ . The extent of the shift in  $RT_{NDT}$  is enhanced by certain chemical elements (such as copper and nickel) present in reactor vessel steels. The Nuclear Regulatory Commission (NRC) has published a method for predicting radiation embrittlement in Regulatory Guide 1.99 Rev. 2 (Radiation Embrittlement of Reactor Vessel Materials)<sup>[1]</sup>. Regulatory Guide 1.99, Revision 2 is used for the calculation of  $RT_{NDT}$  values at  $1/4T$  and  $3/4T$  locations ( $T$  is the thickness of the vessel at the beltline region).

## 2. FRACTURE TOUGHNESS PROPERTIES

The fracture-toughness properties of the ferritic material in the reactor coolant pressure boundary are determined in accordance with the NRC Regulatory Standard Review Plan<sup>[2]</sup>. The pre-irradiation fracture-toughness properties of the Braidwood Unit 2 reactor vessel are presented in Table 1.

### 3. CRITERIA FOR ALLOWABLE PRESSURE-TEMPERATURE RELATIONSHIPS

The ASME approach for calculating the allowable limit curves for various heatup and cooldown rates specifies that the total stress intensity factor,  $K_I$ , for the combined thermal and pressure stresses at any time during heatup or cooldown cannot be greater than the reference stress intensity factor,  $K_{IR}$ , for the metal temperature at that time.  $K_{IR}$  is obtained from the reference fracture toughness curve, defined in Appendix G to the ASME Code<sup>[3]</sup>. The  $K_{IR}$  curve is given by the following equation:

$$K_{IR} = 26.78 + 1.223 \exp [0.0145 (T - RT_{NDT} + 160)] \quad (1)$$

where

$K_{IR}$  = reference stress intensity factor as a function of the metal temperature  $T$  and the metal reference nil-ductility temperature  $RT_{NDT}$

Therefore, the governing equation for the heatup-cooldown analysis is defined in Appendix G of the ASME Code<sup>[3]</sup> as follows:

$$C K_{IM} + K_{IT} \leq K_{IR} \quad (2)$$

where

$K_{IM}$  = stress intensity factor caused by membrane (pressure) stress

$K_{IT}$  = stress intensity factor caused by the thermal gradients

$K_{IR}$  = function of temperature relative to the  $RT_{NDT}$  of the material

$C$  = 2.0 for Level A and Level B service limits

$C$  = 1.5 for hydrostatic and leak test conditions during which the reactor core is not critical

At any time during the heatup or cooldown transient  $K_{IR}$  is determined by the metal temperature at the tip of the postulated flaw, the appropriate value for  $RT_{NDT}$ , and the reference fracture toughness curve. The thermal stresses resulting from the temperature gradients through the vessel wall are calculated and then the corresponding (thermal) stress intensity factors,  $K_{IT}$ , for the reference flaw are computed. From equation 2, the pressure stress intensity factors are obtained and, from these, the allowable pressures are calculated.

For the calculation of the allowable pressure versus coolant temperature during cooldown, the reference flaw of Appendix G to the ASME Code is assumed to exist at the inside of the vessel wall. During cooldown, the controlling location of the flaw is always at the inside of the wall because the thermal gradients produce tensile stresses at the inside, which increase with increasing cooldown rates. Allowable pressure-temperature relations are generated for both steady-state and finite cooldown rate situations. From these relations, composite limit curves are constructed for each cooldown rate of interest.

The use of the composite curve in the cooldown analysis is necessary because control of the cooldown procedure is based on the measurement of reactor coolant temperature, whereas the limiting pressure is actually dependent on the material temperature at the tip of the assumed flaw.

During cooldown, the 1/4 T vessel location is at a higher temperature than the fluid adjacent to the vessel ID. This condition, of course, is not true for the steady-state situation. It follows that, at any given reactor coolant temperature, the  $\Delta T$  developed during cooldown results in a higher value of  $K_{IR}$  at the 1/4 T location for finite cooldown rates than for steady-state operation. Furthermore, if conditions exist so that the increase in  $K_{IR}$  exceeds  $K_{IT}$ , the calculated allowable pressure during cooldown will be greater than the steady-state value.

The above procedures are needed because there is no direct control on temperature at the 1/4 T location and, therefore, allowable pressures may unknowingly be violated if the rate of cooling is decreased at various

intervals along a cooldown ramp. The use of the composite curve eliminates this problem and ensures conservative operation of the system for the entire cooldown period.

Three separate calculations are required to determine the limit curves for finite heatup rates. As is done in the cooldown analysis, allowable pressure-temperature relationships are developed for steady-state conditions as well as finite heatup rate conditions assuming the presence of a 1/4 T defect at the inside of the wall that alleviate the tensile stresses produced by internal pressure. The metal temperature at the crack tip lags the coolant temperature; therefore, the  $K_{IR}$  for the 1/4 T crack during heatup is lower than the  $K_{IR}$  for the 1/4 T crack during steady-state conditions at the same coolant temperature. During heatup, especially at the end of the transient, conditions may exist so that the effects of compressive thermal stresses and lower  $K_{IR}$ 's do not offset each other, and the pressure-temperature curve based on steady-state conditions no longer represents a lower bound of all similar curves for finite heatup rates when the 1/4 T flaw is considered. Therefore, both cases have to be analyzed in order to ensure that at any coolant temperature the lower value of the allowable pressure calculated for steady-state and finite heatup rates is obtained.

The second portion of the heatup analysis concerns the calculation of the pressure-temperature limitations for the case in which a 1/4 T deep outside surface flaw is assumed. Unlike the situation at the vessel inside surface, the thermal gradients established at the outside surface during heatup produce stresses which are tensile in nature and therefore tend to reinforce any pressure stresses present. These thermal stresses are dependent on both the rate of heatup and the time (or coolant temperature) along the heatup ramp. Since the thermal stresses at the outside are tensile and increase with increasing heatup rates, each heatup rate must be analyzed on an individual basis.

Following the generation of pressure-temperature curves for both the steady state and finite heatup rate situations, the final limit curves are produced by constructing a composite curve based on a point-by-point comparison of the steady-state and finite heatup rate data. At any given temperature, the

allowable pressure is taken to be the lesser of the three values taken from the curves under consideration. The use of the composite curve is necessary to set conservative heatup limitations because it is possible for conditions to exist wherein, over the course of the heatup ramp, the controlling condition switches from the inside to the outside, and the pressure limit must at all times be based on analysis of the most critical criterion.

Finally, the 1983 Amendment to 10CFR50<sup>[4]</sup> has a rule which addresses the metal temperature of the closure head flange and vessel flange regions. This rule states that the metal temperature of the closure flange regions must exceed the material  $RT_{NDT}$  by at least 120°F for normal operation when the pressure exceeds 20 percent of the preservice hydrostatic test pressure.

Table 1 indicates that the initial  $RT_{NDT}$  of 20°F occurs in both the vessel flange and the closure head flange of Braidwood Unit 2, so the minimum allowable temperature of this region is 140°F. These limits are shown in Figures 1 and 2 whenever applicable.

#### 4. HEATUP AND COOLDOWN LIMIT CURVES

Limit curves for normal heatup and cooldown of the primary Reactor Coolant System have been calculated using the methods discussed in Section 3. Figure 1 is the heatup curve up to 100°F/hr and applicable for the first 16 EFPY without margins for possible instrumentation errors. Figure 2 is the cooldown curve up to 100°F/hr and applicable for the first 16 EFPY without margins for possible instrumentation errors.

Allowable combinations of temperature and pressure for specific temperature change rates are below and to the right of the limit lines shown in Figures 1 and 2. This is in addition to other criteria which must be met before the reactor is made critical.

The leak limit curve shown in Figure 1 represents minimum temperature requirements at the leak test pressure specified by applicable



codes [2,3]. The 100k test limit curve was determined by methods of References 2 and 4.

Figures 1 and 2 define limits for ensuring prevention of nonductile failure for the Braidwood Unit 2 reactor vessel.

#### 5. ADJUSTED REFERENCE TEMPERATURE

From Regulatory Guide 1.99 Rev. 2 [1] the adjusted reference temperature (ART) for each material in the beltline is given by the following expression:

$$\text{ART} = \text{Initial RT}_{\text{NDT}} + \Delta\text{RT}_{\text{NDT}} + \text{Margin} \quad (3)$$

Initial  $\text{RT}_{\text{NDT}}$  is the reference temperature for the unirradiated material as defined in paragraph NB-2331 of Section III of the ASME Boiler and Pressure Vessel Code. If measured values of initial  $\text{RT}_{\text{NDT}}$  for the material in question are not available, generic mean values for that class of material may be used if there are sufficient test results to establish a mean and standard deviation for the class.

$\Delta\text{RT}_{\text{NDT}}$  is the mean value of the adjustment in reference temperature caused by irradiation and should be calculated as follows:

$$\Delta\text{RT}_{\text{NDT}} = [\text{CF}]f^{(0.28-0.10 \log f)} \quad (4)$$

To calculate  $\Delta\text{RT}_{\text{NDT}}$  at any depth (e.g., at 1/4T or 3/4T), the following formula must first be used to attenuate the fluence at the specific depth.

$$f(\text{depth } x) = f_{\text{surface}}(e^{-.24x}) \quad (5)$$

where  $x$  (in inches) is the depth into the vessel wall measured from the vessel clad/base metal interface. The resultant fluence is then put into equation (4) to calculate  $\Delta\text{RT}_{\text{NDT}}$  at the specific depth.

CF ( $^{\circ}$ F) is the chemistry factor, obtained from Reference 1. All materials in the beltline region of Braidwood Unit 2 were considered for the limiting material.  $RT_{NDT}$  at 1/4T and 3/4T are summarized in Table 2. From Table 2, it can be seen that the limiting material is the circumferential weld for heatup and cooldown curves applicable up to 16 EFPY. A sample calculation for  $RT_{NDT}$  is shown in Table 3.

TABLE 1  
BRAIDWOOD UNIT 2 REACTOR VESSEL TOUGHNESS TABLE (Unirradiated)

<u>Component</u>	<u>Heat No.</u>	<u>Cu (%)</u>	<u>Ni (%)</u>	<u>i (a)</u> <u>(°F)</u>
Closure head flange (b)	2031-V-1	-	-	20
Vessel flange (b)	124P455	-	-	20
Upper Shell	49D963/ 49C904 1-1	.03	.71	-30
Lower Shell	50D102/ 50C97 1-1	.06	.75	-30
Circumferential Weld (c)	WF562	.04	.67	40

- a. The initial  $RT_{NDT}$  (I) values for the forgings and weld are measured values.
- b. To be used for considering flange requirements for heatup/cool-down curves<sup>[4]</sup>
- c. These values from Weld Certification Test Report WF562 are higher than the values of 0.03% Cu and 0.67% Ni used in the PTS submittal<sup>[5]</sup>.

TABLE 2  
 SUMMARY OF ADJUSTED REFERENCE TEMPERATURE (ART) AT 1/4T and 3/4T LOCATION

<u>Component</u>	<u>16 EFY</u>	
	<u>RT<sub>NDT</sub> AT</u>	
	<u>1/4T (°F)</u>	<u>3/4T (°F)</u>
Upper Shell, 49D963/49C904 1-1	9	-2
Lower Shell, 50D102/50C97 1-1	40	21
Circumferential Weld	145*	115*

\* These RT<sub>NDT</sub> numbers used to generate heatup and cooldown curves applicable up to 16 EFY

TABLE 3  
 CALCULATION OF ADJUSTED REFERENCE TEMPERATURES FOR LIMITING  
 BRAIDWOOD UNIT 2 REACTOR VESSEL MATERIAL - CIRCUMFERENTIAL WELD

<u>Parameter</u>	Regulatory Guide 1.99 - Revision 2	
	16 EFY	
	1/4 T	3/4 T
Chemistry Factor, CF (°F)	54.00	54.00
Fluence, f (10 <sup>19</sup> n/cm <sup>2</sup> ) (a)	0.907	0.327
Fluence Factor, ff	0.973	0.693
*****		
$\Delta RT_{NDT} = CF \times ff$ (°F)	52.5	37.4
Initial $RT_{NDT}$ , I (°F)	40.0	40.0
Margin, M (°F) (b)	52.5	37.4

Revision 2 to Regulatory Guide 1.99

Adjusted Reference Temperature,	145	115
$ART = \text{Initial } RT_{NDT} + \Delta RT_{NDT} + \text{Margin}$		

\*\*\*\*\*

(a) Fluence, f, is based upon  $f_{surf}$  (10<sup>19</sup> n/cm<sup>2</sup>, E>1 Mev) = 1.51 at 16 EFY[7]. The Braidwood Unit 2 reactor vessel wall thickness is 8.5 inches at the beltline region[6].

(b) Margin is calculated as,  $M = 2 [\sigma_I^2 + \sigma_\Delta^2]^{0.5}$ . The standard deviation for the initial  $RT_{NDT}$  margin term ( $\sigma_I$ ) is assumed to be 0°F since the initial  $RT_{NDT}$  is a measured value. The standard deviation for  $\Delta RT_{NDT}$ , ( $\sigma_\Delta$ ) is 28°F for the weld, except that  $\sigma_\Delta$  need not exceed 0.50 times the mean value of  $\Delta RT_{NDT}$ .

MATERIAL PROPERTY BASIS

CONTROLLING MATERIAL: CIRCUMFERENTIAL WELD

INITIAL RT<sub>NDT</sub>: 40°F

ART AFTER 16 EPY: 1/4T, 145°F

3/4T, 115°F




Figure 1. Braidwood Unit 2 Reactor Coolant System Heatup Limitations (Heat up rate up to 100°F/hr) Applicable for the First 16 EPY (Without Margins For Instrumentation Errors)

MATERIAL PROPERTY BASIS

CONTROLLING MATERIAL: CIRCUMFERENTIAL WELD  
INITIAL RT<sub>NDT</sub>: 40°F  
ART AFTER 16 EFPY: 1/4T, 145°F  
3/4T, 115°F




Figure 2. Braidwood Unit 2 Reactor Coolant System Cooldown (Cooldown rates up to 100°F/hr) Limitations Applicable for the First 16 EFPY (Without Margins For Instrumentation Errors)

## 6. REFERENCES

- [1] Regulatory Guide 1.99, Revision 2, "Radiation Embrittlement of Reactor Vessel Materials," U.S. Nuclear Regulatory Commission, May, 1988.
- [2] "Fracture Toughness Requirements," Branch Technical Position MTEB 5-2, Chapter 5.3.2 in Standard Review Plan for the Review of Safety Analysis Reports for Nuclear Power Plants, LWR Edition, NUREG-0800, 1981.
- [3] ASME Boiler and Pressure Vessel Code, Section III, Division 1 - Appendixes, "Rules for Construction of Nuclear Power Plant Components, Appendix G, Protection Against Nonductile Failure," pp. 558-563, 1986 Edition, American Society of Mechanical Engineers, New York, 1986.
- [4] Code of Federal Regulations, 10CFR50, Appendix G, "Fracture Toughness Requirements," U.S. Nuclear Regulatory Commission, Washington, D.C., Federal Register, Vol. 48 No. 104, May 27, 1983.
- [5] PTS Submittal for Braidwood Unit 1 Reactor Vessel (Section 5.3, Braidwood FSAR, Amendment 47, Commonwealth Edison Company, April 1986).
- [6] MT-SMART-078(89), "Byron Unit 2 and Braidwood Unit 2 Reactor Vessel Heatup and Cooldown Limit Curves for Normal Operation", N. K. Ray, February 1989.
- [7] WCAP-12845, "Analysis of Capsule U from the Commonwealth Edison Company Braidwood Unit 2 Reactor Vessel Radiation Surveillance Program", E. Terek, et. al., February 1991.



ATTACHMENT 1  
DATA POINTS FOR HEATUP AND COOLDOWN CURVES  
(Without Margins for Instrumentation Errors)

01/11/91

CDE 100 DEG F/HR HEATUP CURVE REG GUIDE 1.99 REV 2 W/O MARGIN

THE FOLLOWING DATA WERE CALCULATED FOR THE INSERVICE HYDROSTATIC LEAK TEST

MINIMUM INSERVICE LEAK TEST TEMPERATURE 1 16 000 EPY)

PRESSURE (PSI)	TEMPERATURE (DEG F)
2000	256
2485	278

PRESSURE (PSI)	PRESSURE STRESS (PSI SQ RT IN )	1.5 KIM
2000	21142	89085
2485	26268	111649

01/11/91

CDE 100 DEG F/HR HEATUP CURVE REG. GUIDE 1 99 REV 2 W/O MARGIN

HEATUP RATE(S) (DEG F/HR) \* 100 0

COMPOSITE CURVE PLOTTED FOR HEATUP PROFILE 2

IRRADIATION PERIOD \* 16 000 EFP YEARS

FLAW DEPTH - (1-ADMIN)

	INDICATED TEMPERATURE (DEG.F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG.F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG.F)	INDICATED PRESSURE (PSI)
1	85 000	528 23	18	170 000	534 55	35	255 000	1022 43
2	90 000	514 60	19	175 000	547 75	36	260 000	1075 42
3	95 000	503 40	20	180 000	562 50	37	265 000	1132 16
4	100 000	494 28	21	185 000	578 80	38	270 000	1193 34
5	105 000	487 22	22	190 000	596 55	39	275 000	1258 81
6	110 000	481 93	23	195 000	616 12	40	280 000	1328 94
7	115 000	478 45	24	200 000	637 43	41	285 000	1404 23
8	120 000	476 53	25	205 000	660 49	42	290 000	1484 74
9	125 000	476 19	26	210 000	685 63	43	295 000	1571 04
10	130 000	479 26	27	215 000	712 74	44	300 000	1663 31
11	135 000	483 61	28	220 000	742 01	45	305 000	1762 04
12	140 000	488 81	29	225 000	773 83	46	310 000	1867 61
13	145 000	495 30	30	230 000	807 97	47	315 000	1980 32
14	150 000	503 04	31	235 000	844 76	48	320 000	2100 72
15	155 000	512 18	32	240 000	884 37	49	325 000	2228 90
16	160 000	522 69	33	245 000	927 20	50	330 000	2365 61
17	165 000		34	250 000	973 12			

01/11/91

CDE COOLDOWN CURVES REG. GUIDE 1 99, REV 2 WITHOUT MARGIN

THE FOLLOWING DATA WERE PLOTTED FOR COOLDOWN PROFILE 1 - STEADY STATE COOLDOWN 1

IRRADIATION PERIOD = 16 000 EFP YEARS  
 FLAW DEPTH = ADMIN 1

INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)	INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)	INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)
85 000	546 34	16	160 000	31	235 000
90 000	553 03	17	165 000	32	240 000
95 000	560 22	18	170 000	33	245 000
100 000	567 95	19	175 000	34	250 000
105 000	576 26	20	180 000	35	255 000
110 000	585 20	21	185 000	36	260 000
115 000	584 68	22	190 000	37	265 000
120 000	605 01	23	195 000	38	270 000
125 000	616 11	24	200 000	39	275 000
130 000	<del>628 05</del> 621 *	25	205 000	40	280 000
135 000	<del>640 86</del> 641 *	26	210 000	41	285 000
140 000	<del>654 64</del> 651 *	27	215 000	42	290 000
145 000	669 38	28	220 000	43	295 000
150 000	685 31	29	225 000	44	300 000
155 000	702 30	30	230 000		

Pressure limited to 621 psi due to flange requirement.

THE FOLLOWING DATA WERE PLOTTED FOR COOLDOWN PROFILE 2 (20 DEG F / HR COOLDOWN )

IRRADIATION PERIOD = 16 000 EFP YEARS  
 FLAW DEPTH = ADMIN T

	INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)
1	85 000	504 08	11	125 000	603 64	21	185 000	811 47
2	90 000	511 05	12	140 000	618 28	22	190 000	841 73
3	95 000	518 58	13	145 000	634 07	23	195 000	874 53
4	100 000	526 68	14	150 000	650 90	24	200 000	909 61
5	105 000	535 42	15	155 000	669 19	25	205 000	947 30
6	110 000	544 81	16	160 000	688 82	26	210 000	987 81
7	115 000	554 85	17	165 000	709 86	27	215 000	1031 39
8	120 000	565 74	18	170 000	732 59	28	220 000	1078 22
9	125 000	577 50	19	175 000	756 95	29	225 000	1128 60
10	130 000	590 14	20	180 000	783 25			

THE FOLLOWING DATA WERE PLOTTED FOR COOLDOWN PROFILE 3 (140 DEG F / HR COOLDOWN )

IRRADIATION PERIOD = 16 000 EFP YEARS  
 FLAW DEPTH = ADMIN T

	INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)
1	85 000	461 03	11	135 000	566 38	20	180 000	758 61
2	90 000	468 33	12	140 000	581 98	21	185 000	788 90
3	95 000	476 24	13	145 000	598 70	22	190 000	821 69
4	100 000	484 75	14	150 000	616 82	23	195 000	856 82
5	105 000	493 97	15	155 000	636 36	24	200 000	894 56
6	110 000	503 80	16	160 000	657 27	25	205 000	935 21
7	115 000	514 53	17	165 000	679 95	26	210 000	979 08
8	120 000	526 07	18	170 000	704 19	27	215 000	1026 15
9	125 000	538 55	19	175 000	730 49	28	220 000	1076 55
10	130 000	551 87						

THE FOLLOWING DATA WERE PLOTTED FOR COOLDOWN PROFILE 4 (160 DEG F / HR COOLDOWN)

IRRADIATION PERIOD = 16 000 EFP YEARS  
 CLAW DEPTH = ADWIN 1

	INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)
1	85 000	417.14	11	135 000	529.00	20	180 000	735.44
2	90 000	424.82	12	140 000	545.57	21	185 000	768.15
3	95 000	433.16	13	145 000	563.59	22	190 000	803.31
4	100 000	442.15	14	150 000	583.00	23	195 000	841.20
5	105 000	451.83	15	155 000	603.84	24	200 000	882.14
6	110 000	462.34	16	160 000	626.41	25	205 000	926.12
7	115 000	473.73	17	165 000	650.63	26	210 000	973.41
8	120 000	486.01	18	170 000	676.87	27	215 000	1024.31
9	125 000	499.28	19	175 000	705.01	28	220 000	1078.84
10	130 000	513.52						

CDE COOLDOWN CURVES REG GUIDE 1 99, REV 2 WITHOUT MARGIN

01/11/91

THE FOLLOWING DATA WERE PLOTTED FOR COOLDOWN PROFILE 5 1 100 DEG F/HR COOLDOWN 1

IRRADIATION PERIOD = 16 000 EFP YEARS  
 FLAW DEPTH = AOWIN 1

	INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)		INDICATED TEMPERATURE (DEG F)	INDICATED PRESSURE (PSI)
1	85 000	326.72	10	130 000	436.38	19	175 000	658.64
2	90 000	335.32	11	135 000	454.12	20	180 000	694.07
3	95 000	344.70	12	140 000	473.34	21	185 000	732.48
4	100 000	354.85	13	145 000	494.17	22	190 000	773.75
5	105 000	365.89	14	150 000	516.54	23	195 000	818.25
6	110 000	377.78	15	155 000	540.86	24	200 000	866.17
7	115 000	390.76	16	160 000	566.97	25	205 000	917.80
8	120 000	404.78	17	165 000	595.19	26	210 000	973.42
9	125 000	419.94	18	170 000	625.76	27	215 000	1033.16

A-8



6.0 REFERENCES

1. Regulatory Guide 1.99, "Radiation Embrittlement of Reactor Vessel Materials," Revision 2, May 1988.
2. NUREG-0800, "Pressure-Temperature Limits," Standard Review Plan, Section 5.3.2.
3. Letter from A. R. Checca (CECo) to T. E. Murley (USNRC), Subject: Braidwood Station, Units 1 and 2, Application for Amendment to Facility Operating License NPF-72 and NPF-77, NRC Docket No. 50-456 and 50-457, December 19, 1990.
4. WCAP-11651, "Analysis of Capsule U from the Commonwealth Edison Company Byron Unit 1 Reactor Vessel Radiation Surveillance Program," November 1987.
5. WCAP-12685, "Analysis of Capsule U from the Commonwealth Edison Company Braidwood Unit 1, Reactor Vessel Radiation Surveillance Program," August 1990.
6. WCAP-12845, "Analysis of Capsule U from the Commonwealth Edison Company Braidwood Unit 2, Reactor Vessel Radiation Surveillance Program," March 1991.