NRC FORM 366 U.S. NUCLY REGULATORY COMMISSION 17.77) Attachm . to AECM-82/417 LICENSEE EVENT REPORT Page 1 1 CONTROL BLOCK: J(1)(PLEASE PRINT OR TYPE ALL REA ED INFORMATION) 1 2 0 0 0 - 0 0 0 0 - 0 0 3 4 LICENSE NUMBER 25 26 S 0 MSGG LICENSEE CODE CON'T L 6 0 5 0 0 0 4 1 6 7 0 9 1 0 8 2 0 1 SOURCE DOCKET NUMBER EVENT DATE EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10) During an inspection by the Fire Protection Coordinator, areas containing safety 0 2 related cable in the Auxiliary Building were identified as not having smoke detectors. 013 These areas were Room 1A605 on the 228 ft. elevation and stairwell 1Ai2 on elevations 0 4 185 to 208. An investigation revealed combustibles in the area. An hourly fire watch 0 5 was established in these areas. There was no threat to plant safety nor to public 0 6 health or safety. SYSTEM CAUSE CAUSE COMP VALVE SUBCODE COMPONENT CODE SUBCODE ZZ Z (15 AB B (12 A (13) Z Z 2 (14) Z (16) Z OCCURRENCE REVISION REPORT SEQUENTIAL EVENT YEAR REPORT NO. CODE TYPE NO LER/RO 81 REPORT 2 0 6 0 0 1 Τ 0 NUMBER COMPONENT ACTION FUTURE EFFECT ON PLANT SHUTDOWN A FTACHMENT SUBMITTED NPRD-4 FORM SUB PRIME COMP HOURS (22 SUPPLIER Z (21) 0101 N (23) N (24) Z | 9 | 9 | 0 Z X CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27) Smoke detectors in these areas were omitted from the original plant design. Similar events have been reported in LER 82-007/01 T-0 and 82-018/01 T-0. The design deficiency is under evaluation. An hourly fire watch will be maintained in the interim. This is being submitted as an interim report. 4 80 METHOD OF FACILITY (30) DISCOVERY DESCRIPTION (32) OTHER STATUS % POWER 1(28 (31) 0 Special Inspection 80 CONTENT ACTIVITY LOCATION OF RELEASE (36) AMOUNT OF ACTIVITY (35) RELEASED OF RELEASE (34) (33) Z NA NA 4.4 80 PERSONNEL EXPOSURES DESCEIPTION (39) TYPE 0 0 0 37 NA 80 PERSONNEL INJURIES DESCRIPTION (41) 0 0 (43) NA 80 LOSS OF OR DAMAGE TO FACILITY (43 TYPE DESCRIPTION Z (42) NA 8209300221 820922 80 PUBLICITY PDR ADOCK 05000416 NRC USE ONLY DESCR SUED PDR S N (44) 68 69 80 NAME OF PREPARER Original Signed by Ray Patterson PHONE .-