

INSERVICE INSPECTION REPORT

FOR

VIRGIL C. SUMMER NUCLEAR STATION (Unit #1)

P. O. Box 88

Jenkinsville, S. C. 29065

SOUTH CAROLINA ELECTRIC & GAS COMPANY

Columbia, S. C. 29218

Commercial Service Date 1-1-84

Report Completion Date 05-24-90

9010010082 900815
PDR ADOCK 05000395
Q PDC

FORM NIS-1 OWNERS' DATA REPORT FOR INSERVICE INSPECTIONS

As required by the Provisions of the ASME Code Rules

1. Owner South Carolina Electric & Gas Company - Columbia, SC 29218
(Name and Address of Owner)
2. Plant V. C. Summer Station - P. O. Box 88 - Jenkinsville, SC 29065
(Name and Address of Plant)
3. Plant Unit 1 4. Owner Certificate of Authorization N/A
(if required)
5. Commercial Service Date 1/1/84 6. National Board Number for Unit N/A
7. Components Inspected:

Component or Appurtenance	Manufacturer or Installer	Manufacturer or Installer Serial No.	State or Province No.	National Board No.
'A' Steam Generator	Westinghouse	75004-1-72	N/A	N/A
'B' Steam Generator	Westinghouse	75005-1-72	N/A	N/A
'C' Steam Generator	Westinghouse	75006-1-72	N/A	N/A
Reactor Coolant	DCC	RC	N/A	N/A
Safety Injection	DCC	SI	N/A	N/A
Chemical Volume & Control	DCC	CS	N/A	N/A
Main Steam	DCC	MS	N/A	N/A
Residual Heat Removal	DCC	RHR	N/A	N/A
Emergency Feedwater	DCC	EF	N/A	N/A
Service Water	DCC	SW	N/A	N/A
Reactor Spray	DCC	SP	N/A	N/A
Feedwater	DCC	FW	N/A	N/A
Spent Fuel	DCC	SF	N/A	N/A
Diesel Generator	DCC	DG	N/A	N/A
Chill Water	DCC	VU	N/A	N/A
Pressurizer	Westinghouse	1581	N/A	W11248
Component Cooling	DCC	CC	N/A	N/A
Reactor Vessel	CBI Nuclear Company	T39	N/A	3
Auxiliary Cooling	DCC	AC	N/A	N/A
Pressurizer Spray	DCC	P. Sp.	N/A	N/A
Pressurizer Relief	DCC	Pz. Rel.	N/A	N/A
Excess Letdown Heat Exchanger	Atlas Industrial	3021	N/A	2398
Service Water Heat Exchanger	Atlas Industrial	2559	N/A	1944

FORM NIS-1 (back)

- 8. Examination Dates 03-7-89 to 05-24-90
- 9. Inspection Interval from 01-01-84 to 12-31-93
- 10. Abstract of Examinations. Include a list of examinations and a statement concerning status of work required for current interval.

See Page 10 of 70 of Summary Report SCE&G #3

- 11. Abstract of Conditions Noted.

See Page 4 of 70 of Summary Report SCE&G #3

- 12. Abstract of Corrective Measures Recommended and Taken

See Page 5 of 70 of Summary Report SCE&G #3

We certify that the statements in this report are correct and the examinations and corrective measures taken conform to the rules of the ASME Code, Section XI.

Date 7/30 1990 Signed SCE&G By M.A. Janett
Owner

Certificate of Authorization No. (if applicable) N/A Expiration Date N/A

CERTIFICATE OF INSERVICE INSPECTION

I, the undersigned, holding a valid commission issued by the National Board of Boiler and Pressure Vessel Inspectors and/or the State of Province of North Carolina and employed by Hartford Steam Boiler Inspection & Insurance Co of Hartford, CT have inspected the components described in this Owner's Data Report during the period 7-7-89 to 8-2-90 and state that to the best of my knowledge and belief, the Owner has performed examinations and taken corrective measures described in this Owner's Data Report in accordance with the requirements of the ASME Code, Section XI.

By signing this certificate neither the Inspector nor his employer makes any warranty, expressed or implied, concerning the examinations and corrective measures described in this Owner's Data Report. Furthermore, neither the Inspector nor his employer shall be liable in any manner for any personal injury or property damage or a loss of any kind arising from or connected with this inspection.

Date 8-3- 1990

[Signature]
Inspector's Signature

Commissions NC 1007
National Board, State, Province and No.

ABSTRACT

This report presents the results of the Inservice Inspection for the fifth Refueling Outage, second period, first interval at the Virgil C. Summer Nuclear Station. Examinations for the circumferential weld, pipe, and fitting base material were conducted in accordance with ASME Section XI. In addition, "C" Steam Generator girth weld #1 and "B" Steam Generator nozzles, (M.S. & F.W.) were examined using ultrasonic techniques. The Steam Generator Tubing for "A, B & C" steam generators were examined by means of Eddy Current Examination techniques. A visual examination of the interior surface of the Reactor Pressure Vessel was performed remotely by means of video camera. No rejectable flaw indications were found in the Class 1 and Class 2 pressure retaining components. The visual examination indications that were found unacceptable were repaired or replaced and reexamined. All reportable indications were dispositioned in accordance with procedures of the South Carolina Electric & Gas Company (SCE&G).

1.0 INTRODUCTION

The Inservice Inspection of the fifth Refueling Outage at the Virgil C. Summer Nuclear Station, Unit 1 was conducted in accordance with the site Technical Specifications and the Final Safety Analysis Report. These documents describe the extent to which the American Society of Mechanical Engineers Boiler and Pressure Vessel Code Section XI, 1974 Edition through Summer of 1975 addendum and 1977 through Summer of 1978 addendum apply to Virgil C. Summer Nuclear Station. This report contains a detailed, item-by-item summary of results of the examinations performed by Nuclear Energy Services and South Carolina Electric and Gas Company personnel since the fourth Refueling Outage through May 24, 1990. Sketches and Data Sheets of the Class 1 and Class 2 system component examinations, visual examination data, limitations, consumable materials, personnel certification and ultrasonic calibration standards/certifications are retained by South Carolina Electric and Gas Company. Information for the following categories may be obtained through the South Carolina Electric and Gas Company plant records system.

- | | |
|-----------------------------------|---------------------------------------|
| (A.) Personnel Certification | (E.) Calibration Block Certifications |
| (B.) NDE Procedures | (F.) Isometrics |
| (C.) NDE Equipment Certifications | (G.) Nonconformance Notices |
| (D.) Consumable Certifications | (H.) Relief Requests |

2.0 EXAMINATION EVALUATION

1. The fifth Inservice Inspection (ISI), identified as Interval 1, Period 2, Outage 5, for the South Carolina Electric and Gas Company (SCE&G) of the Virgil C. Summer Nuclear Station, Unit 1, was performed in accordance with the Inservice Inspection Program prepared by SCE&G. For a description of areas, extent, and frequency of examination, including percentage of components examined in each category, refer to Virgil C. Summer Nuclear Station, Unit 1, ISI Program Plan (QSP-210 and QSP-211). All scheduled nondestructive examinations performed during this period were documented on examination data sheets. Included on these data sheets are the component or system identification, examination method, procedure employed, unique data sheet number, and all applicable equipment settings and examination conditions. The data sheets, together with applicable isometric sketches, are retained for record purposes. In the event that a recordable indication was located, the dimension and location were documented on the appropriate data sheet for evaluation. All evaluations were documented, reviewed and submitted to SCE&G for disposition. The summary of the results of the examinations performed is contained in the Summary Report SCE&G #3 (Pages 16 through 70).
2. Ultrasonic, magnetic particle, and liquid penetrant examinations that revealed flaw indications exceeding the acceptance standards of ASME Code Section XI 1974 Edition through Summer of 1975 addendum and 1977 Edition through Summer of 1978 addendum which apply to V. C. Summer Nuclear Station were identified and transmitted to SCE&G for disposition. All flaw indications exceeding Code acceptance standards are identified in the applicable examination summary "Remarks" column with reference to the applicable NCN involved. The SCE&G documentation for final acceptance of

nongeometric flaw indications is referenced in the examination data package and in the examination summary.

3. For visual examinations, all indications were reported to SCE&G for disposition. All indications discovered during visual examinations have been dispositioned.
4. The results of all examinations performed at the Virgil C. Summer Nuclear Station, Unit 1, during the fifth Refueling Outage show one of the following for all welds and components examined:
 1. No Indications
 2. Acceptable Flaw Indications
 3. Flaw Indications Addressed by SCE&G Disposition

The Summary Table SCE&G #3 included, provides an item by item listing of the ISI results. This table indexes and summarizes the examination data retained by South Carolina Electric & Gas. Areas which did not receive full examination coverage are identified, and the accompanying justification is retained in the Plant Records System.

3. SUMMARY OF EXAMINATIONS

1. The NDE summary table itemizes the results of the Virgil C. Summer Interval 1, Period 2, Outage 5, Inservice Inspection. The following is a brief explanation, by column, of what is contained in the summary tables.
 - A. Drawing/Isometric No. - This column contains the isometric drawing number specified in the SCE&G outage plan.
 - B. Weld/Component Ident. - Identified weld/component as specified in the SCE&G outage plan.
 - C. System Identification - Identifies system being examined.
 - D. Date of Exam - Date the examination was actually performed.

- E. Code Category - ASME BPV Section XI category specified in the SCE&G outage plan.
 - F. Code Item No. - ASME BPV Section XI item number specified in the SCE&G outage plan.
 - G. Indications - This column contains a characterization of indications reported on the Data Sheet. This column will contain either "Yes", "None", or "Geom" (geometry). If "Yes" is indicated, there will also be a brief description of the indication in remarks.
 - H. Limitations - This column contains a "Yes" or the word "None". If a limited examination is identified, the "Remarks" column will describe what that limitation was. In addition, for UT examinations, all weld configurations that preclude examinations from both sides are identified as one sided in this "Remarks" column. Note that a more detailed description of the limitation is contained on the examination data sheets, and in the Summary of Limitations Table 4.
 - I. Remarks - Identifies the extent of limitations, basis for acceptance of flaw indications, etc., and other information as space allows.
 - J. Disposition - This column indicates the disposition. For those welds dispositioned as "Reject", the basis for acceptance by SCE&G is specified in the remarks.
 - K. Report Number - This column contains the applicable examination report number(s).
 - L. NDE Method Used - The NDE method as specified in the SCE&G outage plan.
2. The following abbreviations may be found in this report:

A. - Addendum

ACC.	-	Acceptable
A. SP.	-	Auxillary Containment Spray System
AUX. F.W.	-	Auxillary Feedwater System
B/MAT'L	-	Base Material
BET.	-	Between
CONFIG.	-	Configuration
CONJ.	-	Conjunction
COT.	-	Cotter
CS	-	Chemical and Volume Control system
CVCS	-	Chemical and Volume Control System
ELB.	-	Elbow
EXAM	-	Examination
FW	-	Feedwater System
GEOM	-	Geometrical indications
IEB.	-	IE Bulletin
IND.	-	Indication
INSUL.	-	Insulation
INFO.	-	Information
ISI	-	Inservice Inspection
MB	-	Main Steam Blowdown System
MS	-	Main Steam System
MT	-	Magnetic Particle Examination
N/A	-	Not Applicable
NCN	-	Nonconformance Notice
NOZ.	-	Nozzle
NDE	-	Nondestructive Examination
OBST.	-	Obstruction
PAD	-	Pre-approved Disposition
PL	-	Plate
PREP.	-	Preparation
PT	-	Liquid Penetrant Examination
R/R	-	Relief Request
RC	-	Reactor Coolant
REF	-	Reference
RESTR.	-	Restraint
RH	-	Residual Heat Removal System

RHR	- Residual Heat Removal System
S/CAN	- Spring Can
S/G	- Steam Generator
SI	- Safety Injection
SIS	- Safety Injection System
VU	- Chill Water System
CC	- Component Cooling System
SNUB.	- Snubber
SP	- Containment Spray System
ST	- Surveillance Test Task Sheet
STRU.	- Structural
SW	- Service Water System
TECH SPEC.	- Technical Specification
TRANS.	- Transition
VCSM	- Virgil C. Summer Magnetic Particle Examination Data
VCSP	- Virgil C. Summer Liquid Penetration Examination Data
VCSU	- Virgil C. Summer Ultrasonic Data
VCSV	- Virgil C. Summer Visual Examination Data
VLV.	- Valve
W/	- With
NES	- Nuclear Energy Services
EF	- Emergency Feedwater System
DG	- Diesel Generator System
SF	- Spent Fuel System
RPV	- Reactor Pressure Vessel
HT. EXC.	- Heat Exchanger

STATUS OF CURRENT INTERVAL

The status of examinations for the current interval is in accordance with Table IWB-2412-1, IWC 2412-1 and Article IWD 2400 for the second inspection period. A minimum of 34% but not more than 67% of the examinations were completed.

TABLE 1**NDE PERSONNEL FOR 5TH REFUELING**

Employee	Company
Joseph Hewitt, Project Manager	NES
Clifford Anderson, Lead Technician	NES
Carlos Deluna	NES
Carlos Blum	NES
David Linehan	NES
Todd Ginder	NES
Mark Faust	NES
Stan Varnon	NES
Phil Gainer	NES
Michael Terpening	NES
Dennis Funk	NES
Carl Dodd	NES
Michael Forseth	NES
William Downs	NES
Barry Mether	SCE&G
William Pate	SCE&G
Jack Hulett	SCE&G
Roy Caban	SCE&G
Alan Torres	SCE&G
Frank Shumpert	SCE&G

TABLE 2

1990 REFUEL 5 NCNs FOR ISE

NCN #	ITEM/COMPONENT DESCRIPTION
3742A	CCH-429
3809	FWH-346
SFR-4141	RHR "B" HT. Exch.
3741	XHE-017A
3404	CCH-279
3416	CCH-4002/163
3435	CCH-289
3331	CCH-4007
3434	CCH-075
3398	CCH-095
3494	VUH-088
3699	SFH-042
3671	SFH-032
3749	RCH-4015
3689	RHH-117
3689A	RHH-116
3679	RHH-125/126
3787	FWH-1055
3792	CSH-781
3731	XPP-32A (Dwg. Change)

TABLE 3
CALIBRATION BLOCKS (5th Refuel)

Ultrasonic	Cal. Blocks	Magnetic Particle
CGE-3	4" S/S	AC-11 C/S 11.5 lbs.
CGE-4	6" S/S	AC-12 C/S 10.09 lbs.
CGE-9	RC-Pipe S/S	
CGE-13	10" S/S SCH 40	
CGE-14	12" S/S	
CGE-15	14" S/S	
CGE-16	10" S/S SCH 140	
CGE-17	6" C/S	
CGE-18	8" C/S	
CGE-19	16" C/S	
CGE-21	18" C/S	
CGE-22	32" C/S	
CGE-23	3½" X 6 X 18 S/Gen.	
CGE-24	3½" X 6 X 12¼ Przr.	
CGE-25	3½" X 6 X 19¼ S/Gen.	
CGE-26	30" C/S	
CGE-29	8" S/S SCH 160	
CGE-35	16" C/S	
CGE-37	8" C/S SCH 40	

TABLE 4
Listing of Limitations for 5th Refueling

WELD/ITEM #	DRAWING	METHOD	DESCRIPTION
1	CGE-2-1310	PT	Weld Ident. Plate Rel./Req. 2-Pipe-1
17	CGE-2-2558	PT	Restraint Obstruction Rel./Req. 2-Pipe-1
WS-1	CGE-2-2552	PT	Clamp Obstruction (Lugs) Rel./Req. 2-Pipe-1
WS-3	CGE-2-2552	PT	Clamp Obstruction (Lugs) Rel./Req. 2-Pipe-1
WS-1	CGE-2-3110	PT	Support Configuration Rel./Req. 2-Pipe-1
WS-2	CGE-2-3110	PT	Support Configuration Rel./Req. 2-Pipe-1
3	CGE-2-1110	PT	Ref. SFR-4141 & Rel/Req. 2-H X -4
4	CGE-2-1110	PT	Ref. SFR-4141 & Rel/Req. 2-H X -4
87 LS-12	CGE-2-2105A	MT	Welded Saddle Obstruction Rel./Req. 2-Pipe-1
21 (BC)	CGE-1-4300A	UT	Scans 0° & 45° One sided exam configuration Rel./Req. 1-Pipe-1
1	CGE-1-4300A	UT	Scans 0° & 45° One sided exam configuration Rel./Req. 1-Pipe-1
S/G "C" Weld #1	CGE-1-3100	UT	Scans 0°, 45° & 60° Ident. Plates & Insulation Pads Rel./Req. 1-S/G-1
9	CGE-2-1100	UT	One sided 45° Exam Config. Rel./Req. 2-S/G-1
2	CGE-2-2203	UT	One sided 45° Exam Config. Rel./Req. 2-Pipe-1
1	CGE-2-1150	UT	One sided 45° Exam Welded Obstructions Rel./Req. 2-HX-1
9	CGE-2-2200A	UT	Scans 45° One-sided Exam Configuration Rel./Req. 2-Pipe-1
47	CGE-2-2203	UT	Scans 45° One-sided Exam Configuration Rel./Req. 2-Pipe-1
34 BC	CGE-2-2203	UT	Scans 45° One-sided Exam Configuration Rel./Req. 2-Pipe-1
14	CGE-2-2550	UT	Scans 45° One-sided Exam Configuration Rel./Req. 2-Pipe-1
45	CGE-1-4503	UT	Scans 45° One-sided Exam Configuration Rel./Req. 1-Pipe-1
46	CGE-1-4503	UT	Scans 45° One-sided Exam Configuration Rel./Req. 1-Pipe-1

Listing of Limitations for 5th Refueling (cont'd.)

WELD/ITEM #	DRAWING	METHOD	DESCRIPTION
33	CGE-1-4503	UT	Scans 45° One-sided Exam Configuration Rel./Req. 1-Pipe-1
1	CGE-1-2100A	UT	Scans 0°-60°-45° Welded Attachments Rel./Req. 1-Press-4
116Ls-16	CGE-2-2101B	UT	Scans 45° Welded Attachments Rel./Req. 2-Pipe-1
20	CGE-2-2541	UT	Scans 45° One-sided Exam Config. Rel./Req. 2-Pipe-1
28	CGE-2-2203	UT	Scans 45° One-sided Exam Configuration Rel./Req. 2-Pipe-1
8	CGE-2-2203	UT	Scans 45° One-sided Exam Configuration Rel./Req. 2-Pipe-1
36	CGE-2-2501	UT	Scans 45° One-sided Exam Configuration Rel./Req. 2-Pipe-1
29	CGE-2-2501	UT	Ref. Data Pkg. ISI-8.R.7A.1 Rel./Req. 2-Pipe-1
61	CGE-2-2521A	UT	Scans 45° One-sided Exam Configuration Rel./Req. 2-Pipe-1
9	CGE-2-1100	UT	Nozzle Config. Ref. Rel/Req. 2-S/G-1
11	CGE-2-1100	UT	Nozzle Config. Ref. Rel/Req. 2-S/G-1
CCH-034	C-314-611-10	VT-3	R/R 3-PS-1 Enclosed in Fire Barrier
CCH-142	C-314-611-11	VT-3	Ref. R/R 3-PS-1
CCH-288	C-314-611-15	VT-3	Ref. R/R 3-PS-1
CCH-247	C-314-611-15	VT-3	Ref. R/R 3-PS-1
CCH-078	C-314-611-17	VT-3	Ref. R/R 3-PS-1
CCH-4019	C-314-611-17	VT-3	Partially Enclosed in Fire Barrier R/R 3-PS-1
VUH-238	1MS-22-560	VT-3	Ref. R/R 3-PS-1
VUH-237	1MS-22-561	VT-3	Ref. R/R 3-PS-1
EFH-106	C-314-085-5	VT-3	Ref. R/R 3-PS-1
SFH-081	C-314-651-3	VT-3	Ref. R/R 3-PS-1
SFH-056	C-314-651-4	VT-3	Ref. R/R 3-PS-1
SFH-045	C-314-651-7	VT-3	Ref. R/R 3-PS-1

South Carolina Electric & Gas Company
V. C. Summer Station, Unit 1

Steam Generator A, B. & C
Eddy Current Examination
April 1990

The fifth eddy current examination of V. C. Summer Station steam generator tubing was performed during April 1990. This examination was performed in accordance with the ASME 'Boiler & Pressure Vessel Code' Section XI, 1977 Edition, through Summer 1978 addenda and as specified by the Nuclear Regulatory Commission, Regulatory Guide 1.83, Revision 1, dated July 1975.

The examination was performed on 100% of available tubes in the inlet tube sheet region. A full length (i.e., tube end to tube end) examination was performed on approximately 17% of the available tubes and 15% examined from the inlet tube end around the U-bend to the top support on the outlet side. The inspection was conducted using the latest available digital multi-frequency examination equipment and techniques.

The table below summarizes total tubes in each given category:

	'A'	'B'	'C'	A11
Total number tubes plugged previously	280	507	304	1091
Number tubes - 40% or greater indications	296	389	196	881
Number plugs installed for new indications	88	110	81	279
Number tubes repaired - (sleeved)	76	49	0	125
Number tubes F* applied	132	230	115	477
Total number tubes now plugged	368	617	385	1370
Percent of total bundle now plugged	7.9%	13.2%	8.2%	9.8%

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 ULTRASONIC EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	UT METHOD
CGE-1-2100A	1	PRZ.	04/04/90	B-B	B2.011	NONE	YES*	REF. VCSU-0679 & 0680	ACCEPT	VCSU-0678	UT
CGE-1-2100A	5-1	PRZ.	04/03/90	B-B	B2.012	NONE	NONE	REF. VCSU-0679 & 0680	ACCEPT	VCSU-0678	UT
CGE-1-4503	3	PZ.SP	04/25/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSU-0751	UT
CGE-1-4503	1	PZ.SP	04/25/90	B-J	B9.011	NONE	YES*	ONE SIDE EXAM (PIPE CONFIG.)#	ACCEPT	VCSU-0751	UT
CGE-1-4300A	21BC (BRANCH CONN.)	PZ.SP	04/25/90	B-J	B9.011	NONE	YES*	REF. VCSU-0754*ONE-SIDE CONF#	ACCEPT	VCSU-0753	UT
CGE-1-4503	24	PZ.SP	04/25/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSU-0750	UT
CGE-1-4503	23	PZ.SP	04/25/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSU-0750	UT
CGE-1-4503	25	PZ.SP	04/25/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSU-0752	UT
CGE-1-4503	45	PZ.SP	04/04/90	B-J	B9.011	NONE	YES*	ONE-SIDE EXAM (PIPE CONFIG.)#	ACCEPT	VCSU-0673	UT
CGE-1-4503	46	PZ.SP	04/04/90	B-J	B9.011	NONE	YES*	ONE-SIDE EXAM (PIPE CONFIG.)#	ACCEPT	VCSU-0674	UT
CGE-1-4503	33	PZ.SP	04/04/90	B-J	B9.011	NONE	YES*	ONE-SIDE EXAM (PIPE CONFIG.)#	ACCEPT	VCSU-0672	UT
CGE-1-4503	35	PZ.SP	04/04/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSU-0672	UT
CGE-1-4503	43	PZ.SP	04/04/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSU-0673	UT
CGE-1-3100	1 (TUBE SHEET WELD)	S.G.B	03/28/90	B-B	B2.040	NONE	YES*	REF. VCSU-0664 & 0665	ACCEPT	VCSU-0663	UT
CGE-1-5100	KEYWAY BORE "B"RCP	RCP	04/13/90	* N/A	* N/A	NONE	YES*	*REG. GUIDE 1.14 REF.VCSU-0708	ACCEPT	VCSU-0707	UT
CGE-1-5100	KEYWAY BORE "C"RCP	RCP	04/06/90	* N/A	* N/A	NONE	YES*	*REG. GUIDE 1.14 (TOP SIDE)	ACCEPT	VCSU-0693	UT
CGE-1-5100	FLANGE BOLTS	RCP	04/14/90	B-G-1	B6.190*	NONE	NONE	*EXAMINED IN PLACE	ACCEPT	VCSU-0715	UT
CGE-1-5100	KEYWAY BORE "A"RCP	RCP	04/06/90	* N/A	* N/A	NONE	YES*	*REG. GUIDE 1.14 (TOP SIDE)	ACCEPT	VCSU-0694	UT
CGE-2-2101B	122LS-28	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2101B	122LS-29	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2101B	123LS-30	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2105A	87LS-11	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2105A	87LS-12	MS	04/07/90	C-F	C5.022	NONE	YES*	LIMITED TO 1-1/2" EXAM AREA	ACCEPT	VCSU-0701	UT
CGE-2-2105A	47LS-12	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	47LS-13	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT

SOUTH CAROLINA ELECTRIC & GAS
V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
FIFTH REFUELING OUTAGE
ULTRASONIC EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CGGE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
CGE-2-2105A	49LS-13	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	49LS-14	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	88LS-14	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	88LS-15	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	96LS-20	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	51LS-15	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	51LS-16	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	89LS-16	MS	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0713	UT
CGE-2-2105A	89LS-17	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	75LS-17	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	75LS-18	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	90LS-18	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	90LS-19	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	77LS-19	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2105A	77LS-20	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0704	UT
CGE-2-2101B	117LS-17	MS	04/07/90	C-F	C5.022	YES ^P	NONE	IND. ACCEPTABLE PER IWB-3514 ^B	ACCEPT	VCSU-0701	UT
CGE-2-2101B	79LS-18	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0703	UT
CGE-2-2101B	78LS-18	MS	04/06/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0703	UT
CGE-2-2101B	118LS-20	MS	04/06/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0703	UT
CGE-2-2101B	119LS-21	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2101B	120LS-22	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2101B	120LS-23	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2101B	121LS-26	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2101B	121LS-27	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0701	UT
CGE-2-2101A	77LS-14	MS	04/10/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0706	UT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 ULTRASONIC EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CGE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	IDE METHOD
CGE-2-2101A	76LS-14	MS	04/09/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0702	UT
CGE-2-2101B	116LS-16	MS	04/10/90	C-F	C5.022	GEOM	NONE	IND. GEOMETRY ON I.D. SURFACE	ACCEPT	VCSU-0706	UT
CGE-2-2200A	9	MS	03/04/90	C-F	C5.021	NONE	YES*	ONE-SIDE EXAM (PIPE CONFIG.)*	ACCEPT	VCSU-0670	UT
CGE-2-2202	1	FW	04/21/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSU-0749	UT
CGE-2-2202	2	FW	04/21/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSU-0749	UT
CGE-2-2202	17LS-2	FW	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0749	UT
CGE-2-2202	17LS-3	FW	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0749	UT
CGE-2-2202	18LS-2	MS	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0749	UT
CGE-2-2202	18LS-3	FW	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-0749	UT
CGE-2-2202	16	FW	04/16/90	C-F	C5.021	GEOM	NONE	N/A	ACCEPT	VCSU-0712	UT
CGE-2-2202	14	FW	04/16/90	C-F	C5.021	GEOM	NONE	N/A	ACCEPT	VCSU-0712	UT
CGE-2-2202	13	FW	04/16/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSU-0712	UT
CGE-2-2203	4	FW	04/07/90	C-F	C5.021	GEOM	NONE	N/A	ACCEPT	VCSU-0720	UT
CGE-2-2203	5	FW	04/07/90	C-F	C5.021	GEOM	NONE	N/A	ACCEPT	VCSU-0720	UT
CGE-2-2203	6	FW	04/05/90	C-F	C5.021	GEOM	NONE	N/A	ACCEPT	VCSU-0722	UT
CGE-2-2203	24	FW	04/09/90	C-F	C5.021	GEOM	NONE	N/A	ACCEPT	VCSU-0719	UT
CGE-2-2203	1	FW	04/06/90	C-F	C5.021	GEOM	NONE	REF. VCSU-0695 (0 SCAN)	ACCEPT	VCSU-0696	UT
CGE-2-2203	28	FW	04/18/90	C-F	C5.021	GEOM	YES*	ONE-SIDE EXAM (PIPE CONFIG.)*	ACCEPT	VCSU-0717	UT
CGE-2-2203	8	FW	04/06/90	C-F	C5.021	GEOM	YES*	ONE-SIDE EXAM (PIPE CONFIG.)*	ACCEPT	VCSU-0718	UT
CGE-2-2203	23	FW	04/21/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSU-0715	UT
CGE-2-2203	2	FW	04/06/90	C-F	C5.021	NONE	YES*	ONE-SIDE EXAM REF. VCSU-0695*	ACCEPT	VCSU-0696	UT
CGE-2-2203	46	FW	04/02/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSU-0676	UT
CGE-2-2203	47	FW	04/02/90	C-F	C5.021	NONE	YES*	ONE-SIDE EXAM (PIPE CONFIG.)*	ACCEPT	VCSU-0676	UT
CGE-2-2525	9	RHR B	04/06/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0697	UT
CGE-2-1150	EXCESS LETDOWN HT.EX	CS	04/17/90	C-A	C1.010	NONE	YES*	ONE-SIDE EXAM (VESSEL CONFIG.)*	ACCEPT	VCSU-0723	UT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 ULTRASONIC EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
CGE-2-2541	20	SIS	04/19/90	C-F	C2.01	NONE	YES*	ONE-SIDE EXAM (PIPE CONFIG.)#	ACCEPT	VCSU-0714	UT
CGE-2-2541	10	SIS	04/16/90	C-F	C2.01	GEOM	NONE	N/A	ACCEPT	VCSU-0710	UT
CGE-2-2550	14	SIS	03/30/90	C-F	C2.01	NONE	YES*	ONE-SIDE EXAM (PIPE CONFIG.)#	ACCEPT	VCSU-0662	UT
CGE-2-2550	12	SIS	03/03/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-	UT
CGE-2-2555	8	CC	04/02/90	C-G	C2.01	GEOM	NONE	N/A	ACCEPT	VCSU-0675	UT
CGE-2-2555	14	CC	04/17/90	C-G	C2.01	GEOM	NONE	N/A	ACCEPT	VCSU-0711	UT
CGE-2-2557A	12	SW	04/09/90	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0700	UT
CGE-2-2557A	15	SW	03/29/90	C-G	C2.01	NONE	NONE	REF. VCSU-0667 (0 SCAN)	ACCEPT	VCSU-0668	UT
CGE-2-2557A	2	SW	04/07/90	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0699	UT
CGE-2-2552	10	SP	04/11/90	C-G	C2.01	GEOM	NONE	N/A	ACCEPT	VCSU-0705	UT
CGE-2-2501	36	RHR B	01/11/89	C-F	C2.01	NONE	YES*	ONE-SIDE EXAM (PIPE CONFIG.)#	ACCEPT	VCSU-0612	UT
CGE-2-2501	29	RHR B	07/11/89	C-F	C2.01	NONE	YES*	*REF. DATA PKG. IS!-B-R.7A.1	ACCEPT	VCSU-0548	UT
CGE-2-2501	18	RHR B	02/20/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0571	UT
CGE-2-2521A	22	RHR A	07/06/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0546	UT
CGE-2-2521B	32	RHR A	07/07/89	C-F	C2.01	NONE	NONE	1WB 3514.3b SCAN FOR PT IND.	ACCEPT	VCSU-0547	UT
CGE-2-2521A	17	RHR A	06/21/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0545	UT
CGE-2-2521B	33	RHR A	07/07/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0547	UT
CGE-2-2521A	61	RHR A	06/21/89	C-F	C2.01	NONE	YES*	*ONE SIDED EXAM VLV CONFIG. #	ACCEPT	VCSU-0545	UT
CGE-2-2521A	21	RHR A	07/06/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0546	UT
CGE-2-2524	37	RHR B	11/15/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0559	UT
CGE-2-2524	30	RHR B	11/15/89	C-F	C2.01	YES*	NONE	*DENDRITIC REFRACTED BEAM	ACCEPT	VCSU-0559	UT
CGE-2-2524	27	RHR B	11/15/89	C-F	C2.01	YES*	NONE	*DENDRITIC REFRACTED BEAM	ACCEPT	VCSU-0559	UT
CGE-2-2524	2	RHR B	08/24/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0550	UT
CGE-2-2524	6	RHR B	08/24/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0550	UT
CGE-2-2524	39LS	RHR B	08/24/89	C-F	C2.02	NONE	NONE	N/A	ACCEPT	VCSU-0550	UT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 ULTRASONIC EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
CGE-2-2524	40LS	RHR B	08/24/89	C-F	C2.02	NONE	NONE	N/A	ACCEPT	VCSU-0550	UT
CGE-2-2524	43LS	RHR B	08/24/89	C-F	C2.02	NONE	NONE	N/A	ACCEPT	VCSU-0550	UT
CGE-2-2524	61LS	RHR B	11/15/89	C-F	C2.02	NONE	NONE	N/A	ACCEPT	VCSU-0559	UT
CGE-2-2552	16	SP	12/14/89	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0563	UT
CGE-2-2552	26	SP	12/12/89	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0561	UT
CGE-2-2552	36	SP	01/24/90	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0569	UT
CGE-2-2552	52	SP	12/15/89	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0565	UT
CGE-2-2552	53	SP	12/15/89	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSU-0565	UT
CGE-2-1100	9	S/G B	04/18/90	C-B	C2.020	NONE	YES*	REF. VCSU-0725, 0726, & 0727 #	ACCEPT	VCSU-0724	UT
CGE-2-1100	11	S/G B	04/17/90	C-B	C2.020	NONE	YES*	REF. VCSU-0729, 0730, & 0731 #	ACCEPT	VCSU-0728	UT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 LIQUID PENETRANT EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
CGE-1-4208	5	RC	04/10/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0643	PT
CGE-1-4208	1	RC	04/10/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0643	PT
CGE-1-4208	3	RC	04/10/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0643	PT
CGE-1-4210A	1	RC	04/18/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0669	PT
CGE-1-4210A	9	RC	04/20/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0670	PT
CGE-1-4211A	6	RC	04/13/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0651	PT
CGE-1-4211A	1	RC	04/13/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0651	PT
CGE-1-4212	3	RC	04/17/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0655	PT
CGE-1-4212	5	RC	04/17/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0655	PT
CGE-1-4212	8	RC	04/17/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0655	PT
CGE-1-4503	3	PZ.SP	04/24/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0686	PT
CGE-1-4503	1	PZ.SP	04/24/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0685	PT
CGE-1-4503	21BC	PZ.SP	04/25/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0687	PT
CGE-1-4503	24	PZ.SP	04/24/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0690	PT
CGE-1-4503	23	PZ.SP	04/24/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0689	PT
CGE-1-4503	25	PZ.SP	04/24/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0688	PT
CGE-1-4503	45	PZ.SP	04/04/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0629	PT
CGE-1-4503	46	PZ.SP	04/04/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0629	PT
CGE-1-4503	33	PZ.SP	04/04/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0629	PT
CGE-1-4503	35	PZ.SP	04/04/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0629	PT
CGE-1-4503	43	PZ.SP	04/04/90	B-J	B9.011	NONE	NONE	N/A	ACCEPT	VCSP-0629	PT
CGE-1-4503	3	PZ.RE	04/04/90	B-J	B9.021	NONE	NONE	N/A	ACCEPT	VCSP-0628	PT
CGE-1-4505A	50	CVCS	04/19/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0676	PT
CGE-1-4506A	45	CVCS	04/18/90	B-J	B9.040	NONE	NONE	N/A	ACCEPT	VCSP-0675	PT
CGE-2-1150	WS-1	EX.LD	04/16/90	C-C&C-E	C3.010	NONE	NONE	N/A	ACCEPT	VCSP-0677	PT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUPPER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 LIQUID PENETRANT EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
CGE-2-1150	WS-2	EX.LD	04/16/90	C-C&C-E	C3.010	NONE	NONE	N/A	ACCEPT	VCSP-0677	PT
CGE-2-1160	1	SEALW	04/11/90	C-A	C1.010	YES*	NONE	REF. CGSS-06-0072 FILE 122.05	ACCEPT	VCSP-0641	PT
CGE-2-1160	2	SEALW	06/11/90	C-A	C1.020	NONE	NONE	N/A	ACCEPT	VCSP-0641	PT
CGE-2-3100	WS-1	RHR B	06/28/89	C-C&C-E	C3.070	NONE	NONE	REF. SFR 4141	ACCEPT	VCSP-0593	PT
CGE-2-3100	WS-2	RHR B	06/28/89	C-C&C-E	C3.070	NONE	NONE	REF. SFR 4141	ACCEPT	VCSP-0593	PT
CGE-2-3100	WS-3	RHR B	06/28/89	C-C&C-E	C3.070	NONE	NONE	REF. SFR 4141	ACCEPT	VCSP-0593	PT
CGE-2-2501	36	RHR B	01/11/90	C-F	C2.01	YES*	NONE	REF. VCSU-0586 (148-3514.3b) R	ACCEPT	VCSP-0612	PT
CGE-2-2501	29	RHR B	07/11/89	C-F	C2.01	YES*	NONE	REF. VCSU-0584 (148-3514.3b) &	ACCEPT	VCSP-0597	PT
CGE-2-2501	18	RHR B	02/20/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0619	PT
CGE-2-2521A	22	RHR A	07/06/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0595	PT
CGE-2-2521B	32	RHR A	07/07/89	C-F	C2.01	YES*	NONE	REF. VCSU-0547 (148-3514.3b) @	ACCEPT	VCSP-0596	PT
CGE-2-2521A	17	RHR A	06/20/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0592	PT
CGE-2-2521B	33	RHR B	07/07/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0596	PT
CGE-2-2521A	61	RHR A	06/21/89	C-F	C2.01	YES*	NONE	REF. VCSU-0545 (148-3514.3b) @	ACCEPT	VCSP-0592	PT
CGE-2-2521A	21	RHR A	07/06/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0595	PT
CGE-2-2524	37	RHR B	11/15/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0606	PT
CGE-2-2524	30	RHR B	11/15/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0606	PT
CGE-2-2524	27	RHR B	11/15/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0606	PT
CGE-2-2524	2	RHR B	08/24/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0601	PT
CGE-2-2524	6	RHR B	08/24/89	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0601	PT
CGE-2-2524	39LS	RHR B	08/24/89	C-F	C2.02	NONE	NONE	N/A	ACCEPT	VCSP-0601	PT
CGE-2-2524	40LS	RHR B	08/24/89	C-F	C2.02	NONE	NONE	N/A	ACCEPT	VCSP-0601	PT
CGE-2-2524	43LS	RHR B	08/24/89	C-F	C2.02	NONE	NONE	N/A	ACCEPT	VCSP-0601	PT
CGE-2-2524	61LS	RHR B	11/15/89	C-F	C2.02	NONE	NONE	N/A	ACCEPT	VCSP-0606	PT
CGE-2-2524	WS-1	RHR B	02/07/90	C-C&C-E	C3.040	NONE	NONE	WELDED LUGS	ACCEPT	VCSP-0617	PT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 2 COMMERCIAL DATE: JANUARY 1, 1984
 FRESH REFUELING OUTAGE
 LIQUID PENETRANT EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITER	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
CGE-2-2524	WS-4	RHR 8	08/24/89	C-C&C-E	C3.040	NONE	NONE	N/A	ACCEPT	VCSP-0601	PT
CGE-2-3110	WS-1	CS	04/06/89	C-C&C-E	C3.070	YES*	YES*	REF. SFR-4141*	ACCEPT	VCSP-0582	PT
CGE-2-3110	WS-2	CS	04/06/89	C-C/C-E	C3.070	YES*	YES*	REF. SFR-4141*	ACCEPT	VCSP-0582	PT
CGE-2-3110	WS-3	CS	04/06/89	C-C/C-E	C3.070	NONE	NONE	N/A	ACCEPT	VCSP-0582	PT
CGE-2-3110	WS-4	CS	04/06/89	C-C/C-E	C3.070	NONE	NONE	N/A	ACCEPT	VCSP-0582	PT
CGE-2-2540A	19	CVCS	04/19/89	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSP-0583	PT
CGE-2-2540A	21	CVCS	04/19/89	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSP-0583	PT
CGE-2-2540A	23	CVCS	04/17/89	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSP-0583	PT
CGE-2-2540A	87	CVCS	04/17/89	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSP-0583	PT
CGE-2-2540A	98	CVCS	04/20/89	C-F	C5.011	YES*	NONE	REF. VCSU-0543 (1WB-3514.3b) @	ACCEPT	VCSP-0584	PT
CGE-2-2540B	67	CVCS	05/30/89	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSP-0585	PT
CGE-2-2540B	53	CVCS	05/30/89	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSP-0585	PT
CGE-2-2540B	52	CVCS	05/30/89	C-F	C5.011	YES*	NONE	REF. 1WB-3514.3b for ACCEPTANCE @	ACCEPT	VCSP-0585	PT
CGE-2-2540A	90LS	CVCS	04/20/89	C-F	C5.011	YES*	NONE	REF. VCSU-0543 (1WB-3514.3b) @	ACCEPT	VCSP-0584	PT
CGE-2-2552	10	SP	04/11/89	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0650	PT
CGE-2-2552	16	SP	12/14/89	C-G	C2.01	YES*	NONE	REF. VCSU-563 (1WB-3514.3b)	ACCEPT	VCSP-0609	PT
CGE-2-2552	26	SP	12/17/89	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0609	PT
CGE-2-2552	36	SP	01/24/89	C-G	C2.01	YES*	NONE	REF. VCSU-0569 (1WB-3514.3b) @	ACCEPT	VCSP-0614	PT
CGE-2-2552	52	SP	12/17/89	C-G	C2.01	YES*	NONE	REF. VCSU-0565 (1WB-3514.4b) @	ACCEPT	VCSP-0610	PT
CGE-2-2552	53	SP	12/15/89	C-G	C2.01	YES*	NONE	REF. VCSU-0565 (1WB-3514.3b) @	ACCEPT	VCSP-0610	PT
CGE-2-2552	WS-1	SP	04/10/89	C-C	C3.040	NONE	YES*	WEDGED PIPE CLAMP @	ACCEPT	VCSP-0648	PT
CGE-2-2552	WS-3	SP	04/10/89	C-C	C3.040	NONE	YES*	WEDGED PIPE CLAMP @	ACCEPT	VCSP-0649	PT
CGE-2-2552	WS-5	SP	11/29/89	C-C	C3.040	NONE	NONE	N/A	ACCEPT	VCSP-0607	PT
CGE-2-2552	WS-6	SP	11/29/89	C-C	C3.040	NONE	NONE	N/A	ACCEPT	VCSP-0607	PT
CGE-1-4503	VLV. STUDS-8010A	PRES.	03/18/89	B-G-2	B7.070	NONE	NONE	I.A.W. IEB 82-02	ACCEPT	VCSP-0579	PT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 LIQUID PENETRANT EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	MODE METHOD
CGE-1-4501	VLV. STUDS-8010B	PRES.	06/04/89	B-G-2	67.070	NONE	NONE	I.A.W. IEB 82-02	ACCEPT	VCSP-0586	PT
CGE-1-4501	VLV. STUDS-8010C	PRES.	06/04/89	B-G-2	67.070	NONE	NONE	I.A.W. IEB 82-02	ACCEPT	VCSP-0587	PT
CGE-2-2525	9	RHR B	04/06/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0634	PT
CGE-2-1310	1	RC	04/23/90	C-A	C1.010	NONE	YES*	WELDED IDENTIFICATION PLATE	ACCEPT	VCSP-0682	PT
CGE-2-1310	2	RC	04/23/90	C-A	C1.020	NONE	NONE	N/A	ACCEPT	VCSP-0681	PT
CGE-2-1310	WS-1	RC	04/23/90	C-C	C3.010	NONE	NONE	N/A	ACCEPT	VCSP-0683	PT
CGE-2-1310	WS-2	RC	04/23/90	C-C	C3.010	NONE	NONE	N/A	ACCEPT	VCSP-0683	PT
CGE-2-1310	WS-3	RC	04/23/90	C-C	C3.010	NONE	NONE	N/A	ACCEPT	VCSP-0683	PT
CGE-2-1310	WS-4	RC	04/23/90	C-C	C3.010	NONE	NONE	N/A	ACCEPT	VCSP-0683	PT
CGE-2-2541	20	SIS	04/16/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0671	PT
CGE-2-2541	10	SIS	04/16/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0671	PT
CGE-2-2541	WS-1	SIS	04/18/90	C-C	C3.040	NONE	NONE	N/A	ACCEPT	VCSP-0673	PT
CGE-2-2541	WS-2	SIS	04/18/90	C-C	C3.040	NONE	NONE	N/A	ACCEPT	VCSP-0672	PT
CGE-2-2541	WS-3	SIS	04/17/90	C-C	C3.040	NONE	NONE	N/A	ACCEPT	VCSP-0672	PT
CGE-2-2550	14	SIS	03/30/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0626	PT
CGE-2-2550	12	SIS	03/30/90	C-F	C2.01	NONE	NONE	N/A	ACCEPT	VCSP-0626	PT
CGE-2-1110	4	RHR	08/23/89	C-B	C2.010	*YES	*YES	REF.SFR-4141 & REL/REQ. 2-HX-4	ACCEPT	VCSP-0600	PT
CGE-2-1110	3	RHR	08/23/89	C-B	C2.010	YES*	YES*	REF.SFR-4141 & REL/REQ. 2-HX-4	ACCEPT	VCSP-0600	PT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 MAGNETIC PARTICLE EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
CGE-2-2101B	122LS-28	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0965	RT
CGE-2-2101B	122LS-29	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0965	RT
CGE-2-2101B	123LS-30	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0965	RT
CGE-2-2105A	87LS-11	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0968	RT
CGE-2-2105A	87LS-12	MS	04/07/90	C-F	C5.022	NONE	YES*	PARTIALLY ACT. BY SADDLE PL. 2	ACCEPT	VCSM-0968	RT
CGE-2-2105A	47LS-12	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	47LS-13	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	49LS-13	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	49LS-14	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	88LS-14	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	88LS-15	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	96LS-20	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0964	RT
CGE-2-2105A	51LS-15	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	51LS-16	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	89LS-16	MS	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0997	RT
CGE-2-2105A	89LS-17	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	75LS-17	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	75LS-18	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	90LS-18	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	90LS-19	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	77LS-19	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0963	RT
CGE-2-2105A	77LS-20	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0964	RT
CGE-2-2101B	117LS-17	MS	04/05/90	C-F	C5.022	YES*	NONE	REF. VCSU-751 (1WB-3514.2) @	ACCEPT	VCSM-0965	RT
CGE-2-2101B	79LS-18	MS	04/07/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0967	RT
CGE-2-2101B	78LS-18	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSM-0965	RT

SOUTH CAROLINA ELECTRIC & GAS
V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
FIFTH REFUELING OUTAGE
MAGNETIC PARTICLE EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
CGE-2-2101B	118LS-20	MS	04/05/90	C-F	C5-022	NONE	NONE	N/A	ACCEPT	VCSR-0965	RT
CGE-2-2101B	119LS-20A	MS	04/06/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-0966	RT
CGE-2-2101B	119LS-21	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-0965	RT
CGE-2-2101B	120LS-22	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-0965	RT
CGE-2-2101B	120LS-23	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-0965	RT
CGE-2-2101B	121LS-26	MS	04/05/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-0965	RT
CGE-2-2101B	121LS-27	MS	04/05/90	C-F	C5.022	YES*	NONE	REF. VCSU-0701 (IWB-3514.2) #	ACCEPT	VCSR-0965	RT
CGE-2-2101A	77LS-14	MS	05/04/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-0962	RT
CGE-2-2101A	76LS-14	MS	04/09/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-0969	RT
CGE-2-2101B	116LS-16	MS	04/10/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-0975	RT
CGE-2-2200A	9	MS	04/02/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSR-0940	RT
CGE-2-2202	1	FW	04/21/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSR-1016	RT
CGE-2-2202	2	FW	04/21/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSR-1016	RT
CGE-2-2202	17LS-2	FW	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-1017	RT
CGE-2-2202	17LS-3	FW	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-1017	RT
CGE-2-2202	18LS-2	FW	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-1017	RT
CGE-2-2202	18LS-3	FW	04/21/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSR-1017	RT
CGE-2-2202	16	FW	04/16/90	C-F	C5.021	YES*	NONE	REF. VCSU-0712 (IWB-3514.2) #	ACCEPT	VCSR-0988	RT
CGE-2-2202	14	FW	04/16/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSR-0989	RT
CGE-2-2202	13	FW	04/16/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSR-0989	RT
CGE-2-2203	42	FW	04/09/90	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSR-1007	RT
CGE-2-2203	4	FW	04/05/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSR-1006	RT
CGE-2-2203	5	FW	04/05/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSR-1006	RT
CGE-2-2203	6	FW	04/04/90	C-F	C5.021	YES*	NONE	*INDICATIONS - CODE ACCEPTABLE	ACCEPT	VCSR-1005	RT
CGE-2-2203	24	FW	04/07/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSR-1004	RT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 MAGNETIC PARTICLE EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITER	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	RDE METHOD
CGE-2-2203	1	FW	04/05/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSH-0955	MT
CGE-2-2203	28	FW	04/18/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSH-1011	MT
CGE-2-2203	8	FW	04/05/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSH-1006	MT
CGE-2-2203	23	FW	04/21/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSH-1003	MT
CGE-2-2203	WS-1	FW	04/09/90	C-C&C-E	C3.040	NONE	NONE	N/A	ACCEPT	VCSH-1008	MT
CGE-2-2203	WS-2	FW	04/06/90	C-C&C-E	C3.040	NONE	NONE	N/A	ACCEPT	VCSH-1009	MT
CGE-2-2203	WS-3	FW	04/07/90	C-C&C-E	C3.040	NONE	NONE	N/A	ACCEPT	VCSH-1010	MT
CGE-2-2203	2	FW	04/05/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSH-0955	MT
CGE-2-2203	46	FW	04/02/90	C-F	C5.021	YES*	NONE	REF. VCSU-0676 (1WB-3514.2) B	ACCEPT	VCSH-0945	MT
CGE-2-2203	47	FW	04/02/90	C-F	C5.021	NONE	NONE	N/A	ACCEPT	VCSH-0945	MT
CGE-2-2203	34BC	FW	04/02/90	C-F	C5.031	NONE	NONE	N/A	ACCEPT	VCSH-0945	MT
CGE-2-2555	8	CC	04/02/90	C-G	C2.01	YES*	NONE	REF. VCSU-0675 (1WB-3514.2) B	ACCEPT	VCSH-0944	MT
CGE-2-2555	14	CC	04/17/90	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSH-0987	MT
CGE-2-2557A	12	SW	04/09/90	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSH-0954	MT
CGE-2-2557A	15	SW	03/29/90	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSH-0931	MT
CGE-2-2557A	2	SW	04/07/90	C-G	C2.01	NONE	NONE	N/A	ACCEPT	VCSH-0953	MT
CGE-2-2558	8	AC	04/11/90	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSH-0998	MT
CGE-2-2558	11	AC	03/30/90	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSH-0932	MT
CGE-2-2558	29	AC	04/11/90	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSH-0999	MT
CGE-2-2558	26	AC	04/03/90	C-F	C5.011	YES*	NONE	REF. VCSU-0698 (1WB-3514.2) B	ACCEPT	VCSH-0952	MT
CGE-2-2558	21	AC	04/03/90	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSH-0952	MT
CGE-2-2558	34	AC	04/11/90	C-F	C5.011	NONE	NONE	N/A	ACCEPT	VCSH-0999	MT
CGE-1-2100A	15	PRESZ	04/03/90	B-H	B8.020	NONE	NONE	PRESSURIZER SKIRT	ACCEPT	VCSH-0946	MT
CGE-2-2101B	11BALS-20	WS	04/06/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSH-0966	MT
CGE-2-2101B	11BALS-20A	WS	04/06/90	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSH-0966	MT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OVERTAGE
 MAGNETIC PARTICLE EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITER	INDICATION LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
CGE-2-1100 9		S/G B	04/19/90	C-B	C2.020	NONE	N/A	ACCEPT	VCSR-1014	MT
CGE-2-1100 11		S/G B	04/19/90	C-B	C2.020	NONE	N/A	ACCEPT	VCSR-1015	MT

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	MODE METHOD
CGE-1-1160	REACTOR VESSEL INTER	RPV	04/13/90	B-N-1	B13.010	NONE	NONE	REF. VIDEO TAPES OF INSPECTION	ACCEPT	VCSV-4319	VT-3
CGE-1-1300	RPV CLOSURE HEAD #2	RPV	05/04/90	B-G-2	B7.010	NONE	NONE	CONOSEAL BOLTING	ACCEPT	VCSV-4340	VT-1
CGE-1-1300	RPV CLOSURE HEAD #8	RPV	05/04/90	B-G-2	B7.010	NONE	NONE	CONOSEAL BOLTING	ACCEPT	VCSV-4340	VT-1
CGE-1-1300	RPV CLOSURE HEAD #14	RPV	05/04/90	B-G-2	B7.010	NONE	NONE	CONOSEAL BOLTING	ACCEPT	VCSV-4340	VT-1
CGE-1-1300	RPV CLOSURE HEAD #20	RPV	05/04/90	B-G-2	B7.010	NONE	NONE	CONOSEAL BOLTING	ACCEPT	VCSV-4340	VT-1
CGE-1-4212	FLANGE STUDS	RC	04/18/90	B-G-2	B7.050	NONE	NONE	N/A	ACCEPT	VCSV-4321	VT-1
CGE-1-4212	FLANGE NUTS	RC	04/18/90	B-G-2	B7.050	NONE	NONE	N/A	ACCEPT	VCSV-4322	VT-1
CGE-1-2100A	HANWAY BOLTS (PRESZ)	PRESZ	04/06/90	B-G-2	B7.020	NONE	NONE	N/A	ACCEPT	VCSV-4304	VT-1
CGE-1-3100	HANWAY BOLTS S/G "C"	S/G C	04/09/90	B-G-2	B7.030	NONE	NONE	REF. VCSV-4312 HOT&COLD LEGS	ACCEPT	VCSV-4311	VT-1
CGE-1-5100	LOWER S. HOUSING BOLT	RC	04/18/90	B-G-2	B7.060	NONE	NONE	RCP "B" BOLTING	ACCEPT	VCSV-4325	VT-1
CGE-1-5100	UPPER S. HOUSING BOLT	RC	04/19/90	B-G-2	B7.060	NONE	NONE	RCP "B" BOLTING	ACCEPT	VCSV-4324	VT-1
CGE-2-1160	1	CS	04/11/90	C-A	C1.010	NONE	NONE	N/A	ACCEPT	VCSV-4309	VT-3
CGE-2-1160	2	CS	04/11/90	C-A	C1.020	NONE	NONE	N/A	ACCEPT	VCSV-4310	VT-3
CGE-2-1110	4	RHR B	08/23/89	C-B	C2.010	NONE	NONE	VT IN LIEU OF UT TYPE D CONFIG	ACCEPT	VCSV-2842	VT-1
CGE-2-1110	3	RHR B	08/23/89	C-B	C2.010	NONE	NONE	VT IN LIEU OF UT TYPE D CONFIG	ACCEPT	VCSV-2842	VT-1
CGE-1-4501	VALVE STUDS-8010A	PRESZ	03/20/89	B-G-2	B7.070	NONE	NONE	PRESSURIZER SAFETY VALVE STUDS	ACCEPT	VCSV-2616	VT-1
CGE-1-4501	VALVE NUTS-8010A	PRESZ	03/20/89	B-G-2	B7.070	NONE	NONE	PRESSURIZER SAFETY VALVE NUTS	ACCEPT	VCSV-2619	VT-1
CGE-1-4501	VALVE STUDS-8010B	PRESZ	03/20/89	B-G-2	B7.070	NONE	NONE	PRESSURIZER SAFETY VALVE STUDS	ACCEPT	VCSV-2659	VT-1
CGE-1-4501	VALVE NUTS-8010B	PRESZ	03/20/89	B-G-2	B7.070	NONE	NONE	PRESSURIZER SAFETY VALVE NUTS	ACCEPT	VCSV-2659	VT-1
CGE-1-4501	VALVE STUDS-8010C	PRESZ	06/04/89	B-G-2	B7.070	NONE	NONE	PRESSURIZER SAFETY VALVE STUDS	ACCEPT	VCSV-2660	VT-1
CGE-1-4501	VALVE NUTS-8010C	PRESZ	06/04/89	B-G-2	B7.070	NONE	NONE	PRESSURIZER SAFETY VALVE NUTS	ACCEPT	VCSV-2660	VT01
CGE-1-4501	VALVE 8010B INTERNAL	PRESZ	05/31/89	B-H-2	B12.040	NONE	NONE	N/A	ACCEPT	VCSV-2692	VT-1
IMS-22-694	DGH-001	DG	04/11/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2622	VT-3
IMS-22-694	DGH-002	D	03/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2606	VT-3
IMS-22-694	DGH-005	DG	04/11/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2623	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
1MS-22-694	DGH-006	DG	03/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2608	VT-3
1MS-22-696	DGH-015	DG	04/11/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2624	VT-3
1MS-22-696	DGH-017	DG	04/11/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2625	VT-3
1MS-22-699	DGH-016	DG	03/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2607	VT-3
1MS-22-699	DGH-018	DG	03/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2609	VT-3
1MS-32-080-A	XTK-20A	DG	11/20/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3061	VT-3
1MS-32-080-A	XTK-20B	DG	03/19/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4086	VT-3
1MS-94B-750	XHE-17A	DG	03/16/90	D-B	D.2.2	NONE	NONE	NCM-3731 FOR DWG. CHANGE	ACCEPT	VCSV-4070	VT-3
1MS-94B-750	XHE-17B	DG	03/19/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4088	VT-3
C-314-611-1	CCH-001	CC	10/17/89	D-A	D.1.3	NONE	NONE	SMUBBER	ACCEPT	ST0032487	VT-3
C-314-611-1	CCK-001	CC	10/17/89	D-A	D.1.3	NONE	NONE	SMUBBER	ACCEPT	ST0032488	VT-4
C-314-611-1	CCH-002	CC	10/17/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2968	VT-3
C-314-611-1	CCH-003	CC	04/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2626	VT-3
C-314-611-1	CCH-004	CC	04/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2627	VT-3
C-314-611-1	CCH-005	CC	10/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2969	VT-3
C-314-611-1	CCH-006	CC	10/10/89	D-A	D.1.3	NONE	NONE	SMUBBER	ACCEPT	ST0032489	VT-3
C-314-611-1	CCH-006	CC	10/10/89	D-A	D.1.3	NONE	NONE	SMUBBER	ACCEPT	ST0032490	VT-4
C-314-611-1	CCH-007	CC	04/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2628	VT-3
C-314-611-1	CCH-008	CC	04/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2630	VT-3
C-314-611-1	CCH-010	CC	04/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2629	VT-3
C-314-611-1	CCH-009	CC	04/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2631	VT-3
C-314-611-1	CCH-011	CC	04/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2632	VT-3
C-314-611-1	CCH-012	CC	04/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2633	VT-3
C-314-611-1	CCH-4044	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2638	VT-3
C-314-611-1	CCH-477	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2637	VT-3

SOUTH CAROLINA ELECTRIC & GAS
V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
FIFTH REFUELING OUTAGE
VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
C-314-611-1	CCH-4020	CC	04/13/89	D-A	D.1.2	NONE	NONE		ACCEPT	VCSV-2634	VT-3
C-341-611-2	CCH-019	CC	10/10/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032491	VT-3
C-314-611-2	CCH-019	CC	10/10/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032492	VT-4
C-314-611-2	CCH-015	CC	10/10/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2965	VT-3
C-314-611-2	CCH-016	CC	10/10/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2966	VT-3
C-314-611-2	CCH-017	CC	10/10/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2967	VT-3
C-314-611-2	CCH-475	CC	09/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2868	VT-3
C-314-611-2	CCH-018	CC	09/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2867	VT-3
C-314-611-2	CCH-4000	CC	09/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2866	VT-3
C-314-611-2	CCH-4045	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2777	VT-3
C-314-611-2	CCH-476	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2774	VT-3
C-314-611-2	CCH-4021	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2776	VT-3
C-314-611-2	CCH-027	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2641	VT-3
C-314-611-2	CCH-026	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2636	VT-3
C-314-611-5	CCH-040	CC	08/01/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2781	VT-3
C-314-611-5	CCH-111	CC	08/01/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2782	VT-3
C-314-611-5	CCH-039	CC	08/01/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2780	VT-3
C-314-611-5	CCH-038	CC	08/01/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2779	VT-3
C-314-611-5	CCH-037	CC	08/01/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2778	VT-3
C-314-611-6	CCH-286	CC	08/01/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2783	VT-3
C-314-611-6	CCH-278	CC	10/11/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032493	VT-3
C-314-611-6	CCH-278	CC	10/11/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032494	VT-4
C-314-611-6	CCH-279	CC	08/03/89	D-A	D.1.2	YES	NONE	REF. WCH-3604	ACCEPT	VCSV-2794	VT-3
C-314-611-6	CCH-277	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2784	VT-3
C-314-611-6	CCH-275	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2786	VT-3

SOUTH CAROLINA ELECTRIC & GAS
V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
FIFTH REFUELING OUTAGE
VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITER	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	IDE METHOD
C-314-611-6	CCH-276	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2785	VT-3
C-314-611-6	CCH-272	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2788	VT-3
C-314-611-6	CCH-273	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2787	VT-3
C-314-611-6	CCH-274	CC	10/11/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032495	VT-3
C-314-611-6	CCH-274	CC	10/11/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032496	VT-4
C-314-611-6	CCH-271	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2789	VT-3
C-314-611-6	CCH-269	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2791	VT-3
C-314-611-5	CCH-263	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2793	VT-3
C-314-611-6	CCH-264	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2792	VT-3
C-314-611-6	CCH-270	CC	08/02/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2790	VT-3
C-314-611-7	CCH-112	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2822	VT-3
C-314-611-7	CCH-054	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2823	VT-3
C-314-611-7	CCH-053	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2826	VT-3
C-314-611-7	CCH-052	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2812	VT-3
C-314-611-7	CCH-400	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2820	VT-3
C-314-611-7	CCH-047	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2821	VT-3
C-314-611-7	CCH-047	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2815	VT-3
C-314-611-7	CCH-4002	CC	11/09/89	D-A	D.1.2	YES*	NONE	REF. WCN-3416 & VCSV-2827 @	ACCEPT	VCSV-3060	VT-3
C-314-611-7	CCH-048	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2816	VT-3
C-314-611-8	CCH-479	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2813	VT-3
C-314-611-8	CCH-486	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032497	VT-3
C-314-611-8	CCH-486	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032498	VT-4
C-314-611-8	CCH-262	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032499	VT-3
C-314-611-8	CCH-262	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032500	VT-4
C-314-611-8	CCH-260	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2825	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	RDE METHOD
C-314-611-8	CCH-259	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2824	VT-3
C-314-611-8	CCH-257	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2814	VT-3
C-314-611-8	CCH-256	CC	08/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2807	VT-3
C-314-611-8	CCH-255	CC	08/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2808	VT-3
C-314-611-8	CCH-128	CC	08/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2810	VT-3
C-314-611-8	CCH-241	CC	08/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2800	VT-3
C-314-611-8	CCH-252	CC	08/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2796	VT-3
C-314-611-8	CCH-242	CC	08/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2797	VT-3
C-314-611-8	CCH-131	CC	08/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2799	VT-3
C-314-611-8	CCH-243	CC	08/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2798	VT-3
C-314-611-8	CCH-244	CC	08/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2795	VT-3
C-314-611-8	CCH-132	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2819	VT-3
C-314-611-8	CCH-133	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2818	VT-3
C-314-611-8	CCH-134	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032501	VT-3
C-314-611-8	CCH-134	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032502	VT-4
C-314-611-8	CCH-134	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032503	VT-3
C-314-661-8	CCH-254	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032504	VT-4
C-314-611-8	CCH-254	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032504	VT-4
C-314-611-8	CCH-480	CC	08/15/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2817	VT-3
C-314-611-8	CCH-130	CC	08/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2809	VT-3
C-314-611-9	CCH-772	CC	04/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2649	VT-3
C-314-611-9	CCH-765	CC	04/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2651	VT-3
C-314-611-9	CCH-770	CC	04/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2652	VT-3
C-314-611-9	CCH-768	CC	04/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2653	VT-3
C-314-611-9	CCH-774	CC	04/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2648	VT-3
C-314-611-9	CCH-766	CC	04/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2654	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING STAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITER	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	RDE METHOD
C-314-611-9	CCH-763	CC	04/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2650	VT-3
C-314-611-9	CCH-1505	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2719	VT-3
C-314-611-9	CCH-762	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2720	VT-3
C-314-611-9	CCH-761	CC	07/24/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2728	VT-3
C-314-611-9	CCH-760	CC	07/24/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2727	VT-3
C-314-611-9	CCH-759	CC	07/24/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2726	VT-3
C-314-611-9	CCH-758	CC	07/24/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2725	VT-3
C-314-611-9	CCH-757	CC	07/24/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2724	VT-3
C-314-611-9	CCH-753	CC	07/24/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2723	VT-3
C-314-611-9	CCH-752	CC	07/24/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2722	VT-3
C-314-611-9	CCH-751	CC	07/24/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2721	VT-3
C-314-611-10	CCH-036	CC	10/04/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2940	VT-3
C-314-611-10	CCH-035	CC	10/04/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2942	VT-3
C-314-611-10	CCH-034	CC	10/04/89	D-A	D.1.2	N/A	YES*	*REF-RELIEF REQUEST 3-PS-1	ACCEPT	N/A	VT-3
C-314-611-10	CCH-033	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2771	VT-3
C-314-611-10	CCH-032	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2770	VT-3
C-314-611-10	CCH-4008	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2775	VT-3
C-314-611-10	CCH-031	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2769	VT-3
C-314-611-10	CCH-030	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2768	VT-3
C-314-611-10	CCH-473	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2773	VT-3
C-314-611-10	CCH-029	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2767	VT-3
C-314-611-10	CCH-028	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2766	VT-3
C-314-611-11	CCH-147	CC	10/04/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2941	VT-3
C-314-611-11	CCH-146	CC	10/04/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2943	VT-3
C-314-611-11	CCH-145	CC	10/04/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2944	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1985
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-611-11	CCH-144	CC	10/04/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2945	VT-3
C-314-611-11	CCH-142	CC	10/04/89	D-A	D.1.2	N/A	*YES	REF. RELIEF REQUEST 3-PS-1*	ACCEPT	N/A	VT-3
C-314-611-11	CCH-141	CC	07/31/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2772	VT-3
C-314-611-11	CCH-140	CC	10/04/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2946	VT-3
C-314-611-11	CCH-485	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032505	VT-3
C-314-611-11	CCH-485	CC	07/13/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032506	VT04
C-314-611-12	CCH-301	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2700	VT-3
C-314-611-12	CCH-302	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2701	VT-3
C-314-611-12	CCH-307	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2702	VT-3
C-314-611-12	CCH-308	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2703	VT-3
C-314-611-12	CCH-311	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2704	VT-3
C-314-611-12	CCH-310	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2705	VT-3
C-314-611-12	CCH-317	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2707	VT-3
C-314-611-12	CCH-316	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2706	VT-3
C-314-611-12	CCH-319	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2708	VT-3
C-314-611-12	CCH-382	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2709	VT-3
C-314-611-12	CCH-383	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2710	VT-3
C-314-611-12	CCH-334	CC	07/19/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2711	VT-3
C-314-611-12	CCH-336	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2848	VT-3
C-314-611-12	CCH-325	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2849	VT-3
C-314-611-12	CCH-324	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2850	VT-3
C-314-611-12	CCH-327	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2851	VT-3
C-314-611-12	CCH-326	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2852	VT-3
C-314-611-12	CCH-328	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2853	VT-3
C-314-611-12	CCH-4010	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2854	VT-3

SOUTH CAROLINA ELECTRIC & GAS
V. C. SUPPER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
FIFTH REFUELING OUTAGE
VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITER	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-611-12	CCH-330	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2855	V6-3
C-314-611-12	CCH-332	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2713	VT-3
C-314-611-12	CCH-331	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2712	VT-3
C-314-611-12	CCH-333	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2714	VT-3
C-314-611-13	CCH-024	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2643	VT-3
C-314-611-13	CCH-023	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2645	VT-3
C-314-611-13	CCH-022	CC	10/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2948	VT-3
C-314-611-13	CCH-021	CC	10/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2947	VT-3
C-314-611-13	CCH-338	CC	08/07/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2806	VT-3
C-314-611-13	CCH-337	CC	08/07/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2805	VT-3
C-314-611-13	CCH-020	CC	09/06/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2856	VT-3
C-314-611-13	CCH-339	CC	09/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2863	VT-3
C-314-611-14	CCH-482	CC	09/28/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2864	VT-3
C-314-611-14	CCH-162	CC	09/06/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2861	VT-3
C-314-611-14	CCH-289	CC	09/07/89	D-A	D.1.2	YES*	NONE	REF. NCM-3435 & VCSV-2862*	ACCEPT	VCSV-2865	VT-3
C-314-611-14	CCH-163	CC	11/09/89	D-A	D.1.2	YES*	NONE	REF. NCM-3416 & VCSV-2813*	ACCEPT	VCSV-3059	VT-3
C-314-611-14	CCH-164	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2835	VT-3
C-314-611-14	CCH-165	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2834	VT-3
C-314-611-14	CCH-166	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2833	VT-3
C-314-611-14	CCH-168	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2831	VT-3
C-314-611-14	CLH-167	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2832	VT-3
C-314-611-14	CCH-170	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2830	VT-3
C-314-611-14	CCH-171	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2829	VT-3
C-314-611-14	CCH-290	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2828	VT-3
C-314-611-15	CCH-156	CC	03/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2614	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUPPLER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-611-15	CCH-483	CC	03/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2613	VT-3
C-314-611-15	CCH-155	CC	03/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2612	VT-3
C-314-611-15	CCH-287	CC	03/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2615	VT-3
C-314-611-15	CCH-4017	CC	03/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2611	VT-3
C-314-611-15	CCH-158	CC	03/09/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2610	VT-3
C-314-611-15	CCH-159	CC	07/26/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2745	VT-3
C-314-611-15	CCH-172	CC	07/26/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2746	VT-3
C-314-611-15	CCH-173	CC	07/26/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2747	VT-3
C-314-611-15	CCH-177	CC	07/26/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2748	VT-3
C-314-611-15	CCH-178	CC	07/26/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2749	VT-3
C-314-611-15	CCH-288	CC	07/26/89	D-A	D.1.2	NONE	YES*	REF. RELIEF REQUEST 3-PS-1A	ACCEPT	VCSV-2751	VT-3
C-314-611-15	CCH-247	CC	07/26/89	D-A	D.1.2	NONE	YES*	REF. RELIEF REQUEST 3-PS-1A	ACCEPT	VCSV-2750	VT-3
C-314-611-16	CCH-077	CC	08/07/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2802	VT-3
C-314-611-16	CCH-125	CC	08/07/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2804	VT-3
C-314-611-16	CCH-124	CC	08/07/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2803	VT-3
C-314-611-16	CCH-123	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2759	VT-3
C-314-611-16	CCH-176	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2762	VT-3
C-314-611-16	CCH-122	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2758	VT-3
C-314-611-16	CCH-175	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2761	VT-3
C-314-611-16	CCH-119	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2757	VT-3
C-314-611-16	CCH-399	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2763	VT-3
C-314-611-16	CCH-118	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2756	VT-3
C-314-611-16	CCH-120	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2765	VT-3
C-314-611-16	CCH-116	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2755	VT-3
C-314-611-16	CCH-174	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2760	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
C-314-611-16	CCH-115	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2754	VT-3
C-314-611-16	CCH-114	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2753	VT-3
C-314-611-16	CCH-478	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2764	VT-3
C-314-611-16	CCH-113	CC	07/27/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2752	VT-3
C-314-611-16	CCH-083	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2684	VT-3
C-314-611-16	CCH-085	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2685	VT-3
C-314-611-16	CCH-097	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2686	VT-3
C-314-611-16	CCH-096	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2687	VT-3
C-314-611-16	CCH-098	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2689	VT-3
C-314-611-16	CCH-099	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2688	VT-3
C-314-611-16	CCH-4011	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2681	VT-3
C-314-611-16	CCH-396	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2682	VT-3
C-314-611-16	CCH-4004	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2683	VT-3
C-314-611-16	CCH-086	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2691	VT-3
C-314-611-16	CCH-093	CC	07/12/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2690	VT-3
C-314-611-16	CCH-4012	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2715	VT-3
C-314-611-16	CCH-393	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2717	VT-3
C-314-611-16	CCH-4005	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2718	VT-3
C-314-611-16	CCH-391	CC	07/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2716	VT-3
C-314-611-16	CCH-390	CC	06/22/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2666	VT-3
C-314-611-16	CCH-101	CC	06/22/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2664	VT-3
C-314-611-16	CCH-102	CC	06/22/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2665	VT-3
C-314-611-16	CCH-4013	CC	06/22/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2663	VT-3
C-314-611-16	CCH-4014	CC	06/22/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2662	VT-3
C-314-611-16	CCH-4007	CC	08/14/89	D-A	D.1.2	YES*	NONE	REF. NCH-3331 & VCSV-2655	ACCEPT	VCSV-2811	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-611-16	CCH-4006	CC	04/26/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2676	VT-3
C-314-611-17	CCH-070	CC	09/06/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2857	VT-3
C-314-611-17	CCH-075	CC	09/06/89	D-A	D.1.2	YES*	NONE	REF. NCH-3434 "ACCEPT AS IS" #	REJECT	VCSV-2859	VT-3
C-314-611-17	CCH-071	CC	09/06/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2858	VT-3
C-314-611-17	CCH-072	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2841	VT-3
C-314-611-17	CCH-073	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2840	VT-3
C-314-611-17	CCH-074	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2839	VT-3
C-314-611-17	CCH-076	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2838	VT-3
C-314-611-17	CCH-079	CC	09/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2860	VT-3
C-314-611-17	CCH-080	CC	08/16/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2837	VT-3
C-314-611-17	CCH-078	CC	09/05/89	D-A	D.1.2	N/A	YES*	REF. RELIEF REQUEST 3-PS-1*	ACCEPT	N/A	VT-3
C-314-611-17	CCH-4019	CC	09/05/89	D-A	D.1.2	NONE	YES*	PARTIAL REF. REL/REQ. 3-PS-1*	ACCEPT	VCSV-2843	VT-3
C-314-611-17	CCH-378	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2844	VT-3
C-314-611-17	CCH-379	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2845	VT-3
C-314-611-17	CCH-380	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2846	VT-3
C-314-611-17	CCH-381	CC	09/05/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2847	VT-3
C-314-611-17	CCH-384	CC	07/18/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2695	VT-3
C-314-611-17	CCH-385	CC	07/18/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2694	VT-3
C-314-611-17	CCH-783	CC	07/18/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2693	VT-3
C-314-611-17	CCH-320	CC	07/18/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2696	VT-3
C-314-611-17	CCH-321	CC	07/18/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2699	VT-3
C-314-611-17	CCH-315	CC	07/18/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2697	VT-3
C-314-611-17	CCH-314	CC	07/18/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2698	VT-3
C-314-611-17	CCH-313	CC	07/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2678	VT-3
C-314-611-17	CCH-312	CC	07/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2679	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	CODE METHOD
C-314-611-17	CCH-309	CC	07/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2677	VT-3
C-314-611-17	CCH-303	CC	07/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2675	VT-3
C-314-611-17	CCH-304	CC	07/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2676	VT-3
C-314-611-17	CCH-4016	CC	07/03/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2674	VT-3
C-314-611-17	CCH-4015	CC	06/23/89	D-A	D.1.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-2669	VT-3
C-314-611-17	CCH-4015	CC	06/23/89	D-A	D.1.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-2670	VT-4
C-314-611-17	CCH-107	CC	06/23/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2672	VT-3
C-314-611-17	CCH-105	CC	06/23/89	D-A	D.1.2	NONE	NONE	SPRING CAN	ACCEPT	VCSV-2667	VT-3
C-314-611-17	CCH-105	CC	06/23/89	D-A	D.1.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-2668	VT-4
C-314-611-17	CCH-106	CC	06/23/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2671	VT-3
C-314-611-18	CCH-109	CC	07/25/89	D-A	D.1.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-2737	VT-3
C-314-611-18	CCH-109	CC	07/25/89	D-A	D.1.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-2742	VT-4
C-314-611-18	CCH-091	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2733	VT-3
C-314-611-18	CCH-092	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2734	VT-3
C-314-611-18	CCH-088	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2730	VT-3
C-314-611-18	CCH-087	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2729	VT-3
C-314-611-18	CCH-251	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2738	VT-3
C-314-611-18	CCH-094	CC	07/25/89	D-A	D.1.2	YES*	NONE	REF. VCSV-2735 (PAD-12 ACC.)	ACCEPT	VCSV-2744	VT-3
C-314-611-18	CCH-484	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2741	VT-3
C-314-611-18	CCH-095	CC	07/25/89	D-A	D.1.2	YES*	NONE	REF. NCB-3398 & VCSV-2736	ACCEPT	VCSV-2743	VT-3
C-314-611-18	CCH-090	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2732	VT-3
C-314-611-18	CCH-089	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2731	VT-3
C-314-611-18	CCH-292	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2739	VT-3
C-314-611-18	CCH-300	CC	07/25/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2740	VT-3
C-314-611-18	CCH-299	CC	09/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2869	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE MODE
C-314-611-18	CCH-160	CC	09/20/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2870	VT-3
C-314-611-18	CCH-149	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2647	VT-3
C-314-611-18	CCH-4027	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2646	VT-3
C-314-611-18	CCH-136	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2644	VT-3
C-314-611-18	CCH-135	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2642	VT-3
C-314-611-18	CCH-143	CC	10/10/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032507	VT-3
C-314-611-18	CCH-143	CC	10/10/89	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0032508	VT-4
C-314-611-18	CCH-137	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2635	VT-3
C-314-611-18	CCH-138	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2640	VT-3
C-314-611-18	CCH-481	CC	04/13/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-2639	VT-3
1MS-14-043	XPP-1A	CC	03/12/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4068	VT-3
1MS-14-043	XPP-1B	CC	03/06/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4063	VT-3
1MS-14-043	XPP-1C	CC	03/06/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4064	VT-3
1MS-14-019	XTK-3-CC	CC	11/21/89	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-3064	VT-3
1MS-14-001	XHE-2A-CC	CC	01/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-3085	VT-3
1MS-14-001	XHE-2B-CC	CC	02/09/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4011	VT-3
1MS-22-550	VUH-020	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2879	VT-3
1MS-22-550	VUH-021	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2878	VT-3
1MS-22-550	VUH-022	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2892	VT-3
1MS-22-550	VUH-024	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2877	VT-3
1MS-22-550	VUH-026	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2897	VT-3
1MS-22-550	VUH-028	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2875	VT-3
1MS-22-550	VUH-030	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2873	VT-3
1MS-22-550	VUH-032	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2876	VT-3
1MS-22-550	VUH-1476	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2895	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
1MS-22-550	VUH-1477	VU	09/26/89		D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2894	VT-3
1MS-22-551	VUH-1484	VU	09/26/89	-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2907	VT-3
1MS-22-551	VUH-016	VU	09/21/89	-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2880	VT-3
1MS-22-551	VUH-014	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2904	VT-3
1MS-22-551	VUH-012	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2883	VT-3
1MS-22-551	VUH-010	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2889	VT-3
1MS-22-551	VUH-009	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2890	VT-3
1MS-22-552	VUH-1483	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2901	VT-3
1MS-22-552	VUH-164	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2912	VT-3
1MS-22-552	VUH-163	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2918	VT-3
1MS-22-552	VUH-162	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2917	VT-3
1MS-22-552	VUH-170	VU	10/18/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2983	VT-3
1MS-22-552	VUH-166	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2893	VT-3
1MS-22-552	VUH-167	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2908	VT-3
1MS-22-552	VUH-153	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2898	VT-3
1MS-22-552	VUH-017	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2906	VT-3
1MS-22-552	VUH-158	VU	10/05/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2950	VT-3
1MS-22-552	VUH-169	VU	10/05/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2952	VT-3
1MS-22-552	VUH-171	VU	10/18/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2978	VT-3
1MS-22-553	VUH-172	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2911	VT-3
1MS-22-553	VUH-173	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2919	VT-3
1MS-22-553	VUH-174	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2910	VT-3
1MS-22-553	VUH-175	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2920	VT-3
1MS-22-553	VUH-154	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2916	VT-3
1MS-22-553	VUH-008	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2915	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	MODE METHOD
1MS-22-553	WIJ-176	VU	10/18/89	D-B	D-2.2	NONE	*PAD-12 REPLACED COTTER KEY	ACCEPT	VCSV-2980	VT-3
1MS-22-553	WIJ-180	VU	10/18/89	D-B	D-2.2	NONE	*PAD-12 REPLACED COTTER KEY	ACCEPT	VCSV-2979	VT-3
1MS-22-553	WIJ-177	VU	10/05/89	D-B	D-2.2	NONE	*PAD-12 REPLACED COTTER KEY	ACCEPT	VCSV-2964	VT-3
1MS-22-553	WIJ-178	VU	10/18/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2982	VT-3
1MS-22-553	WIJ-179	VU	10/05/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2953	VT-3
1MS-22-553	WIJ-157	VU	10/05/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2951	VT-3
1MS-22-553	WIJ-152	VU	10/05/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2955	VT-3
1MS-22-553	WIJ-007	VU	10/18/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2990	VT-3
1MS-22-553	WIJ-1485	VU	10/18/89	D-B	D-2.2	SOME	*PAD-12 REPLACED COTTER KEY	ACCEPT	VCSV-2981	VT-3
1MS-22-554	WIJ-1404	VU	10/18/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2989	VT-3
1MS-22-554	WIJ-1403	VU	10/18/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2988	VT-3
1MS-22-554	WIJ-161	VU	10/05/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2957	VT-3
1MS-22-554	WIJ-160	VU	10/05/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2958	VT-3
1MS-22-554	WIJ-168	VU	10/05/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2959	VT-3
1MS-22-554	WIJ-159	VU	10/05/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2960	VT-3
1MS-22-554	WIJ-201	VU	10/17/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2971	VT-3
1MS-22-554	WIJ-212	VU	10/17/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2974	VT-3
1MS-22-554	WIJ-210	VU	10/17/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2972	VT-3
1MS-22-554	WIJ-202	VU	10/18/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2984	VT-3
1MS-22-554	WIJ-203	VU	10/18/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2985	VT-3
1MS-22-554	WIJ-193	VU	11/02/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-3026	VT-3
1MS-22-554	WIJ-195	VU	11/02/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-3016	VT-3
1MS-22-554	WIJ-197	VU	11/02/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-3018	VT-3
1MS-22-559	WIJ-1474	VU	09/26/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2888	VT-3
1MS-22-559	WIJ-1472	VU	09/26/89	D-B	D-2.2	NONE	N/A	ACCEPT	VCSV-2909	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NO. METHOD
1MS-22-559	VUH-005	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2905	VT-3
1MS-22-559	VUH-006	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2885	VT-3
1MS-22-559	VUH-011	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2891	VT-3
1MS-22-559	VUH-013	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2882	VT-3
1MS-22-559	VUH-015	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2881	VT-3
1MS-22-559	VUH-018	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2884	VT-3
1MS-22-559	VUH-023	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2886	VT-3
1MS-22-559	VUH-025	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2876	VT-3
1MS-22-559	VUH-027	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2896	VT-3
1MS-22-559	VUH-029	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2874	VT-3
1MS-22-559	VUH-031	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2872	VT-3
1MS-22-559	VUH-033	VU	09/21/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2867	VT-3
1MS-22-559	VUH-004	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2922	VT-3
1MS-22-559	VUH-005	VU	10/18/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2977	VT-3
1MS-22-559	VUH-002	VU	10/17/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2970	VT-3
1MS-22-559	VUH-001	VU	10/18/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2991	VT-3
1MS-22-559	VUH-151	VU	10/05/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2954	VT-3
1MS-22-559	VUH-155	VU	10/05/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2949	VT-3
1MS-22-559	VUH-156	VU	10/05/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2956	VT-3
1MS-22-559	VUH-211	VU	10/17/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2973	VT-3
1MS-22-559	VUH-204	VU	10/18/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2986	VT-3
1MS-22-559	VUH-205	VU	10/18/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2987	VT-3
1MS-22-559	VUH-194	VU	11/01/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3027	VT-3
1MS-22-559	VUH-196	VU	11/02/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3017	VT-3
1MS-22-559	VUH-198	VU	11/02/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3019	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITER	INDICATION LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	MODE METHOD
1MS-22-560	VJH-238	VU	10/19/89	D-B	D.2.2	N/A	REF. RELIEF REQUEST 3-PS-1	ACCEPT	N/A	VT-3
1MS-22-560	VJH-236	VU	10/19/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3001	VT-3
1MS-22-560	VJH-234	VU	10/19/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-2999	VT-3
1MS-22-560	VJH-232	VU	10/19/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-2997	VT-3
1MS-22-560	VJH-230	VU	10/19/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-2995	VT-3
1MS-22-560	VJH-228	VU	10/19/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-2993	VT-3
1MS-22-560	VJH-226	VU	11/02/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3025	VT-3
1MS-22-560	VJH-224	VU	11/02/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3023	VT-3
1MS-22-560	VJH-222	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3009	VT-3
1MS-22-560	VJH-221	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3008	VT-3
1MS-22-560	VJH-218	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3005	VT-3
1MS-22-560	VJH-217	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3004	VT-3
1MS-22-560	VJH-214	VU	11/02/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3021	VT-3
1MS-22-560	VJH-208	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3014	VT-3
1MS-22-560	VJH-206	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3012	VT-3
1MS-22-560	VJH-200	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3011	VT-3
1MS-22-561	VJH-199	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3010	VT-3
1MS-22-561	VJH-207	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3013	VT-3
1MS-22-561	VJH-209	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3011	VT-3
1MS-22-561	VJH-213	VU	11/02/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3020	VT-3
1MS-22-561	VJH-215	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3002	VT-3
1MS-22-561	VJH-216	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3003	VT-3
1MS-22-561	VJH-219	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3006	VT-3
1MS-22-561	VJH-220	VU	10/31/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3007	VT-3
1MS-22-561	VJH-223	VU	11/02/89	D-B	D.2.2	NONE	N/A	ACCEPT	VCSV-3022	VT-3

SOUTH CAROLINA ELECTRIC & GAS
V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
FIFTH REFUELING OUTAGE
VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	RDE METHOD
1MS-22-561	VUH-225	VU	11/02/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3024	VT-3
1MS-22-561	VUH-227	VU	10/16/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2992	VT-3
1MS-22-561	VUH-229	VU	10/19/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2994	VT-3
1MS-22-561	VUH-231	VU	10/19/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2996	VT-3
1MS-22-561	VUH-233	VU	10/19/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2998	VT-3
1MS-22-561	VUH-235	VU	10/19/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3000	VT-3
1MS-22-561	VUH-237	VU	10/19/89	D-B	D.2.2	N/A	YES*	REF. RELIEF REQUEST 3-PS-1	ACCEPT	N/A	VT-3
1MS-22-623	VUH-1487	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3056	VT-3
1MS-22-623	VUH-1488	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3029	VT-3
1MS-22-623	VUH-087	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2923	VT-3
1MS-22-623	VUH-089	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3042	VT-3
1MS-22-623	VUH-091	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2933	VT-3
1MS-22-623	VUH-093	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2931	VT-3
1MS-22-623	VUH-095	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2930	VT-3
1MS-22-623	VUH-096	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2927	VT-3
1MS-22-623	VUH-098	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3045	VT-3
1MS-22-623	VUH-101	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3043	VT-3
1MS-22-623	VUH-102	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2937	VT-3
1MS-22-623	VUH-105	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2939	VT-3
1MS-22-623	VUH-106	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2926	VT-3
1MS-22-623	VUH-110	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3050	VT-3
1MS-22-623	VUH-1506	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3057	VT-3
1MS-22-623	VUH-108	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3048	VT-3
1MS-22-623	VUH-112	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3051	VT-3
1MS-22-623	VUH-1507	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3058	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
1MS-22-623	VUH-1486	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3055	VT-3
1MS-22-624	VUH-115	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3038	VT-3
1MS-22-624	VUH-117	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3031	VT-3
1MS-22-624	VUH-119	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3033	VT-3
1MS-22-624	VUH-1409	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3040	VT-3
1MS-22-624	VUH-1410	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3035	VT-3
1MS-22-624	VUH-121	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3036	VT-3
1MS-22-625	VUH-086	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2924	VT-3
1MS-22-625	VUH-088	VU	11/07/89	D-B	D.2.2	YES*	NONE	REF. NCR-3494 "ACCEPT AS IS" &	ACCEPT	VCSV-3047	VT-3
1MS-22-625	VUH-090	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2934	VT-3
1MS-22-625	VUH-092	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2932	VT-3
1MS-22-625	VUH-094	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2929	VT-3
1MS-22-625	VUH-097	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2928	VT-3
1MS-22-625	VUH-099	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3066	VT-3
1MS-22-625	VUH-100	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3064	VT-3
1MS-22-625	VUH-102	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2936	VT-3
1MS-22-625	VUH-104	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2938	VT-3
1MS-22-625	VUH-107	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2925	VT-3
1MS-22-625	VUH-109	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3049	VT-3
1MS-22-625	VUH-1400	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3053	VT-3
1MS-22-625	VUH-113	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3052	VT-3
1MS-22-625	VUH-1401	VU	11/08/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3054	VT-3
1MS-22-626	VUH-114	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3039	VT-3
1MS-22-626	VUH-116	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3030	VT-3
1MS-22-626	VUH-118	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3032	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
1MS-22-626	VUH-1408	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3034	VT-3
1MS-22-626	VUH-1402	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3041	VT-3
1MS-22-626	VUH-120	VU	11/07/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3037	VT-3
1MS-22-637	VUH-1037	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2902	VT-3
1MS-22-637	VUH-1038	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2903	VT-3
1MS-22-637	VUH-1039	VU	10/17/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2975	VT-3
1MS-22-637	VUH-1040	VU	10/17/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2976	VT-3
1MS-22-638	VUH-1556	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2900	VT-3
1MS-22-638	VUH-1557	VU	09/26/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2899	VT-3
1MS-22-638	VUH-1559	VU	09/28/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2935	VT-3
1MS-22-638	VUH-1562	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2921	VT-3
1MS-22-638	VUH-1560	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2913	VT-3
1MS-22-638	VUH-1561	VU	09/27/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2914	VT-3
1MS-22-638	VUH-1563	VU	10/05/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2961	VT-3
1MS-22-638	VUH-1564	VU	10/05/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2962	VT-3
1MS-22-638	VUH-1565	VU	10/05/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-2963	VT-3
1MS-54-055	XPP-48A	VU	03/12/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4067	VT-3
1MS-54-055	XPP-48B	VU	03/09/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4065	VT-3
1MS-54-055	XPP-48C	VU	03/09/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4066	VT-3
1MS-54-087	XHX-1A-VU	VU	11/20/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3062	VT-3
1MS-54-087	XHX-1B-VU	VU	01/09/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3068	VT-3
1MS-54-087	XHX-1C-VU	VU	11/20/89	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3068	VT-3
1MS-07-058	XSG-0002A	RC	03/26/90	C-C/C-E	C3.20	NONE	NONE	REF. 1MS-07-61,66,67,& 68	ACCEPT	VCSV-4231	VT-3
1MS-07-058	XSG-0002B	RC	03/26/90	C-C/C-E	C3.20	NONE	NONE	REF. 1MS-07-61,66,67,& 68	ACCEPT	VCSV-4232	VT-3
1MS-08-011	XHE-009	CS	04/16/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4320	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUPPER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-611-19	CCH-422	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4292	VT-3
C-314-611-19	CCH-421	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4293	VT-3
C-314-611-19	CCH-420	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4290	VT-3
C-314-611-19	CCH-419	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4276	VT-3
C-314-611-19	CCH-418	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4278	VT-3
C-314-611-19	CCH-417	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4280	VT-3
C-314-611-19	CCH-416	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4289	VT-3
C-314-611-19	CCH-402	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4282	VT-3
C-314-611-19	CCH-406	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4294	VT-3
C-314-611-19	CCH-404	CC	04/04/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035959	VT-3
C-314-611-19	CCH-404	CC	04/04/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035960	VT-4
C-314-611-19	CCH-405	CC	04/04/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035961	VT-3
C-314-611-19	CCH-405	CC	04/04/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035962	VT-4
C-314-611-19	CCH-403	CC	03/29/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4251	VT-3
C-314-611-19	CCH-401	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4267	VT-3
C-314-611-20	CCH-415	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4274	VT-3
C-314-611-20	CCH-414	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4256	VT-3
C-314-611-20	CCH-403	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4259	VT-3
C-314-611-20	CCH-403	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4273	VT-3
C-314-611-20	CCH-413	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4272	VT-3
C-314-611-20	CCH-412	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4257	VT-3
C-314-611-20	CCH-411	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4271	VT-3
C-314-611-20	CCH-410	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4270	VT-3
C-314-611-20	CCH-409	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4269	VT-3
C-314-611-20	CCH-408	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4268	VT-3
C-314-611-20	CCH-407	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4268	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
C-314-611-21	CCH-4041	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4297	VT-3
C-314-611-21	CCH-4042	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4296	VT-3
C-314-611-21	CCH-462	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4287	VT-3
C-314-611-21	CCH-4040	CC	04/04/90	D-A	D.1.3	NONE	NONE	SMUBBER	ACCEPT	ST0035966	VT-3
C-314-611-21	CCH-4040	CC	04/04/90	D-A	D.1.3	NONE	NONE	SMUBBER	ACCEPT	ST0035967	VT-4
C-314-611-21	CCH-461	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4286	VT-3
C-314-611-21	CCH-471	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4277	VT-3
C-314-611-21	CCH-460	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4285	VT-3
C-314-611-21	CCH-459	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4281	VT-3
C-314-611-21	CCH-458	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4279	VT-3
C-314-611-21	CCH-457	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4284	VT-3
C-314-611-21	CCH-456	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4283	VT-3
C-314-611-21	CCH-455	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4288	VT-3
C-314-611-21	CCH-455	CC	03/31/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4254	VT-3
C-314-611-21	CCH-454	CC	03/29/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4260	VT-3
C-314-611-21	CCH-452	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4261	VT-3
C-314-611-21	CCH-448	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4262	VT-3
C-314-611-21	CCH-447	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4264	VT-3
C-314-611-22	CCH-470	CC	03/29/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4243	VT-3
C-314-611-22	CCH-469	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4242	VT-3
C-314-611-22	CCH-468	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4241	VT-3
C-314-611-22	CCH-467	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4240	VT-3
C-314-611-22	CCH-466	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4239	VT-3
C-314-611-22	CCH-465	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4238	VT-3
C-314-611-22	CCH-464	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4246	VT-3
C-314-611-22	CCH-463	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4246	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
C-314-611-22	CCH-446	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4263	VT-3
C-314-611-22	CCH-443	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4266	VT-3
C-314-611-22	CCH-444	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4265	VT-3
C-314-611-22	CCH-445	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4255	VT-3
C-314-611-22	CCH-442	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4258	VT-3
C-314-611-22	CCH-441	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4275	VT-3
C-314-611-23	CCH-431	CC	04/04/90	D-A	D.1.3	NONE	NONE	SHUBBER	ACCEPT	ST0035963	VT-3
C-314-611-23	CCH-431	CC	04/04/90	D-A	D.1.3	NONE	NONE	SHUBBER	ACCEPT	ST0035964	VT-4
C-314-611-23	CCH-432	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4233	VT-3
C-314-611-23	CCH-430	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4234	VT-3
C-314-611-23	CCH-429	CC	04/07/90	D-A	D.1.2	*YES	NONE	*REF NCM-3742A	ACCEPT	VCSV-4306	VT-3
C-314-611-23	CCH-427	CC	03/29/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4225	VT-3
C-314-611-23	CCH-428	CC	03/29/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4253	VT-3
C-314-611-23	CCH-426	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4235	VT-3
C-314-611-23	CCH-425	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4236	VT-3
C-314-611-23	CCH-424	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4237	VT-3
C-314-611-23	CCH-423	CC	03/30/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4245	VT-3
1MS-22-698	DGH-1193	DG	03/02/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4052	VT-3
1MS-22-698	DGH-1191	DG	03/02/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4051	VT-3
1MS-22-698	DGH-1192	DG	03/06/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4062	VT-3
1MS-22-698	DGH-1190	DG	03/06/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4061	VT-3
1MS-08-009	XHE-014	CS	04/03/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4317	VT-3
1MS-08-010	XHE-011	CS	04/02/90	D-A	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4298	VT-3
1MS-08-080	XTK-012A	CS	03/13/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4069	VT-3
1MS-08-080	XTK-012B	CS	03/19/90	D-A	D.1.2	NONE	NONE	N/A	ACCEPT	VCSV-4087	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	RDE METHOD
C-314-085-4	EFH-097	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4224	VT-3
C-314-085-4	EFH-098	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4225	VT-3
C-314-085-4	EFH-099	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4226	VT-3
C-314-085-4	EFH-100	EF	02/21/90	D-B	D.2.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4017	VT-3
C-314-085-4	EFH-100	EF	02/21/90	D-B	D.2.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4024	VT-4
C-314-085-4	EFH-4007	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4019	VT-3
C-314-085-4	EFH-4025	EF	01/30/90	D-B	D.2.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-3077	VT-3
C-314-085-4	EFH-4025	EF	01/30/90	D-B	D.2.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-3083	VT-4
C-314-085-4	EFH-4046	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4021	VT-3
C-314-085-5	EFH-096	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4223	VT-3
C-314-085-5	EFH-095	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4222	VT-3
C-314-085-5	EFH-094	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4221	VT-3
C-314-085-5	EFH-4026	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4228	VT-3
C-314-085-5	EFH-4035	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4229	VT-3
C-314-085-5	EFH-4034	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4230	VT-3
C-314-085-5	EFH-4045	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4014	VT-3
C-314-085-5	EFH-102	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4018	VT-3
C-314-085-5	EFH-4028	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4016	VT-3
C-314-085-5	EFH-103	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4020	VT-3
C-314-085-5	EFH-104	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4022	VT-3
C-314-085-5	EFH-105	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4023	VT-3
C-314-085-5	EFH-106	EF	02/21/90	D-B	D.2.2	N/A	YES*	*REF. RELIEF REQUEST 3-PS-1	ACCEPT	N/A	N/A
C-314-085-5	EFH-4031	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3079	VT-3
C-314-085-5	EFH-107	EF	01/30/90	D-B	D.2.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-3083	VT-3
C-314-085-5	EFH-107	EF	01/30/90	D-B	D.2.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-3084	VT-4

SOUTH CAROLINA ELECTRIC & CO.
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-085-5	EFH-4/22	EF	03/26/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4227	VT-3
C-314-085-5	EFH-4023	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3076	VT-3
C-314-085-5	EFH-109	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3075	VT-3
C-314-085-5	EFH-110	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3073	VT-3
C-314-085-5	EFH-4024	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3072	VT-3
C-314-085-5	EFH-4027	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3074	VT-3
C-314-085-5	EFH-4020	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3081	VT-3
1MS-17-085	XPP-021A	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3076	VT-3
1MS-17-085	XPP-021B	EF	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4015	VT-3
1MS-17-084	XPP-003	EF	01/30/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3082	VT-3
1MS-13-004	XHE-0005A	RH	02/01/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3086	VT-3
1MS-13-004	XHE-0005B	RH	02/21/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-4013	VT-3
C-314-651-1	SFH-047	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4044	VT-3
C-314-651-1	SFH-048	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4032	VT-3
C-314-651-1	SFH-049	SF	02/06/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036237	VT-3
C-314-651-1	SFH-049	SF	02/06/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036238	VT-4
C-314-651-3	SFH-064	SF	02/01/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-3092	VT-3
C-314-651-3	SFH-065	SF	01/31/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036239	VT-3
C-314-651-3	SFH-065	SF	01/31/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036240	VT-4
C-314-651-3	SFH-016	SF	02/01/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-3094	VT-3
C-314-651-3	SFH-014	SF	01/30/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036229	VT-3
C-314-651-3	SFH-014	SF	01/30/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036230	VT-4
C-314-651-3	SFH-015	SF	01/30/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036231	VT-3
C-314-651-3	SFH-015	SF	01/30/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036232	VT-4
C-314-651-3	SFH-013	SF	02/02/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4004	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SIMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-651-3	SFH-081	SF	02/02/90	D-C	D.3.2	N/A	*YES	*REF. RELIEF REQUEST 3-PS-1	ACCEPT	N/A	N/A
C-314-651-3	SFH-083	SF	01/30/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036241	VT-3
C-314-651-3	SFH-083	SF	01/30/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036242	VT-4
C-314-651-3	SFH-082	SF	02/02/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4007	VT-3
C-314-651-3	SFH-084	SF	02/02/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4006	VT-3
C-314-651-4	SFH-4007	SF	03/05/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4055	VT-3
C-314-651-4	SFH-067	SF	03/05/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4059	VT-3
C-314-651-4	SFH-066	SF	03/05/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4058	VT-3
C-314-651-4	SFH-054	SF	03/05/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4030	VT-3
C-314-651-4	SFH-055	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4030	VT-3
C-314-651-4	SFH-056	SF	02/23/90	D-C	D.3.2	N/A	*YES	*REF. RELIEF REQUEST 3-PS-1	ACCEPT	N/A	N/A
C-314-651-4	SFH-058	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4034	VT-3
C-314-651-4	SFH-057	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4039	VT-3
C-314-651-4	SFH-057	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-3088	VT-3
C-314-651-5	SFH-007	SF	02/01/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-3091	VT-3
C-314-651-5	SFH-006	SF	02/01/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-3091	VT-3
C-314-651-5	SFH-005	SF	01/31/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036227	VT-3
C-314-651-5	SFH-005	SF	01/31/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036228	VT-4
C-314-651-5	SFH-004	SF	02/01/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-3090	VT-3
C-314-651-5	SFH-003	SF	02/01/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-3089	VT-3
C-314-651-5	SFH-001	SF	02/02/90	D-C	D.3.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4002	VT-3
C-314-651-5	SFH-001	SF	02/02/90	D-C	D.3.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4003	VT-4
C-314-651-6	SFH-063	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4033	VT-3
C-314-651-6	SFH-095	SF	02/23/90	D-C	D.3.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4067	VT-3
C-314-651-6	SFH-095	SF	02/23/90	D-C	D.3.3	NONE	NONE	N/A	ACCEPT	VCSV-4068	VT-4
C-314-651-6	SFH-4000	SF	02/06/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036243	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1994
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-651-6	SFH-4000	SF	02/06/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036244	VT-4
C-314-651-6	SFH-061	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4045	VT-3
C-314-651-6	SFH-039	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4046	VT-3
C-314-651-6	SFH-008	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4035	VT-3
C-314-651-6	SFH-4001	SF	02/23/90	D-C	D.3.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4025	VT-3
C-314-651-6	SFH-4001	SF	02/23/90	D-C	D.3.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4026	VT-4
C-314-651-7	SFH-053	SF	03/05/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4054	VT-3
C-314-651-7	SFH-050	SF	03/05/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4056	VT-3
C-314-651-7	SFH-051	SF	03/05/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4057	VT-3
C-314-651-7	SFH-052	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4029	VT-3
C-314-651-7	SFH-4006	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4027	VT-3
C-314-651-7	SFH-4009	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4028	VT-3
C-314-651-7	SFH-040	SF	02/06/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036233	VT-3
C-314-651-7	SFH-040	SF	02/06/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036234	VT-4
C-314-651-7	SFH-041	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4042	VT-3
C-314-651-7	SFH-042	SF	02/23/90	D-C	D.3.2	*YES	NONE	REF. NCH-3699	ACCEPT	VCSV-4041	VT-3
C-314-651-7	SFH-043	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4036	VT-3
C-314-651-7	SFH-044	SF	02/06/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036235	VT-3
C-314-651-7	SFH-044	SF	02/06/90	D-C	D.3.3	NONE	NONE	NER	ACCEPT	ST0036236	VT-4
C-314-651-7	SFH-045	SF	02/23/90	D-C	D.3.2	N/A	*YES	RELIEF REQUEST 3-PS-1	ACCEPT	N/A	N/A
C-314-651-7	SFH-046	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4038	VT-3
C-314-651-8	SFH-4010	SF	02/01/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036245	VT-3
C-314-651-8	SFH-4010	SF	02/01/90	D-C	D.3.3	NONE	NONE	SNUBBER	ACCEPT	ST0036246	VT-4
C-314-651-8	SFH-4003	SF	02/02/90	D-C	D.3.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4008	VT-3
C-314-651-8	SFH-4003	SF	02/02/90	D-C	D.3.3	NONE	NONE	SPRING CAN	ACCEPT	VCSV-4009	VT-4

SOUTH CAROLINA ELECTRIC & GAS
V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
FIFTH REFUELING OUTAGE
VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-651-8	SFH-032	SF	02/02/90	D-C	D.3.3	*YES	NONE	*REF. MCN-3671 ACCEPT AS IS	ACCEPT	VCSV-4001	VT-3
C-314-651-8	SFH-033	SF	02/02/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4005	VT-3
C-314-651-8	SFH-034	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4037	VT-3
C-314-651-8	SFH-035	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4040	VT-3
C-314-651-8	SFH-036	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4043	VT-3
C-314-651-8	SFH-037	SF	02/23/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4031	VT-3
1MS-11-025	XPP-032A	SF	03/16/90	D-C	D.3.2	NONE	NONE	REF. MCN-3731 (DWG. CHANGE)	ACCEPT	VCSV-4071	VT-3
1MS-11-025	XPP-032B	SF	03/22/90	D-C	D.3.2	NONE	NONE	N/A	ACCEPT	VCSV-4090	VT-3
1MS-18-002	XTK-60	SP	02/01/90	D-B	D.2.2	NONE	NONE	N/A	ACCEPT	VCSV-3087	VT-3
C-314-671-3	CSH-945	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034654	VT-3
C-314-671-3	CSH-945	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0035978	VT-4
C-314-671-3	CSH-947	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034655	VT-3
C-314-671-3	CSH-947	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0035979	VT-4
C-314-671-3	CSH-947	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034656	VT-3
C-314-671-3	CSH-948	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0035657	VT-3
C-314-671-3	CSH-949	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034658	VT-3
C-314-671-3	CSH-950	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0035980	VT-4
C-314-671-3	CSH-950	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034659	VT-3
C-314-671-3	CSH-959	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0035981	VT-4
C-314-671-3	CSH-959	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034602	VT-3
C-314-671-3	CSH-765	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034666	VT-3
C-314-671-6	CSH-979	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034625	VT-3
C-314-671-6	CSH-875	CS	04/13/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034626	VT-3
C-314-671-6	CSH-876	CS	04/21/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0035975	VT-4
C-314-671-6	CSH-876	CS	04/21/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0035975	VT-4
C-314-671-8	CSH-478	CS	04/17/90	B-K-2	B11.10	NONE	NONE	SMUBBER	ACCEPT	ST0034598	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
C-314-671-8	CSH-478	CS	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035969	VT-4
C-314-671-8	CSH-477	CS	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034597	VT-3
C-314-671-8	CSH-477	CS	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035968	VT-4
C-314-671-8	CSH-920	CS	04/22/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034639	VT-3
C-314-671-8	CSH-920	CS	04/22/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035976	VT-4
C-314-671-19	CSH-989	CS	04/21/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034668	VT-3
C-314-671-19	CSH-989	CS	04/21/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035982	VT-4
C-314-081-1	FWH-336	FW	04/19/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER "A"	ACCEPT	ST0034699	VT-3
C-314-081-1	FWH-336	FW	04/19/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER "A"	ACCEPT	ST0035987	VT-4
C-314-081-1	FWH-336	FW	04/19/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER "B"	ACCEPT	ST0034700	VT-3
C-314-081-1	FWH-336	FW	04/19/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER "B"	ACCEPT	ST0035988	VT-4
C-314-081-1	FWH-337	FW	04/19/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034701	VT-3
C-314-081-1	FWH-337	FW	04/19/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035989	VT-4
C-314-081-2	FWH-338	FW	04/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034702	VT-3
C-314-081-3	FWH-341	FW	04/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035990	VT-3
C-314-081-3	FWH-341	FW	04/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034705	VT-4
C-314-081-3	FWH-346	FW	04/16/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035991	VT-3
C-314-081-3	FWH-346	FW	04/16/90	C-C&C-E	C3.60	YES*	NONE	SNUBBER REF. NCM-3809(ACC.) #	REJECT	ST0034706	VT-4
C-314-011-1	MSH-004	MS	04/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035991	VT-3
C-314-011-1	MSH-004	MS	04/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035996	VT-4
C-314-011-1	MSH-005	MS	04/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034720	VT-3
C-314-011-1	MSH-005	MS	04/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035997	VT-4
C-314-011-2	MSH-007	MS	03/31/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034721	VT-3
C-314-011-1	MSH-007	MS	03/31/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035998	VT-4
C-314-011-2	MSH-008	MS	03/31/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034722	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
C-314-011-2	MSH-008	MS	03/31/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035999	VT-4
C-314-011-2	MSH-009	MS	03/31/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034723	VT-3
C-314-011-2	MSH-009	MS	03/31/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036000	VT-4
C-314-011-2	MSH-010	MS	03/31/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034724	VT-3
C-314-011-2	MSH-010	MS	03/31/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036001	VT-4
C-314-011-3	MSH-012	MS	04/03/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034725	VT-3
C-314-011-3	MSH-012	MS	04/03/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036002	VT-4
C-314-011-3	MSH-013	MS	04/03/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034726	VT-3
C-314-011-3	MSH-013	MS	04/03/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036003	VT-4
C-314-011-3	MSH-015	MS	04/07/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034728	VT-3
C-314-011-3	MSH-015	MS	04/07/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036004	VT-4
C-314-011-16	MSH-182	MS	03/02/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036325	VT-3
C-314-011-16	MSH-182	MS	03/02/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036205	VT-4
C-314-601-1	RCH-041	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034740	VT-3
C-314-601-1	RCH-041	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036005	VT-4
C-314-601-1	RCH-042	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034741	VT-3
C-314-601-1	RCH-042	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036006	VT-4
C-314-601-1	RCH-043	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034742	VT-3
C-314-601-1	RCH-043	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036007	VT-4
C-314-601-1	RCH-044	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0043743	VT-3
C-314-601-1	RCH-044	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036008	VT-4
C-314-601-1	RCH-045	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034744	VT-3
C-314-601-1	RCH-045	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036009	VT-4
C-314-601-1	RCH-046	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034745	VT-3
C-314-601-1	RCH-046	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036010	VT-4

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
C-314-601-1	RCH-053	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034750	VT-3
C-314-601-1	RCH-053	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036014	VT-4
C-314-601-1	RCH-047	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034746	VT-3
C-314-601-1	RCH-047	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036011	VT-4
C-314-601-1	RCH-048	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034747	VT-3
C-314-601-1	RCH-048	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036012	VT-4
C-314-601-1	RCH-051	RC	03/29/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034748	VT-3
C-314-601-1	RCH-051	RC	03/29/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036013	VT-4
C-314-601-1	RCH-4015	RC	03/30/90	B-K-2	B11.10	YES@	NONE	REF. NCH-3749 (SNUBBER "A")	REJECT	ST0034925	VT-3
C-314-601-1	RCH-4015	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER "A"	ACCEPT	ST0036022	VT-4
C-314-601-1	RCH-4015	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER "B"	ACCEPT	ST0034926	VT-3
C-314-601-1	RCH-4015	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER "B"	ACCEPT	ST0036023	VT-4
C-314-601-1	RCH-4015	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER "A"	ACCEPT	ST0034927	VT-3
C-314-601-1	RCH-4017	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER "A"	ACCEPT	ST0036024	VT-4
C-314-601-1	RCH-4017	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER "B"	ACCEPT	ST0034928	VT-3
C-314-601-1	RCH-4017	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER "B"	ACCEPT	ST0036025	VT-4
C-314-601-1	RCH-4017	RC	04/01/90	B-K-2	B11.10	NONE	NONE	SNUBBER "A"	ACCEPT	ST0034931	VT-3
C-314-601-1	RCH-4019	RC	03/29/90	B-K-2	B11.10	NONE	NONE	SNUBBER "A"	ACCEPT	ST0036026	VT-4
C-314-601-1	RCH-4019	RC	03/29/90	B-K-2	B11.10	NONE	NONE	SNUBBER "A"	ACCEPT	ST0034932	VT-3
C-314-601-1	RCH-4019	RC	03/29/90	B-K-2	B11.10	NONE	NONE	SNUBBER "B"	ACCEPT	ST0036027	VT-4
C-314-601-1	RCH-4019	RC	03/29/90	B-K-2	B11.10	NONE	NONE	SNUBBER "B"	ACCEPT	ST0034933	VT-3
C-314-601-1	RCH-4020	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036328	VT-4
C-314-601-1	RCH-4020	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034847	VT-3
C-314-601-4	RCH-294	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036019	VT-4
C-314-601-4	RCH-294	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034848	VT-3
C-314-601-4	RCH-295	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT		

SOUTH CAROLINA ELECTRIC & GAS
V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
FIFTH REFUELING OUTAGE
VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	IDE METHOD
C-314-601-4	RCH-295	RC	03/30/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036020	VT-4
C-314-641-3	RHH-149	RH	02/07/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035469	VT-3
C-314-641-3	RHH-149	RH	02/07/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036221	VT-4
C-314-641-3	RHH-148	RH	02/07/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035468	VT-3
C-314-641-3	RHH-148	RH	02/07/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036220	VT-4
C-314-641-4	RHH-155	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035475	VT-3
C-314-641-4	RHH-155	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036222	VT-4
C-314-641-4	RHH-163	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035483	VT-3
C-314-641-4	RHH-163	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036224	VT-4
C-314-641-4	RHH-161	RH	02/02/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035481	VT-3
C-314-641-4	RHH-158	RH	02/02/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035478	VT-3
C-314-641-4	RHH-117	RH	02/20/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035437	VT-3
C-314-641-4	RHH-117	RH	02/20/90	C-C&C-E	C3.60	YES	NONE	REF. NCH-3689 RETEST ACCEPTED	REJECT	ST0036214	VT-4
C-314-641-4	RHH-118	RH	02/09/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035438	VT-3
C-314-641-4	RHH-118	RH	02/09/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036215	VT-4
C-314-641-4	RHH-115	RH	02/09/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035435	VT-3
C-314-641-4	RHH-115	RH	02/09/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036212	VT-3
C-314-641-4	RHH-116	RH	02/22/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035436	VT-3
C-314-641-4	RHH-116	RH	02/22/90	C-C&C-E	C3.60	YES	NONE	REF. NCH-3689A RETEST ACCEPTED	REJECT	ST0036213	VT-4
C-314-641-5	RHH-4003	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035523	VT-3
C-314-641-5	RHH-4003	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036226	VT-4
C-314-641-5	RHH-103	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035423	VT-3
C-314-641-5	RHH-103	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036210	VT-4
C-314-641-5	RHH-104	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035424	VT-3
C-314-641-5	RHH-104	RH	02/12/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036211	VT-4

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-641-5	RHH-102	RH	02/02/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035422	VT-3
C-314-641-5	RHH-102	RH	02/02/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036209	VT-4
C-314-641-6	RHH-125	RH	02/07/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035445	VT-3
C-314-641-6	RHH-125	RH	02/07/90	C-C&C-E	C3.60	YES	NONE	REF. NCH-3679 RETEST ACCEPTED	REJECT	ST0036216	VT-4
C-314-641-6	RHH-128	RH	02/20/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035448	VT-3
C-314-641-6	RHH-128	RH	02/20/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036218	VT-4
C-314-641-6	RHH-129	RH	02/20/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035449	VT-3
C-314-641-6	RHH-129	RH	02/20/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036219	VT-4
C-314-641-6	RHH-129	RH	02/20/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035446	VT-3
C-314-641-6	RHH-126	RH	02/07/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036217	VT-4
C-314-641-6	RHH-126	RH	02/07/90	C-C&C-E	C3.60	YES	NONE	REF. NCH-3679 RETEST ACCEPTED	REJECT	ST0036217	VT-4
C-314-691-3	RHH-4023	RH	02/02/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035535	VT-3
C-314-691-3	RHH-4024	RH	02/02/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035536	VT-3
C-314-691-6	SIH-144	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034963	VT-3
C-314-691-6	SIH-144	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036029	VT-4
C-314-691-6	SIH-146	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034964	VT-3
C-314-691-6	SIH-146	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036030	VT-3
C-314-691-6	SIH-148	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034965	VT-3
C-314-691-6	SIH-148	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036031	VT-4
C-314-691-6	SIH-148	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034973	VT-3
C-314-691-9	SIH-173	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036033	VT-4
C-314-691-9	SIH-173	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034974	VT-3
C-314-691-9	SIH-176	SI	04/10/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036034	VT-3
C-314-691-9	SIH-176	SI	04/10/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035048	VT-3
C-314-691-9	SIH-456	SI	04/11/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036058	VT-4
C-314-691-9	SIH-456	SI	04/11/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036058	VT-4
C-314-691-9	SIH-182	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034977	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	ROE METHOD
C-314-691-9	SIH-182	SI	04/15/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035035	VT-4
C-314-691-11	SIH-399	SI	04/22/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035012	VT-3
C-314-691-11	SIH-399	SI	04/22/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036045	VT-4
C-314-691-12	SIH-411	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035019	VT-3
C-314-691-12	SIH-411	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036051	VT-4
C-314-691-12	SIH-205	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034985	VT-3
C-314-691-12	SIH-205	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036038	VT-4
C-314-691-12	SIH-429	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035031	VT-3
C-314-691-12	SIH-429	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036056	VT-4
C-314-691-12	SIH-410	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035018	VT-3
C-314-691-12	SIH-410	SI	04/16/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036050	VT-4
C-314-691-12	SIH-412	SI	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035020	VT-3
C-314-691-12	SIH-412	SI	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036052	VT-4
C-314-691-12	SIH-206	SI	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034986	VT-3
C-314-691-12	SIH-206	SI	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036039	VT-4
C-314-691-12	SIH-427	SI	04/11/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035030	VT-3
C-314-691-12	SIH-427	SI	04/11/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036055	VT-4
C-314-691-12	SIH-425	SI	04/10/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035028	VT-3
C-314-691-12	SIH-425	SI	04/10/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036053	VT-4
C-314-691-12	SIH-425	SI	04/10/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035016	VT-3
C-314-691-13	SIH-404	SI	04/14/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036048	VT-4
C-314-691-13	SIH-404	SI	04/14/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0034989	VT-3
C-314-691-13	SIH-225	SI	04/14/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036042	VT-4
C-314-691-13	SIH-225	SI	04/14/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035015	VT-3
C-314-691-13	SIH-403	SI	04/14/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036047	VT-4
C-314-691-13	SIH-403	SI	04/14/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036047	VT-4

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-691-16	SIH-459	SI	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035051	VT-3
C-314-691-16	SIH-459	SI	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036060	VT-4
C-314-691-16	SIH-434	SI	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035035	VT-3
C-314-691-16	SIH-434	SI	04/17/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036057	VT-4
C-314-691-23	SIH-380	SI	04/13/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035000	VT-3
C-314-691-23	SIH-380	SI	04/13/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036043	VT-4
C-314-691-13	SIH-402	SI	04/11/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0035014	VT-3
C-314-691-13	SIH-402	SI	04/11/90	B-K-2	B11.10	NONE	NONE	SNUBBER	ACCEPT	ST0036046	VT-4
C-314-691-12	SIH-426	SI	04/10/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035029	VT-3
C-314-691-12	SIH-426	SI	04/10/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036054	VT-4
C-314-691-12	SIH-202	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034984	VT-4
C-314-691-12	SIH-202	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036037	VT-4
C-314-691-12	SIH-187	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034980	VT-3
C-314-691-12	SIH-187	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036036	VT-4
C-314-691-12	SIH-209	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034987	VT-3
C-314-691-12	SIH-209	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036040	VT-4
C-314-691-12	SIH-167	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034970	VT-3
C-314-691-12	SIH-167	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036032	VT-4
C-314-691-12	SIH-409	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035017	VT-3
C-314-691-12	SIH-409	SI	04/08/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036049	VT-4
C-314-691-9	SIH-457	SI	04/10/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035049	VT-3
C-314-691-9	SIH-457	SI	04/10/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036059	VT-4
C-314-691-13	SIH-221	SI	04/11/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0034988	VT-3
C-314-691-13	SIH-221	SI	04/11/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036041	VT-4
C-314-691-11	SIH-394	SI	04/16/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035009	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE MODE
C-314-691-11	SIH-394	SI	04/16/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036044	VT-4
C-314-661-2	SPH-4003	SP	02/15/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035652	VT-3
C-314-661-2	SPH-4003	SP	02/15/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036267	VT-3
C-314-661-2	SPH-082	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035592	VT-3
C-314-661-2	SPH-082	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036269	VT-4
C-314-661-2	SPH-083	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035593	VT-3
C-314-661-2	SPH-083	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036250	VT-4
C-314-661-2	SPH-084	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035594	VT-3
C-314-661-2	SPH-084	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036251	VT-4
C-314-661-2	SPH-085	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035595	VT-3
C-314-661-2	SPH-085	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036252	VT-4
C-314-661-2	SPH-086	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035596	VT-3
C-314-661-2	SPH-086	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036253	VT-4
C-314-661-2	SPH-086	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035653	VT-3
C-314-661-2	SPH-4004	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036268	VT-4
C-314-661-2	SPH-087	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035597	VT-3
C-314-661-2	SPH-087	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036254	VT-4
C-314-661-3	SPH-089	SP	02/13/90	C-C&C-E	C3.60	NONE	YES*	SNUBBER*REF. R/R 2-PS-1	ACCEPT	ST0035599	VT-3
C-314-661-3	SPH-089	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036255	VT-4
C-314-661-3	SPH-092	SP	02/26/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035601	VT-3
C-314-661-3	SPH-092	SP	02/26/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036256	VT-4
C-314-661-3	SPH-093	SP	02/26/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035602	VT-3
C-314-661-3	SPH-093	SP	02/26/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036257	VT-4
C-314-661-3	SPH-093	SP	02/26/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035604	VT-3
C-314-661-3	SPH-095	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036258	VT-4
C-314-661-3	SPH-095	SP	02/13/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036258	VT-4

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	RDE METHOD
C-314-661-3	SPH-252	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035637	VT-3
C-314-661-3	SPH-252	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036265	VT-4
C-314-661-3	SPH-251	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035634	VT-3
C-314-661-3	SPH-251	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036264	VT-4
C-314-661-3	SPH-249	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035634	VT-3
C-314-661-3	SPH-249	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036262	VT-4
C-314-661-3	SPH-250	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035635	VT-3
C-314-661-3	SPH-250	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036263	VT-4
C-314-661-3	SPH-250	SP	02/14/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035605	VT-3
C-314-661-4	SPH-105	SP	02/15/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036259	VT-4
C-314-661-4	SPH-105	SP	02/15/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035607	VT-6
C-314-661-4	SPH-109	SP	02/09/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036261	VT-4
C-314-661-4	SPH-109	SP	02/09/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035606	VT-3
C-314-661-4	SPH-108	SP	02/09/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036260	VT-4
C-314-661-4	SPH-108	SP	02/09/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035608	VT-3
C-314-661-4	SPH-110	SP	02/20/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0036062	VT-4
C-314-661-4	SPH-110	SP	02/20/90	C-C&C-E	C3.60	NONE	NONE	SNUBBER	ACCEPT	ST0035146	VT-3
C-314-611-2	CCH-025	CC	03/02/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036154	VT-4
C-314-611-2	CCH-025	CC	03/02/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035183	VT-3
C-314-611-9	CCH-754	CC	03/06/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036181	VT-4
C-314-611-9	CCH-754	CC	03/06/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035184	VT-3
C-314-611-9	CCH-755	CC	03/06/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036182	VT-4
C-314-611-9	CCH-755	CC	03/06/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035185	VT-3
C-314-611-9	CCH-756	CC	03/01/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036183	VT-4
C-314-611-9	CCH-756	CC	05/01/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035186	VT-3
C-314-611-9	CCH-764	CC	02/15/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT		

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMNER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	WDE METHOD
C-314-611-9	CCH-764	CC	02/15/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036184	VT-4
C-314-611-9	CCH-765	CC	03/01/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035187	VT-3
C-314-611-9	CCH-765	CC	03/01/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036185	VT-4
C-314-611-9	CCH-767	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035188	VT-3
C-314-611-9	CCH-767	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036186	VT-4
C-314-611-9	CCH-771	CC	03/01/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035189	VT-3
C-314-611-9	CCH-771	CC	03/01/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036187	VT-4
C-314-611-9	CCH-773	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035190	VT-3
C-314-611-9	CCH-773	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036188	VT-4
C-314-611-12	CCH-305	CC	02/15/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035166	VT-3
C-314-611-12	CCH-305	CC	02/15/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036172	VT-4
C-314-611-12	CCH-318	CC	02/15/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035168	VT-3
C-314-611-12	CCH-318	CC	02/15/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036173	VT-4
C-314-611-12	CCH-323	CC	02/16/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035170	VT-3
C-314-611-12	CCH-323	CC	02/16/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036175	VT-4
C-314-611-12	CCH-322	CC	02/16/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035169	VT-3
C-314-611-12	CCH-322	CC	02/16/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036174	VT-4
C-314-611-12	CCH-329	CC	02/27/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035171	VT-3
C-314-611-12	CCH-329	CC	02/27/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036176	VT-4
C-314-611-12	CCH-126	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035156	VT-3
C-314-611-12	CCH-126	CC	02/27/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036162	VT-3
C-314-611-16	CCH-100	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035150	VT-3
C-314-611-16	CCH-100	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036156	VT-4
C-314-611-16	CCH-392	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035178	VT-3
C-314-611-16	CCH-392	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036179	VT-4

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	NDE METHOD
C-314-611-16	CCH-084	CC	03/07/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035149	VT-3
C-314-611-15	CCH-084	CC	03/07/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036155	VT-4
C-314-611-16	CCH-397	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035181	VT-3
C-314-611-16	CCH-397	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036180	VT-4
C-314-611-16	CCH-117	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035154	VT-3
C-314-611-16	CCH-117	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036160	VT-4
C-314-611-16	CCH-121	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035155	VT-3
C-314-611-16	CCH-121	CC	03/08/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036161	VT-4
C-314-611-17	CCH-376	CC	03/01/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035175	VT-3
C-314-611-17	CCH-376	CC	03/01/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036177	VT-4
C-314-611-17	CCH-386	CC	02/15/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035176	VT-3
C-314-611-17	CCH-386	CC	02/15/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036178	VT-4
C-314-611-17	CCH-103	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER "A"	ACCEPT	ST0035151	VT-3
C-314-611-17	CCH-103	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER "A"	ACCEPT	ST0036157	VT-4
C-314-611-17	CCH-103	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER "B"	ACCEPT	ST0035152	VT-3
C-314-611-17	CCH-103	CC	02/28/90	D-A	D.1.3	NONE	NONE	SNUBBER "B"	ACCEPT	ST0036158	VT-4
C-314-611-18	CCH-108	CC	03/07/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035153	VT-3
C-314-611-18	CCH-108	CC	03/07/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036159	VT-4
C-314-611-18	CCH-291	CC	03/07/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035159	VT-3
C-314-611-18	CCH-291	CC	03/07/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036165	VT-4
C-314-611-18	CCH-294	CC	03/05/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035161	VT-3
C-314-611-18	CCH-294	CC	03/05/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036167	VT-4
C-314-611-18	CCH-293	CC	03/05/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035160	VT-3
C-314-611-18	CCH-293	CC	03/05/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036166	VT-4
C-314-611-18	CCH-295	CC	03/05/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035162	VT-3

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	IDE METHOD
C-314-611-18	CCH-295	CC	03/05/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036168	VT-4
C-314-611-18	CCH-298	CC	03/27/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035165	VT-3
C-314-611-18	CCH-298	CC	03/27/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036171	VT-4
C-314-661-18	CCH-297	CC	03/27/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035164	VT-3
C-314-611-18	CCH-297	CC	03/27/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036170	VT-4
C-314-611-18	CCH-127	CC	03/30/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035157	VT-3
C-314-611-18	CCH-127	CC	03/30/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036163	VT-4
C-314-611-18	CCH-296	CC	04/18/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035163	VT-3
C-314-611-18	CCH-296	CC	04/18/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0036169	VT-4
C-314-611-21	CCH-453	CC	04/06/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0034587	VT-3
C-314-611-21	CCH-453	CC	04/06/90	D-A	D.1.3	NONE	NONE	SNUBBER	ACCEPT	ST0035965	VT-4
C-314-251-8	SWH-036	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0035663	VT-3
C-314-251-8	SWH-036	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0036271	VT-4
C-314-251-8	SWH-040	SW	03/06/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0035664	VT-3
C-314-251-8	SWH-040	SW	03/06/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0036272	VT-4
C-314-251-8	SWH-047	SW	03/06/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0035665	VT-3
C-314-251-8	SWH-047	SW	03/06/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0036273	VT-4
C-314-251-8	SWH-047	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0035666	VT-3
C-314-251-8	SWH-064	SW	03/06/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0036274	VT-4
C-314-251-8	SWH-064	SW	03/06/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0035667	VT-3
C-314-251-8	SWH-065	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0036275	VT-4
C-314-251-8	SWH-065	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0035668	VT-3
C-314-251-8	SWH-066	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0036276	VT-4
C-314-251-8	SWH-066	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0035669	VT-3
C-314-251-8	SWH-067	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0036277	VT-4
C-314-251-8	SWH-067	SW	03/05/90	D-B	D.2.3	NONE	NONE	SNUBBER	ACCEPT	ST0036277	VT-4

SOUTH CAROLINA ELECTRIC & GAS
 V. C. SUMMER, UNIT 1 - COMMERCIAL DATE: JANUARY 1, 1984
 FIFTH REFUELING OUTAGE
 VISUAL EXAMINATION RESULTS

DRAWING/ ISOMETRIC NUMBER	ID NUMBER	SYSTEM	DATE OF EXAMINATION	CODE CATEGORY	CODE ITEM	INDICATION	LIMITATION	REMARKS	DISPOSITION	REPORT NUMBER	TYPE METHOD
C-314-251-11	SMN-4019	SM	04/15/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0035124	VT-3
C-314-251-11	SMN-4019	SM	04/15/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0036063	VT-4
C-314-251-11	SMN-4020	SM	04/15/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0035125	VT-3
C-314-251-11	SMN-4020	SM	04/15/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0036064	VT-4
C-314-251-17	SMN-081	SM	03/01/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0035122	VT-3
C-314-251-17	SMN-081	SM	03/01/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0036278	VT-4
C-314-251-17	SMN-083	SM	03/07/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0035123	VT-3
C-314-251-17	SMN-083	SM	03/07/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0036279	VT-4
C-314-251-8	SMN-031	SM	03/26/90	C-C&C-E	C3.60	NONE	NONE	SMUBBER	ACCEPT	ST0035660	VT-3
C-314-251-8	SMN-031	SM	03/26/90	C-C&C-E	C3.60	NONE	NONE	SMUBBER	ACCEPT	ST0036269	VT-4
C-314-251-8	SMN-032	SM	03/26/90	C-C&C-E	C3.60	NONE	NONE	SMUBBER	ACCEPT	ST0035661	VT-3
C-314-251-8	SMN-032	SM	03/26/90	C-C&C-E	C3.60	NONE	NONE	SMUBBER	ACCEPT	ST0036270	VT-4
C-314-085-5	EFH-101	EF	03/26/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0035252	VT-3
C-314-085-5	EFH-101	EF	03/26/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0036195	VT-4
C-314-085-5	EFH-4019	EF	03/26/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0035265	VT-3
C-314-085-5	EFH-4019	EF	03/26/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0036197	VT-4
C-314-085-5	EFH-4021	EF	03/26/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0035266	VT-3
C-314-085-5	EFH-4021	EF	03/26/90	D-B	D.2.3	NONE	NONE	SMUBBER	ACCEPT	ST0036198	VT-4
CGE-1-4303	16	SI	10/22/88	B-J	B9.011	NONE	NONE	EXAMINED PER IEB 88-08	ACCEPT	VCSU-0464	UT
C-314-011-15	MSH-179	MS	10/11/88	C-C/C-E	C3.50	NONE	NONE	N/A	ACCEPT	VCSV-2423	VT-3
CGE-2-4201A	WS-1	RC	10/17/88	B-K-?	B10.010	NONE	YES*	# REF.REL/REQ. 1-IWA-1	ACCEPT	VCSP-0480	PT
CGE-2-2201A	62LS59	MS	10/05/88	C-F	C5.022	NONE	NONE	N/A	ACCEPT	VCSU-291	UT

NOTE:

The last four entries on this page were inadvertently left off the summary of completed examination performed during the fourth refueling outage.