

September 19, 1990

Docket No. 50-213

DISTRIBUTION

Mr. Edward J. Mroczka
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
P. O. box 270
Hartford, Connecticut 06141-0270

Docket file EJordan
SNorris ACRS (10)
NRC & L PDRs AWang
PDI-4 Rdg JStoiz
SVarga OGC
BBoger GHill (4)
DHagan Wanda Jones
JCalvo GPA/PA
OC/LFMB

Dear Mr. Mroczka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 77228)

The Commission has issued the enclosed Amendment No. 131 to Facility Operating License No. DPR-61 for the Haddam Neck Plant, in response to your application dated July 26, 1990.

The amendment will provide an exception to specification 4.0.4 for entry into Mode 3 for surveillance requirement 4.7.1.2.2, "Auxiliary Feedwater System Operability." This TS change will allow the plant to progress to Mode 3 without first demonstrating auxiliary feedwater operability.

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

original signed by Alan Wang

Alan B. Wang, Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

- 1. Amendment No. 131 to DPR-61
- 2. Safety Evaluation

cc w/enclosures:
See next page

OGC	: PDI-4:LA	: PDI-4:PM	: PDI-4:D	: OGC		
NAME	: SNorris	: AWang/Bank	: JStoiz	: APT		
DATE	: 08/14/90	: 08/14/90	: 08/15/90	: 08/27/90		

OFFICIAL RECORD COPY
Document Name: AMEND 77228

9010010238 900919
PDR ADOCK 05000213
P PIC

DF01
11



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

September 19, 1990

Docket No. 50-213

Mr. Edward J. Mroczka
Senior Vice President
Nuclear Engineering and Operations
Connecticut Yankee Atomic Power Company
Northeast Nuclear Energy Company
P. O. Box 270
Hartford, Connecticut 06141-0270

Dear Mr. Mroczka:

SUBJECT: ISSUANCE OF AMENDMENT (TAC NO. 77228)

The Commission has issued the enclosed Amendment No. 131 to Facility Operating License No. DPR-61 for the Haddam Neck Plant, in response to your application dated July 26, 1990.

The amendment will provide an exception to specification 4.0.4 for entry into Mode 3 for surveillance requirement 4.7.1.2.2, "Auxiliary Feedwater System Operability." This TS change will allow the plant to progress to Mode 3 without first demonstrating auxiliary feedwater operability.

A copy of the related Safety Evaluation is also enclosed. The Notice of Issuance will be included in the Commission's biweekly Federal Register notice.

Sincerely,

Alan Wang

Alan S. Wang, Project Manager
Project Directorate I-4
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Enclosures:

1. Amendment No. 131 to DPR-61
2. Safety Evaluation

cc w/enclosures:
See next page

Mr. Edward J. Mrocza
Connecticut Yankee Atomic Power Company

Haddam Neck Plant

cc:

Gerald Garfield, Esquire
Day, Berry and Howard
Counselors at Law
City Place
Hartford, Connecticut 06103-3499

R. M. Kacich, Manager
Generation Facilities Licensing
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

W. D. Romberg, Vice President
Nuclear Operations
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

D. O. Nordquist
Director of Quality Services
Northeast Utilities Service Company
Post Office Box 270
Hartford, Connecticut 06141-0270

Kevin McCarthy, Director
Radiation Control Unit
Department of Environmental Protection
State Office Building
Hartford, Connecticut 06106

Regional Administrator
Region I
U. S. Nuclear Regulatory Commission
475 Allendale Road
King of Prussia, Pennsylvania 19406

Bradford S. Chase, Under Secretary
Energy Division
Office of Policy and Management
80 Washington Street
Hartford, Connecticut 06106

Board of Selectmen
Town Hall
Haddam, Connecticut 06103

E. A. DeBarba, Nuclear Station Director
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
RFD 1, Post Office Box 127E
East Hampton, Connecticut 06424

J. T. Shedlosky, Resident Inspector
Haddam Neck Plant
c/o U. S. Nuclear Regulatory Commission
Post Office Box 116
East Haddam Post Office
East Haddam, Connecticut 06423

G. H. Bouchard, Nuclear Unit Director
Haddam Neck Plant
Connecticut Yankee Atomic Power Company
RFD 1, Post Office Box 127E
East Hampton, Connecticut 06424