DCS No: 50220-820924 Date: 27 September 1982

PRELIMINARY NOTIFICATION OF EVENT OR UNUSUAL OCCURRENCE--PNO-I-82-31C

This preliminary notification constitutes EARLY notice of events of POSSIBLE safety or public interest significance. The information is as initially received without verification or evaluation, and is basically all that is known by the Region I staff on this date.

Facility:	Nine Mile Point, Unit 1	Licensee Emergency Classification:			
	DN 50-220	Notification of Unusual Event			
	Oswego, New York	Alert			
	김 이야지 않는 것 같아. 그는 것은 것은 것	Site Area Emergency			
		General Emergency			
		X Not Applicable			

Subject: LINEAR INDICATIONS IN REACTOR RECIRCULATION SYSTEM PIPING (UPDATE)

PNO-I-82-31B reported 8 ultrasonic (UT) indications in the Emergency Condenser System piping (10") and 4 UT indications in the Shutdown Cooling System piping (14"). This piping connects to the 28" Recirculation System piping.

Evaluation of these indications by the licensee showed that they are due to piping geometry, and therefore not reportable. UT examination of 26 additional welds in the Emergency Condenser, Core Spray, and Shutdown Cooling System has resulted in no reportable indications. Additional UT examinations are planned by the licensee.

The licensee does not plan to issue a press release. The NRC does not plan to issue a press release but will continue to respond to inquiries.

The State of New York has been notified.

CONTACT: H. Kister 488-1233		Brunner -1225					
Chairman Palladino Comm. Gilinsky Comm. Ahearne	MNBB EDO PA MPA ELD	Phillips <u>22243</u> NRR ights INPO NSAC	IE OIA AEOD	Willste NMSS RES	<u>Mail</u> : ADM DOT	1:DMB :Trans.	Only
PDR Regional Offices Reg		ND V-1:05"	TMI Resident Section RI Resident Office Zone Matrix - 4720				
8210010007 82092 PDR I&E PNO-I-82-031C PI			Licensee:	Licensees)	<u> </u>		
Region I Form 83 (Rev. June 1932)			(Reactor	Licensees)		TES	14