

SEVENTH REGION  
ATLANTA, GEORGIA

02 JUL 27 AIO - 02



July 22, 1982  
L-82-299

Mr. James P. O'Reilly  
Regional Administrator, Region II  
U. S. Nuclear Regulatory Commission  
101 Marietta Street, Suite 3100  
Atlanta, Georgia 30303

Dear Mr. O'Reilly:

Re: ST. LUCIE UNIT 1  
Docket No. 50-335  
IE Inspection Report 82-17

Florida Power & Light Company has reviewed the subject inspection report and a response is attached.

There is no proprietary information in the report.

Very truly yours,

A handwritten signature in cursive script that reads "Robert E. Uhrig".

Robert E. Uhrig  
Vice President  
Advanced Systems & Technology

REU/PLP/cab

Attachment

cc: Harold F. Reis, Esquire

8210010084 820915  
PDR ADOCK 05000335  
Q PDR

ATTACHMENT

Re: St. LUCIE UNIT 1  
Docket No. 50-335  
IE Inspection Report 82-17

Finding:

Technical Specification 6.9.1.4 requires the licensee to submit an annual report to NRC Region II giving the complete results of steam generator tube inservice inspections by March 1 of the year following the inspections. Technical Specification 4.4.10.1 requires inservice inspections in accordance with Section XI of the ASME Boiler and Pressure Vessel Code. This code requires submittal of a report for these inspections to NRC Region II within 90 days after completion of the inspections.

Contrary to the above, on May 14, 1982, the reports for steam generator and other inservice inspections conducted by the licensee in 1981 had not been submitted to NRC Region II.

Response

1. FPL concurs with the finding.
2. This finding occurred because the steam generator inspection information being prepared by our vendor did not arrive in time to meet the required submittal date, and because we failed to provide an interim response.
3. As corrective action, we request our vendor to expedite the issuance of the information. The report was submitted June 22, 1982.
4. As corrective action to prevent recurrence of this problem, we have placed this item on our operations department tracking system to ensure a report is issued on time. In the future, we will submit an interim report if a complete report is not available for submittal.
5. Full compliance was achieved June 22, 1982.