

APPENDIX A

NOTICE OF VIOLATION

Florida Power and Light Company
St. Lucie 1

Docket No. 50-335
License No. DPR-67

As a result of the inspection conducted on May 11-14, 1982, and in accordance with the NRC Enforcement Policy, 47 FR 9987 (March 9, 1982), the following violation was identified.

Technical Specification 6.9.1.4 requires the licensee to submit an annual report to NRC Region II giving the complete results of steam generator tube inservice inspections by March 1 of the year following the inspections. Technical Specification 4.4.10.1 requires inservice inspections in accordance with Section XI of the ASME Boiler and Pressure Vessel Code. This code requires submittal of a report for these inspections to NRC Region II within 90 days after completion of the inspections.

Contrary to the above, on May 14, 1982, the reports for steam generator and other inservice inspections conducted by the licensee in 1981 had not been submitted to NRC Region II.

This is a Severity Level V Violation.

Pursuant to the provisions of 10 CFR 2.201, you are hereby required to submit to this office within thirty days of the date of this Notice, a written statement or explanation in reply, including: (1) admission or denial of the alleged violation; (2) the reasons for the violation if admitted; (3) the corrective steps which have been taken and the results achieved; (4) corrective steps which will be taken to avoid further violations; and (5) the date when full compliance will be achieved. Consideration may be given to extending your response time for good cause shown.

JUN 18 1982

Date: _____

8210010092 820915
PDR ADOCK 05000335
G PDR