

VIRGINIA ELECTRIC AND POWER COMPANY
RICHMOND, VIRGINIA 23261

R. H. LEASBURG
VICE PRESIDENT
NUCLEAR OPERATIONS

September 27, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
Attn: Mr. Robert A. Clark, Chief
Operating Reactors Branch No. 3
Division of Licensing
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Serial No. 542
NO/WDC:acm
Docket No. 50-339
License No. NPF-7

Gentlemen:

AMENDMENT TO OPERATING LICENSE NPF-7
NORTH ANNA POWER STATION UNIT NO. 2
PROPOSED OPERATING LICENSE AMENDMENT

Pursuant to 10 CFR 50.90, the Virginia Electric and Power Company requests an amendment to Operating License NPF-7 for North Anna Power Station, Unit No. 2. The proposed change to the Operating License is enclosed.

License Condition 2.C(15)(h)(4) currently states, "The fuel oil storage and transfer system shall be modified to include the installation of a separate high level alarm for each day tank, the installation of independent pressure switches for each pump which will be set to stop the pumps on high day tank level, and the submittal of Technical Specifications verifying proper operation of all transfer pump control switches and day tank high level alarms. The modifications shall be completed no later than the October, 1982 Fall maintenance outage." The proposed change is to complete License Condition 2.C(15)(h)(4) by the end of the second refueling outage.

License Condition 2.C(15)(h)(2) currently states, "The lube oil system shall be modified to the manufacturer's recommendations for providing continuous lubrication of the lower portions of the engine. The modifications shall further provide for partial filling of the upper lube oil supply header and lube oil booster/accumulator system which will force oil into the upper lube oil header during engine startup. The modifications shall be completed no later than the October, 1982 Fall maintenance outage." The proposed change is to complete License Condition 2.C(h)(15)(2) by the end of the second refueling outage.

The proposed amendment is provided in Attachment 1. A discussion of the proposed changes is provided in Attachment 2.

This request has been reviewed and approved by the Station Nuclear Safety and Operating Committee and the Safety Evaluation and Control Staff. It has been determined that this request does not involve an unreviewed safety question as defined in 10 CFR 50.59.


8210010103 820927
PDR ADOCK 05000339
P PDR

*Adol
w/check
\$4,000*

VIRGINIA ELECTRIC AND POWER COMPANY TO Harold R. Denton

We have evaluated this request in accordance with the criteria in 10 CFR 170.22. Since this request involves a safety issue which the staff should be able to determine does not pose a significant hazard consideration for Unit 2, a Class III license amendment fee is required for Unit 2. Accordingly, a voucher check in the amount of \$4000 is enclosed in payment of the required fees.

Very truly yours,



R. H. Leasburg

Attachments

1. Proposed Operating License Amendment
2. Discussion of Proposed Operating License Amendment
3. Voucher Check No. 80266 for \$4000

cc: Mr. James P. O'Reilly
Regional Administrator
Region II

COMMONWEALTH OF VIRGINIA)
)
CITY OF RICHMOND)

The foregoing document was acknowledged before me, in and for the City and Commonwealth aforesaid, today by R. H. Leasburg, who is Vice President-Nuclear Operations, of the Virginia Electric and Power Company. He is duly authorized to execute and file the foregoing document in behalf of that Company, and the statements in the document are true to the best of his knowledge and belief.

Acknowledged before me this 27th day of September, 19 82.

My Commission expires: 2-26, 19 85.

Ann C. Morse

Notary Public

(SEAL)