



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-338

NORTH ANNA POWER STATION, UNIT NO. 1

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 140
License No. NPF-4

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company et al., (the licensee) dated June 26, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter 1;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

9010020163 900913
PDR ADUCK 05000338
P PDC

2. Accordingly, license condition 2.D.(3)t. is hereby added to Facility Operating License No. NPF-4 to read as follows:

t. Fire Protection

VEPCO shall implement and maintain in effect all provisions of the approved fire protection program as described in the Final Safety Analysis Report for the facility and as approved in the SER dated February 1979 subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.


3. In addition, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.D.(2) of Facility Operating License No. NPF-4 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 140, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

4. This license amendment is effective as of the date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 13, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 140

TO FACILITY OPERATING LICENSE NO. NPF-4

DOCKET NO. 50-338

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Page

IV
VIIIa
XV
3/4 3-52 through 3/4 3-53a (deleted)
3/4 7-75 through 3/4 7-84 (deleted)
B 3/4 3-3
B 3/4 7-9
B 3/4 7-10
6-1a
6-7
6-13
6-21

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>	
3/4.2.1 Axial Flux Difference	3/4 2-1
3/4.2.2 Heat Flux Hot Channel Factor	3/4 2-5
3/4.2.3 Nuclear Enthalpy Hot Channel Factor	3/4 2-9
3/4.2.4 Quadrant Power Tilt Ratio	3/4 2-12
3/4.2.5 DNB Parameters	3/4 2-14
<u>3/4.3 INSTRUMENTATION</u>	
3/4.3.1 REACTOR TRIP SYSTEM INSTRUMENTATION	3/4 3-1
3/4.3.2 ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION	3/4 3-15
3/4.3.3 MONITORING INSTRUMENTATION	
Radiation Monitoring	3/4 3-35
Movable Incore Detectors	3/4 3-39
Seismic Instrumentation	3/4 3-40
Meteorological Instrumentation	3/4 3-43
Auxiliary Shutdown Panel Monitoring Instrumentation	3/4 3-46
Accident Monitoring Instrumentation	3/4 3-49
Loose Parts Monitoring System	3/4 3-56
Explosive Gas Monitoring Instrumentation	3/4 3-59
<u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1 REACTOR COOLANT LOOPS AND COOLANT CIRCULATION	
Startup and Power Operation	3/4 4-1
Hot Standby	3/4 4-2
Shutdown	3/4 4-3
Isolated Loop	3/4 4-4
Isolated Loop Startup	3/4 4-5

DELETED

NORTH ANNA - UNIT 1

Villa

Amendment No. 2,57,140.

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 TURBINE CYCLE.....	B 3/4 7-1
3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION.....	B 3/4 7-4
3/4.7.3 COMPONENT COOLING WATER SUBSYSTEM.....	B 3/4 7-4
3/4.7.4 SERVICE WATER SYSTEM.....	B 3/4 7-4
3/4.7.5 ULTIMATE HEAT SINK.....	B 3/4 7-5
3/4.7.6 FLOOD PROTECTION.....	B 3/4 7-5
3/4.7.7 CONTROL ROOM EMERGENCY HABITABILITY.....	B 3/4 7-5
3/4.7.8 SAFEGUARDS AREA VENTILATION SYSTEM.....	B 3/4 7-5
3/4.7.9 RESIDUAL HEAT REMOVAL SYSTEMS.....	B 3/4 7-6
3/4.7.10 HYDRAULIC SNUBBERS.....	B 3/4 7-6
3/4.7.11 SEALED SOURCE CONTAMINATION.....	B 3/4 7-7
3/4.7.12 SETTLEMENT OF CLASS 1 STRUCTURES.....	B 3/4 7-7a
3/4.7.13 GROUNDWATER LEVEL - SERVICE WATER RESERVOIR.....	B 3/4 7-9

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES.....	B 3/4 8-1
3/4.8.2 ONSITE POWER DISTRIBUTION SYSTEMS.....	B 3/4 8-1

3/4.9 REFUELING OPERATIONS

3/4.9.1 BORON CONCENTRATION.....	B 3/4 9-1
3/4.9.2 INSTRUMENTATION.....	B 3/4 9-1

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
3/4.9.3 DECAY TIME.....	B 3/4 9-1
3/4.9.4 CONTAINMENT BUILDING PENETRATIONS.....	B 3/4 9-1
3/4.9.5 COMMUNICATIONS.....	B 3/4 9-1
3/4.9.6 MANIPULATOR CRANE OPERABILITY.....	B 3/4 9-2
3/4.9.7 CRANE TRAVEL - SPENT FUEL PIT.....	B 3/4 9-2
3/4.9.8 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION.....	B 3/4 9-2
3/4.9.9 CONTAINMENT PURGE AND EXHAUST ISOLATION SYSTEM.....	B 3/4 9-2
3/4.9.10 and 3/4.9.11 WATER LEVEL-REACTOR VESSEL AND SPENT FUEL PIT.....	B 3/4 9-3
3/4.9.12 FUEL BUILDING VENTILATION SYSTEM.....	B 3/4 9-3
 <u>3/4.10 SPECIAL TEST EXCEPTIONS</u>	
3/4.10.1 SHUTDOWN MARGIN.....	B 3/4 10-1
3/4.10.2 GROUP HEIGHT, INSERTION AND POWER DISTRIBUTION LIMITS.....	B 3/4 10-1
3/4.10.3 PHYSICS TESTS.....	B 3/4 10-1
3/4.10.4 REACTOR COOLANT LOOPS.....	B 3/4 10-1

INSTRUMENTATION

BASES

3/4.3.3.6 POST-ACCIDENT INSTRUMENTATION

The OPERABILITY of the post-accident instrumentation ensures that sufficient information is available on selected plant parameters to monitor and assess these variables following an accident.

3/4.3.3.9 LOOSE PARTS MONITORING SYSTEM

OPERABILITY of the Loose Parts Monitoring System provides assurance that loose parts within the RCS will be detected. This capability is designed to ensure that loose parts will not collect and create undesirable flow blockages.

This Page Intentionally Left Blank

PLANT SYSTEMS

BASES

3/4.7.13 GROUNDWATER LEVEL-SERVICE WATER RESERVOIR

A program to monitor groundwater levels in the area of the service water reservoir has been established to ensure that the integrity of the service water reservoir embankments and pumphouse is maintained.

Groundwater threshold levels have been established based on historical groundwater data available in 1977. These levels are sufficiently conservative to ensure that the service water reservoir and pumphouse will perform their intended function. An engineering evaluation will be performed if these threshold values are exceeded, to determine if there is any substantive cause to believe that any aspect of the service water reservoir, dike or pumphouse will not perform its intended function. A conclusion to this effect, and the appropriate corrective actions to be performed, will be reported to the Commission.

The groundwater threshold levels are periodically reviewed to determine whether a changing groundwater environment warrants a change in threshold levels.

DELETED

NORTH ANNA - UNIT 1

B 3/4 7-10

Amendment No. 3.1140.

6.0 ADMINISTRATIVE CONTROLS

6.1 RESPONSIBILITY

6.1.1 The Station Manager shall be responsible for overall facility operation. In his absence, the Assistant Station Manager (Operations and Maintenance) shall be responsible for overall facility operation. During the absence of both, the Station Manager shall delegate in writing the succession to this responsibility.

6.1.2 The Shift Supervisor (or during his absence from the Control Room, a designated individual) shall be responsible for the Control Room command function and shall be the only individual that may direct the licensed activities of licensed operators. A management directive to this effect, signed by the Senior Vice President - Nuclear, shall be reissued to all station personnel on an annual basis.

6.2 ORGANIZATION

ONSITE AND OFFSITE ORGANIZATION

6.2.1 Onsite and Offsite Organization

An onsite and an offsite organization shall be established for facility operation and corporate management. The onsite and offsite organization shall include the positions for activities affecting the safety of the nuclear power plant.

- a. Lines of authority, responsibility, and communication shall be established and defined for the highest management levels through intermediate levels to and including all operating organization positions. These relationships shall be documented and updated, as appropriate, in the form of organization charts, functional descriptions of departmental responsibilities and relationships, and job descriptions for key personnel positions, or in equivalent forms of documentation. These requirements shall be documented in the UFSAR.
- b. The Station Manager shall be responsible for overall unit safe operation and shall have control over those onsite activities necessary for safe operation and maintenance of the plant.
- c. The Vice President - Nuclear Operations shall have corporate responsibility for overall plant nuclear safety and shall take any measures needed to ensure acceptable performance of the staff in operating, maintaining, and providing technical support to the plant to ensure nuclear safety.
- d. The management position responsible for training of the operating staff and the management position responsible for the quality assurance functions shall have sufficient organizational freedom including sufficient independence from cost and schedule when opposed to safety considerations.

ADMINISTRATIVE CONTROLS

- e. The management position responsible for health physics shall have direct access to that onsite individual having responsibility for overall facility management. Health physics personnel shall have the authority to cease any work activity when worker safety is jeopardized or in the event of unnecessary personnel radiation exposures.

FACILITY STAFF

6.2.2 The Facility organization shall be as shown in the UFSAR.

- a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Reactor Operator shall be in the control room when fuel is in the reactor. In addition, while the unit is in MODES 1, 2, 3 or 4, at least one licensed Senior Reactor Operator shall be in the Control Room.
- c. A health physics technician# shall be onsite when fuel is in the reactor.
- d. ALL CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.

The health physics technician composition may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence provided immediate action is taken to fill the required positions.

ADMINISTRATIVE CONTROLS

- k. Review of every unplanned onsite release of radioactive material to the environs including the preparation of reports covering evaluation, recommendations and disposition of the corrective action to prevent recurrence and the forwarding of these reports to the Vice President-Nuclear Operations and the Management Safety Review Committee.
- l. Review changes to the PROCESS CONTROL PROGRAM and the OFFSITE DOSE CALCULATION MANUAL.
- m. Review of the Fire Protection Program and implementing procedures and shall submit recommended changes to the Station Manager.

AUTHORITY

6.5.1.7 The SNSOC shall:

- a. Provide written approval or disapproval of items considered under 6.5.1.6(a) through (c) above. SNSOC approval shall be certified in writing by an Assistant Station Manager.
- b. Render determinations in writing with regard to whether or not each item considered under 6.5.1.6(a) through (e) above constitutes an unreviewed safety question.
- c. Provide written notification within 24 hours to the Vice President-Nuclear Operations and the Management Safety Review Committee (MSRC) of disagreement between the SNSOC and the Station Manager; however, the Station Manager shall have responsibility for resolution of such disagreements pursuant to 6.1.1 above.

RECORDS

6.5.1.8 The SNSOC shall maintain written minutes of each meeting and copies shall be provided to the Station Manager, Vice President-Nuclear Operations and the MSRC.

6.5.2 MANAGEMENT SAFETY REVIEW COMMITTEE (MSRC)

FUNCTION

6.5.2.1 The MSRC shall function to provide independent review of designated activities in the areas of:

- a. Station Operations
- b. Maintenance
- c. Reactivity Management
- d. Engineering
- e. Chemistry and Radiochemistry
- f. Radiological Safety
- g. Quality Assurance Practices
- h. Emergency Preparedness

ADMINISTRATIVE CONTROLS

COMPOSITION

6.5.2.2 The MSRC shall be composed of the MSRC Chairman and a minimum of four MSRC members. The Chairman and all members of the MSRC shall have qualifications that meet the requirements of Section 4.7 of ANSI/ANS 3.1-1979 Rev. 1 (Draft).

ALTERNATES

6.5.2.3 All alternate members shall be appointed in writing by the MSRC Chairman to serve on a temporary basis; however, no more than two alternates shall participate as voting members in MSRC activities at any one time.

CONSULTANTS

6.5.2.4 Consultants should be utilized as determined by the MSRC Chairman to provide expert advice to the MSRC.

MEETING FREQUENCY

6.5.2.5 The MSRC shall meet at least once per calendar quarter.

QUORUM

6.5.2.6 The minimum quorum of the MSRC necessary for the performance of the MSRC review and audit functions of these Technical Specifications shall consist of the Chairman or his designated alternate and at least 50% of the MSRC members including alternates. No more than a minority of the quorum shall have line responsibility for operation of the unit.

REVIEW

- 6.5.2.7 The MSRC shall be responsible for the review of:
- a. The safety evaluations for 1) changes to procedures, equipment or systems and 2) tests or experiments completed under the provision of Section 50.59, 10 CFR, to verify that such actions did not constitute an unreviewed safety question.
 - b. Proposed changes to procedures, equipment or systems which involve an unreviewed safety question as defined in Section 50.59, 10 CFR.
 - c. Proposed tests or experiments which involve an unreviewed safety question as defined in Section 50.59, 10 CFR.
 - d. Proposed changes to Technical Specifications or this Operating License.

ADMINISTRATIVE CONTROLS

- c. Surveillance and test activities of safety related equipment.
- d. Security Plan implementation.
- e. Emergency Plan implementation.
- f. Fire Protection Program implementation.
- g. PROCESS CONTROL PROGRAM implementation.
- h. OFFSITE DOSE CALCULATION MANUAL implementation.
- i. Quality Assurance Program for effluent and environmental monitoring, using the guidance in Regulatory Guide 1.21, Revision 1, June 1974 and Regulatory Guide 4.1, Revision 1, April 1975.

6.8.2 Each procedure of 6.8.1 above, except 6.8.1.d, 6.8.1.e, and 6.8.1.f and changes thereto, shall be reviewed and approved by the SNSOC prior to implementation and reviewed periodically as set forth in administrative procedures. Procedure of 6.8.1.d, 6.8.1.e, and 6.8.1.f shall be reviewed and approved as per 6.5.1.6.i, 6.5.1.6.j, and 6.5.1.6.m. SNSOC approval shall be certified in writing by an Assistant Station Manager.

6.8.3 Temporary changes to procedures of 6.8.1 above may be made provided:

- a. The intent of the original procedure is not altered.
- b. The change is approved by two members of the plant supervisory staff, at least one of whom holds a Senior Reactor Operator's License on the unit affected.
- c. The change is documented, reviewed, and approved by the SNSOC within 14 days of implementation. SNSOC approval shall be certified in writing by an Assistant Station Manager.

6.8.4 The following programs shall be established, implemented, and maintained:

a. Primary Coolant Sources Outside Containment

A program to reduce leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to as low as practical levels. The systems include the recirculation spray, safety injection, chemical and volume control, gas stripper, and hydrogen recombiners. The program shall include the following:

- (i) Preventive maintenance and periodic visual inspection requirements, and
- (ii) Integrated leak test requirements for each system at refueling cycle intervals or less.

ADMINISTRATIVE CONTROLS

b. In-Plant Radiation Monitoring

A program which will ensure the capability to accurately determine the airborne iodine concentration in vital areas under accident conditions. This program shall include the following:

- (i) Training of personnel,
- (ii) Procedures for monitoring, and
- (iii) Provisions for maintenance of sampling and analysis equipment.

c. Secondary Water Chemistry

A program for monitoring of secondary water chemistry to inhibit steam generator tube degradation. This program shall include:

- (i) Identification of a sampling schedule for the critical variables and control points for these variables,
- (ii) Identification of the procedures used to measure the values of the critical variables,
- (iii) Identification of process sampling points,
- (iv) Procedures for the recording and management of data,
- (v) Procedures defining corrective actions for all control point chemistry conditions,
- (vi) A procedure identifying (a) the authority responsible for the interpretation of the data, and (b) the sequence and timing of administrative events required to initiate corrective action, and
- (vii) Monitoring of the condensate at the discharge of the condensate pumps for evidence of condenser inleakage. When condenser inleakage is confirmed, the leak shall be repaired, plugged, or isolated within 96 hours.

d. Post-Accident Sampling

A program which will ensure the capability to obtain and analyze reactor coolant, radioactive iodines and particulates in plant gaseous effluents, and containment atmosphere samples under accident conditions. The program shall include the following:

- (i) Training of personnel,
- (ii) Procedures for sampling and analysis,
- (iii) Provisions for maintenance of sampling and analysis equipment.

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator, Region II, within the time period specified for each report. These reports shall be submitted pursuant to the requirement of the applicable specification:

- a. Inservice Inspection Reviews, Specification 4.0.5, shall be reported within 90 days of completion.
- b. MODERATOR TEMPERATURE COEFFICIENT. Specification 3.1.1.4.
- c. RADIATION MONITORING INSTRUMENTATION. Specification 3.3.3.1, Table 3.3-6, Action 35.
- d. SEISMIC INSTRUMENTATION. Specifications 3.3.3.3 and 4.3.3.3.2.
- e. METEOROLOGICAL INSTRUMENTATION. Specification 3.3.3.4.
- f. Deleted.
- g. LOOSE PARTS MONITORING SYSTEMS. Specification 3.3.3.9.
- h. REACTOR COOLANT SYSTEM SPECIFIC ACTIVITY. Specification 3.4.8.
- i. OVERPRESSURE PROTECTION SYSTEMS. Specification 3.4.9.3.
- j. EMERGENCY CORE COOLING SYSTEMS. Specification 3.5.2 and 3.5.3.
- k. SETTLEMENT OF CLASS 1 STRUCTURES. Specification 3.7.12.
- l. GROUND WATER LEVEL - SERVICE WATER RESERVOIR. Specification 3.7.13.
- m. Deleted.
- n. RADIOACTIVE EFFLUENTS. As required by the ODCM.
- o. RADIOLOGICAL ENVIRONMENTAL MONITORING. As required by the ODCM.
- p. SEALED SOURCE CONTAMINATION. Specification 4.7.11.1.3.
- q. REACTOR COOLANT SYSTEM STRUCTURAL INTEGRITY. Specification 4.4.10. For any abnormal degradation of the structural integrity of the reactor vessel or the Reactor-Coolant System pressure boundary detected during the performance of Specification 4.4.10, an initial report shall be submitted within 10 days after detection and a detailed report submitted within 90 days after the completion of Specification 4.4.10.

ADMINISTRATIVE CONTROLS

- r. - CONTAINMENT STRUCTURAL INTEGRITY. Specification 4.6.1.6. For any abnormal degradation of the containment structure detected during the performance of Specification 4.6.1.6, an initial report shall be submitted within 10 days after the completion of Specification 4.6.1.6. A final report, which includes (1) a description of the condition of the liner plate and concrete, (2) inspection procedure, (3) the tolerance on cracking, and (4) the corrective actions taken, shall be submitted within 90 days after the completion of Specification 4.6.1.6.

6.10 RECORD RETENTION

6.10.1 The following records shall be retained for at least five years:

- a. Records and logs of facility operation covering time interval at each power level.
- b. Records and logs of principal maintenance activities, inspections, repair and replacement of principal items of equipment related to nuclear safety.
- c. ALL REPORTABLE EVENTS and Special Reports.
- d. Records of surveillance activities, inspections and calibrations required by these Technical Specifications.
- e. Records of changes made to Operating Procedures.
- f. Records of radioactive shipments.
- g. Records of sealed source leak tests and results.
- h. Records of annual physical inventory of all sealed source material of record.
- i. Records of the annual audit of the Station Emergency Plan and implementing procedures.
- j. Records of the annual audit of the Station Security Plan and implementation procedures.

6.10.2 The following records shall be retained for the duration of the Facility Operating License:



UNITED STATES
NUCLEAR REGULATORY COMMISSION
WASHINGTON, D. C. 20555

VIRGINIA ELECTRIC AND POWER COMPANY

OLD DOMINION ELECTRIC COOPERATIVE

DOCKET NO. 50-339

NORTH ANNA POWER STATION, UNIT NO. 2

AMENDMENT TO FACILITY OPERATING LICENSE

Amendment No. 123
License No. NPF-7

1. The Nuclear Regulatory Commission (the Commission) has found that:
 - A. The application for amendment by Virginia Electric and Power Company, et al., (the licensee) dated June 26, 1990, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act), and the Commission's rules and regulations set forth in 10 CFR Chapter I;
 - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
 - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
 - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
 - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.

2. Accordingly, license condition 2.C.(23) is hereby added to Facility Operating License NPF-7 to read as follows:

(23) Fire Protection

VEPCO shall implement and maintain in effect all provisions of the approved fire protection program as described in the Final Safety Analysis Report for the facility and as approved in the SER dated February 1979 subject to the following provision:

The licensee may make changes to the approved fire protection program without prior approval of the Commission only if those changes would not adversely affect the ability to achieve and maintain safe shutdown in the event of a fire.


3. In addition, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. NPF-7 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 123, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

4. This license amendment is effective as of the date of issuance and shall be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Herbert N. Berkow, Director
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

Attachment:
Changes to the Technical
Specifications

Date of Issuance: September 13, 1990

ATTACHMENT TO LICENSE AMENDMENT NO. 123

TO FACILITY OPERATING LICENSE NO. NPF-7

DOCKET NO. 50-339

Replace the following pages of the Appendix "A" Technical Specifications with the enclosed pages as indicated. The revised pages are identified by amendment number and contain vertical lines indicating the area of change. The corresponding overleaf pages are also provided to maintain document completeness.

Page

IV
VIII
XIII
3/4 3-49 through 3/4 3-50a (deleted)
3/4 7-59 through 3/4 7-70 (deleted)
B 3/4 3-3
B 3/4 7-9
B 3/4 7-10
6-1a
6-8
6-14
6-21

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.2 POWER DISTRIBUTION LIMITS</u>	
3/4.2.1 Axial Flux Difference	3/4 2-1
3/4.2.2 Heat Flux Hot Channel Factor	3/4 2-5
3/4.2.3 Nuclear Enthalpy Hot Channel Factor	3/4 2-9
3/4.2.4 Quadrant Power Tilt Ratio	3/4 2-12
3/4.2.5 DNB Parameters	3/4 2-15
<u>3/4.3 INSTRUMENTATION</u>	
3/4.3.1 REACTOR TRIP SYSTEM INSTRUMENTATION	3/4 3-1
3/4.3.2 ENGINEERED SAFETY FEATURE ACTUATION SYSTEM INSTRUMENTATION	3/4 3-15
3/4.3.3 MONITORING INSTRUMENTATION	
Radiation Monitoring	3/4 3-38
Movable Incore Detectors	3/4 3-42
Auxiliary Shutdown Panel Monitoring Instrumentation.....	3/4 3-43
Accident Monitoring Instrumentation	3/4 3-46
Explosive Gas Monitoring Instrumentation.....	3/4 3-52
<u>3/4.4 REACTOR COOLANT SYSTEM</u>	
3/4.4.1 REACTOR COOLANT LOOPS AND COOLANT CIRCULATION	
Startup and Power Operation	3/4 4-1
Hot Standby	3/4 4-2
Shutdown	3/4 4-3
Isolated Loop	3/4 4-4
Isolated Loop Startup	3/4 4-5

INDEX

LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 TURBINE CYCLE	
Safety Valves	3/4 7-1
Auxiliary Feedwater System	3/4 7-5
Emergency Condensate Storage Tank	3/4 7-7
Activity	3/4 7-8
Main Steam Trip Valves	3/4 7-10
Steam Turbine Assembly	3/4 7-11
Overspeed Protection	3/4 7-12
3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION	3/4 7-13
3/4.7.3 COMPONENT COOLING WATER SUBSYSTEM	3/4 7-14
3/4.7.4 SERVICE WATER SYSTEM	3/4 7-15
3/4.7.5 ULTIMATE HEAT SINK	3/4 7-16
3/4.7.6 FLOOD PROTECTION	3/4 7-17
3/4.7.7 CONTROL ROOM EMERGENCY HABITABILITY SYSTEMS	3/4 7-18
3/4.7.8 SAFEGUARDS AREA VENTILATION SYSTEM	3/4 7-21
3/4.7.9 RESIDUAL HEAT REMOVAL SYSTEM	
RHR - Operating	3/4 7-23
RHR - Shutdown	3/4 7-24
3/4.7.10 SNUBBERS	3/4 7-25
3/4.7.11 SEALED SOURCE CONTAMINATION	3/4 7-51
3/4.7.12 SETTLEMENT OF CLASS 1 STRUCTURES	3/4 7-53
3/4.7.13 GROUNDWATER LEVEL-SERVICE WATER RESERVOIR	3/4 7-57

INDEX

1. LIMITING CONDITIONS FOR OPERATION AND SURVEILLANCE REQUIREMENTS

PAGE

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A. C. SOURCES

Operating 3/4 8-1

Shutdown 3/4 8-10

3/4.8.2 ONSITE POWER DISTRIBUTION SYSTEMS

A. C. Distribution - Operating 3/4 8-11

A. C. Distribution - Shutdown 3/4 8-12

D. C. Distribution - Operating 3/4 8-13

D. C. Distribution - Shutdown 3/4 8-15

Containment Penetration Conductor Overcurrent
Protective Devices 3/4 8-16

Motor Operated Valves Thermal Overload Protection
and/or Bypass Devices 3/4 8-21

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.7 PLANT SYSTEMS</u>	
3/4.7.1 TURBINE CYCLE.....	B 3/4 7-1
3/4.7.2 STEAM GENERATOR PRESSURE/TEMPERATURE LIMITATION.....	B 3/4 7-4
3/4.7.3 COMPONENT COOLING WATER SUBSYSTEM.....	B 3/4 7-4
3/4.7.4 SERVICE WATER SYSTEM.....	B 3/4 7-4
3/4.7.5 ULTIMATE HEAT SINK.....	B 3/4 7-5
3/4.7.6 FLOOD PROTECTION.....	B 3/4 7-5
3/4.7.7 CONTROL ROOM EMERGENCY HABITABILITY.....	B 3/4 7-5
3/4.7.8 SAFEGUARDS AREA VENTILATION SYSTEM.....	B 3/4 7-5
3/4.7.9 RESIDUAL HEAT REMOVAL SYSTEMS.....	B 3/4 7-6
3/4.7.10 SNUBBERS.....	B 3/4 7-6
3/4.7.11 SEALED SOURCE CONTAMINATION.....	B 3/4 7-7
3/4.7.12 SETTLEMENT OF CLASS 1 STRUCTURES.....	B 3/4 7-7
3/4.7.13 GROUNDWATER LEVEL - SERVICE WATER RESERVOIR.....	B 3/4 7-9
<u>3/4.8 ELECTRICAL POWER SYSTEMS</u>	
3/4.8.1 and 3/4.8.2 A.C. AND D.C. POWER SOURCES AND DISTRIBUTION.....	B 3/4 8-1

INDEX

BASES

<u>SECTION</u>	<u>PAGE</u>
<u>3/4.9 REFUELING OPERATIONS</u>	
3/4.9.1 BORON CONCENTRATION.....	B 3/4 9-1
3/4.9.2 INSTRUMENTATION.....	B 3/4 9-1
3/4.9.3 DECAY TIME.....	B 3/4 9-1
3/4.9.4 CONTAINMENT BUILDING PENETRATIONS.....	B 3/4 9-1
3/4.9.5 COMMUNICATIONS.....	B 3/4 9-1
3/4.9.6 MANIPULATOR CRANE OPERABILITY.....	B 3/4 9-2
3/4.9.7 CRANE TRAVEL - SPENT FUEL PIT.....	B 3/4 9-2
3/4.9.8 RESIDUAL HEAT REMOVAL AND COOLANT CIRCULATION.....	B 3/4 9-2
3/4.9.9 CONTAINMENT PURGE AND EXHAUST ISOLATION SYSTEM.....	B 3/4 9-2
3/4.9.10 and 3/4.9.11 WATER LEVEL-REACTOR VESSEL AND SPENT FUEL PIT.....	B 3/4 9-3
3/4.9.12 FUEL BUILDING VENTILATION SYSTEM.....	B 3/4 9-3
 <u>3/4.10 SPECIAL TEST EXCEPTIONS</u>	
3/4.10.1 SHUTDOWN MARGIN.....	B 3/4 10-1
3/4.10.2 GROUP HEIGHT, INSERTION AND POWER DISTRIBUTION LIMITS.....	B 3/4 10-1
3/4.10.3 PHYSICS TESTS.....	B 3/4 10-1
3/4.10.4 REACTOR COOLANT LOOPS.....	B 3/4 10-1
3/4.10.5 POSITION INDICATOR CHANNELS - SHUTDOWN.....	B 3/4 10-1

DELETED

NORTH ANNA - UNIT 2

B 3/4 3-3

Amendment No. 88, 123,

PLANT SYSTEMS

BASES

3/4 7.13 GROUNDWATER LEVEL-SERVICE WATER RESERVOIR

A program to monitor groundwater levels in the area of the service water reservoir has been established to ensure that the integrity of the service water reservoir embankments and pumphouse is maintained.

Groundwater threshold levels have been established based on historical groundwater data available in 1977. These levels are sufficiently conservative to ensure that the service water reservoir and pumphouse will perform their intended function. An engineering evaluation will be performed if these threshold values are exceeded, to determine if there is any substantive cause to believe that any aspect of the service water reservoir, dike or pumphouse will not perform its intended function. A conclusion to this effect, and the appropriate corrective actions to be performed, will be reported to the Commission.

The groundwater threshold levels are periodically reviewed to determine whether a changing groundwater environment warrants a change in threshold levels.

DELETED

NORTH ANNA - UNIT 2

B 3/4 7-10

Amendment o. 123,

ADMINISTRATIVE CONTROLS

- e. The management position responsible for health physics shall have direct access to that onsite individual having responsibility for overall facility management. Health physics personnel shall have the authority to cease any work activity when worker safety is jeopardized or in the event of unnecessary personnel radiation exposures.

FACILITY STAFF

6.2.2 The Facility organization shall be as shown in the UFSAR.

- a. Each on duty shift shall be composed of at least the minimum shift crew composition shown in Table 6.2-1.
- b. At least one licensed Reactor Operator shall be in the control room when fuel is in the reactor. In addition, while the unit is in MODES 1, 2, 3 or 4, at least one licensed Senior Reactor Operator shall be in the Control Room.
- c. A health physics technician# shall be onsite when fuel is in the reactor.
- d. ALL CORE ALTERATIONS shall be observed and directly supervised by either a licensed Senior Reactor Operator or Senior Reactor Operator Limited to Fuel Handling who has no other concurrent responsibilities during this operation.

#The health physics technician and Fire Brigade composition may be less than the minimum requirements for a period of time not to exceed 2 hours in order to accommodate unexpected absence provided immediate action is taken to fill the required positions.

ADMINISTRATIVE CONTROLS

MEETING FREQUENCY

6.5.1.4 The SNSOC shall meet at least once per calendar month and as convened by the SNSOC Chairman or his designated alternate.

QUORUM

6.5.1.5 A quorum of the SNSOC consists of the Chairman or Vice-Chairman and two members including alternates.

RESPONSIBILITIES

6.5.1.6 The SNSOC shall be responsible for:

- a. Review of 1) all procedures required by Specifications 6.8.1, 6.8.2 and 6.8.3 and changes thereto, 2) all programs required by Specification 6.8.4 and changes thereto, 3) any other proposed procedures or changes thereto as determined by the Station Manager to affect nuclear safety.
- b. Review of all proposed tests and experiments that affect nuclear safety.
- c. Review of all proposed changes or modifications to plant systems or equipment that affect nuclear safety.
- d. Review of all proposed changes to Appendix "A" Technical Specifications and Appendix "B" Environmental Protection Plan. Recommended changes shall be submitted to the Station Manager.
- e. Investigation of all violations of the Technical Specifications including the preparation and forwarding of reports covering evaluation and recommendations to prevent recurrence to the Vice President-Nuclear and the offsite management position responsible for independent/operational event review.
- f. Review of all REPORTABLE EVENTS and Special Reports.
- g. Review of facility operations to detect potential nuclear safety hazards.
- h. Performance of special reviews, investigations or analyses and reports thereon as requested by the Chairman of the Station Nuclear Safety and Operating Committee or Station Manager.
- i. Review of the Plant Security Plan and implementing procedures and shall submit recommended changes to the Station Manager.
- j. Review of the Emergency Plan and implementing procedures and shall submit recommended changes to the Station Manager.

ADMINISTRATIVE CONTROLS

- K. Review of every unplanned onsite release of radioactive material to the environs including the preparation of reports covering evaluation, recommendations and disposition of the corrective action to prevent recurrence and the forwarding of these reports to the Vice President-Nuclear and the offsite management position responsible for independent/operational event review.
- I. Review changes to the PROCESS CONTROL PROGRAM and the OFFSITE DOSE CALCULATION MANUAL
- m. Review of the Fire Protection Program and implementing procedures and shall submit recommended changes to the Station Manager.

AUTHORITY

6.5.1.7 The SNSOC shall:

- a. Provide written approval or disapproval of items considered under 6.5.1.6(a) through (c) above, SNSOC approval shall be certified in writing by an Assistant Station Manager.
- b. Render determinations in writing with regard to whether or not each item considered under 6.5.1.6(a) through (e) above constitutes an unreviewed safety question.
- c. Provide written notification within 24 hours to the Vice President-Nuclear and the offsite management position responsible for independent/operational event review of disagreement between the SNSOC and the Station Manager; however, the Station Manager shall have responsibility for resolution of such disagreements pursuant to 6.1.1 above.

RECORDS

6.5.1.8 The SNSOC shall maintain written minutes of each meeting and copies shall be provided to the Station Manager, Vice President-Nuclear and the offsite management position responsible for independent/operational event review.

6.5.2 INDEPENDENT/OPERATIONAL EVENT REVIEW (IOER) GROUP

FUNCTION

6.5.2.1 The IOER Group shall function to provide independent review of designated activities in the areas of:

- a. Nuclear power plant operations
- b. Nuclear engineering
- c. Chemistry and radiochemistry
- d. Metallurgy
- e. Instrumentation and control
- f. Radiological safety
- g. Mechanical and electrical engineering
- h. Administrative controls and quality assurance practices
- i. Other appropriate fields associated with the unique characteristics of the nuclear power plant

ADMINISTRATIVE CONTROLS

- c. Surveillance and test activities of safety related equipment.
- d. Security Plan implementation.
- e. Emergency Plan implementation.
- f. Fire Protection Program implementation.
- g. PROCESS CONTROL PROGRAM implementation.
- h. OFFSITE DOSE CALCULATION MANUAL implementation.
- i. Quality Assurance Program for effluent and environmental monitoring, using the guidance in Regulatory Guide 1.21, Revision 1, June 1974 and Regulatory Guide 4.1, Revision 1, April 1975.

6.8.2 Each procedure of 6.8.1 above, except 6.8.1.d, 6.8.1.e, and 6.8.1.f and changes thereto, shall be reviewed and approved by the SNSOC prior to implementation and reviewed periodically as set forth in administrative procedures. Procedure of 6.8.1.d, 6.8.1.e, and 6.8.1.f shall be reviewed and approved as per 6.5.1.6.i, 6.5.1.6.j, and 6.5.1.6.m. SNSOC approval shall be certified in writing by an Assistant Station Manager.

6.8.3 Temporary changes to procedures of 6.8.1 above may be made provided:

- a. The intent of the original procedure is not altered.
- b. The change is approved by two members of the plant supervisory staff, at least one of whom holds a Senior Reactor Operator's License on the unit affected.
- c. The change is documented, reviewed, and approved by the SNSOC within 14 days of implementation. SNSOC approval shall be certified in writing by an Assistant Station Manager.

6.8.4 The following programs shall be established, implemented, and maintained:

a. Primary Coolant Sources Outside Containment

A program to reduce leakage from those portions of systems outside containment that could contain highly radioactive fluids during a serious transient or accident to as low as practical levels. The systems include the recirculation spray, safety injection, chemical and volume control, gas stripper, and hydrogen recombiners. The program shall include the following:

- (i) Preventive maintenance and periodic visual inspection requirements, and
- (ii) Integrated leak test requirements for each system at refueling cycle intervals or less.

ADMINISTRATIVE CONTROLS

6.6 REPORTABLE EVENT ACTION

6.6.1 The following actions shall be taken for REPORTABLE EVENTS:

- a. The Commission shall be notified and a report submitted pursuant to the requirements of Section 50.73 to 10 CFR Part 50, and
- b. Each REPORTABLE EVENT shall be reviewed by the SNSOC and the results of this review shall be submitted to the Vice President-Nuclear and the offsite management position responsible for IOER.

6.7 SAFETY LIMIT VIOLATION

6.7.1 The following actions shall be taken in the event a Safety Limit is violated:

- a. The facility shall be placed in at least HOT STANDBY within one hour.
- b. The NRC Operations Center shall be notified by telephone as soon as possible and in all cases within one hour. The Vice President-Nuclear and the offsite management position responsible for IOER shall be notified within 24 hours.
- c. A Safety Limit Violation Report shall be prepared. The report shall be reviewed by the SNSOC. This report shall describe (1) applicable circumstances preceding the violation, (2) effects of the violation upon facility components, systems or structures, and (3) corrective action taken to prevent recurrence.
- d. The Safety Limit Violation Report shall be submitted to the Commission, the Vice President-Nuclear and the offsite management position responsible for IOER within 14 days of the violation.

6.8 PROCEDURES AND PROGRAMS

6.8.1 Written procedures shall be established, implemented and maintained covering the activities referenced below:

- a. The applicable procedures recommended in Appendix "A" of Regulatory Guide 1.33, Revision 2, February 1978.
- b. Refueling operations.

ADMINISTRATIVE CONTROLS

SPECIAL REPORTS

6.9.2 Special reports shall be submitted to the Regional Administrator, Region II, within the time period specified for each report. These reports shall be submitted pursuant to the requirement of the applicable specification:

- a. Inservice Inspection Reviews, Specification 4.0.5, shall be reported within 90 days of completion.
- b. MODERATOR TEMPERATURE COEFFICIENT. Specification 3.1.1.4.
- c. Deleted.
- d. RADIATION MONITORING INSTRUMENTATION. Specification 3.3.3.1, TABLE 3.3-6 Action 35.
- e. REACTOR COOLANT SYSTEM SPECIFIC ACTIVITY. Specification 3.4.8.
- f. OVERPRESSURE PROTECTION SYSTEMS. Specification 3.4.9.3.
- g. EMERGENCY CORE COOLING SYSTEMS. Specification 3.5.2 and 3.5.3.
- h. SETTLEMENT OF CLASS 1 STRUCTURES. Specification 3.7.12.
- i. GROUND WATER LEVEL - SERVICE WATER RESERVOIR. Specification 3.7.13.
- j. Deleted.
- k. Deleted.
- l. RADIOACTIVE EFFLUENTS. As required by the ODCM.
- m. RADIOLOGICAL ENVIRONMENTAL MONITORING. As required by the ODCM.
- n. SEALED SOURCE CONTAMINATION. Specification 4.7.11.1.3.
- o. REACTOR COOLANT SYSTEM STRUCTURAL INTEGRITY. Specification 4.4.10. For any abnormal degradation of the structural integrity of the reactor vessel or the Reactor Coolant System pressure boundary detected during the performance of Specification 4.4.10, an initial report shall be submitted within 10 days after detection and a detailed report submitted within 90 days after the completion of Specification 4.4.10.
- p. CONTAINMENT STRUCTURAL INTEGRITY. Specification 4.6.1.6. For any abnormal degradation of the containment structure detected during the performance of Specification 4.6.1.6, an initial report shall be submitted within 10 days after completion of Specification 4.6.1.6. A final report, which includes (1) a description of the condition of the liner plate and concrete, (2) inspection procedure, (3) the tolerance on cracking, and (4) the corrective actions taken, shall be submitted within 90 days after the completion of Specification 4.6.1.6.