

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A | L | J | M | F | 1 | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | 5

CONT  
0 1 | REPORT SOURCE | L | 6 | 0 | 5 | 0 | 0 | 0 | 3 | 4 | 8 | 7 | 0 | 8 | 3 | 1 | 8 | 2 | 5 | 0 | 9 | 2 | 7 | 8 | 2 | 9

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)  
0 3 | At 0600 on 8/31/82, while performing FNP-1-STP-123.2 (Control Room  
0 3 | Emergency Ventilation Performance Test), the "B" train emergency air  
0 4 | cleanup system was declared inoperable when it failed to meet the  
0 5 | acceptance criteria. Tech. Spec. 3.7.7 requires the "B" train emergency  
0 6 | air cleanup system to be operable. Tech. Spec. 3.7.7 action statement  
0 7 | requirements were met. Health/Safety of the public was not affected.  
0 8 | (Note: This LER is applicable to both Units 1 and 2 at FNP.)

0 9 | SYSTEM CODE | S | G | 11 | CAUSE CODE | X | 12 | CAUSE SUBCODE | Z | 13 | COMPONENT CODE | F | I | L | T | E | R | 14 | COMP SUBCODE | Z | 15 | VALVE SUBCODE | Z | 16

17 | LER-RO REPORT NUMBER | 8 | 2 | 21 | 22 | SEQUENTIAL REPORT NO. | 0 | 5 | 2 | 24 | 26 | OCCURRENCE CODE | 0 | 3 | 28 | 29 | REPORT TYPE | L | 30 | REVISION NO. | 0 | 32  
ACTION TAKEN | C | 18 | FUTURE ACTION | Z | 19 | EFFECT ON PLANT | Z | 20 | SHUTDOWN METHOD | Z | 21 | HOURS | 0 | 0 | 0 | 22 | ATTACHMENT SUBMITTED | N | 23 | NRC-4 FORM SUB | N | 24 | PRIME COMP. SUPPLIER | A | 25 | COMPONENT MANUFACTURER | A | 2 | 2 | 0 | 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)  
1 0 | This event was due to the failure of the charcoal filter to meet the  
1 1 | efficiency requirements. The charcoal was replaced, the efficiency  
1 2 | verified as being acceptable and the "B" train emergency air cleanup  
1 3 | system was returned to service at 1503 on 8/31/82.

1 4 | FACILITY STATUS | G | 28 | % POWER | 0 | 0 | 0 | 29 | OTHER STATUS | NA | 30 | METHOD OF DISCOVERY | 31 | DISCOVERY DESCRIPTION | Surveillance Test | 32

1 5 | ACTIVITY CONTENT | Z | 33 | AMOUNT OF ACTIVITY | NA | 35 | LOCATION OF RELEASE | NA | 36

1 6 | PERSONNEL EXPOSURES NUMBER | 0 | 0 | 0 | 37 | TYPE | Z | 38 | DESCRIPTION | NA | 39

1 7 | PERSONNEL INJURIES NUMBER | 0 | 0 | 0 | 40 | DESCRIPTION | NA | 41

1 8 | LOSS OF OR DAMAGE TO FACILITY TYPE | Z | 42 | DESCRIPTION | 3210010139 820927 PDR ADOCK 05000348 PDR | 43

1 9 | ISSUED DESCRIPTION | N | 44 | NRC USE ONLY

GPO 91-7-324