(7-77)

LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | A L T M F 2 (2) | 0 0 - 0 0 0 0 0 - 0 0 (3) | 4 1 1 1 1 (4) | (5)

7 8 9 LICENSEE CODE 14 15 LICENSE NUMBER 25 26 LICENSE TYPE 30 57 CAT 58

CON'T

0 1 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 4 (7) | 0 9 0 5 8 2 (8) | 0 9 2 7 8 2 (9)

7 8 60 61 DOCKET NUMBER 68 69 EVENT DATE 74 75 REPORT DATE 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 | At 1600 on 9/5/82, while performing FNP-2-STP-33.0 (Solid State Protec-

0 3 | tion System Reliability Test), the A train auto trip logic for high

0 4 | steam generator differential pressure was declared inoperable when a

0 5 | failed card indication was received by the automatic tester. Tech.

0 6 | Spec. 3.3.2, in part, requires this trip logic to be operable. Tech.

0 7 | Spec. 3.3.2 action statement requirements were met. Health/Safety of

0 8 | the public was not affected.

7 8 9 80

	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP. SUBCODE	VALVE SUBCODE
0 9	I A (11)	E (12)	G (13)	I N S T R U (14)	X (15)	Z (16)
	9 10	11	12	13 18	19	20

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 2	—	0 3 7	/	0 3	L	—	0
	21 22	23	24 26	27	28 29	30	31	32

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
C (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	N (25)	W 1 2 0 (26)
33	34	35	36	37 40	41	42	43	44 47

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 | This event was due to the failure of the universal card (A317). The

1 1 | card was replaced and following the successful completion of FNP-2-STP-

1 2 | 33.0, the A train auto trip logic for high steam generator differential

1 3 | pressure was returned to service at 1615 on 9/5/82.

1 4 |

7 8 9 80

	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
1 5	E (28)	1 0 0 (29)	NA	B (31)	Surveillance Test
	7 8 9	10 12	13 44	45 46	80

	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
1 6	Z (33)	Z (34)	NA	NA
	7 8 9	10 11	44	45 80

	PERSONNEL EXPOSURES NUMBER	TYPE	DESCRIPTION (39)
1 7	0 0 0 (37)	Z (38)	NA
	7 8 9 11	12 13	80

	PERSONNEL INJURIES NUMBER	DESCRIPTION (41)
1 8	0 0 0 (40)	NA
	7 8 9 11	12 80

	LOSS OF OR DAMAGE TO FACILITY TYPE	DESCRIPTION (43)
1 9	Z (42)	NA
	7 8 9 10	80

8210010147 820927
PDR ADOCK 05000348
S PDR

	PUBLICITY ISSUED	DESCRIPTION (45)	NRC USE ONLY
2 0	N (44)	NA	
	7 8 9 10	68 69	80

NAME OF PREPARER W. G. Hairston, III PHONE (205) 899-5156

NRC 21-7-926