

Two North Ninth Street • Allentown, PA 18101 • 215 / 770-5151

September 22, 1982

Mr. Ronald C. Haynes Director, Region I U.S. Nuclear Regulatory Commission 631 Park Avenue King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION LICENSEE EVENT REPORT 82-016/01P ER 100450 FILE 841-23 PLA- 1311

Docket No. 50-387 License No. NPF-14

Dear Mr. Haynes:

This transmission confirms the telephone report of September 21, 1982, by Mr. F.T. Eisenhuth to Mr. B. Bores of your staff. The event which required the prompt reporting is hereby summarized. The turbine building vent monitoring system noble gas monitor was declared out of service on 9/18/82 at 0730, and grab sampling once per 8 hours was initiated. However, the mechanical vacuum pump was in service until 1835 on 9/20/82, contrary to the provisions of Technical Specification Table 3.3.7.11-1, Item 3.a, Action 114. The condition is considered reportable in accordance with Technical Specification 6.9.1.8.a.

2/Keiser

H.W. Keiser Superintendent of Plant-Susquehanna

LAK/cw

cc: Richard C. DeYoung - Director, Office of Inspection and Enforcement
Norman H. Haller - Director, Office of Management and Program Control
U.SN.R.C - Resident Inspector, Susquehanna SES
INPO Records Center - Suite 1500, 1100 Circle 75 Parkway, Atlanta, GA 30339