

# LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1 | N | J | S | G | S | 2 | 0 | 0 | - | 0 | 0 | 0 | 0 | 0 | - | 0 | 0 | 3 | 4 | 1 | 1 | 1 | 1 | 4 | \_\_\_\_\_ | 5  
8 9      14 15      25 26      57 CAT 58

CON'T  
0 1 | REPORT SOURCE | L | 0 | 5 | 0 | 0 | 0 | 3 | 1 | 1 | 7 | 0 | 8 | 2 | 2 | 8 | 2 | B | 0 | 9 | 1 | 6 | 8 | 2 | 9  
8      60 61      68 69      74 75      80

### EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

0 2 | At 1400 hours, August 22, 1982, it was discovered that the seal was cut on the 100'  
0 3 | Elevation Containment Air Lock out door. The air lock was declared inoperable and  
0 4 | Action Statement 3.6.1.3 was entered at 1400 hours. The inner door was operable and  
0 5 | maintained closed. At 1400 hours, August 23, 1982, the inner door was locked closed  
0 6 | in compliance with the Action Statement.  
0 7 |  
0 8 |

0 9 | SYSTEM CODE | CAUSE CODE | CAUSE SUBCODE | COMPONENT CODE | COMP. SUBCODE | VALVE SUBCODE  
9 10      11 12      13 14      15 16      17 18      19 20  
S A      A      B      P E N E T R      A      Z  
11 12 13 14 15 16  
17 | LER RO REPORT NUMBER | EVENT YEAR | SEQUENTIAL REPORT NO. | OCCURRENCE CODE | REPORT TYPE | REVISION NO.  
21 22      23      24 25 26      27      28 29      30      31      32  
8 2      -      0 9 0      /      0 3      L      -      0  
18 | ACTION TAKEN | FUTURE ACTION | EFFECT ON PLANT | SHUTDOWN METHOD | HOURS | ATTACHMENT SUBMITTED | NPRD-4 FORM SUB. | PRIME COMP. SUPPLIER | COMPONENT MANUFACTURER  
33 34      35      36      37      38      39      40      41      42      43      44      45      46      47  
H      F      Z      Z      0 0 0 0      Y      N      N      C 1 3 0  
18 19 20 21 22 23 24 25 26 27 28 29 30 31 32 33 34 35 36 37 38 39 40 41 42 43 44 45 46 47

### CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

1 0 | The seal was damaged by personnel closing the door with excessive force. The seal  
1 1 | was replaced and the door was satisfactorily tested. The air lock was declared  
1 2 | operable and Action Statement 3.6.1.3 was terminated at 1500 hours, August 23, 1982.  
1 3 | Personnel are being trained in proper operation of air lock doors.. Design Change  
1 4 | Requests have been submitted to install snubbers on the doors.

1 5 | FACILITY STATUS | % POWER | OTHER STATUS | METHOD OF DISCOVERY | DISCOVERY DESCRIPTION  
8 9      10 11      12 13      14 15      16 17      18 19  
E      0 8 1      NA      A      Operational Event  
28 29 30 31 32

1 6 | ACTIVITY CONTENT RELEASED OF RELEASE | AMOUNT OF ACTIVITY | LOCATION OF RELEASE  
8 9      10 11      12 13      14 15      16 17  
Z      Z      NA      NA  
33 34 35 36

1 7 | PERSONNEL EXPOSURES NUMBER | TYPE | DESCRIPTION  
8 9      10 11      12 13  
0 0 0      Z      NA  
37 38 39

1 8 | PERSONNEL INJURIES NUMBER | DESCRIPTION  
8 9      10 11      12 13  
0 0 0      NA  
40 41

1 9 | LOSS OF OR DAMAGE TO FACILITY TYPE | DESCRIPTION | \_\_\_\_\_  
8 9      10 11      12 13      14 15      16 17  
Z      NA      8210010239 820916  
PDR ADOCK 05000311 PDR  
42 43

2 0 | PUBLICITY ISSUED | DESCRIPTION | \_\_\_\_\_  
8 9      10 11      12 13      14 15      16 17  
N      NA  
44 45