

ATTACHMENT 1

8210010246 820713
PDR ADDCK 05000338
P PDR

- H. The license is authorized to receive from the Surry Nuclear Power Station Unit Nos. 1 and 2, possess, and store irradiated Surry fuel assemblies containing special nuclear material, enriched to not more than 4.1% by weight U-235 subject to the following conditions:
 - a. Surry fuel assemblies may not be placed in the North Anna Power Station Unit Nos. 1 and 2 reactors.
 - b. Irradiated fuel shipped to North Anna shall have been removed from the Surry reactor no less than 730 days prior to shipment.
 - c. No more than 500 Surry irradiated fuel assemblies shall be received for storage at the North Anna Unit Nos. 1 and 2 spent fuel pool.

- I. This amended license is effective as of the date of issuance and shall expire at midnight, February 18, 2011.

ATTACHMENT 2

E. Physical Protection

The licensee shall fully implement and maintain in effect all provisions of the following Commission approved documents, including amendments and changes made pursuant to the authority of 10 CFR 50.54(p). These approved documents consists of information withheld from public disclosure pursuant to 10 CFR 2.790(d):

- (1) "North Anna Power Station Security Plan", dated January 12, 1979.
- (2) "North Anna Power Station Safeguards Contingency Plan", dated May 1, 1980, submitted as a revised Chapter 8 to the Physical Security Plan, and submitted pursuant to 10 CFR 73.40. The Contingency Plan shall be fully implemented, in accordance with 10 CFR 73.40(b), within 30 days of this approved by the Commission.
- (3) "North Anna Power Station Guard Training and Qualification Plan", dated September 15, 1980. This Plan shall be fully implemented in accordance with 10 CFR 73.55(b)(4), within 60 days of this approval by the Commission. All security personnel shall be qualified as required in the above plans within two years of this approval.

F. Deleted.

G. If VEPCO plans to remove or to make significant changes in the normal operation of equipment that controls the amount of radioactivity in effluents from the North Anna Power Station, the NRC shall be notified in writing regardless of whether the change affects the amount of radioactivity in the effluents.

H. VEPCO shall report any violations of the requirements contained in Section 2, Items C.(3) through C.(21), E, F and G of this license within 24 hours by telephone and confirmed by telegram, mailgram, or facsimile transmission to the Director of the Regional Office, or his designate, no later than the first working day following the violation, with a written followup report within 14 days.

I. The license is authorized to receive from the Surry Nuclear Power Station Unit Nos. 1 and 2, possess, and store irradiated Surry fuel assemblies containing special nuclear material, enriched to not more than 4.1% by weight U-235 subject to the following conditions:

- a. Surry fuel assemblies may not be placed in the North Anna Power Station Unit Nos. 1 and 2 reactors.
- b. Irradiated fuel shipped to North Anna shall have been removed from the Surry reactor no less than 730 days prior to shipment.
- c. No more than 500 Surry irradiated fuel assemblies shall be received for storage at the North Anna Unit Nos. 1 and 2 spent fuel pool.

J. This license is effective as of the date of issuance and shall expire February 19, 2011.

ATTACHMENT 3