

ATTACHMENT 2
LICENSE AMENDMENT APPLICATION, LCR 93-23, NLR 94041
FACILITY OPERATING LICENSE NPF-57
HOPE CREEK GENERATING STATION
DOCKET NO. 50-354

TECHNICAL SPECIFICATION PAGES WITH PEN AND INK CHANGES

The following Technical Specifications for
Facility Operating License No. NPF-57 are affected
by this license amendment request:

<u>Technical Specification</u>	<u>Page</u>
3.8.1.1.b.2	3/4 8-1
4.8.1.1.2	3/4 8-7 thru 3/4 8-9

3/4.8 ELECTRICAL POWER SYSTEMS

3/4.8.1 A.C. SOURCES

A.C. SOURCES - OPERATING

LIMITING CONDITION FOR OPERATION

3.8.1.1 As a minimum, the following A.C. electrical power sources shall be OPERABLE:

- a. Two physically independent circuits between the offsite transmission network and the onsite Class 1E distribution system, and
- b. Four separate and independent diesel generators, each with:
 1. A separate fuel oil day tank containing a minimum of 200 gallons of fuel,
 2. A separate fuel storage system consisting of two storage tanks containing a minimum of 48,800 gallons of fuel,**and
 3. A separate fuel transfer pump for each storage tank.

APPLICABILITY: OPERATIONAL CONDITIONS 1, 2, and 3.

ACTION:

- a. With one offsite circuit of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. If any diesel generator has not been successfully tested within the past 24 hours, demonstrate its OPERABILITY by performing Surveillance Requirement 4.8.1.1.2.a.4 and 4.8.1.1.2.a.5 for each such diesel generator separately within 24 hours. Restore the inoperable offsite circuit to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- b. With one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the above required A.C. offsite sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and at least once per 8 hours thereafter. If the diesel generator became inoperable due to any cause other than preplanned preventive maintenance or testing, demonstrate the OPERABILITY of the remaining diesel generators by performing Surveillance Requirement 4.8.1.1.2.a.4 and 4.8.1.1.2.a.5 separately for each diesel generator within 24 hours*; restore the inoperable diesel generator to OPERABLE status within 72 hours or be in at least HOT SHUTDOWN within the next 12 hours and in COLD SHUTDOWN within the following 24 hours.
- c. With one offsite circuit of the above required A.C. sources and one diesel generator of the above required A.C. electrical power sources inoperable, demonstrate the OPERABILITY of the remaining A.C. sources by performing Surveillance Requirement 4.8.1.1.1.a within 1 hour and

INSERT
FROM
NEXT
PAGE

*This test is required to be completed regardless of when the inoperable diesel generator is restored to OPERABILITY.

INSERT FOR PAGE 3/4 8-1:

** With the fuel storage system of one or more diesel generators containing less than 48,800 gallons of fuel, but greater than 44,709 gallons, the associated diesel generator is considered operable for up to 48 hours to allow for fuel replenishment.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

5. Verifying that on an ECCS actuation test signal, without loss of offsite power, the diesel generator starts on the auto-start signal and operates on standby for greater than or equal to 5 minutes. The generator voltage and frequency shall be 4160 ± 420 volts and 60 ± 1.2 Hz within 10 seconds after the auto-start signal; the steady state generator voltage and frequency shall be maintained within these limits during this test.
6. Simulating a loss of offsite power in conjunction with an ECCS actuation test signal, and:
 - a) Verifying loss of power is detected and deenergization of the emergency busses and load shedding from the emergency busses.
 - b) Verifying the diesel generator starts* on the auto-start signal, energizes the emergency busses with permanently connected loads within 10 seconds after receipt of the start signal, energizes the autoconnected shutdown loads through the load sequencer and operates for greater than or equal to 5 minutes while its generator is loaded with the emergency loads. After energization, the steady state voltage and frequency of the emergency busses shall be maintained at 4160 ± 420 volts and 60 ± 1.2 Hz during this test.
7. Verifying that all automatic diesel generator trips, except engine overspeed, generator differential current, generator overcurrent, bus differential current and low lube oil pressure are automatically bypassed upon loss of voltage on the emergency bus concurrent with an ECCS actuation signal.#

8. DELETED

8. Verifying the diesel generator operates for at least 24 hours. During the first 22 hours of this test, the diesel generator shall be loaded to between 4300 and 4400 kW** and during the remaining 2 hours of this test, the diesel generator shall be loaded to between 4800 and 4873 kW. The generator voltage and

*This diesel generator start (10 sec) and subsequent loading (130 sec) from ambient conditions may be preceded by an engine prelube period and/or other warmup procedures recommended by the manufacturer so that mechanical stress and wear on the diesel engine is minimized.

**This band is meant as guidance to avoid routine overloading of the engine. Loads in excess of this band shall not invalidate the test; the loads; however, shall not be less than 4300 kW nor greater than 4873 kW.

#Generator differential current, generator overcurrent, and bus differential current is two-out-of-three logic and low lube oil pressure is two-out-of-four logic.

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

frequency shall be 4160 ± 420 volts and 60 ± 1.2 Hz within 10 seconds after the start signal; the steady state generator voltage and frequency shall be maintained within these limits during this test. Within 5 minutes after completing this 24-hour test, perform Surveillance Requirement 4.8.1.1.2.h.4.b). **

9. Verifying that the auto-connected loads to each diesel generator do not exceed the continuous rating of 4430 kW.
10. Verifying the diesel generator's capability to:
 - a) Synchronize with the offsite power source while the generator is loaded with its emergency loads upon a simulated restoration of offsite power,
 - b) Transfer its loads to the offsite power source,
 - c) Be restored to its standby status, and
 - d) Diesel generator circuit breaker is open.
11. Verifying that with the diesel generator operating in a test mode and connected to its bus, a simulated ECCS actuation signal overrides the test mode by (1) returning the diesel generator to standby operation, and (2) automatically energizes the emergency loads with offsite power.
12. Verifying that the fuel oil transfer pump transfers fuel oil from each fuel storage tank to the day tank of each diesel via the installed cross connection lines.
13. Verifying that the automatic load sequence timer is OPERABLE with the interval between each load block within $\pm 10\%$ of its design interval.
14. Verifying that the following diesel generator lockout features prevent diesel generator starting only when required:
 - a) Engine overspeed, generator differential, and low lube oil pressure (regular lockout relay, (1) 86R).
 - b) Backup generator differential and generator overcurrent (backup lockout relay, (1) 86B)
 - c) Generator ground and lockout relays-regular, backup and test, energized (breaker failure lockout relay, (1) 86F)

**If Surveillance Requirement 4.8.1.1.2.h.4.b) is not satisfactorily completed, it is not necessary to repeat the preceding 24 hour test. Instead, the diesel generator may be operated at between 4300 kw and 4400 kw for one hour or until operating temperature has stabilized prior to repeating Surveillance Requirement 4.8.1.1.2.h.4.b).

ELECTRICAL POWER SYSTEMS

SURVEILLANCE REQUIREMENTS (Continued)

- i. At least once per 10 years or after any modifications which could affect diesel generator interdependence by starting all diesel generators simultaneously, during shutdown, and verifying that all diesel generators accelerate to at least 514 rpm in less than or equal to 10 seconds.
- j. At least once per 10 years by:
1. Draining each fuel oil storage tank, removing the accumulated sediment and cleaning the tank using a sodium hypochlorite solution or equivalent, and
 2. Performing a pressure test of those portions of the diesel fuel oil system designed to Section III, subsection ND of the ASME Code in accordance with ASME Code Section XI Article IWD-5000.

INSERT FROM
NEXT PAGE

4.8.1.1.3 Reports - All diesel generator failures, valid or non-valid, shall be reported to the Commission within 30 days pursuant to Specification 6.9.2. Reports of diesel generator failures shall include the information recommended in Regulatory Position C.3.b of Regulatory Guide 1.108, Revision 1, August 1977. If the number of failures in the last 100 valid tests, on a per nuclear unit basis, is greater than or equal to 7, the report shall be supplemented to include the additional information recommended in Regulatory Position C.3.b of Regulatory Guide 1.108, Revision 1, August 1977.

4.8.1.1.4 The buried fuel oil transfer piping's cathodic protection system shall be demonstrated OPERABLE at least once per 2 months and at least once per year by subjecting the cathodic protection system to a performance test.

For any start of a diesel generator, the diesel must be loaded in accordance with the manufacturer's recommendations.

This band is meant as guidance to avoid routine overloading of the engine. Loads in excess of this band shall not invalidate the test; the loads; however, shall not be less than 4300 kW nor greater than 4873 kW.

INSERT FOR PAGE 3/4 8-9:

k. At least once per refueling cycle# by:

1. Verifying the diesel generator operates for at least 24 hours. During the first 22 hours of this test, the diesel generator shall be loaded to between 4300 and 4400 kW## and during the remaining 2 hours of this test, the diesel generator shall be loaded to between 4800 and 4873 kW. The generator voltage and frequency shall be 4160 ± 420 volts and 60 ± 1.2 Hz within 10 seconds after the start signal; the steady state generator voltage and frequency shall be maintained within these limits during the test.
2. Within 5 minutes after completing 4.8.1.1.2.k.1, simulate a loss of offsite power by itself and verify that the diesel generator starts on the auto-start signal, energizes the emergency busses with permanently connected loads within 10 seconds after receipt of the start signal, energizes the autoconnected shutdown loads through the load sequencer and operates for greater than or equal to 5 minutes while its generator is loaded with the shutdown loads. After energization, the steady state voltage and frequency of the emergency busses shall be maintained at 4160 ± 420 volts and 60 ± 1.2 Hz during the test.

- OR -

Operate the diesel generator between 4300 kW and 4400 kW for one hour or until operating temperature has stabilized. Within 5 minutes of shutting down the diesel generator, simulate a loss of offsite power by itself and verify that the diesel generator starts on the auto-start signal, energizes the emergency busses with permanently connected loads within 10 seconds after receipt of the start signal, energizes the autoconnected shutdown loads through the load sequencer and operates for greater than or equal to 5 minutes while its generator is loaded with the shutdown loads. After energization, the steady state voltage and frequency of the emergency busses shall be maintained at 4160 ± 420 volts and 60 ± 1.2 Hz during the test.