



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

September 22, 1982

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-015/03L-0
ER 100450 FILE 841-23
PLA- 1310

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-015/03L-0. This event was determined to be reportable, per Technical Specification 6.9.1.9.c, in that the Spray Pond level and temperature were not monitored from July 27, 1982 to August 25, 1982.

H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/cw

Attachment

cc: A. Schwencer
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Sr. Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8210010393 820922
PDR ADOCK 05000387
S PDR

IE22