



UNITED STATES  
 NUCLEAR REGULATORY COMMISSION  
 REGION III  
 799 ROOSEVELT ROAD  
 GLEN ELLYN, ILLINOIS 60137

(2 copies)

✓	GEN	B
✓	REG	
✓	FILE	JB
✓	OIL	6/3/91
	MIP	

MAY 17 1991

Docket No. 50-461

Illinois Power Company  
 ATTN: Mr. J. S. Perry  
 Vice President  
 Clinton Power Station  
 Mail Code V-275  
 Post Office Box 678  
 Clinton, IL 61727

Gentlemen:

SUBJECT: NRC INSPECTION REPORT NO. 50-461/91007(DRP)

This refers to the routine safety inspection conducted by Messrs. P. G. Brochman, J. F. Schapker, and F. L. Brush of this office from March 26 through April 29, 1991, of activities at Clinton Power Station, authorized by NRC Operating Licensee No. NPF-62, and to the discussion of our findings with you and others of your staff at the conclusion of the inspection.

The enclosed copy of our inspection report identifies areas examined during the inspection. Within these areas, the inspection consisted of a selective examination of procedures and representative records, observations, and interviews with personnel.

No violations of NRC requirements were identified during the course of this inspection. However, we are requesting that your evaluation of the impact on the design basis for control room habitability, due to the presence of a tank of anhydrous ammonia or other hazardous chemicals stored at the Shield Soil Service Company in DeWitt, Illinois, be forwarded to this office within 60 days of receipt of this letter. This issue is discussed further in inspection report paragraph 5 and is tracked as unresolved item 461/91007-01(DRP).

In accordance with 10 CFR 2.790 of the Commission's regulations, a copy of this letter and the enclosed inspection report will be placed in the NRC Public Document Room.

9404120059 910517  
 PDR ADOCK 05000461  
 G PDR


110021

HOOS

MAY 17 1991

We will gladly discuss any questions you have concerning this inspection.

Sincerely,



Edward G. Greenman, Director  
Division of Reactor Projects

Enclosure: Inspection Report  
No. 50-461/91007(DRP)

cc w/enclosure:

J. Cook, Manager - Clinton Power Station

F. Spangenberg, III, Manager -  
Licensing and Safety

DCD/DCB (RIDS)

Licensing Fee Management Branch

Clinton SRI

A. T. Gody, Jr., NRR LPM

J. McCaffrey, Chief, Public  
Utilities Division

D. Rosenblatt, Governor's  
Office of Consumer Services

S. Zabel, Esquire, Shiff,  
Hardin, & Waite

Chairman, DeWitt County Board

Illinois Department of

Nuclear Safety

Perry SRI

R. A. Hasse, RIII