

LICENSEE EVENT REPORT

CONTROL BLOCK: \_\_\_\_\_ (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 N C B E P 2 00-0000-0003 411111 4 5  
7 8 9 14 15 25 26 30 57 CAT 58

CON'T  
01 L 6050-0324 70826828 092482 9  
7 8 60 61 68 69 74 75 80

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10

02 A technical review of fire protection CO2 systems surveillance procedures indicated  
03 that the CO2 storage bottle weighing device, utilized for operability testing of the  
04 HPCI room and Control Building CO2 systems, had not undergone periodic calibration to  
05 assure its accuracy. These systems were declared inoperable until the surveillance  
06 was satisfactorily performed. This event did not affect the health and safety of the  
07 public.

08 Technical Specifications 3.7.7.3, 6.9.1.9c 80

09 A B 11 D 12 Z 13 X X X X X X 14 Z 15 Z 16  
7 8 9 10 11 12 13 18 19 20  
17 LER/RO REPORT NUMBER 8 2 1 0 7 0 3 L 0  
21 22 23 24 26 27 28 29 30 31 32  
ACTION TAKEN FUTURE ACTION EFFECT ON PLANT SHUTDOWN METHOD HOURS ATTACHMENT SUBMITTED NPRD-4 FORM SUB. PRIME COMP. SUPPLIER COMPONENT MANUFACTURER  
G 18 X 19 Z 20 Z 21 0 0 0 0 N 23 N 24 25 26

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS 27

10 This occurred due to a failure to recognize the need for accuracy restraints on the  
11 weighing device. An applicable calibration procedure and periodicity have been im-  
12 plemented to ensure the device has been properly calibrated. The subject fire protec-  
13 tion surveillances have been satisfactorily performed. Involved personnel have been  
14 counseled to be aware of plant equipment calibration requirements.

15 H 28 0 0 0 29 NA C 31 Procedure Technical Review 32  
7 8 9 10 12 13 44 45 46

16 Z 33 Z 34 NA NA 36  
7 8 9 10 11 44 45

17 0 0 0 37 Z 38 NA 39  
7 8 9 10 11 12 13

18 0 0 0 40 NA 41  
7 8 9 10 11 12

19 Z 42 NA 43  
7 8 9 10

20 N 44 B210010475 820924 PDR ADOCK 05000324 S PDR  
7 8 9 10 68 69 80

NAME OF PREPARER M. J. PASTVA, JR.

PHONE: 919-457-9521