

T-1137

NUCLEAR REGULATORY COMMISSION

ORIGINAL

In the Matter of: ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
METAL COMPONENTS WORKING GROUP

DATE: September 30, 1982 PAGES: 1 - 268
AT: Washington, D. C.

TRO4

ALDERSON  REPORTING

400 Virginia Ave., S.W. Washington, D. C. 20024

Telephone: (202) 554-2345

8210040080 820930
PDR ACRS
T-1137 PDR

1 NUCLEAR REGULATORY COMMISSION
 2 ADVISORY COMMITTEE ON REACTOR SAFEGUARDS
 3 - - -
 4 METAL COMPONENTS WORKING GROUP
 5 - - -

6 Room 1167
 7 1717 H Street, N.W.
 8 Washington, D.C.
 9 September 30, 1982

10 The Working Group met, pursuant to notice, at
 11 8:30 a.m., MIKE BENDER (Chairman of the Working Group)
 12 presiding.

13 PRESENT:

- 14 ACRS MEMBERS:
 15 M. BENDER (Chairman)
 16 P. SHEWMON
 17 D. WARD
 18 F. REMICK

- 19 CONSULTANTS:
 20 I. CATTON
 21 Z. ZUDANS
 22 MR. ABBOTT
 23 MR. BINFORD
 24 MR. KOITS
 25 MR. THEOFANOUS

1 CONSULTANTS (Continued):

2 MR. WECHSLER

3 MR. IRWIN

4 ALSO PRESENT:

5 BILL BOCK, ACRS Fellow

6 DESIGNATED FEDERAL EMPLOYEE:

7 AL IGNE

8

9

* * *

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 A transcript of the meeting is being kept, and
2 it is requested that each speaker first identify himself
3 or herself and speak with sufficient clarity and volume
4 so that he or she can be readily heard. We have not
5 received either written or requests for oral statements
6 during this meeting, so no time has been set aside.
7 However, if there is anyone who wishes to make comments,
8 if you will let Mr. Igne know what it is you would like
9 to make a comment about and we can work out some
10 arrangements and provide some time, we will certainly do
11 so.

12 I wanted to add a few thoughts about our
13 situation at the moment, partially to get the working
14 group up to speed and partially to help the staff in its
15 organization and presentation this morning.

16 We have received what I would presume to be
17 near to a position from the regulatory staff on a
18 screening procedure for deciding when thermal shock is a
19 problem that needs special regulatory attention. I
20 don't know whether that means regulatory action. And
21 hopefully, all of the consultants and members of the
22 subcommittee have had a chance to take a look at what
23 has been proposed and we will be able to make
24 intelligent comments on the presentation or what's in
25 the written material as it is presented.

1 Steve Hanauer has offered to try to provide a
2 coherent discussion of it, and we have set aside a
3 couple of hours for his presentation. And hopefully, he
4 will tolerate some questions, but if we work on it too
5 hard we may not hear the whole story, so I would like to
6 encourage you to address your questions to him in the
7 line of trying to be sure you understand what he is
8 saying rather than trying to digress into areas that may
9 need to be taken up later on today.

10 I have sent out for the working group's
11 consideration what amounts to a draft discussion of the
12 issue as I understood it, with corrections for various
13 members of the working group and particularly
14 consultants who have suggested things that should be
15 included or alterations in the way words should be said.

16 I don't offer that discussion as either a
17 highly professional technical document nor a literary
18 masterpiece. It was only intended to try to get
19 together as well as I could in the a short time the
20 information that had been presented, and offer some kind
21 of interpretation.

22 I would again urge people that have strong
23 feelings about improving it to provide alternative
24 discussion material that could be included in the
25 document or added as an appendix. Any way which makes

1 any sense.

2 A lot of the work was done by Bill Bock, and I
3 appreciate his diligent effort to respond to a lot of
4 recommendations from a lot of different people. The
5 working group has not yet reached the position on what
6 probably are the important questions we asked, and I
7 think I would like to run down through those that I can
8 think of today and see if they represent a reasonable
9 list of things which ultimately ought to provide some
10 kind of -- we ultimately ought to provide some kind of
11 position on.

12 The first is whether the staff's screening
13 criteria, as it is presented, is acceptable. The
14 criteria for judging those screening criteria probably
15 are: Do they provide adequate time to do something
16 about the issue, if it is important to do something
17 about it. Whether they are exactly the right screening
18 criteria clearly is an important part of that issue.
19 And so it should be kept in mind when you're listening
20 to the staff presentation.

21 The second point that I believe we ought to
22 make sure we have a position on is the question of what
23 the licensees and applicants should be doing about
24 pressurized thermal shock. And the things that come to
25 mind are the question of whether the training program is

1 adequate, whether the non-destructive examination
2 program is a useful one and can be effective; whether we
3 know about the materials' properties and materials in
4 question to be able to make a judgment about them;
5 whether we understand the neutron damage question well
6 enough to be able to relate it to the materials'
7 properties; do we understand the transients that are of
8 concern, and have we identified those that represent the
9 important issues, and do we accept the operational
10 strategy which goes with the safety judgments.

11 By operational strategy, I mean the
12 capabilities of the operators in terms of being able to
13 diagnose the accident. Their ability to respond in a
14 timely way; if they have diagnosed the accident
15 properly, and whether we accept the circumstances which
16 require them to think not only about when they need to
17 be pressurized, but also, when they need to keep the
18 system pressurized. And the fact that that is a
19 somewhat contradictory kind of operating requirement is
20 something we need to give some thought to.

21 In addition, we need to think more, I believe,
22 about the matter of whether there is enough time
23 involved in this program which the NRC staff is
24 presenting to the Commissioners to get the results which
25 are needed to have a position on the safety of these

1 vessels. We may not have heard enough about what's
2 going on to make that judgment, but if it is necessary
3 to do further research and development work we ought to
4 have some understanding about whether they can
5 accomplish what they claim they are going to accomplish
6 within the specified time.

7 And lastly, I suggest we think a little bit
8 about whether the systems that are licensed and
9 operating have enough diagnostic instrumentation to be
10 able to judge the seriousness of a problem from the
11 indications which have been available to the operators.
12 And if there is not enough diagnostic instrumentation,
13 then it may be appropriate to suggest what needs to be
14 done to provide for additional instrumentation.

15 The last point I would like to make has to do
16 really with whether the story which is being presented
17 is really understandable by anybody except the
18 technicians that developed the story. And one of the
19 things that was suggested was to try to use Pellini's
20 fracture analysis approach as a more understandable way
21 of presenting the story to people who were not steeped
22 in technological issues.

23 I think some comments on that approach, and
24 Combustion Engineering people offered it as their way of
25 telling the story. Whether it's a good one or not I

1 don't know. Dr. Zudans has some commentary on it. You
2 might want to think some about whether that is an
3 approach that is more understandable than one we are
4 likely to hear today. I don't put it out as necessarily
5 the best way to present the story.

6 That is essentially all of the thoughts I have
7 on the subject matter. I would like now to ask the
8 working group members and the ACRS members, including
9 Dr. Remick who has just joined our sterling cast, and
10 Mr. Ward who has showed up occasionally --

11 (Laughter.)

12 -- whether they have any additional thoughts on this
13 subject. Why don't we just start around the table?

14 MR. AXTMANN: I will wait until the end of the
15 day.

16 MR. SHEWMON: I have nothing now.

17 MR. REMICK: Not now, thank you.

18 MR. KOUTS: I think we might ask what should
19 -- you say what should the licensees and applicants do
20 in light of the problem and what we know about it and
21 what we don't know about it. And I wonder if we
22 shouldn't add: what should the NRC do.

23 MR. BENDER: Well, that is certainly an
24 important point, indeed. Thank you.

25 If there is nothing else, I think the order in

1 which we have planned this agenda was to turn the
2 meeting over to the NRC staff for what amounts to about
3 three hours. So, Dr. Hanauer has the stage.

4 MR. HANAUER: Thank you, Mr. Chairman. A year
5 ago, we told the ACRS and the Commission that there was
6 no immediate need for changes or shutdowns of plants,
7 and asked for a year in which to address this problem.
8 And for the past year, we and the industry have been
9 involved in an intensive, multi-disciplinary study of
10 the pressurized thermal shock problem, whose initial
11 culmination is the report, a draft of which you received
12 a month or so ago.

13 The report which you received was the draft
14 which we sent to our colleagues in the NRC, and both our
15 colleagues and their comments and questions on our own
16 continuing study have produced a large number of
17 important but non-essential changes in this report, for
18 which a new edition is due on my boss's desk in a day or
19 two.

20 So that what you have represents a lot of
21 thought and has been discussed with a lot of people but
22 is not the NRC staff's management's position on
23 pressurized thermal shock. We agreed with your
24 subcommittee and the staff to have a dialogue at this
25 stage in order to discuss at some length and with some

1 freedom the various technical issues involved, of which
2 there are a large number, so that what you see is Steve
3 Hanauer and a bunch of his colleagues' proposal to Mr.
4 Denton, to Mr. Stello, for discussion by peers, by the
5 public, by the ACRS. And eventually, will result in
6 some recommendation to the Commission.

7 The exact context of this is still being
8 discussed by lawyers and so on. Whether it will result
9 in rulemaking or some other piece of legal paper is not
10 yet decided and will be decided, I suspect, by a group
11 of people. No single one of them is in this room at the
12 present time.

13 So that what I would like to present you with
14 is a technical discussion of this difficult and
15 disorderly problem. Our first analysis which you heard
16 a year or so ago was an attempt at generic review of the
17 pressurized thermal shock problem, based on what we knew
18 a little over a year ago.

19 And what we did then was to pick the eight
20 plants which seemed to be, at that time, based upon what
21 we knew, the lead plants for each of the three
22 manufacturers of nuclear steam supply designs, and we
23 asked them in a period of some few months to analyze the
24 pressurized thermal shock problem, the transients, the
25 vessel properties, the integration of these two into

1 some kind of analysis and to make us recommendations
2 regarding where they viewed the safety of the plant and
3 the justification for the continued operation.

4 These plants have, in fact, -- the owners of
5 these plants have, in fact, done this, and we have eight
6 reports. In every case, the plant owners at least
7 started, and most of them finished, with a traditional
8 safety analysis approach to this problem. They selected
9 a few relatively severe pressurized thermal shock
10 sequences. They calculated the response of the plants
11 to these sequences in some detail, using the kinds of
12 evaluation models that we traditionally use around here,
13 and concluded that the plants were okay today but that
14 in a few years some of these plants might not be okay.

15 Not surprisingly, some of the technical
16 material which we received in the course of this
17 disagreed with each other, partly because some of the
18 reporting was generic and some of the reporting was
19 plant-specific. And this was perhaps our first serious
20 insight as a result of this process, which is that
21 generic analysis will get you just so far and in order
22 to decide the risk or the situation or the necessary
23 remedies for any given plant, a plant-specific analysis
24 is required.

25 And whereas a year ago we were looking for a

1 fairly simple prescription that would establish whether
2 a plant had to shut down or anneal its vessel, or
3 whether continued operation was allowed, one of the
4 results of this past year's study is that no such simple
5 prescription has, in fact, emerged. And that what we
6 are proposing instead is a simple prescription to be
7 used for screening those plants for which a
8 plant-specific analysis is required and necessary in
9 order to provide the justification for continued
10 operation, or in order to guide both the owner and NRC
11 in deciding what remedial measures are necessary.

12 So, the slide from generic analyses to
13 plant-specific analysis is the first lesson of the last
14 year's work. The second lesson of the last year's work
15 is that these design basis evaluation model, highly
16 conservative, over simplified sequences analyzed in this
17 conservative, over-simplified way did not, in fact,
18 address the real problem in the way in which we cite.

19 I am not imputing bad faith or anything like
20 that; that is how we have traditionally always done our
21 work, but in fact, the results in my opinion, just as
22 many such results, tended to obscure rather than
23 illuminate the problem.

24 The grandfather of such analysis is the
25 emergency core cooling requirements, about which a great

1 deal has been said. But I think it is now clear to me,
2 and I think to many other people as well, that the
3 highly schematic, highly simplified, highly conservative
4 emergency core cooling approach which we approved a
5 dozen years ago is not today the way to optimize the use
6 of resources, or even to get the best safety. I will
7 give you one example from emergency core cooling which
8 most of the people in this room are familiar with.

9 It is required to calculate the behavior of
10 the plant to a loss of coolant accident with the
11 assumption that the off-site power is not available.
12 And so, we saw some designs in response to these rules
13 in which the off-site power, even if it was on, was
14 incapable because the startup transformer was too small
15 for powering all of the trains of the emergency core
16 cooling system.

17 It's a little bit like sailboard handicapping
18 rules. We had plants built to match the acceptance
19 criteria, and where we had over-simplified them, the
20 plants became over simplified and did not adequately
21 make use of cost-effective ways to improve safety.

22 It is my believe and the belief of my
23 colleagues who have helped me write this report that
24 this is also true of pressurized thermal shock. And we
25 have, therefore, not used the traditional design basis

1 approach.

2 Now, the staff is not monolithic on this, and
3 so we have found this very difficult. This is one of
4 our first forays into the use of probablistic schemes,
5 and application of the safety goal in trying to decide
6 what level of safety should be provided, and there are
7 gaps in the reasoning.

8 There are places where the scientific basis of
9 what we are doing is less than adequate, but it has
10 always been that way. And I will try and tell you a
11 connected story in which we will expose to you the
12 places where we used science and the places where we
13 used judgment and conjecture.

14 The outline of what I'm going to tell you
15 today is shown here.

16 (Slide.)

17 I have already talked some about the general
18 approach which we used, and I will talk about it some
19 more. This general approach involves the evaluation of
20 the over-cooling transients which have already occurred,
21 and the deriving of initial screening criteria from this
22 actual experience.

23 We then used probabilistic techniques to find
24 out how conservative the screening criterion is and
25 deduced from it our recommendations, and from the gaps

1 that we found in the reasoning recommendations for
2 future work and for the regulatory approach for
3 pressurized thermal shock.

4 Now, this approach will be seen to be both
5 deterministic and probabilistic. The deterministic
6 approach, as usual, has the difficulty that it is very
7 hard to know how conservative it is, and that it is very
8 hard to put realism into it, although we have made some
9 serious attempt to do so.

10 The probabilistic approach is beset by the
11 usual difficulties of probabilistic approaches in the
12 present state of the art. Completeness, realism,
13 adequacy of the input data, the stuff that has been
14 debated around this table many times. And so, we have
15 put these two things together with the result that you
16 have seen and which I will discuss.

17 (Slide.)

18 The overall topology of the problem I have
19 tried to indicate in this viewgraph. Here is the
20 probability of something worse than the abscissa
21 occurring. And I have used the temperature as a measure
22 of the severity of over cooling. Now, this is an
23 over-simplification. There are lots of
24 over-simplifications in this business.

25 In fact, the temperature rate, the pressure

1 and the characteristics of the material are all central
2 variables which have to be considered, and so this
3 considers a part of the problem; namely, the
4 transients. And since lower temperatures are more
5 severe, the curve is monotonic in this way. This is an
6 integral cumulative probability or frequency
7 distribution at some temperature. The probability or
8 frequency of getting anything worse than this
9 temperature, a lower temperature, is given by the
10 intersection of these curves, and there is some
11 unspecified probability or frequency scale.

12 Now, I first plot here the over-cooling
13 transients that have actually been experienced, and this
14 is some kind of a distribution. And we have used this
15 distribution, as I will show you, to derive in a
16 substantially unscientific way, a screening criteria to
17 use. We also realized, however, that experience stops
18 at something substantially over 200 degrees, but that
19 much more severe transients are possible. And at least
20 one such has been reported in Europe about which we know
21 not enough and about which we hope to find out next week
22 in the discussions with the German RSK.

23 We, therefore, show schematically a
24 probabilistic approach in the usual way, where we
25 consider initiating events, safety functions,

1 probabilities of success or failure of the safety
2 functions and consequences, and we draw then a
3 probability consequence curve in the usual way, except
4 that severity goes to the left, so it slants the way in
5 which you don't expect from cumulative distributions.

6 And this I call for shorthand the PRA. Up at
7 this end, the PRA should satisfactorily agree with the
8 experience. Down at this end, we have no experience so
9 in the tail of the curve we used the probabilistic
10 results because that is all we have.

11 In deriving these curves we find from time to
12 time sequences which are apparently outliers. If they
13 turn out not to be outliers, if they turn out to be
14 real, then the curve has to be distorted to include the
15 effect of the sequences.

16 For a while, we had the sequence of the week
17 which determined the aspect of the discussion of the
18 week with one or another owner's group and which
19 constituted perhaps, if you were excitable, the crisis
20 of the week in the regulatory staff. But we have
21 surmounted this, and we now have a curve which has some
22 substance to it, although by no means is this adequately
23 fully delineated.

24 You see how far this is from the concept of
25 the design basis accident and the evaluation model,

1 simplified conservative analysis. The analyses here are
2 all intended to be realistic, and the level of safety or
3 degree of conservatism is intended to be provided by how
4 far down you go on this tail, and what you choose to be
5 the probability of what you don't provide for.

6 Now, this is imperfectly provided in the
7 present scheme, and so we have, in fact, provided at
8 least one substantial quantified conservatism in how we
9 reckon up the actual state of a given reactor vessel for
10 comparison with our screening criteria.

11 Furthermore, in the present state of the art
12 we really don't believe this curve very well, and the
13 people who have done the calculations have told us that
14 there is plus or minus at least two orders of magnitude
15 uncertainty in the frequencies or probabilities
16 associated with the vertical location of the curve on
17 this diagram.

18 Such being the case, we have not done what we
19 would do if we had a better curve. If we had a better
20 curve and a well-defined safety goal, we would simply
21 plot the safety goal in probability space. Where it
22 crossed the curve would give us the answer in severity
23 space, and that would be the regulatory result.

24 Of course, we don't have that.

25

1 MR. BENDER: Steve, this seems like the right
2 time to ask this question on the matter of the
3 uncertainty in that curve. It probably varies all along
4 the curve. As you know more about what is up at the top
5 part of it than you do down at the bottom, when you
6 describe the matter of two orders of magnitude
7 uncertainty, how do you perceive it? Is it that
8 uncertainty at the tail end or is it in the middle? Or
9 is it all along the curve?

10 MR. HANAUER: Well, there are two major
11 components of the uncertainty. One is in the
12 transients. The other is in the response of the vessel
13 to these transients. The people who calculate the
14 response of the vessel, say, two orders of magnitude
15 plus or minus uncertainty in that calculation, and they
16 have told us -- I will ask Jack Stroisnider, who makes
17 these speeches to me about not misusing his
18 calculations, is it relatively uniform, as far as we
19 know?

20 MR. STROSNIDER: Yes, the vessel response, I
21 think, is uniform along the whole line, the whole curve.

22 MR. BENDER: We will leave it that way for a
23 while.

24 MR. HANAUER: Well, let me complete the
25 answer, as far as transients are concerned. The

1 uncertainty arises as much from not knowing what is
2 going to happen as from the uncertainty in how you
3 calculate it. Neither of these is two orders of
4 magnitude. If you draw your trees correctly, then what
5 might happen is represented by the various branches of
6 the trees, and then the uncertainty is calculating the
7 probability that the operator does not do something or
8 the pump does not work or whatever it is.

9 In general, the operator response is very
10 difficult to predict, and the machinery response is
11 somewhat easier, and in general these uncertainties are
12 somewhat less than two orders of magnitude.

13 MR. BENDER: Well, I am trying not to prolong
14 this digression, but if I listen to what you are saying,
15 I guess I would read two things into it. First of all,
16 the people that are analyzing the vessel have assigned
17 an uncertainty to the results that represents two orders
18 of magnitude. I do not know which way the uncertainty
19 is biased or if it is biased at all. Maybe you have
20 drawn a median curve or an average curve or some such
21 thing.

22 In addition to that, I would have to add that
23 there is the uncertainty associated with the transients
24 that must be multiplied, added, or subtracted from the
25 uncertainty in the other part of the analysis.

1 MR. HANAUER: Never subtract it, Mr.

2 Chairman. Never subtract it.

3 MR. BENDER: Statistical people say there is a
4 plus or minus to everything, and that sometimes the
5 uncertainties offset each other, and I do not know in a
6 statistical sense whether this analysis comes out that
7 way or not.

8 MR. HANAUER: Neither do we.

9 MR. BENDER: I guess we have to make those
10 kinds of judgments about them.

11 MR. HANAUER: That is right. What I am going
12 to show you is in general point estimates of
13 probabilities, and I wave my arms vigorously in talking
14 about uncertainties, but in fact the science behind
15 these estimates is very modest indeed.

16 MR. BENDER: Okay. We have probably digressed
17 enough.

18 MR. HANAUER: No, it is an important point.
19 Now, where do you put design basis accidents along
20 here? A design basis accident is a specified sequence
21 of events. You get a double-ended break in the cold leg
22 at a time when the off-site power is unavailable, and
23 there is -- in addition the worst single failure occurs
24 in the emergency core cooling system. You calculate in
25 accordance with an evaluation model that requires you to

1 throw all the water injected during blowdown on the
2 floor. You can recite this stuff as well as I can.
3 That is a design basis accident.

4 Such a sequence contains traditionally a large
5 number of improbable factors. The off-site power isn't
6 available. The water all spills on the floor, and so
7 on. And therefore, it ought to be found rather far down
8 in the tail of this curve. However, in fact it may be
9 far off the diagram because of its cascading of event,
10 of disadvantageous events that goes into it, but in fact
11 you can't find it on this curve, because for this curve
12 the severity which I have represented by temperature has
13 been calculated realistically or as realistically as we
14 know how, and I will have a slide later, and there is
15 some considerable reckoning in the report about the
16 conservative and non-conservative and realistic aspects
17 of these calculations.

18 So, if you want to try to put a design basis
19 sequence on here, you will find that it is very severe.
20 That is to say, it has a very low temperature, and if
21 the probability is reckoned realistically, it is way off
22 the page, but since the low temperature is also done
23 unrealistically, you can't plot it on here at all, and
24 so there is a dysjunction between the traditional design
25 basis approach and the approach that we are using here,

1 which is to the best of our present knowledge essential
2 and difficult to manage.

3 MR. ZUDANS: But you might remark, this is not
4 a PTS problem anyway.

5 MR. HANAUER: What isn't?

6 MR. ZUDANS: A design basis accident.

7 MR. HANAUER: Well, one approach to the PTS
8 problem would be to make a design basis PTS accident,
9 and this was in fact what the atoners did when we asked
10 them for their analysis of PTS. There wasn't anything
11 wrong with it. That is how we were all thinking a year
12 ago. It just didn't seem to solve the problem.

13 (Slide.)

14 MR. HANAUER: Now, let me talk a minute about
15 experience. We have had eight overcooling transients,
16 and I have represented two of them here in two
17 vu-graphs. Here is what happened at H.B. Robinson, when
18 the relief valve blew off during preoperational testing,
19 and you see the pressure went through a considerable
20 gyration, and the temperature behaved rather smoothly.
21 The two lines are for two of the three loops at
22 Robinson. The one that was associated directly with the
23 break in the secondary system came down to some lower
24 temperature which was then restored, so you see, there
25 is a temperature transient which looks sort of amenable,

1 and there is a pressure transient which goes all over
2 the map.

3 This is even more noticeable if I display the
4 Rancho Seco transient of infamous memory.

5 (Slide.)

6 MR. HANAUER: Here is, again, a rather modest
7 and amenable looking temperature transient associated
8 with a pressure transient that nearly defies
9 description.

10 MR. REMICK: What temperature are you
11 referring to?

12 MR. HANAUER: These temperatures are the
13 temperatures which were measured in the cold leg, and
14 that is one of the problems in this thing. We don't
15 have any thermocouples in the downcomer. We don't have
16 any thermocouples on the vessels in these plants.

17 MR. REMICK: Is this fluid temperature?

18 MR. HANAUER: Well, it is almost fluid
19 temperature. In these plants, there is either a bypass
20 line with some resistance thermometers in it, or the
21 resistance thermometers are stuck into the cold leg in
22 wells or in clamps of some kind, and so they are
23 intended to measure fluid temperature. As long as the
24 main cooling pumps are on, they measure fluid
25 temperature rather well. Water is well mixed in the

1 cold leg and the bypass samples this in an adequate way,
2 and the detectors stuck into the line sees a well-mixed
3 sample.

4 When you turn the main pumps off and you get
5 either natural circulation or stagnation, then the
6 measurement is in fact not very good. You get
7 stratification in the cold leg. You get peculiar
8 temperature changes along the cold leg as well as up and
9 down in the cold leg and it becomes a matter of chance
10 and substantial uncertainty what you are measuring.

11 What we have done in this analysis is to take
12 what these temperature measuring devices measured, since
13 we don't have a model for correcting them, and we have
14 assumed that these measured temperatures are the
15 temperatures of the water in the downcomer right at the
16 vessel wall, which is in fact a rather poor assumption
17 for some of these.

18 Okay. Finally, I show you the temperature
19 transient in the Ginna steam generator tube rupture less
20 than a year ago.

21 (Slide.)

22 MR. HANAUER: And you will see that in this
23 case the operators did a thing which at least looks
24 bizarre on a temperature trace. They depressurized the
25 system and produced a substantial temperature excursion

1 measured in the cold leg, and you also see here a
2 stylized representation, this dotted line, of this
3 temperature transient, and that is the next thing.

4 MR. BENDER: Excuse me, Steve. Before you go
5 on, because these numbers and curves may get discussed
6 more later it is important to know whether we have any
7 feeling for the relationship between those temperatures
8 and what the real temperature of the vessel was.

9 MR. HANAUER: Very little, except that we know
10 there are substantial differences. I don't have any
11 analysis. We don't have a very good model, as a matter
12 of fact, although we have now the Criari experiments
13 supported by the Electric Power Research Institute which
14 are being correlated and which we have used in the
15 analysis of one of our transients, which I will talk
16 about later on, but we do not have analyses of these
17 eight overcooling transients in that respect, namely,
18 some model that predicts what the temperature of the
19 fluid was right down along the vessel wall as related to
20 the temperature in the cold leg.

21 MR. WECHSLER: Can you say the vessel wall was
22 no lower in temperature than these values?

23 MR. HANAUER: No, sir, you can't say that. We
24 can't say either of those possible statements, because
25 of the unknown degree of stratification in the cold leg

1 during these measurements.

2 Furthermore, it could, at least in principle,
3 be investigated with some calculation which would have
4 whatever validity it had after you looked at it for a
5 while, but this has not been done. Mr. Throm is our
6 expert on this subject. Do you know of any calculations
7 that have attempted to look at this?

8 MR. THROM: No, not on these specific events.

9 MR. BENDER: Monroe's question is extremely
10 important to think about, at least. If we haven't done
11 any analysis that relates back to the vessel wall yet,
12 then somehow or another I have to believe that what has
13 been going on in the last year is too generic.

14 MR. HANAUER: I thought I told you that
15 already, that it was too generic.

16 MR. BENDER: I am not complaining about that
17 observation, but somewhere along the way it seems to me
18 during this period of time those that own vessels should
19 have been doing some computations of some sort, and I am
20 a little surprised that we don't have access to them.
21 Is it that they haven't really done any calculation, or
22 they haven't provided the results? Or either one?

23 MR. HANAUER: You will talk to the owners'
24 groups this afternoon. I suggest you ask them. As far
25 as I know, we have everything they do.

1 MR. BENDER: I will in fact ask that question
2 again. Go ahead.

3 MR. HANAUER: Neal, you wanted to say
4 something? Mr. Randall?

5 MR. RANDALL: I thought there was some
6 confusion in Professor Wechsler's remarks. I think he
7 was referring to how you get from the water temperature
8 in the downcomer to the temperature at the crack tip in
9 the metal. You were referring to how you get from the
10 water temperature measured in the cold leg to the water
11 in the downcomer?

12 MR. HANAUER: Yes, sir, that is what I was
13 talking about. I don't know what -- Dr. Wechsler, was
14 that what you were talking about?

15 MR. ZUDANS: No, I don't think so. The
16 question was very simple and straight. Is this the
17 lowest possible temperature in the downcomer or not?
18 And if you can't make that statement --

19 MR. BENDER: I think you said vessel. I think
20 vessel is the right question to ask.

21 MR. WECHSLER: Ultimately, that is what we
22 have to know.

23 MR. HANAUER: The answer is no, this is not
24 the lowest possible temperature, because of the unknown
25 degree of stratification at the point of measurement.

1 MR. BENDER: It is certain that the vessel
2 temperature cannot be lower than the temperature at the
3 vessel wall.

4 MR. HANAUER: The temperature of the fluid at
5 the vessel wall?

6 MR. BENDER: Yes.

7 MR. HANAUER: Quite so.

8 MR. CATTON: But you don't know whether this
9 is the temperature of the fluid or not. The wall could
10 be heating up with the RTD, so that could be higher.

11 MR. HANAUER: This is in the pipe.

12 MR. CATTON: It is still in the well, and the
13 well is connected.

14 MR. HANAUER: It is a very large pipe. Based
15 on experience, not calculation, and not analysis, I
16 would say that effect is fairly small.

17 MR. CATTON: It sticks pretty far into the
18 pipe.

19 MR. HANAUER: Yes, sir.

20 MR. BINFORD: Steve, what you are saying is,
21 you are measuring a temperature in a pipe which bears an
22 unknown relationship to temperatures elsewhere in the
23 system?

24 MR. HANAUER: Unknown is too strong, but I
25 cannot certify to you that this measured temperature is

1 the lowest temperature of water even in the pipe.

2 MR. BINFORD: But you really don't know the
3 relationship between that temperature and the
4 temperature anywhere else. You may have some
5 qualitative feeling for it, but you don't have a
6 quantitative relationship, because you don't know the
7 conditions, and that is no fault of yours. The
8 conditions are very variable.

9 MR. HANAUER: Well, the cold leg pipe should
10 be the coldest place in the system for the most
11 important transients, because the coldest water in the
12 system is being injected into the cold leg pipe.

13 MR. BINFORD: Well, I would agree with that.

14 MR. THEOFALOUS: I think that the impression
15 that is being generated here is that we know very little
16 about those things, and if we had this temperature we
17 could almost say nothing about the temperature in the
18 downcomer, and I really don't agree with that.

19 MR. HANAUER: I don't, either.

20 MR. THEOFALOUS: Well, if you agree with me,
21 then why are you saying that?

22 MR. HANAUER: Well, let me try and say it
23 better, then. There is an uncertainty here, and I
24 cannot in response to somebody's question certify that
25 this measured of temperature as a function of time is as

1 cold as the water in the downcomer right at the vessel
2 wall can be. There is an uncertainty. This uncertainty
3 is caused by the difficulty in measuring in this large
4 pipe at very low flows, and I would not want to
5 represent, and tried very hard, maybe too hard, not to
6 represent that this temperature was the temperature of
7 the water in the downcomer right at the vessel wall. It
8 is related to it, and as you point out, we know a lot
9 more than nothing about this relationship, but we have
10 not made the calculation.

11 MR. THEOFALOUS: I guess my point was
12 referring to this aspect of it, that I was concerned
13 that people might get the impression that we cannot make
14 those calculations. I think in some of your earlier
15 statements you referred to the difficulty of making such
16 calculations, and I guess I don't agree with that, and I
17 don't agree that a year later we still don't have those
18 calculations. I really see no reason for that.

19 MR. KOUTS: Was high pressure injection being
20 done here?

21 MR. HANAUER: On Ginna, yes, it was.

22 MR. KOUTS: So there was that source.

23 MR. AXTMANN: Does that negative spike
24 correlate with some action that was taken?

25 MR. HANAUER: Yes, the operators depressurized

1 the primary system, reduced the pressure in the primary
2 system.

3 MR. CATTON: They were also playing games with
4 the safety injection. It was on and off.

5 MR. BENDER: Steve, with great reluctance, I
6 would like to ask whether in a probabilistic sense we
7 know something about the temperature of the vessel wall.

8 MR. HANAUER: No, sir, not in the sense we are
9 talking about. We know a lot about the temperature in
10 the vessel wall. We have taken this temperature to be
11 the temperature of the water in contact with the vessel
12 wall, and we have heat transfer both at the wall and in
13 the metal calculations. What we don't know
14 deterministically or probabilistically, we have not
15 evaluated in any quantitative way the difference between
16 this temperature and the temperature of the water at the
17 vessel wall.

18 MR. THECFALOUS: Let me rephrase my question
19 following this one. Would you agree that we can find
20 what the temperature of the wall would be if one was
21 given, let's say, a month's time?

22 MR. HANAUER: We could find this temperature
23 with some assumptions about what is going on in this
24 pipe, yes, and these assumptions would not be completely
25 arbitrary, because they have some measurements. Yes, we

1 could make some calculations.

2 Mr. Throm?

3 MR. THROM: Given an event, there is a lot of
4 information that you would like to have concerning the
5 plant conditions that we really haven't tried to get
6 together, nor really are available in a plant. The data
7 we are seeing from Criari indicates that the real
8 problem is in the very low flow situation, stagnant loop
9 flows or loop flows that are even less than the
10 anticipated natural circulation flows, and we don't have
11 data that really verifies what those conditions are.
12 Given the assumption that it was stagnant, we are coming
13 up with models that would allow you to predict what the
14 downcomer response would be, but then you are also
15 assuming either a no loop flow or some assumption of
16 what the loop flow is, and I think it is kind of
17 sensitive in that range.

18 MR. THEOFALOUS: Again I think that you are
19 trying to say that because we are not absolutely
20 certain, that is a good enough reason for not trying to
21 do the job here, and I really don't agree with that. I
22 think we know much more than what you are implying, and
23 I think a good job can be done in determining those
24 temperatures, and I think that should be done as soon as
25 possible.

1 MR. BENDER: We have probably belabored this
2 point enough to be sure that there is some more
3 discussion to be had about it, but let's go on.

4 MR. HANAUER: Now, this temperature or some
5 temperature related to it, in the spirit of the last ten
6 minutes, is the driving function for a calculation of
7 the temperature distribution in the vessel wall.
8 Because of the very large thermal inertia, we have
9 represented these rather unwieldy curves with
10 exponential temperature decays of which an example is
11 shown here in the dotted line.

12 We are changing our code so we can put these
13 traces in directly, but we don't have that capability.

14 (Slide.)

15 MR. HANAUER: Here is the stylized temperature
16 pressure transient which we have used for some fraction
17 of our work, and I will try to be clear about where we
18 have used real transients and where we have used
19 stylized transients. The stylized transients begins at
20 a temperature two zero and ends asymptotically at a
21 temperature T_F with an exponential behavior, and the
22 pressure is assumed to be a constant. This, of course,
23 is a gross oversimplification for some transient in
24 which the pressure does this.

25 (Slide.)

1 MR. HANAUER: As shown on the top of this
2 curve. And so an improved model which, as I say, is
3 under development, is very badly needed in this area.
4 On the other hand, the pressure dependence is not
5 enormous, rather surprisingly, as we will come to in a
6 moment.

7 (Slide.)

8 MR. HANAUER: Now, the result of this
9 calculation is this frequency, this cumulative frequency
10 distribution. Here is the temperature, and now this
11 temperature is the temperature TF, which is used to give
12 a stylized representation of the temperature in the
13 inlet pipe as measured, and which has in it then the
14 uncertainties which we have discussed, and here are the
15 eight incidents which are calculated and discussed in
16 the report which you have.

17 The most severe one we paid any attention to
18 had a final temperature of 350 degrees. Above that, one
19 has very little problem with pressurized thermal shock.
20 And the lowest one had a final temperature evaluated of
21 225 degrees, and what we did was, we took the 350
22 reactor years for pressurized water reactors and divided
23 the numerator by the denominator, and there we have the
24 frequency.

25 Now, statistically, this is not very well

1 defined with eight events in this way, but here is their
2 frequency distribution.

3 There is one other thing that needs to be said
4 about this curve. These eight incidents contained no
5 incidents at a Combustion plant, and the three worst
6 ones were at B&W plants, which, however, have been the
7 subject of substantial backfitting programs to deal with
8 the causes of these three transients. So, here is an
9 additional uncertainty. If you try and separate these
10 into three B&W events, and four or five depending on
11 which reckoning you use, Westinghouse plant events, then
12 these statistics get really awful, and we have not
13 chosen to do this, but in fact it needs to be done, and
14 this is one of the pieces of unfinished business, is to
15 investigate in a more serious way whether there are any
16 essential differences which would affect the pressurized
17 thermal shock risk in the three kinds of plants that we
18 are dealing with.

19 MR. BENDER: Steve, those eight events as you
20 have cited have resulted in some backfits, two kinds of
21 backfits, procedural changes and some changes in the
22 physical plant.

23 MR. HANAUER: Well, one of them is Three Mile,
24 for which a very large list has been imposed.

25 MR. BENDER: The point I am trying to make is

1 this. That curve there, or whatever you want to call
2 it, is clearly not a good statistical representation of
3 anything. It is just a computed probability of an event
4 that has occurred. But when you take into consideration
5 the corrective actions, a new probability curve has to
6 be drawn. If you are only going to work on the basis of
7 historical evidence, then all the events are random, and
8 there is no way of correcting a random kind of
9 occurrence, but in view of the fact that there are
10 corrective measures that have been taken, would the
11 staff want to argue that this is probably a worst case
12 representation, or less than worst case? Are we better
13 off today or not?

14 MR. HANAUER: Well, I will give you my
15 opinion, and I will invite my colleagues on the staff to
16 flesh out the staff opinion. This is surely not worst
17 case. Much worse transients are possible, and have not
18 occurred, but there is no reason why they couldn't,
19 except their lower probability prima facie based upon
20 what is happening.

21 There is no way in my opinion that this could
22 be a worst case. Since we have had corrective measures,
23 it is my opinion that this curve is somewhat worse than
24 plants today. How much worse, well, if we do our PRA
25 very well, and if it has the kind of discrimination

1 which would show up such differences, then the PRA curve
2 would lie below this one, and if that were the only
3 reason for the difference, you would say that that shows
4 the benefit of what we have done in backfitting, or you
5 could wait ten years and draw -- or 350 more reactor
6 years and see if the curve looked any different.

7 Well, we don't have time for that. The
8 current answer, since we can't do it with experience,
9 has to be in the probabilistic evaluation which should
10 be done on the plants as they are now with the backfits
11 in, and those plants that do plant specific evaluations
12 need to do that, and it will show for a variety of
13 reasons that present day plants are better than this,
14 and that will be one of the reasons.

15 Now, let me invite my colleagues to say either
16 something different or any other remarks that should be
17 added.

18 MR. ZUDANS: Since most or let's say the key
19 argument in PRA is this experience, is eight data
20 points, does it represent any kind of a credible basis
21 for any statistical analysis at all?

22 MR. HANAUER: One can do statistical things
23 with eight points. We haven't done it. And Mr.
24 Bender's question is one of the reasons it doesn't
25 represent today's plants, and therefore doesn't justify

1 very much messing around in our opinion.

2 MR. BENDER: Well, there is a little bit of a
3 contradiction in the discussion. It doesn't represent
4 today's plants. I fully agree with that. And because
5 it doesn't, trying to present a frequency relationship
6 of the sort you have there distorts the problem
7 probably.

8 MR. HANAUER: Yes.

9 MR. BENDER: And distorts it in what may make
10 the public safety question seem worse than it really is.

11 MR. HANAUER: If you really believe that all
12 our backfits have made things better, which seems
13 probable if you look at the backfits, then, yes, this
14 gives a picture of the public risk which is worse than
15 the facts.

16 MR. BENDER: What is missing here is, and it
17 troubles me, and it troubles you, and probably the whole
18 staff, are the events that haven't occurred.

19 MR. HANAUER: Of course. That is what the
20 other half of this discussion is, the probabilistic
21 discussion.

22 MR. BENDER: And whether the events that
23 haven't occurred can be presented probabilistically may
24 be the crucial issue.

25 MR. HANAUER: Indeed. We are in violent

1 agreement.

2 (General laughter.)

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. BENDER: Okay. Go ahead. I had not
2 expected to reach any agreement with you, Steve.

3 MR. HANAUER: I now pause extremely briefly to
4 present some results from a deterministic fracture
5 mechanics analysis. This has gone far beyond Pellini's
6 diagram because we now know how to calculate these
7 things in at least in elastic fracture mechanics in a
8 rather deterministic way.

9 (Slide.)

10 And we now have a great deal of experimental
11 and theoretical evidence that in the range of
12 applicability that this stuff does indeed predict the
13 failure modes and the failure effects of vessels made
14 out of the kinds of materials of which we are talking.

15 What we do not know, and what is the amount of
16 conservatism in this analysis for warm materials which
17 are very ductile and for which linear elastic fracture
18 mechanics is an approximation.

19 Now, as an old instrumentation and control
20 engineer, I am far out of my depth; I have studied this
21 subject, but I am no expert in it. And so I may not
22 even answer the first question, but call on my expert
23 colleagues.

24 This is the result of a whole series of
25 calculations using a code similar to OCA about which the

1 fracture mechanics in the room know far more than I.
2 What we have done is to calculate --

3 MR. BENDER: Would you spell "OCA"?

4 MR. HANAUER: O-C-A.

5 MR. BENDER: Thank you.

6 MR. HANAUER: A whole series of stylized
7 transients, they had constant pressures and exponential
8 temperature decays. Later on I will show you some
9 results for real transients.

10 These are deterministic transients. They
11 assume that there is a flaw wherever there needs to be a
12 flaw. They include the time-dependent heat transfer of
13 the water, whose temperature is given by the exponential
14 decay into the metal and the time-dependent heat
15 conduction within the metal.

16 They include the metal properties as a
17 function of depth through the wall, as a function of
18 neutron irradiation which varies through the wall, and
19 also as a function of the local temperature which varies
20 with both time and position.

21 They include thermal and pressure-related
22 stresses, and they include the effect of crack arrests,
23 but not, in these calculations, the effect of warm
24 prestressing.

25 Now, the abscissa is the relative cooldown

1 temperature; namely, the TF from the stylized transient
2 minus RT NDT, the reference temperature which
3 characterizes the material.

4 MR. SHEWMON: They also assumed a flaw size.
5 Is this a quarter of the wall size or what?

6 MR. HANAUER: No specific flaw size was
7 assumed. The flaw was assumed to be however big it
8 needed to be. I told you I would need help.

9 MR. KLECKER: Ray Klecker.

10 From the standpoint we assumed that a flaw
11 greater than, say, from the clad up to about 1 inch,
12 actually a little larger. And we looked at all crack
13 sizes within that range.

14 MR. SHEWMON: Go ahead.

15 MR. BENDER: That answer is not too clear to a
16 lot of us. If you are doing a computation, you have to
17 do it with explicit flaw size in mind. If I were to
18 pick a point on that curve, on any of those curves,
19 could I identify a flaw size that was related?

20 MR. KLECKER: We can go back to the original
21 calculations, yes, and pick out what that flaw size was.

22 MR. HANAUER: It does a search through flaw
23 sizes and picks the one that starts. If any one starts,
24 it assumes the worst flaw, not some specific depth, but
25 it looks and sees if there is any flaw that we can --

1 MR. SHEWMON: If it assumed the range, then
2 there would be a probability, and I do not see any
3 probability up there.

4 MR. HANAUFER: There is no probability here.

5 MR. SHEWMON: The dividing line between crack
6 initiation or no crack initiation, there was a flaw size
7 or else there was some -- well, let us go on.

8 VOICE: Very simply, a parametric study was
9 done which assumes the presence of a flaw, and the final
10 solution was a flaw as a basis of a range of flaw sizes.

11 If the study showed crack initiation for any
12 size flaw from very small, let us say, quarter-inch up
13 to an inch, that initiated it. We assumed the presence
14 of a flaw. It was not probabilistic. The size was
15 indeterminate and determined by a parametric study.

16 MR. BENDER: Go ahead. We will come back to
17 it someday, maybe not today, but someday.

18 MR. HANAUFER: Now, the original curves which
19 we saw from an early version of this study had, in fact,
20 coalesced into a single curve here and a single curve
21 there. And more detailed studies have resulted in these
22 dependencies.

23 Notice that the whole length here is 150
24 degrees or so, so that these differences are really
25 quite small. We have here the pressure and here the

1 cooldown temperature relative to the reference
2 temperature of the material at its inner surface. We
3 did not assume a constant temperature, and we did not
4 assume a constant reference temperature through the
5 thickness of the material. But we pinned it, in order
6 to plot it, to the reference temperature at the inner
7 surface.

8 MR. BENDER: Well, Steve, there is a shape of
9 the temperature distribution.

10 MR. HANAUER: Yes, sir. I will say it again.
11 The temperature, T_F , is this asymptotic temperature of
12 the water at large times. The R_T is the reference
13 transition temperature at the inner surface of the
14 ferritic material.

15 MR. SHEWMON: Did you use a bounding or a most
16 probable heat transfer coefficient to get from the
17 T -final to the steel temperature? That has been a
18 question of argument before.

19 MR. HANAUER: We have used several. For this
20 study the heat transfer coefficient was, I think, 300.

21 MR. KLECKER: I think on this one it was
22 1,000. The later ones, we used 300 or 330.

23 MR. HANAUER: We have used various numbers,
24 and this can be discussed.

25 MR. SHEWMON: And the 1,000 is bounding, and

1 300 is more likely, or what?

2 MR. KLECKER: I would say 300 or somewhere
3 thereabouts is more realistic.

4 MR. SHEWMON: Okay. Thank you.

5 MR. HANAUER: The Westinghouse calculations,
6 which give similar results, is actually a heat transfer
7 correlation and gives similar results to our 300 curves.

8 All right. Now, first of all, the two
9 families of curves are for two different values of
10 beta. The inverse time constant for the assumed water
11 transient. Here is a large value of beta where the
12 water temperature comes down quite quickly, and the heat
13 transfer is almost entirely dominated by the conduction
14 into the material.

15 Here is a much smaller value of beta, where
16 the water temperature comes down much more slowly, and
17 both then the water temperature variation and the
18 conduction into the material contribute. And as you can
19 see, a somewhat either higher pressure or lower
20 temperature can be tolerated if it happens more slowly,
21 not surprisingly.

22 Here are the different final temperatures. If
23 TF minus RT NDT were really a correlation parameter,
24 these two curves would coalesce. In fact, for a
25 15-degree change in TF , there is approximately down here

1 a 15-degree change in the severity, so that they do not
2 quite coalesce and therefore, TF minus RT NDT is not
3 quite a good correlation parameter.

4 MR. BENDER: Steve, if I were concerned about
5 the pressure condition and wanted to try to make some
6 judgment about where I would like the pressure to be,
7 clearly I would like to have it as low as practical, but
8 there are some operational questions associated.

9 MR. HANAUER: There is also a question of
10 cooling the core.

11 MR. BENDER: Yes. And you were trying to make
12 a judgment as to where a suitable pressure might be,
13 where might I draw a line?

14 MR. HANAUER: Well, the first thing to notice
15 about pressure is its surprisingly small contribution if
16 you take the more severe curves, the pressure slope from
17 zero all the way up to 2500 is only worth about 40
18 degrees. So that the stresses in this model are
19 primarily thermal, and the pressure stress is
20 significant but not really a large part of it.

21 For the slower one, where conditions are less
22 severe, the pressure has much larger importance and is
23 worth something like 100 degrees. For this purpose, you
24 would like the pressure to be as low as possible, for
25 the most severe transients, which turn out to be the

1 small-break loss-of-coolant accidents.

2 In the intermediate size where flow stagnates,
3 the pressure calculated is about 1000 pounds. We think
4 the pressure will hang up at about 1000 p.s.i. So you
5 are down here, and there is not much hay to be made in
6 trying to get the pressure much lower.

7 MR. BENDER: I do not know if you are going to
8 proceed from here to the question of crack arrest, but
9 if you are not, then I may as well lay the question out
10 here.

11 The Staff, I think, probably is following a
12 good regulatory strategy in arguing you should protect
13 against crack initiation. But in the sense of what puts
14 the public in jeopardy, there is a question of whether a
15 crack which initiates will arrest.

16 MR. HANAUER: But crack arrest is, in fact, in
17 this model, and a similar curve can be drawn with crack
18 arrest. What you get is that down below about 500
19 pounds per square inch, these curves slant to the left
20 quite strongly. I do not think I brought one with crack
21 arrest. I am sorry about that. It is in the report,
22 however, and it is also in the P&L report, very clearly
23 indeed.

24 Crack arrest seems to make a significant
25 difference only at pressures below about 50 p.s.i. Now,

1 the models which we have used later on in our
2 probabilistic study include the effect of crack arrest,
3 and in one important transient, include the effect of
4 warm prestressing also in order to get more realistic.

5 MR. ZUDANS: Steve, do you have a similar set
6 of curves for a coefficient of 300?

7 MR. HANAUER: Such data exist. I do not have
8 such a curve with me.

9 MR. ZUDANS: Have you seen them?

10 MR. HANAUER: It becomes less severe because
11 the heat transfer is less. It is really more important
12 for this one than for this one. And my recollection is
13 they do not coalesce very much better. Somebody please
14 correct me.

15 MR. RANDALL: In Appendix D, page 18, there is
16 a table giving that effect of a difference of H-300
17 versus H-1000.

18 MR. ZUDANS: Which page?

19 MR. RANDALL: D.18, the biggest number in the
20 table is 29 degrees, and both of them are around 10. So
21 it would not affect that.

22 MR. HANAUER: It is not negligible, but it is
23 not very large either, and I cannot tell you whether
24 they coalesce any better or not. One would have to go
25 look through a whole bunch of calculations to find out.

1 MR. REMICK: Steve, there is something I do
2 not understand. You talk about flows stagnating, yet
3 when the curves that you had showed an exponential
4 measured decrease in temperature that was fairly rapid,
5 how could you have stagnation and temperatures changing
6 that rapidly?

7 MR. HANAUER: Because in the first place, we
8 have not had a transient where the flow completely
9 stagnated, as far as I know. In the second place, the
10 Criari data show that there is mixing in the cold leg.
11 And this is a physical fact. The flow does not stagnate
12 all the way. The third reason is that we are injecting
13 the cold water right into this space.

14 MR. REMICK: I understand. But if you are
15 injecting it in, you cannot inject it in if there is
16 stagnation. Something has to be moving.

17 MR. HANAUER: Yes. The flow stagnation is not
18 total. The motion is not zero. If it were, the cold
19 water would not get into the reactor, and we would not
20 have any problem.

21 MR. THEOFALOUS: What do you mean by
22 "stagnation" now? Do you mean the loop flow, what you
23 normally call "loop flow," the flow going through the
24 loop, or convection currents?

25 MR. HANAUER: How I use it is that for a

1 certain class of transients which turns out to be very
2 important, the net flow in the loops is essentially
3 zero, but the local flow and mixing, as was pointed out
4 a moment ago, is not zero. You are injecting cold
5 water, and it has to go somewhere. And we have these
6 measurements that show that there is a certain amount of
7 local flow and mixing. Now, when I mean "stagnation," I
8 mean that the natural circulation through the loops is
9 stopped.

10 MR. THEOFALOUS: And I thought you said the
11 Criari data show that there is good mixing in the cold
12 leg under those conditions?

13 MR. HANAUER: There is a substantial amount of
14 mixing. I do not know whether you want to call it good
15 or not.

16 MR. THEOFALOUS: Because my interpretation of
17 that is that the data shows there is very good
18 stratification.

19 MR. HANAUER: There is stratification, yes.
20 Levy has made a model to show the stratification and
21 what mixing takes place, and it seems to correlate a
22 substantial amount of the Criari data. And they are now
23 doing some more tests to see if it works.

24 MR. KOUTS: I thought Forrest was referring to
25 the temperature spike in the Ginna transient, and that,

1 I thought, was a result of temperature change which
2 caused local flashing.

3 MR. HANAUER: Yes, sir.

4 MR. REMICK: No, I was referring to the beta.
5 If you had a beta .12, as you did in one curve, that
6 meant every 8 minutes roughly the temperature was
7 changing by a factor of E, which is several hundred
8 degrees. To me, that hardly seems like stagnation.
9 That is what bothered me.

10 MR. HANAUER: No, that is not quite right.
11 The temperature difference to the final temperature is
12 changing by a factor of E. The exponential is related
13 only to the difference between TL and TI. So that, yes,
14 in the first 8 minutes you get about a factor of E
15 change in the temperature difference, and after that --

16 MR. REMICK: Well, that could be several
17 hundred degrees in 8 minutes.

18 MR. HANAUER: Our TFs are in the range of 200
19 to 350 degrees. So, yes, there is 200 to 300 degrees
20 between TO and TF; that is quite right. And in this
21 range the temperature changes quite quickly on the
22 8-minute schedule.

23 MR. BENDER: Steve, when you are making this
24 computation in the face of the other essentially
25 stagnant core circulation, the cooling of the wall is

1 dominated by the ECCS flow. Is that what you are saying?

2 MR. HANAUER: For certain transients, that is
3 true, yes.

4 MR. BENDER: Now, some people have asked
5 questions about whether the temperature of that coolant
6 of the ECCS coolant could affect the wall temperature
7 under those conditions.

8 MR. HANAUER: Indeed, it could. And warming
9 that water is one of the things that ought to be done in
10 plants with brittle vessels.

11 MR. BENDER: But the computation now is based
12 on what water temperature?

13 MR. HANAUER: The computation which we now
14 have, which is a Westinghouse Owners Group computation,
15 used 60-degree water, allowed for --

16 MR. BENDER: Is that centigrade or Fahrenheit?

17 MR. HANAUER: Fahrenheit. Allowed for mixing
18 in the cold-leg pipe in accordance with a model derived
19 from the Criari tests, allowed for heat transfer from
20 the cold-leg pipe wall, in accordance with a model and
21 then put this water into the downcomer, I do not think
22 with any further mixing.

23 I see nods in the Westinghouse bleachers.

24 MR. MEYER: I am Daniel Meyer of the
25 Westinghouse Owners Group.

1 There was some further mixing.

2 MR. HANAUER: So that was the model that was
3 used in the current calculations.

4 MR. BENDER: Go ahead, Steve.

5 MR. HANAUER: Now, this is the deterministic
6 calculation, and the people at Oak Ridge fixed up their
7 deterministic calculation -- or already had it fixed, I
8 do not know which -- and used a calculation of this
9 type, not on the stereotyped transients but on seven, on
10 five of the seven transients which actually occurred --
11 five or six. Six, I think. One of them we just did not
12 have the data on the time-dependence, and so we could
13 not do it.

14 (Slide.)

15 Here is the results. Now, this is a
16 deterministic fracture mechanics calculation of the kind
17 I described, with a heat transfer coefficient of -- what
18 did they use for this one? I cannot remember.

19 MR. KLECKER: That one was 330, as I recall.

20 MR. HANAUER: And what they did was they
21 calculated for each transient a value of RT NDT at the
22 interval for which no crack would be initiated even if
23 there was a flaw. That is a net result, is this solid
24 curve. And I have also plotted here as a dotted curve
25 the T_f evaluation of these same events off the

1 previous vuegraph.

2 But now you see this is not the stereotyped
3 anymore. For this calculation it is not necessary to
4 represent the transient with a constant pressure and an
5 exponential temperature decay.

6 We used these zigs and zags in these
7 temperature and pressure plots that were taken from the
8 actual events. And as you see, it is somewhat less
9 severe because it is somewhat stereotyped, and it was
10 possible then to use a more realistic depiction of the
11 actual transient as it occurs.

12 And here they are plotted in the same
13 cumulative frequency way with the same strictures that
14 have to be placed on it for backfits since then. This
15 represents the plants as they were at the time the
16 transients happened rather than the plants as they are
17 now.

18 And you will observe the, crudely speaking,
19 about a 50-degree difference between these. That is to
20 say, if you believe the critical RT NDT curve, then the
21 TF representation was about 50 degrees conservative. Of
22 course, this is a better way of representing this kind
23 of phenomenon.

24 MR. THEOFALOUS: Does this mean that if the
25 calculation of RT NDT was a good one, a correct one, and

1 if the temperature in the particular transient was 50
2 degrees lower, we would have a crack initiation?

3 MR. HANAUER: No, it does not mean that. Here
4 are two calculations of the same set of transients. One
5 is stereotyped TF-style; the other uses the actual
6 transients.

7 MR. SHEWMON: TF?

8 MR. HANAUER: TF constant pressure, the same
9 business. TF constant beta, same pressure. That says
10 that for these transients RT NDT could be about 50
11 degrees higher than the TF we were using, without
12 cracking the vessel.

13 MR. KOUTS: That is assuming that the water
14 temperature according to the top curve is the vessel
15 wall temperature. According to the bottom curve --

16 MR. HANAUER: No, sir. This top curve
17 represents the water temperature by TF and beta. This
18 curve represents the water temperature by what was
19 actually measured in the cold leg. This curve has a
20 constant pressure. This curve uses the pressure as was
21 measured.

22 MR. KOUTS: Where did they get the
23 measurements?

24 MR. HANAUER: There are measurements of
25 pressures in primary systems. The temperatures were in

1 the cold leg; the pressures are on the pressurizer. But
2 the pressure, remember these are transients
3 characterized in minutes so that there should not be any
4 problem.

5 MR. KOUTS: I thought we had no temperature
6 measurements in the cold leg.

7 MR. HANAUER: But not the downcomer.

8 MR. KOUTS: So this assumes the measure of the
9 temperature in the cold leg is the measure of
10 temperature in the downcomer? That is what I said the
11 first time.

12 MR. HANAUER: I am sorry, I did not understand
13 you to say that. Yes, this has that same problem in
14 it. We do not have a way out at the present time. We
15 do not have a calculation.

16 MR. THEOFALOUS: So this difference then is
17 just the effect of the pressure?

18 MR. HANAUER: It is the effect of the
19 pressure. It has three effects in it: one, the effect
20 of the pressure; second, the stereotyping of the
21 temperature variation; and third, the fact that the
22 final temperature is not just a temperature that will
23 break the vessel.

24 (Slide.)

25 Here you see depending on situations -- here

1 is RT NDT you see out here -- and the transient can be
2 colder than RT NDT by an amount that depends on the
3 temperature, the beta, and the pressure.

4 MR. THEOFALOUS: Probably that is the main
5 effect. That is about 50 degrees.

6 MR. HANAUER: Well, 50 degrees is here. So
7 there are lots of ways to get 50 degrees.

8 MR. THEOFALOUS: If you look at the difference
9 between TF -- okay. Yes.

10 MR. HANAUER: It is different for each
11 transient. There were high-pressure transients and
12 low-pressure transients. The high-pressure transients
13 are up here; the lower-pressure transients are down here.

14 MR. THEOFALOUS: Is there any way you can give
15 a feel of how important the pressure variation is? I
16 would not guess that it is too important.

17 MR. HANAUER: I do not have anything hard. It
18 seems to be worth, for this low one, as much as 15
19 degrees plus; for the fast ones, rather less.

20 MR. ZUDANS: Steve, could you go back to the
21 previous slide?

22 (Slide.)

23 MR. HANAUER: Yes, sir.

24 MR. ZUDANS: And look at one of the shelves,
25 the dashed shelf, and the correspondingly solid-line

1 shelf.

2 MR. HANAUER: Yes. This one and this one, for
3 example.

4 MR. ZUDANS: That is supposed to represent the
5 same event; right?

6 MR. HANAUER: Yes, sir.

7 MR. ZUDANS: And therefore, the probability is
8 the same. And the dashed curve shows the fluid
9 temperature at that point, your stylized?

10 MR. HANAUER: Yes.

11 MR. ZUDANS: And the solid curve represents
12 which RT NDT would initiate the crack; is that right?

13 MR. HANAUER: Yes. In accordance with this
14 model, of course.

15 MR. ZUDANS: And the fluid temperature, of
16 course, and the solid curve varied all over the slope?

17 MR. HANAUER: Yes. We used the measurement in
18 the cold leg to represent the fluid temperature.

19 MR. ZUDANS: This actually then shows what you
20 said how much higher the RT NDT would have to be than
21 the fluid temperature?

22 MR. HANAUER: Exactly. Okay.

23 Now, from this collection of information, we
24 derived a screening criteria.

25 (Slide.)

1 Now, I have to tell you plainly that there is
2 not as much science as one would like in the derivation
3 of the screening criterion. I will also tell you
4 exactly how we did it, which will tell you how little
5 science there is.

6 What we did is, we had a much earlier version
7 of these curves. Because our initial curves had some
8 mistakes in them which the industry owners groups
9 pointed out to us, and they were right in some of them,
10 and so we made some major changes in our curves from the
11 ones we had in June to the ones we have now.

12 On the original set of curves -- completely
13 arbitrary, because we did not have the Strosnider
14 results at that time in the form in which we have them
15 now -- I took 10^{-2} , a completely arbitrary value based
16 on the idea that anticipated operating occurrences have
17 a frequency bound of about 1 in 40 years. So 10^{-2} is
18 comfortably below that.

19 But without any really scientific basis, I
20 took 10^{-2} , and at that time this curve crossed the 260
21 and this curve crossed at 280. The 50-degree difference
22 had not shown at that time, and so I held my nose and
23 picked 270.

24 Now, that is the amount of science there is in
25 the 270-degree screening criterion. But since that time

1 we have developed some better idea about how
2 conservative it is.

3

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 If you really believed these curves and wanted
2 to use them in some detail, and if you really any
3 scientific basis for 10^{-2} , you would pick a number in
4 the low 300's for the screening criterion based on this
5 curve. It is my opinion that that is too high, based
6 upon some probabilistic discussion that I will give you
7 a little later.

8 There is really more justification to 270 than
9 that, but the original basis is indeed rather thin.

10 MR. BINFORD: Steve, let me ask one question
11 here. It appears to me that the dotted curve is merely
12 the solid curve, as you have said and presented in a
13 stylized fashion. Once you have the solid curve, which
14 is the actual conditions, what is the use of using the
15 dotted curve at all?

16 MR. HANAUER: The dotted curve is a grosser
17 approximation, which I don't use much any more.

18 MR. BINFORD: Well, it just appears to me that
19 all this does is to demonstrate that your simplification
20 is reasonable.

21 MR. HANAUER: Now, the reason to show the
22 dotted curves in the Tf is that we had to do our
23 probabilistic work using Tf, We don't have the codes
24 today to do RT critical for the probabilistic work. We
25 will one of these days, but today we don't, and that is

1 one important estimate. I have carried the Tf along.

2 So the screening criterion -- and I will get
3 to a stopping place, Mr. Chairman, in about, I predict,
4 ten minutes or so.

5 MR. BENDER: Fine.

6 MR. HANAUER: Well, I will one way or another
7 get to a stopping place pretty soon.

8 MR. BENDER: Why don't you announce when you
9 would like to break.

10 MR. HANAUER: Yes, sir. You will see my
11 coattails disappear through the door.

12 (Laughter.)

13 So all the work I have been talking about so
14 far is for longitudinal cracks, and so we picked 270
15 degrees for longitudinal cracks in the manner which I
16 have described. We then ask, what about circumferential
17 cracks. This turns out to be very important, for three
18 reasons:

19 First of all, it's different and in some
20 vessels the circumferential cracks, the circumferential
21 welds will dominate because they contain higher copper
22 material;

23 Secondly, some vessels don't have longitudinal
24 welds, and for those vessels the circumferential welds
25 will surely dominate;

1 And thirdly, the consequences for a severe
2 vessel break all the way around the circumferential weld
3 are substantially more serious.

4 MR. BOCK: Steve, what about plate material?

5 MR. HANAUER: I beg your pardon?

6 MR. BOCK: What about the reactor vessel plate
7 material? Don't the vendors believe in some cases it is
8 more limiting than the welds?

9 MR. HANAUER: There are some cases on which
10 the plate material is more limiting. In that case you
11 don't have any good reason for picking one crack
12 orientation over another until we learn something about
13 rolling directions and so on, about which I think very
14 little is known today about flaws. And I suppose for
15 those vessels one should pick longitudinal flaws, for
16 lack of any information.

17 There are only a small number of such
18 vessels. In general, the copper-coated welding
19 electrodes in the vessels of interest created a material
20 which is substantially more susceptible to radiation
21 embrittlement, and so the welds almost always dominate
22 in all of the high-brittle vessels. In general, even in
23 vessels where the plate dominates the situation is
24 reasonably in hand.

25 Now, there are a few vessels about which we

1 know very little, and here we are simply going to have
2 to get some more information if it can be hand. The
3 circumferential crack therefore has to be treated. It
4 is restraint-constrained in an entirely different way, as
5 the crack begins to open in the fracture mechanics
6 calculation. And of course the pressure stress is half
7 as much for the circumferential flaw as it is for the
8 longitudinal flaw, because of the way longitudinal and
9 hoop stresses are related in a pressure vessel.

10 We put these into a series of calculations
11 which are reported in Appendix D, and the result is we
12 have selected 300 degrees Fahrenheit as approximately
13 equivalent to 270 degrees for longitudinal flaws.

14 MR. SHEWMON: When I see "longitudinal crack"
15 up there, should I think of a longitudinal weld, that
16 this crack then -- so the crack is always running in the
17 weld material?

18 MR. HANAUER: Yes, sir. That is the picture
19 we have.

20 MR. SHEWMON: That is not the picture I was
21 shown yesterday by one of you guys. But let's go
22 ahead.

23 MR. HANAUER: That is our current picture, and
24 our current model is based on long longitudinal cracks
25 or long circumferential cracks.

1 MR. SHEWMON: Running always in weld
2 material?

3 MR. HANAUER: Yes, sir.

4 Okay. Now, a final question in deterministic
5 space is, okay, suppose that is the criterion, how do we
6 evaluate the vessel in Skunky Hollow Unit No. 3 and
7 determine its properties to be compared with the
8 screening criterion.

9 We convened a peer group, an expert group, to
10 do this.

11 (Slide.)

12 And their recommendation, which we have
13 adopted, is the following: The RT NDT of any given
14 vessel at any given time is of course -- starts at some
15 initial value and then increases in accordance with the
16 radiation. I will come back to this and talk about the
17 -- no, I'd better talk about them now.

18 Neither of these things is known perfectly, of
19 course. There are substantial measurement
20 uncertainties, and also there are uncertainties
21 regarding the material which is being measured. In many
22 cases the material which is being measured is not the
23 actual weld or a prolongation of it, but a qualification
24 piece which was made on a different day, with nominally
25 the same materials.

1 And so there are at least these two sources of
2 uncertainty. Now, for some vessels and for some weld
3 types, less material is available and so one is forced
4 to consider a population of vessels and welds to infer
5 the properties of weld X in vessel Y from a much larger
6 population, which may or may not be made of the same
7 material.

8 MR. SHEWMON: I used to think that a best
9 estimate was something like a median or mean value.
10 have yet to see anybody who works for the NRC give me a
11 median or mean value. So is that what I will term an
12 NRC best estimate, or is that sort of a best estimate in
13 the sense of mean or median?

14 MR. HANAUER: As one NRC employee, I will tell
15 you that what is intended there is the mean or the
16 median.

17 MR. SHEWMON: Okay.

18 MR. HANAUER: And you will find in Appendix P
19 of the report values for this which may convince you
20 that at long last somebody in the NRC is trying to do
21 that for best estimates. It comes hard. Our whole
22 tradition is different.

23 Now then, the object is to use the best
24 estimate of the initial measurements, which are
25 available for almost all vessels, and then to use

1 Guthrie's correlation for different families, different
2 populations of weld materials, to estimate the change as
3 a function of irradiation.

4 Now, this is not a simple matter. We have
5 already had a discussion this morning with one of the
6 owners groups who would like to quarrel with some of the
7 numbers in Appendix P. We seem to be forever quarreling
8 with the numbers in Appendix P.

9 There is, first of all, the calculation of
10 neutron leakage flux, a subject understood by at most
11 seven people in the world, I think.

12 (Laughter.)

13 And calculated with great difficulty. The
14 codes are not very easy to use and the assumptions that
15 go into the codes can be argued about almost
16 interminably.

17 Having calculated the flux at the inner
18 surface, it is necessary to calculate the attenuation of
19 the neutron flux through the wall and the change in
20 neutron energy spectrum through the wall, because the
21 energy of the neutrons determines their effect on the
22 properties of the material.

23 This matter can also be discussed at greater
24 length. I will say today, I will say now, it could be
25 reopened at much greater length if you want. We now use

1 a model somewhat different from the one in Reg Guide
2 1.99 which includes, we think, the effect of the
3 spectrum hardening through the wall, and we have Mr.
4 Lois and others who are prepared to discuss those
5 questions with you.

6 Then, for conservatism -- and this is one of
7 the places where we put it in explicitly -- for
8 conservatism we add twice the standard deviation of this
9 value. Since there are two components, we consider
10 separately the standard deviations involved in these two
11 components. And since they arise from different
12 physical phenomenon, we add them up at statistically
13 uncorrelated standard deviations.

14 So the result is the initial, the change, plus
15 two standard deviations.

16 MR. BENDER: Steve, in putting in the two
17 sigma allowance you are trying, I suppose, to bound the
18 data?

19 MR. HANAUER: Yes, sir.

20 MR. BENDER: How much of the data is bounded
21 by that?

22 MR. HANAUER: I'm not an expert on this. I
23 have seen the curves and it is, two sigma gets the right
24 percentage of it, which is 95. And there are in
25 Appendix D scatter diagrams that show these bounding

1 curves and how they do it, and there is -- has Guthrie's
2 report come out? Where is Les?

3 MR. RANDALL: This is George Guthrie.

4 MR. HANAUER: How do you do, sir. I have
5 never met you. Has your report been published?

6 MR. GUTHRIE: Not yet, no. No, sir.

7 MR. BENDER: Is it necessary to cover 95
8 percent of the data?

9 MR. HANAUER: Well, how bounding would you
10 like to be? Would you like to deal with a best
11 estimate, with one sigma, with two sigma, with something
12 else? That selection has a lot of arbitrariness to it.

13 MR. BENDER: Well, if every point in a set of
14 curves had equal weight, I guess I would probably accept
15 the argument pretty well. I'm not sure that the points
16 should be given equal weight, because there is a lot of
17 variation in how the determinations are made.

18 Can you comment on that?

19 MR. GUTHRIE: Well, they were given equal
20 weight. But we also had in here, there are two factors
21 to the uncertainty. One part of the uncertainty is due
22 to the fact that we don't know. When we are fitting a
23 curve, we have a Sharpey shift given to us for each
24 point. We have the chemistry given to us for each point
25 and we have the fluids given to us for each point.

1 That assumes that there was an error in the
2 fluence. There are several errors in each of the data
3 points that have to be considered. There is an error in
4 the reported chemistry, there is an error in the
5 reported fluence, and there is an error in the reported
6 Sharpey shift.

7 I took into account the errors in the Sharpey
8 shifts, I took into account the errors in the fluence,
9 and I minimized the sums of the squares of the errors
10 between, the discrepancies between the measured Sharpey
11 shift value and the calculated Sharpey shift value, plus
12 the sums of the squares of the errors between the
13 reported fluence and the fluence as it was adjusted by
14 the fitting code.

15 In other words, the fluence for each one of
16 these points was an adjustable parameter, and within
17 that sort of a method all of the points were weighted
18 deeply.

19 Other people have made studies where they have
20 studied various populations separately and they find
21 that the exponential power, the exponent on the fluence,
22 is different for welds and for plate material. In
23 particular, Combustion Engineering has an opinion that
24 the exponent on the fluence for weld material is a lower
25 value than for the plate material.

1 MR. BENDER: Well, that's enough for now.

2 MR. HANAUER: Here is the Guthrie correlation,
3 or one of the many depictions of the Guthrie
4 correlation.

5 (Slide.)

6 This is hard to see, so the abscissa is the
7 fluence 10^{18} , 10^{19} , 10^{20} ; the ordinate is the RT
8 NDT plus 2 sigma, which had to be uncoupled. And as you
9 can see, this is for three different percentages of
10 copper and these are the correlations we are using.

11 Now then, these correlations, as you can see
12 from this simplified curve --

13 (Slide.)

14 Here is a curve which is intended to show
15 schematically how these things go together. Here is
16 Guthrie's mean curve here for copper and nickel, and
17 here's Guthrie's mean curve plus two sigma. And I've
18 added in the sigma in the RTO also, which would move
19 these curves up or down depending on what RTO was.
20 However, the Guthrie correlation gets very large at very
21 large levels of fluence.

22 And we believe that the Reg Guide 1.99 limit
23 is a more realistic limit at very large fluence levels.
24 However, since the Reg Guide 1.99 already is a limiting
25 curve, we added twice the value of the initial standard

1 deviation and didn't put in another term with the
2 standard deviation in it. It is already in it.

3 So that the way in which we predict RT NDT for
4 this vessel is we decide, we estimate the fluence at
5 some particular time and then we go to this curve, which
6 -- we go to this curve, plus the PTO, whatever it was.
7 And if the fluence is higher than this amount, we use
8 the Reg Guide 1.99 limit.

9 And this then is a defined procedure for
10 giving a conservative estimate of the state of any
11 particular vessel. The results are shown on the next
12 vugraph. You had better use your handout, because my
13 vugraph machine did me dirt and this is essentially
14 illegible.

15 (Slide.)

16 I'm sorry about that. I don't have my handout
17 up here. I will try and work from this.

18 Here are the first seven plants in Appendix P,
19 Table P-1 in your report. Here is the initial RT.
20 Notice that we have numbers like minus 56, so I hope,
21 Dr. Shewmon, you can accept that we really tried to do
22 some best estimate here.

23 Here is the delta obtained in the way that I
24 have described, and here is the standard deviation for a
25 large fraction of the population. The two standard

1 deviations is 60 degrees, but some others are no
2 better.

3 And here is the result as of the last day in
4 December in 1981, that being the date for which these
5 calculations were made. And these are more or less in
6 order, and you will see that in the right-hand column is
7 quite a crude estimate of when these plants will exceed
8 the screening criterion.

9 The first one is Robinson Unit 2 -- or Unit 3,
10 which will exceed the criterion in February 1987, four
11 and a half years from now. So that even for our lead
12 plant, our lucky lead plant, there is a substantial
13 amount of time to do something.

14 MR. BENDER: Steve, is that prior to actions
15 to change the fuel?

16 MR. HANAUER: These estimates are now somewhat
17 -- Neil, do you want to comment?

18 MR. RANDALL: For Robinson we took into
19 account the reduced fuel loading because we had the
20 numbers. All of the others, we did not take into
21 account reduced flux.

22 MR. HANAUER: This is obviously a somewhat
23 moving target. Fuel loadings change, calculational
24 methods are improved. And so I predict by the end of
25 this year there will be a different set of numbers. I

1 know last year there was a different set of numbers.

2 MR. BENDER: When you look up there you become
3 aware of the two sigma value, which doesn't look like a
4 very big number by itself.

5 MR. HANAUER: Plus or minus 60 is not small.

6 MR. BENDER: It is an important number, but if
7 it were the only one --

8 MR. HANAUER: I've seen whole days spent on
9 10-degree differences.

10 MR. BENDER: I'm sure that is the case, and as
11 a matter of fact you are sort of leading to the question
12 I was trying to ask. Because there are a lot of other
13 places where those incremental values are being put
14 together, you are led to wonder how many numbers like 10
15 to 30 degrees are being cranked into that value.

16 MR. HANAUER: Into this value? I hope none in
17 this value. Now, you might ask how much of that stuff
18 is in the screening criterion. The answer, there is a
19 fair amount in the screening criterion. The OCA code,
20 for example, assumes that there is a flaw every place
21 there needs to be a flaw; what is that worth? And the
22 probabilistic discussion after the break gives some
23 insight into that.

24 MR. CATTON: What is ten degrees worth in
25 years, just to get a feel for those numbers?

1 MR. HANAUER: One to three.

2 MR. CATTON: One to three years. So 30
3 degrees up there would be three to nine years?

4 MR. HANAUER: Yes. It's a lot of years.

5 MR. CATTON: So it is important.

6 MR. HANAUER: Yes.

7 MR. BOCK: Of the RT NDT numbers given up
8 there, can you break those down as to which are
9 Guthrie-limited and which are 1.99 limited?

10 MR. HANAUER: It can be done. I can't do it.

11 MR. SHEWMON: Is he approaching the end? Are
12 we going to take a break?

13 MR. HANAUER: Yes. This is my last pre-break
14 vugraph.

15 MR. SHEWMON: Well, before or after the break,
16 I would like to hear a discussion of whether the
17 operators are sent home the days we think we're going to
18 get a transient, whether we are doing anything to work
19 with them. That discussion has been completely devoid
20 in that area.

21 MR. HANAUER: Yes. That is after the break.

22 MR. BENDER: Are there any other questions?

23 MR. REMICK: On Robinson, Steve, the
24 difference in the delta RT between the circumferential
25 and the axial, is that due to a difference of materials

1 in the weld material or is fluence factored into that
2 difference?

3 MR. HANAUER: Both factors are there, but the
4 largest one is the difference in the copper content of
5 the weld.

6 MR. REMICK: Thank you.

7 MR. BENDER: This sounds like the right time.

8 MR. SHEWMON: One last point, and we will see
9 what we're talking about after the break. Not that
10 those sorts of things have ever inhibited this Committee
11 particularly.

12 But I have the feeling that these numbers are
13 probably about what they should be, or at least much of
14 the gross conservatism has been squeezed out of them.
15 The other thing comes back to how these relate to the
16 particular trip points that you have said and what is
17 likely to happen after these criteria or trip points or
18 whatever you call them do happen, and that maybe we will
19 discuss for the next couple of years. But maybe we will
20 discuss it today.

21 MR. HANAUER: We will discuss it at some
22 length after the break.

23 MR. SHEWMON: Fine. Okay.

24 MR. ZUDANS: The explanation of difference in
25 delta RDT was given as being different chemistry in the

1 welds. So why are the initials the same?

2 MR. SHEWMON: Because we don't know any
3 better.

4 MR. BENDER: Could we break now and let Dr.
5 Zufans get that question after the break?

6 (Recess.)

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. BENDER: If we could reconvene, there may
2 be a couple of open questions yet. Bob?

3 MR. AXTMANN: If I heard you correctly before
4 the break, you were saying that neutron spectrum hardens
5 while it goes through the wall. Is that right?

6 MR. HANAUER: Yes, sir.

7 MR. AXTMANN: Could you explain that a little
8 bit?

9 MR. HANAUER: Not very well. I will call on
10 the experts very soon. The neutron damage comes from
11 the interaction of the fast neutrons with the atoms in
12 the metal.

13 MR. BENDER: Could we have some quiet in the
14 back of the room, please?

15 MR. HANAUER: The nominal measurement of
16 neutron flux to include all neutrons above one MEV and
17 no neutrons below MEV is a gross approximation. In
18 fact, there is a spectrum of damage per interaction
19 which depends in a continuous way on the neutron
20 energy. There are various models to represent this.
21 The model which we presently favor uses displacement per
22 atom of the metal as a function of neutron energy. When
23 you do this, you will find that, and you have to know
24 the interaction probability as a function of neutron
25 energy, which of course changes.

1 When you do that, you find that the neutrons
2 of lower energy have a higher probability of
3 interacting, and therefore as this beam of neutrons goes
4 through the material, the lower energy neutrons are
5 preferentially removed, and so the beam is attenuating
6 as it goes through the material, but the beam at the --
7 deep into the material has proportionately a larger
8 fraction of higher energy neutrons which have a higher
9 damage potential per neutron, and there is a model for
10 this based upon metallurgical and neutron physics
11 measurements.

12 MR. AXTMANN: Thank you.

13 MR. HANAUER: Now, if you want anything more
14 than that, I have to call on my experts.

15 MR. BENDER: Let's presume he doesn't. Any
16 other questions?

17 MR. HANAUER: I left one open, which is the
18 operator thing, which I will get to.

19 MR. WECHSLER: Steve, you mentioned just
20 before the break the fact that the Guthrie regression
21 analysis leads to very high delta RT NDT's at the higher
22 fluences, and that because of that, you choose to use
23 the Reg. Guide 1.99 curve to govern at the high fluence
24 rate, at the high fluence portion of the curve. I
25 wonder if you could amplify that a little for me. I am

1 a little puzzled, because if the Guthrie analysis leads
2 to high values, one has to feel that that is because the
3 surveillance results lead to high values at the high
4 fluence end, and thus there must be some rationale that
5 allows you to prefer to go to the Reg. Guide rather than
6 the Guthrie fit at the high fluence end.

7 MR. HANAUER: Well, a little is all I can
8 discuss it, and then I will refer to my experts. The
9 Guthrie correlation, and we have Mr. Guthrie to discuss
10 it, chose to use a very simple form for the correlation
11 which was justified in many different ways. When you
12 look at how it relates to the data at very high fluence,
13 we have decided that in fact it is substantially above
14 the data in the very high fluence in spite of its
15 overall least squares characterization, and in our
16 examination of the data at high fluence, we believe that
17 the Reg. Guide 1.99 satisfactorily bounded the data.

18 Now, that is an extremely general answer, and
19 I will call on Mr. Randall and Mr. Guthrie to
20 collectively or together to answer you in more detail.

21 MR. RANDALL: Well, when we applied the
22 Guthrie mean plus two, some of the squares, sigma nought
23 plus sigma ielta, and compared that number with the Reg.
24 Guide upper limit plus the two sigma nought, the former
25 was higher, but we know that we don't have any

1 surveillance data which fell above the upper limit line
2 of the Reg. Guide 1.99, which was an upper limit line,
3 so we simply said we won't make them use a number higher
4 than any we have observed, and that is why we fell back
5 to Reg. Guide 1.99 in that fluence region.

6 MR. ZUDANS: But that raises another
7 question. You did that yet in the rest of the portion
8 those data points were included. Then the correlation
9 would have been different if you dropped those points,
10 the ones -- the section of the curve you based on Reg.
11 Guide 1.99 covers a certain range of points, data points
12 that were put in the correlation that affected the
13 previous set, and that means in one cases you included
14 them and in one case you didn't, and that is rather
15 arbitrary.

16 Is that what you did? In other words, there
17 was a set of data points where the correlation would be
18 right. The Guthrie correlation exceeds that Reg. Guide,
19 and at that point you say, okay, because the Reg. Guide
20 is known to be a bound, you use the Reg. Guide yet you
21 leave the correlation the way it was. And actually, you
22 should have excluded those points in the correlation to
23 see what the correlation does then.

24 MR. BENDER: So you are saying break it into
25 two populations.

1 MR. ZUDANS: That is right. Did you do that
2 or not?

3 MR. RANDALL: No, we did not.

4 MR. ZUDANS: In that case it is quite
5 arbitrary.

6 MR. RANDALL: Well, if I understand you, we
7 did not go back and redo the Guthrie correlation.

8 MR. ZUDANS: But, see, the Guthrie correlation
9 is affected by those points beyond certain fluence.

10 MR. RANDALL: Certainly.

11 MR. HANAUER: Perhaps Mr. Guthrie could
12 comment on this point.

13 MR. WARD: Were there any data above that
14 fluence in the Guthrie correlation?

15 MR. GUTHRIE: As I understand it, whether --

16 MR. RANDALL: This comes about because of the
17 addition of the two sigma nought plus the sigma delta
18 squared. There is a scatter point that will show you
19 what the data were.

20 MR. WECHSLER: That is Page 17 in Appendix E.

21 MR. RANDALL: Yes, E-17 is right. Now, that
22 shows how well the Guthrie formula fit the data base
23 that we had. Now, when we add that plus two sigma line
24 is really two sigma on that calculation, which is two
25 times 24 degrees or 48. It does lie above the points of

1 the high fluence, and maybe that explains why there is
2 this difference.

3 MR. WECHSLER: That lies above the points at
4 low fluence as well.

5 MR. RANDALL: Yes, it does.

6 MR. WECHSLER: So that would hardly be a
7 reason. The fact remains that the residual calculated
8 minus observed for data points, let us say, above
9 10 shows roughly the same scatter as the points
10 below 10^{19} , as the points far below 10^{19} . So I have
11 to say I really don't understand your answer.

12 MR. SHEWMON: Would you restate your original
13 question?

14 MR. WECHSLER: Yes. My question relates to
15 the statement that Steve Hanauer made that the Guthrie
16 fit, the Guthrie equation shows very high predicted
17 delta T or delta RT's NDT and for that reason instead of
18 using the Guthrie fit for the higher fluences, they
19 chose to use the Reg. Guide 1.99, and so I asked, what
20 is the rationale for having done that. I understood
21 Neal Randall to say that the reason was, as you can see
22 in this figure, E-17 in Appendix E, you can see that the
23 plus two sigma line is above all the residual values in
24 that plot, not just those that pertain to fluences above
25 10^{19} , and so I still remain uncertain as to the

1 rationale for using the Reg. Guide above 10^{19th} .

2 MR. RANDALL: All I can do is repeat my
3 original statement that being pressed to not be
4 overconservative, we used Reg. Guide 1.99 upper limit in
5 that region because no data points from surveillance
6 fell above that Reg. Guide upper limit curve.

7 MR. BINFORD: If you superimposed on that
8 diagram of E-17 the Reg. Guide 1.99, I wonder what it
9 would look like.

10 MR. RANDALL: I have not done that.

11 MR. GUTHRIE: I was not intimately involved in
12 drawing this broken part of the curve there, where the
13 1.99 went in. But if you look at this figure that we
14 have been referring to for the last couple of minutes,
15 if you became sympathetic to the owners and wanted to
16 give them as much as you could and still maintain
17 safety, you could draw a slightly tilted line in the
18 upper righthand part of the figure and still bound the
19 data that is plotted on this graph, and this does give
20 -- well, it doesn't penalize the owners as much as they
21 would be penalized if you used the plus two sigma lines.

22 It is possible to draw another straight line
23 which intersects the plus two sigma line somewhere
24 around 1×10^{19th} , and goes down to the right, and
25 therefore is lower in the higher fluence ratings.

1 MR. WECHSLER: I see, so you are essentially
2 saying that above 10^{19th} in Figure H-17, there are
3 more points lying above the zero line than lie below
4 it. In other words, your formula overpredicts based on
5 the actual data for fluences above 10^{19th}.

6 MR. GUTHRIE: In H-17, what I am saying is
7 that in that pattern under the plus two sigma line in
8 the upper righthand corner there, if you wanted to give
9 the owners everything you could without sacrificing
10 safety, you could draw that plus two sigma line with a
11 slight downward slope up there in the upper righthand
12 corner -- you don't have to keep it flat -- and still
13 cover all the data that is available.

14 MR. BENDER: Let me ask, if I can, that we
15 leave the detail of this discussion to the private
16 conversations. I want to get Dr. Hanauer through this
17 story today, and we may be able to come back to this or
18 get to questions later on.

19 MR. ZUDANS: There still remains this question
20 that I asked, namely, why the population wasn't split up
21 into two pieces at that point.

22 MR. BENDER: You might even ask whether it
23 should be in several populations, or whether you should
24 have a straight line. There are a lot of things you
25 could ask. Or how good is the fit.

1 Bill, did you have something different?

2 MR. BOCK: Well, I wanted to elaborate a
3 little bit on this subject. I think I know what the
4 problem is. But we could defer that. I can do it in
5 about two minutes, or we could defer it.

6 MR. BENDER: Well, go ahead.

7 MR. BOCK: The problem, I believe, is not so
8 much the fluence as the nickel, and if you flip over two
9 pages to where you see percent nickel as the abscissa,
10 virtually all of the test specimens used have a nickel
11 composition of less than .75 percent, so we have good
12 data in that range, but we are now trying to apply it to
13 vessels with much higher nickel content, for example,
14 Robinson is 1.2, or Calhoun with 1.0.

15 So, we are beyond the range of experimental
16 data, and we are trying to extrapolate out there.

17 MR. BENDER: Well, that is one viewpoint.
18 Steve, I think we had better go ahead.

19 MR. HANAUER: What I propose to do now is to
20 talk about the probabilistic analyses we have done, to
21 bring in the question of what the operators do and what
22 we have done about what the operators do, and then to
23 talk about where we go from here.

24 The probabilistic analysis in June was viewed
25 by us as a long-term research program. However, as a

1 response to our June position paper, in this room, the
2 industry pointed out a number of things which in their
3 opinion we have done incorrectly, and brought to us in
4 May, actually, a Westinghouse owners' group
5 probabilistic study of pressurized thermal shock that
6 provided a great deal of insight, and which has, I
7 certainly hope, been provided to you.

8 There is a very large amount of documentation
9 on this whole subject. You will find it summarized in
10 Appendices A and B of the report. If the working group
11 discovers it doesn't have some important pieces of
12 paper, they may lay the oversight on us, and we will of
13 course make all of it available. I don't believe any of
14 it is proprietary, but if it is, we know how to do that
15 too.

16 Now, we have a research program going on which
17 in a couple of years will presumably walk in the same
18 footsteps as the work I will now describe, perhaps with
19 additional precision and completeness, perhaps not, but
20 the work I will now describe is the work of the
21 Westinghouse owners' group reported to us in a May
22 letter and in several meetings between June and now.

23 What they did was to consider about 20
24 initiating events that could lead to overcooling
25 transients and pressurized thermal shock. They then

1 drew in the usual way event trees and safety functions,
2 and determined which event sequences of the possible
3 ones were in fact significant in terms of probability
4 and could in fact result in pressurized thermal shock
5 sequences. Those that they consider to be significant,
6 after some of our discussions, they then characterized
7 in terms of TF, theta, and constant pressure, and
8 frequency or probability as a result of their evaluation
9 of the trees.

10 They then used Strosnider's results, which
11 have been discussed with the subcommittee on several
12 occasions, and which I will recapitulate very briefly,
13 to determine probabilistically an evaluation in detail
14 of the curve beyond but including the range in which the
15 experience was involved.

16 Now, here is the place I suggest to consider
17 the role of the operator in the actual experiences, the
18 role of the equipment functionability, and the actions
19 of the operator determined which sequence actually took
20 place in these eight events amongst the dozens or
21 hundreds of possibilities of sequences, and so what we
22 have in these eight events, evaluate them how you want,
23 what they have evaluated is the eight sequences which
24 actually occurred, and any inference you draw from them
25 assumes that the operator actions as well as the

1 equipment actions of those eight sequences are somehow
2 typical of how the operators and the machinery works in
3 a more general way.

4 Now, we know that at best such an
5 extrapolation is only approximate, and that the right
6 way to do it is to consider all of the possible
7 sequences or all of the significant sequences, and to
8 include in them in some way at the branch points the
9 operator does or does not do this or that important
10 function which significantly affects the output of the
11 pressurized thermal shock sequence.

12 Now, the methodology, the science behind this
13 is not very well developed. Swain and his co-workers at
14 Sandia have over the past number of years published a
15 number of handbooks and methods to estimate the
16 probability of whether the operating crew will or will
17 not do some necessary thing. We have at this time no
18 methods for estimating whether the operators will do
19 better than that and will in fact mitigate the situation
20 beyond their stereotyped procedures.

21 Similarly, we have at the present time no
22 models for predicting whether the operators will do
23 something bizarre and make the situation worse outside
24 the parameters of their operating procedures. About 150
25 miles north of here is one data point in which the

1 operators did in fact do some bizarre things, and the
2 consequences were severe indeed. However, we don't have
3 at this time any really scientific way of making such
4 predictions, although we do have the beginnings of a
5 scientific way of predicting whether they will or will
6 not do some defined correct thing.

7 Now, this has been handled in two ways which
8 are really quite diverse. In the Westinghouse
9 probabilistic study, the Westinghouse owners' group
10 probabilistic study, one of the parameters is the time
11 delay of the operators in doing certain important,
12 correct things, and one of the time delays is infinity,
13 they don't do it at all, and so operator action has been
14 included in this way in the probabilistic study.

15 Now, it is also clear from the pressure curves
16 which I showed earlier and from the course of some of
17 the actual events that the operators can really make
18 things a lot worse or a lot better, and so we have in
19 progress and more than half completed a program in which
20 we have audited the procedures related to pressurized
21 thermal shock in the eight plants for which we got
22 pressurized thermal shock evaluations from the licensees
23 last year.

24 Then, in addition to auditing the procedures,
2 audit team has discussed with representative members

1 of the operating crew how well they understand
2 pressurized thermal shock, and has assessed in an
3 extremely crude way the likelihood of whether these
4 operators would do the right thing in a pressurized
5 thermal shock sequence. This evaluation was not
6 quantitative, but was rather an overall evaluation. The
7 results have been varied. Some crews did rather well
8 and some crews did rather poorly.

9 These audit results -- I guess there are now
10 three or four, Jim, that have been issued. Do you
11 remember?

12 MR. CLIFFORD: All of them have been
13 completed. The reports are in and should be distributed
14 very shortly.

15 MR. HANAUER: There are a few reports that
16 have already been distributed, aren't there?

17 MR. SHEWMON: The Robinson report was
18 distributed several months ago. We have not seen
19 anything since.

20 MR. HANAUER: Jim, what is the present status,
21 please? Mr. Clifford.

22 MR. CLIFFORD: Jim Clifford of the staff. All
23 of the reports have been received and submitted to
24 licensing and should be distributed shortly.

25 MR. BENDER: We have seen more than one, but I

1 don't think we have seen them all.

2 MR. HANAUER: You have certainly not seen them
3 all. At least one has been deferred.

4 MR. SHEWMON: Well, I haven't, and the
5 consultants who are most interested in that haven't.

6 MR. BENDER: Well, I agree with that, that
7 they haven't been probably generally distributed.

8 MR. HANAUER: The results have been, there is
9 one other piece of information, and that is, there is an
10 ongoing very large and well known to the Committee
11 improvement program in emergency operating procedures
12 involving a large program of realistic analyses of a
13 large number of event sequences. The correlating of
14 these realistic analyses into new technical procedure
15 guidelines, including some symptom-based guidelines for
16 maintenance or restoration of the critical safety
17 functions, this is under Three Mile Island Action Plan
18 Item 1-C-1. It has been going on for at least a couple
19 of years, and very likely will be going on for at least
20 a couple of more years.

21 As part of this program and as part of the
22 pressurized thermal shock analysis, we have a
23 Westinghouse report dated a couple of months ago in
24 which a team of Westinghouse owners' group evaluated the
25 presently developmental Westinghouse owners' group

1 emergency operating procedure guidelines, and that is
2 probably not the formal title, and concluded that in
3 fact they don't treat pressurized thermal shock
4 particularly well, and a substantial number of changes
5 were appropriate.

6 This report I certainly hope has been sent to
7 the Committee.

8 MR. BENDER: Steve, your observation leads me
9 to a direction which I hoped you would be able to
10 discuss some. The Robinson report was not very
11 comforting.

12 MR. HANAUER: No, sir.

13 MR. BENDER: It was an audit done very early
14 in this program, however. Are we in a position now to
15 say that we know what kind of training program the
16 operators need?

17 MR. HANAUER: Well, I will give you my
18 opinion, which is that the procedure guidelines, at
19 least the Westinghouse procedure guidelines, which are
20 the relevant ones for Robinson, are being changed in
21 quite a drastic way for Three Mile Island type reasons,
22 and that a few months ago the developmental revised
23 procedures were shown to need some more work regarding
24 pressurized thermal shock. That tells me, no, we don't
25 know all we should about pressurized thermal shock in

1 emergency operating procedures, and in fact the audit
2 team developed a very useful, I think, set of guidelines
3 about the things that should be done now in auditing
4 pressurized thermal shock procedures, and that these
5 guidelines can be found in Appendix -- Which one is it,
6 Jim? Do you remember? Of this report?

7 MR. CLIFFORD: Appendix C.

8 MR. HANAUER: Appendix C of this report
9 contains a discussion of what can be done now. The
10 right way to fix this for the long term is to get these
11 guidelines right for pressurized thermal shock and
12 everything else. You walk, you see, between overcooling
13 the vessel on one side and undercooling the core on the
14 other side, and that is one of the reasons why I don't
15 want a highly conservative pressurized thermal shock
16 design basis accident which impels the operator to
17 undercool the core and make us another kind of an
18 accident.

19 Your point is very well taken, in other words,
20 that we don't know some things about how to write these
21 procedures, and the training, of course, goes with the
22 procedures. We in our offices, the kinds of people we
23 have in a room, in our quiet offices, must solve the
24 pressurized thermal shock problem before and not give
25 contradictory instructions to the people on the night

1 shift who have to make these decisions and operate the
2 plants.

3 Therefore, the audit teams have very properly
4 been rather modest in what they have recommended as
5 short-term changes.

6 MR. BENDER: Well, I don't think we can
7 explore this further today, but as a long-time proponent
8 of repressurization for a number of reasons, recognizing
9 that it can't hurt anything in the thermal shock
10 business, I was rather hopeful that at least that aspect
11 of things would have been developed better and sooner.
12 and I am not clear that we understand even what needs to
13 be done.

14 MR. HANAUER: It has not, and practically
15 every line or every page in the Westinghouse procedure
16 review points out that for this, that, and the other
17 sequences the operators are told to repressurize to
18 2,000 psi.

19 MR. BENDER: Well, that is hardly reassuring,
20 but let's go on.

21 MR. HANAUER: All right. Now, at the present
22 time, we do not have the calculational facility. We
23 have all of the theory, but we simply haven't done the
24 code work to represent these various transients in terms
25 of critical RT NDT and thereby to take into account the

1 reality of the transients. We have been in the present
2 state of development constrained to use TF, beta, and
3 constant pressure to characterize all of these different
4 sequences.

5 (Slide.)

6 MR. HANAUER: When you do it you get these
7 results. If you will direct your attention first to the
8 dotted curve, this is the Westinghouse PRA expressed in
9 terms of TF. Now, in fact, the Westinghouse PRA used
10 TF, beta, and pressure, and so I am oversimplifying an
11 oversimplification in order to get it onto a
12 one-dimensional vu-graph, but this is the curve which is
13 obtained. You will notice that it has the same shape as
14 my first vu-graph that showed tails and so on, and that
15 shouldn't surprise anybody. It goes from very high
16 frequency above about 300 degrees to rather low
17 frequency, ⁻⁴10 or lower below 200 degrees.

18 Now, the staff has not accepted every detail
19 of the May-June Westinghouse PRA. The staff has found a
20 number of sequences we believe were incorrectly
21 characterized, some overconservative, some
22 overoptimistic, and the staff has not agreed with some
23 of the Westinghouse frequencies and probabilities, and
24 so the staff has, and this is explained at some length
25 in the report and in Appendix G to the report, the staff

1 has devised a PRA which differs to some degree from the
2 Westinghouse PRA, and which is shown as the solid curve
3 here.

4 Now, neither of these has had the kind of
5 man-years of work or the kind of peer review that this
6 subject deserves, and both of these results must be
7 characterized as preliminary in some ways. My own
8 belief is that a great deal more of this work is
9 justified. We have a research program in this area, and
10 I think the industry ought to work on this, too.

11 Moreover, we have only the Westinghouse
12 generic analysis, in which they have tried to bound or
13 typify in various parts of analyses the Westinghouse
14 plants, so that it is generic to Westinghouse plants and
15 individual plants may differ substantially. This
16 question has not been evaluated, and the applicability
17 of this to Combustion and B&W plants is not now known.
18 We do not have comparable analyses for these other kinds
19 of plants.

20

21

22

23

24

25

1 MR. SHEWMON: You've plotted the frequency of
2 what up there?

3 MR. HANAUER: This is the frequency of getting
4 a transient more severe than TF equal to this value. We
5 are back to TF, beta and pressure, and what I did, or
6 what we did was to take the dozens of different
7 sequences --

8 MR. SHEWMON: TF is fluid temperature?

9 MR. HANAUER: Yes, sir. Each sequence we
10 characterized in terms of TF, beta, pressure and
11 frequency, and this is a result plotted in TF space.

12 MR. BENDER: Steve, a separate aspect of the
13 same question has to do with the matter of how much
14 operator reaction is in those curves.

15 MR. HANAUER: There's a lot.

16 MR. BENDER: Westinghouse, as I recall it, set
17 up three time periods -- maybe there were more -- for
18 operator response and assigned some frequency of correct
19 action to each time period.

20 MR. HANAUER: Yes, sir.

21 MR. BENDER: Is there any judgment of whether
22 using those kinds of what amounts to arbitrary
23 evaluations of operator response has an effect on the
24 depiction up there? And are they important to the
25 argument?

1 MR. HANAUER: I can speak best to the staff
2 analysis. The dominant events in the staff analysis do
3 not depend very much on operator action. We evaluated
4 the Westinghouse numbers. They seemed reasonable to us,
5 but in the end in ours, -- I haven't undone the
6 Westinghouse one enough to answer. But in ours, the
7 operator action is not terribly important because the
8 dominant event is the stagnant, small break loss of
9 coolant accident and the operator can't do much about it.

10 In some of the others, the operator reactions
11 are important. I don't have an analysis that answers
12 your question in any quantitative way.

13 MR. ZUDANS: Just quickly to make sure that we
14 are on the same wavelength. You said these curves
15 represent the beta and p is constant. Did Westinghouse
16 consider constant pressure when they did their PRA?

17 MR. HANAUER: Westinghouse did exactly what I
18 described. They also characterized sequences for
19 constant pressure, TF and beta because the only
20 probabilistic vessel response calculation in town
21 requires that as input.

22 Now, this can and should be improved, but has
23 not been at the present time.

24 MR. ZUDANS: I have a problem with this
25 concept of constant pressure.

1 MR. HANAUER: Of course. It is a gross
2 over-simplification.

3 MR. BENDER: Well, it depends upon what
4 pressure you use.

5 MR. THEOFALOUS: It seems to me if you could
6 take this curve one step farther, a small step farther,
7 to give it in terms of critical RT NDT, it would be
8 extremely useful. And of course, that could help you
9 focus on exactly the kinds of sequences that are
10 important to look at. And one can dig in more detail
11 into those sequences.

12 MR. HANAUER: It could, indeed. That is a
13 piece of business that has to be addressed.

14 MR. THEOFALOUS: You could use that chart to
15 get from this kind of a plot to this plot down here.

16 MR. BENDER: But you have to become very plant
17 specific I think in order to do that.

18 MR. VAGINS: You have it in the following
19 curves.

20 MR. THEOFALOUS: Maybe you have it already.

21 MR. VAGINS: Within a range of some transients.

22 MR. HANAUER: Yes. At the moment we have this
23 stereotyping of the transient as an intermediate step.
24 You are quite right, we should develop a better method.

25 (Slide.)

1 I now show you three of the probabilistic
2 vessel failures. You have had this described to you
3 before. In two minutes, what Strosnider and his
4 colleagues have done is taken essentially the same
5 deterministic fracture mechanics model, as we discussed
6 earlier, but instead of assigning conservative or
7 estimated values for the parameters, they took frequency
8 distributions of the parameters which were not well
9 known or which were subject to variation and calculated
10 a large number of possible events in which these various
11 parameters were picked in the Monte Carlo probabilistic
12 way from these frequency distributions.

13 The result was then they did this ⁶ 10⁶ or
14 more times for each case in a code that does this for
15 you, and the result is that some fraction of these 10⁶
16 resulted in vessel failure and some fraction did not.
17 And from this was deduced in a simple way an estimate of
18 the probability of vessel failure, given this transient.

19 Now, the problem at the moment in doing what
20 you suggested a moment ago is that this code today is
21 set up with TF, beta and pressure. Next year we will
22 have something better. And I have three cross-plots of
23 this response surface, which are in the report and which
24 you have no doubt seen before.

25 Here it is with temperature as the abscissa.

1 Always the probability of failure is the ordinate, and
2 here, beta is the parameter. As you can see, these
3 curves are very steep in temperature. That is to say, a
4 factor of 10 change in probability is associated with a
5 very small number of degrees, like 10 or 20, change in
6 temperature. So the temperature is, indeed, a dominant
7 variable.

8 You also see that for large values of beta
9 there is very little difference, but as beta gets small
10 it makes a substantial difference and decreases
11 substantially the probability of vessel failure
12 calculated in this way.

13 Another cut of the same response surface is
14 shown here --

15 (Slide.)

16 -- in which the abscissa is pressure, and here
17 is an answer to your question now, in probability
18 space. Here is the probability of failure as a function
19 of pressure with a constant beta of .15, and now the
20 temperature, T final, is the parameter. And you see
21 that the slopes of these curves are not very large; that
22 a factor of 10 in failure probability is associated with
23 1000 psi or more. This is not exactly negligible but it
24 is not the very steep behavior that was shown in
25 temperature space.

1 (Slide.)

2 A third section or cross-plot of the same
3 surface is given here, in which we plot the beta
4 dependence, and not surprisingly for all large betas,
5 the dependence is very small. But as the betas become
6 smaller, the accidents become much less severe. So as
7 we knew already, but it is comforting to see it, as a
8 result for slow transients the thermal stresses are
9 small and the probability of vessel failure is small.

10 MR. THEOFALOUS: The question I was asking
11 before could be answered also in terms of these graphs
12 here. Do you have a way, -- if you knew that you were
13 interested in a distribution of this plot, do you have a
14 way of backing out which sequences are contributing to
15 that?

16 MR. HANAUER: Yes, but a fairly crude one,
17 which we can show very quickly in the next slide. Let
18 me show you an example.

19 (Slide.)

20 We have, in fact, made the calculation,
21 exemplified by this curve. This one has -- this one is
22 for the Westinghouse probabilistic analysis, and the
23 Strosnider, et al vessel failure analysis, coupled in
24 the way that I have described. And you see here the
25 contributions of various kinds of accidents. So yes, it

1 can be done. It is some work.

2 Now, yes sir?

3 MR. SHEWMON: Before you go with your
4 development I want to go back and finish your question.
5 I wanted to see the previous slide, but you can answer
6 the question here.

7 MR. HANAUER: Do you want the next previous
8 one?

9 MR. SHEWMON: I wanted beta versus conditional
10 failure. We were talking earlier about heat transfer
11 coefficients of 300 or 1000. Is that with 300 or 1000?

12 (Slide.)

13 MR. HANAUER: Three hundred.

14 MR. SHEWMON: And that, what, tends to flatten
15 it off then, when one gets the very high betas?

16 MR. HANAUER: Well, it is a combination of the
17 300 and the conduction in the metal.

18 MR. SHEWMON: Yes, but if you get -- I mean,
19 they are in series, so the conduction of the metal isn't
20 a disposal parameter.

21 MR. HANAUER: That's correct.

22 MR. SHEWMON: And as you get the heat transfer
23 in the liquid slower, that ought to --

24 MR. HANAUER: There's a curve in your report
25 where the heat transfer coefficient has a parameter

1 which I didn't reproduce. It would be -- or it's in the
2 appendix, isn't it? Jack, maybe you can refer to it.

3 We have the surface cut in heat transfer space.

4 MR. SHEWMON: I would have taken a yes for an
5 answer.

6 MR. HANAUER: The answer is yes.

7 MR. STROSNIDER: It's Figure H-30.

8 MR. HANAUER: Figure H-30 has just that
9 dependency in it.

10 MR. ZUDANS: Was cladding included in these
11 calculations for both heat transfer and mechanical, or
12 neither, or some other combination?

13 MR. HANAUER: Heat transfer, yes. Mechanical,
14 no. The heat transfer of the cladding was included in
15 deciding to use 300. That includes the effect of the
16 cladding; it was lumped.

17 Now, in these calculations the stress due to
18 the differential expansion of the cladding is not
19 included. We have done some more recent calculations,
20 but it is not included in this.

21 MR. ZUDANS: So if the 300 represents both the
22 film coefficient and the cladding, what was the film
23 coefficient in that combination?

24 MR. KLECKER: If one assumes water to metal
25 heat transfer coefficient of 300, the effect of heat

1 transfer coefficient is approximately 200. If you
2 assume roughly 600 to 1000, then the effect of heat
3 transfer is more like 300.

4 MR. ZUDANS: So this is not the effect of
5 coefficient of heat transfer and metal? The 300 was
6 assumed for the film coefficient and the metal
7 contribution was added to it?

8 MR. KLECKER: We have done that in our
9 deterministic calculations.

10 MR. STROSNIDER: Let me answer that. The
11 effective heat transfer coefficient was 300 which would
12 correlate to a film transfer coefficient of 600 to 1000.

13 MR. ZUDANS: So you never run any calculations
14 of film coefficient of 300?

15 MR. STROSNIDER: No.

16 MR. ZUDANS: Plus the conductivity in the
17 metal. So really, all of this conversation has been
18 misleading. That is not the film coefficient; it is the
19 600 to 1000, and that is quite a different story.

20 MR. SHEWMON: Well, let me ask, since another
21 factor of 2 in whatever they have called their transfer
22 coefficient, and all of a sudden it starts having an
23 order of magnitude change in the probability of the
24 accident. So I would be interested in -- it is your
25 Figure H-30, go look at it -- I would be interested in

1 hearing the heat transfer people comment on what they
2 think of a film transfer coefficient of 600 to 1000 by a
3 factor of 2 or 4.

4 MR. THEOFALOUS: Two or even three.

5 MR. BENDER: But how do you convert that into
6 the overall heat transfer coefficient? What I'm talking
7 about is if I cut the film coefficient in half, what
8 would be the overall heat transfer coefficient
9 equivalent to 300, when you are using a value of 600 to
10 1000?

11 MR. ZUDANS: That's a good point.

12 MR. THEOFALOUS: I have done that in the
13 little thing I gave you, and that is one I remember. I
14 was coming up with a best estimate, something like 200
15 for overall, 200 to 300 overall.

16 MR. BENDER: Well, it seems to me one of these
17 days you've got to look at that point. It is not a
18 one-to-one relationship, but it does have a big effect.

19 MR. SHEWMON: Steve, if you look at your
20 curve, it has between one and two orders of magnitude
21 difference in going from 300 to 150. So there is a
22 profound effect on the probability, if I might use that
23 word.

24 MR. ZUDANS: And it's not sure that this is
25 the film coefficient. Maybe this is combined.

1 MR. SHEWMON: But at least he is on a steep
2 part of the curve.

3 MR. BENDER: If I heard Jack Strosnider right,
4 he was talking about the overall coefficient.

5 MR. ZUDANS: That's right. And that is 600 to
6 1000.

7 MR. BENDER: In Theo's number, the 300 might
8 be 200, and that might be an important difference.

9 MR. HANAUER: It might, indeed.

10 MR. BENDER: Carry on, Steve.

11 (Slide.)

12 MR. HANAUER: The results. I have two, one
13 for the Westinghouse and one for the staff. The results
14 are plotted as frequency per reactor year of cracking
15 the vessel without arrest. Now, arrest is in the
16 model. If the crack arrested, we didn't count it as a
17 failure, and we included in our arrest model an upper
18 shelf tough failure limit of 200 ksi square root of
19 inch, so we didn't allow arrest with a K1 applied higher
20 than 200 ksi square root of inch.

21 So we don't show any arrest for cracks that
22 extend more than about halfway through the metal, if I
23 recall correctly. But crack arrest is now in here, and
24 when it says "crack extension, no arrest," it really
25 means crack extension with arrest calculated not to

1 occur.

2 Now then, here is the frequency per reactor
3 year, and it is plotted in terms of the RT NDT at the
4 surface of the vessel. So a vessel starts off at the
5 beginning of life off the lefthand side of this diagram,
6 and as the vessel ages its RT NDT creeps to the right in
7 accordance with the fluids and the properties of the
8 material. And then, as the temperature gets in the
9 interesting range, the probability of it failing per
10 reactor year or frequency per reactor year goes up in
11 accordance with this curve.

12 As you can see, --

13 MR. THEOFALOUS: Are you going to change?

14 MR. HANAUER: Soon.

15 MR. THEOFALOUS: Before you change, I was
16 curious on the small break. Some small break LOCAs will
17 result in loss of natural circulation, while some other
18 ones will not. And the difference in the behavior is
19 very different, drastically different. And I was
20 wondering how do you assign relative probabilities to
21 those small breaks that don't have natural circulation
22 versus the ones that do? And which ones are you
23 plotting here?

24 MR. HANAUER: I will tell you how we did it.

25 This is a plot of the Westinghouse analysis in which the

1 small break loss of coolant accident has a negligible
2 contribution because in their analysis, which included
3 the effects of warm pre-stressing, as ours did not, they
4 calculated that the small break loss of coolant
5 accidents would be arrested by warm pre-stress phenomena.

6 As you will see in the next slide, in ours the
7 small break LOCA is dominant. What we did was we
8 divided the spectrum of break sizes and selected for a
9 separate set of boxes the break size in which -- the
10 break size range in which stagnation would occur. We
11 calculated its frequency and its consequences separately
12 from the others, and they turn to to dominate.

13 MR. BENDER: Before you get off that, --

14 MR. HANAUER: I have another one for the staff
15 PRA.

16 MR. BENDER: I just want to ask what pressure
17 is associated with this computation?

18 MR. HANAUER: Each sequence was evaluated in
19 this approximate way and characterized by a constant
20 pressure. They were different for different sequences.

21 MR. BENDER: But they are mostly elevated
22 pressures now?

23 MR. HANAUER: Well, the one that dominates the
24 small break LOCA that stagnates is -- we used a pressure
25 of 1000 psi, which is where we calculated the pressure

1 would hang up.

2 MR. ZUDANS: In determining this arrest or not
3 arrest curve, essentially the critical RT NDT at the
4 surface was the crack propagation through the thickness
5 followed, and the stress factor reduces, and the RT NDT
6 reduction taken into account?

7 MR. HANAUER: Yes, sir, that was done in some
8 detail for each calculation. The properties of the
9 material as a function of the irradiation, which is
10 different through the wall, and the temperature as the
11 temperature changes, the change in K_I as the crack
12 enlarges, and the change in the critical in the crack
13 initiation K and in the crack arrest K as a function of
14 temperature were all taken into account.

15 MR. BENDER: But the crack is always in the
16 worst place?

17 MR. HANAUER: This is all for longitudinal
18 cracks.

19 MR. BENDER: Yes, I know.

20 MR. HANAUER: And there was a crack size
21 frequency distribution applied here. It wasn't assumed
22 that a crack of the correct size was always there for
23 this calculation.

24 MR. ZUDANS: The reason I asked the question
25 is when you discussed initiation of a crack you stated

1 the pressure effects are not greatly significant. Now
2 as you propagate in the wall the temperature stresses
3 disappear.

4 MR. HANAUER: Not in the timescale of these
5 calculations they don't.

6 MR. ZUDANS: Well, they go for minutes. The
7 heat transfer and temperature distribution get
8 stresses. In fact, thermal stresses, in fact, on the
9 outside are compressive.

10 MR. HANAUER: Yes.

11 MR. ZUDANS: So there is some point where
12 there is no thermal stress contribution whatsoever, and
13 the only driving force is pressure.

14 MR. HANAUER: We have one experiment where
15 thermal stresses alone drove a crack 95 percent through
16 the wall.

17 MR. SHEWMON: You have what?

18 MR. HANAUER: There is one of the HHST
19 experiments where the vessel was cooled with liquid
20 nitrogen on the inside, and thermal stresses drove a
21 crack about 95 percent through the wall. Which is what
22 was predicted by this model.

23 MR. ZUDANS: But that was --

24 MR. HANAUER: That was an extreme case. That
25 wasn't a pressurized thermal shock case. That was a

1 very severe thermal transient.

2 MR. ZUDANS: But here, -- well, --.

3 MR. SHEWMON: That was a long time where they
4 kept on doing something to it?

5 MR. HANAUER: Cooling it. No pressure.

6 MR. KLECKER: I was just going to comment on
7 the fact that you do, indeed, have compressive stresses
8 at external, but the fact that you have a stress
9 distribution puts a moment on the vessel, so even though
10 they were compressive without any crack being present,
11 the fracture mechanics takes into account the generation
12 of this moment.

13 MR. ZUDANS: In other words, if you compute it
14 correctly and remove the material on the crack that is
15 already propagated, the stress factor is not --

16 MR. BENDER: Well, we want to be very careful
17 about using the small experimental models as a basis for
18 evaluating.

19 MR. HANAUER: This one was six feet long and a
20 couple of feet in diameter, and six inches thick, as I
21 recall.

22 MR. BENDER: Well, I'm not going to try to
23 debate the experimental circumstances so much as to just
24 recognize that we don't understand the structural models
25 as well as we ought to. And while there are people that

1 calculate things, might be able to calculate the results
2 relating them, to the specific vessel that we are
3 talking about needs to be understood a lot better than I
4 understand it.

5 Go ahead, Steve.

6 (Slide.)

7 MR. HANAUER: The most significant curve is
8 the one -- to us at the present time -- is the one based
9 on the NRC analysis which differs from the Westinghouse
10 one in several important respects. But by far the most
11 important is the dominant feature of the dominant
12 contribution of the small break loss of coolant accident
13 in the range where it stagnates.

14 In the interesting range -- this is, in fact,
15 the dominant contributor, and it goes from about 250 in
16 the Westinghouse curve to about 205 in the staff's
17 curves.

18 As I said before, there are a substantial
19 number of youthful features of these curves, and the
20 methodology in some respects and the input data in some
21 respects are not matured to the point where one really
22 ought to believe these curves in the sense of deriving
23 regulatory requirements directly from them, and we do
24 not do so.

25 That is to say, we have not laid an ordinate

1 here as some value of acceptable risk and read it over
2 to the curve and read out surface RT NDT that tells
3 whether these plants can run or not. We don't believe
4 that the methodology -- and goodness knows, enough
5 differences and difficulties in this methodology have
6 been discussed by you and us today to make my point I
7 think entirely adequately.

8 What this tells us is, first of all, the
9 slopes. The slopes are, in fact, a factor of 10 for
10 about 20 to 30 degrees change in RT NDT. And that tells
11 us that, in fact, within the limitations of this model,
12 the RT NDT of the vessel is, as we expected, a central
13 parameter in judging the acceptability of operation of
14 one of these embrittled vessels.

15 Now, at first site, this implies that a vessel
16 at 270 degrees is in big trouble, and that it implies a
17 failure probability of greater than 10^{-4} per reactor
18 year, and vessel failure makes my corns itch and gets a
19 lot of people itchy in a lot of places. And 10^{-4} , if
20 I really believed it, would be kind of an alarm signal.

21 This isn't true because of the conservatism in
22 selecting the value of the vessel to RT NDT to compare
23 with 270.

24 (Slide.)

25 Here I have plotted in a very crude way a

1 frequency distribution of vessels that satisfy the 270
2 degree criterion. Whether this is actually the case is
3 not known, but I have used the picture provided by the
4 earlier discussion of the scatter of the data. This is
5 a curve for which two sigma was 60 degrees, which is
6 kind of a typical value for the plants which we were
7 talking about, and I have located the two-sigma point at
8 270 degrees. So this is the spectrum of the actual
9 properties of vessels which just hit the screening
10 criterion if vessel properties are normally distributed
11 and if two sigma is 60 degrees, so there is a kind of an
12 assumption leap here.

13 MR. SHEWMON: Would you explain if the small
14 break LOCA is the worst one you have come up with,
15 stagnation, I would be interested in hearing you go
16 through what is the scenario which gets us into trouble,
17 or what is assumable, since you differ by several orders
18 of magnitude from Westinghouse. There must be some
19 difference. The perception might be interesting.

20 MR. HANAUER: Yes. The accident occurs in the
21 following way. There is a break in the primary system
22 in which the leakage rate exceeds at high pressure the
23 injection rate of the high pressure injection system.
24 And in which the energy carrying out the break exceeds
25 in the early part of the accident the decay heat which

1 has to be removed.

2 The result is that the inventory of primary
3 fluid decreases because the outflow is greater than the
4 income. And the inventory decreases but the heat
5 generation means that the pressure doesn't go down. The
6 pressure is calculated for the case I've seen to hang up
7 at about 1000 psi. As the pressure decreases below the
8 shutoff head of the high pressure injection, the high
9 pressure injection comes on, the inventory continues to
10 decrease but there is finally a secular equilibrium
11 established. The pressure goes down to about 1000 psi,
12 the input from the HPI can make up the loss at some
13 lower pressure. The leakage rate goes down with
14 pressure and the pump injection rate goes up with
15 pressure, and an equilibrium is established at about
16 1000 psi.

17 But during this period, the level is too low
18 to support natural circulation. And so, the water going
19 in the cold leg -- there isn't any loop flow to mix up.
20 There isn't any significant flow from the steam
21 generator through the cold leg into the reactor vessel.
22 The only flow which is available is whatever churning
23 goes on from the heat input from the walls of the inlet
24 pipe, plus whatever mixing takes place. And here we
25 have reference to the criari tests.

1 MR. SHEWMON: So in that case you are cooling
2 one part of the vessel badly and the other part isn't
3 getting cooled?

4 MR. HANAUER: Well, that depends upon what
5 goes on in the downcomer. If you have no activity in
6 the downcomer at all, you have a stripe of cold water
7 going down the downcomer which, depending on the vessel
8 and depending upon which downcomer you look at, either
9 does or doesn't have a weld close enough to get cold.

10 Now, that is one of the things that has to be
11 looked at plant specific. We've assumed that there is a
12 weld there. That's the scenario.

13 MR. THEOFALOUS: On this problem, I think that
14 you -- I think your temperature in the downcomer is
15 overly conservative. You are using probably -- you have
16 the cold leg as part of the downcomer, like you say, in
17 your report and I think this is just way, way, overly
18 conservative. And I have done myself some calculations
19 on that, and if you would like I could give you
20 numbers. I gave it to Ed yesterday.

21 MR. HANAUER: Well, if you gave them to Ed,
22 you gave them to me. And yes, this is subject to plenty
23 more calculational refinements.

24 MR. KOUTS: I think if you look at it
25 carefully you will probably find a number of other very

1 large conservatisms there. The heat transfer
2 coefficient under these circumstances is likely to be
3 much lower than you assume for other kinds of transients
4 that you've analyzed.

5 The probability distribution for the cracks,
6 which really have to take into account the probability
7 that a crack exists in a location, in a weld, which is
8 in the thermal stripe region.

9 MR. BENDER: Herb, could you use the mike?
10 The reporter is having trouble hearing you.

11 MR. HANAUER: Yes, I think all of these are
12 things which have to be taken into consideration and
13 have not yet been.

14 MR. KOUIS: In light of the steepness of the
15 curve with respect to heat transfer coefficient that was
16 just pointed out earlier, these will probably have a
17 profound effect on the thing which is having the largest
18 influence on the shape of your total curve.

19

20

21

22

23

24

25

1 MR. HANAUER: Yes. Now, they do not have an
2 enormous influence, because the next one comes in 20
3 degrees higher. And there are a number of contributors
4 within 20 to 50 degrees.

5 MR. KOUTS: Well, I am looking at the
6 probability.

7 MR. HANAUER: Yes. These curves are steep.
8 If this curve were to disappear, the probability would
9 change by about a decade in this region. So, yes, as I
10 said, these things are not mature; they are still under
11 development.

12 MR. BENDER: Steve, to just get back to the
13 pressure question one more time. If the number was 1000
14 p.s.i., would that be because a break is limiting the
15 rate at which the pressure can decay?

16 MR. HANAUER: Yes, sir.

17 MR. BENDER: And that presupposes that an
18 operator does not do anything to change the pressure
19 from that level?

20 MR. HANAUER: That is correct.

21 MR. BENDER: Thank you.

22 MR. HANAUER: It is this kind of consideration
23 that led us to stay at 270 in spite of the fact that our
24 best notion of operating experience tells us that if
25 ⁻² 10 were a real number, we should go up above 300

1 degrees somewhere.

2 (Slide.)

3 But it was the kinds of considerations in this
4 curve that told us for the present to stay at 270 rather
5 than switch.

6 Now, the amount of science in this conclusion
7 is not very large. There are large uncertainties in the
8 probabilistic evaluation. There are uncertainties we
9 have discussed in the inference from experience.

10 You can get more safety, more conservatism, by
11 decreasing the screening criterion. You can get a lower
12 level of safety, less conservatism, by increasing the
13 screening criterion from 270. If you believe the slopes
14 of these curves, then a 30-degree change in the
15 screening criterion gives you about a factor of 10 in
16 the probability of wrecking plants due to pressurized
17 thermal shock.

18 MR. ZUDANS: One question. When the heat
19 transfer analysis was done with a stagnant hot leg and a
20 certain amount of fluid coming in, was still the
21 assumption made that the entire surface of the reactor
22 vessel and the downcomer gets washed with that cold
23 fluid?

24 MR. HANAUER: Yes, sir.

25 MR. ZUDANS: That is not likely to happen, is

1 it?

2 MR. HANAUER: No, it does not fit. We used
3 the available calculations of thermal hydraulics, and we
4 used the available reactor failure probability
5 calculations for which that incompatible assumption was
6 made.

7 MR. ZUDANS: So the thermal stresses then
8 computed were based on asymmetric configurations?

9 MR. HANAUER: Yes.

10 MR. ZUDANS: And that is not right either.

11 MR. HANAUER: That is correct. That is the
12 present state of our calculational ability.

13 MR. THEOFALOUS: Well, you found a lot of
14 reasons why you assumed the small break, and I want to
15 look at the second one. Is there anything in doubt
16 concerning the steam line breaks calculation?

17 MR. HANAUER: Of course.

18 MR. THEOFALOUS: But anything of substance?

19 MR. HANAUER: Of course. The small steam line
20 breaks turn out to be more serious than the big ones.
21 First of all, they have a much higher probability; and
22 secondly --

23 MR. THEOFALOUS: But those are reflected in
24 here. I am saying, is there anything which puts the
25 line into doubt -- this line, which already reflects the

1 different sizes and so on -- is there something in the
2 methodology is what I am asking? A heat transfer
3 coefficient or what have you?

4 MR. SHEWMON: That is why we are paying you
5 this exorbitant fee to come here and help us with that.

6 (Laughter.)

7 MR. HANAUER: The answer is that many of the
8 same models were used; in particular, the reactor vessel
9 failure model was identical. Of course, now you have
10 either forced circulation or natural circulation, so the
11 heat transfer coefficient and the mixing in the
12 downcomer is more likely to be realistic.

13 It turns out that the worst steam line break
14 is a small break which occurs at hot standby, rather
15 than in operation, because you do not have the power
16 generation to heat things up. But that has a lower
17 probability. That is all in this curve, and all of the
18 numbers are subject to discussion. What is the
19 probability of a large small steam line, a small steam
20 line break, a bypass valve opening, which is a steam
21 line break; all of that stuff.

22 MR. THEOFALOUS: So the interesting question
23 is how does one proceed from here? If we wanted, for
24 example, to take advantage of what Professor Shewmon has
25 said, and we wanted to look at the probability of

-5

1 10 , and I want to know what steam line break and
2 what particular scenario gave you that point, can I get
3 that point from somebody?

4 MR. HANAUER: Yes. It is discussed briefly in
5 the report. And we have some more information.

6 MR. THEOFALOUS: I do not think you have this
7 kind of information in the report. I looked at the
8 report.

9 MR. HANAUER: Look in Appendix G.

10 MR. BENDER: Steve, separately from Theo's
11 comments about the point, is the matter of how much we
12 understand the heat transfer, heat transport behavior,
13 of the steam generator as a whole, which seems to me to
14 have a big influence on steam line break behavior?

15 MR. HANAUER: For large steam line breaks,
16 there is a lot of uncertainty because the steam
17 generator is far outside its normal operating
18 conditions. For small steam line breaks, remember small
19 steam line breaks are not necessarily rending metal,
20 they are bypass valves open or relief valves open or
21 something like that.

22 The steam generator is operating near its
23 normal mode, and that is not a large uncertainty.

24 MR. BENDER: Well, maybe not, but I would like
25 to know more about it.

1 MR. HANAUER: There is a limiting return
2 here. You would not want to pay too much or delineate
3 too elegantly the heat generator elements of this curve,
4 if you are imprisoned in the reactor failure probability
5 calculations with the many uncertainties that are
6 involved there.

7 MR. BENDER: Well, I agree with that. And
8 maybe we would be working too hard under the tail. But
9 a lot depends upon how much feedwater is in the steam
10 generator, particularly under shutdown conditions and
11 what its temperature is and what is being done to
12 control it.

13 MR. HANAUER: You can be more elegant in this
14 area by picking more scenarios, chopping up your
15 probabilities, and considering many different branch
16 points in your event tree and analyzing each one. This,
17 to the extent that the models are available, this is
18 only the use of resources to do this.

19 MR. BENDER: Paul, did you have another
20 question?

21 MR. SHEWMON: No.

22 MR. BENDER: How near are you, Steve, to being
23 at the end of your harassment?

24 (Laughter.)

25 MR. HANAUER: I would say with a typical

1 question density somewhere between 30 and 50 minutes.

2 MR. BENDER: Well, carry on. We will try to
3 hold down the question density.

4 MR. HANAUER: I do not learn anything if you
5 do not ask questions.

6 MR. BENDER: I know. But we are the
7 absorbers, not you.

8 (Slide.)

9 MR. HANAUER: The next thing to do is to
10 compare these numbers with the safety goal. This turns
11 out to be extremely difficult to do, not suprisingly.
12 The safety goal is in terms of core melt and in terms of
13 public risk. And so we have to get from the frequency
14 or probability of vessel cracks, which is what we have
15 been working on, to the probability that cores melt and
16 the probability that the public is at risk.

17 I have expressed these as two unknown
18 quantities X and Y, those being what you do with unknown
19 quantities. The discussion in the report that you have
20 has misled almost everybody, and I have therefore
21 completely rewritten in the next edition of the report,
22 which you will receive in the not-too-distant future.

23 X and Y are not known. They are both less
24 than 1. X is the probability that the core melts if the
25 vessel cracks. Not every vessel crack melts the core.

1 It depends upon the size of the crack compared to the
2 size of the replenishing capability and on the location
3 of the crack, whether the core drains or whether one
4 can, in fact, continue to fill the vessel to some
5 reasonable level.

6 And it depends also on the heat transfer
7 characteristics of a core which is partly covered with
8 water and which is old to some extent by the various
9 loss-of-coolant accident experiments, but about which
10 there is a great deal more to be known.

11 Now, what I have done is to write down how you
12 compare this kind of calculation with the safety goal.
13 You take the safety goal guideline of 10^{-4} . You do
14 not want to spend it all on pressurized thermal shock.
15 And so I took a tenth of it, an arbitrary fraction. And
16 I said, we are okay with the safety goal if X times F is
17 less than or equal to 10^{-5} .

18 Well, the numbers you get for F are in the
19 range 10^{-6} , 10^{-5} , if you believe these calculations
20 for a vessel, at 270.

21 (Slide.)

22 Now, for most of the vessels, the F is a very
23 small number for vessels below 200, which is a lot of
24 them. F is a very small number, and there is no safety
25 goal problem at all.

1 But let us take a 270-degree vessel, and I
 2 have suggested to you that this line characterizes the
 3 population of 270-degree vessels, and maybe half of them
 4 -- well, they are in the range, very small to 10^{-5} ,
 5 10^{-6} ; and some of them are much higher in an unknown
 6 proportion.

7 I have not done any calculation, but only
 8 drawn this curve and waved my arms.

9 (Slide.)

10 If F is in the 10^{-6} to 10^{-5} range,
 11 everything is just beautiful. For some fraction of
 12 270-degree vessels, F will be in the 10^{-3} range. And
 13 for those fraction of the vessels, we probably do not
 14 meet the core melt criteria.

15 Now, this fraction of vessels is fairly
 16 small. There is a nice intellectual problem here which
 17 I do not know how to address. Here is a vessel which is
 18 calculated to be 270 by our formula. The probability of
 19 its actual value is either on this curve or on some
 20 other curve that we do not know. I do not know how to
 21 put that into safety goal language.

22 But surely the fact that most such vessels are
 23 down in the 10^{-5} range has to be taken into account in
 24 looking at the safety goal. This is a question of
 25 application of the safety goal that deserves a lot of

1 attention and has not had it. I do not know how to go
2 from there.

3 Similarly, with public risk, it is simply that
4 $XF \times Y$, the probability that a lot of stuff gets out if
5 you have one of these coremelts must be less than some
6 number like 5×10^{-8} . Now, that number has a whole
7 bunch of assumptions in it about meteorology and
8 population and stuff that is some kind of an average
9 number. Again, we do not know why for longitudinal
10 cracks that produce orderly coremelts, Y is probably a
11 pretty small number. At Indian Point Y is less than
12 10^{-2} for such things.

13 If you get the crack that goes all the way
14 around and you get a jet-propelled top half of the
15 reactor going up, we have a calculation that says there
16 is just about enough stuff to restrain it, it maybe will
17 and maybe will not come apart and fly up. And whether
18 it has enough energy if it flies up to significantly
19 damage the containment so a lot of stuff gets out is not
20 clear because there is not a lot of stuff when this
21 happens; the core melts forthwith but not instantly.

22 And we do not have analyses like this. This
23 sequence has not been analyzed, but I can turn the
24 problem around. I can say, if F is 10^{-5} , then
25 coremelt is okay and risk will be okay if Y is less than

-2

1 5 x 10 . And those sound like reasonable numbers,
2 but I have no science behind them.

3 So the comparison with the safety goal is not
4 very satisfactory. It seems like we are not wildly out
5 of line, but we do not have enough science and enough
6 calculations today to make a quantitative check. Why?
7 Because we do not have PRAs in which vessel failures of
8 this kind have been calculated in any significant detail.

9 MR. BENDER: And if you had, you could not
10 believe them.

11 MR. HANAUER: They would have whatever degree
12 of belief was appropriate. We are having some trouble
13 believing the vessel crack calculations. They need more
14 work. I do not know whether you believe vessel failure
15 coremelt calculations or not. I have not seen any.

16 (Slide.)

17 Now, then in section 8.7 or thereabouts, we
18 have spent a good bit of time on the uncertainties. By
19 the way, section 8.7 has a few statements that are not
20 exactly right, and they have been rewritten, too. But,
21 in fact, there are -- I do not need to dwell on any
22 today -- a very substantial number of uncertainties in
23 all of this.

24 (Slide.)

25 Now, the conclusions we draw, let me now

1 emphasize that these are the Staff's conclusions. And
2 they are being submitted to Mr. Denton within a week, to
3 Mr. Stello and to Mr. Dircks probably within a few
4 weeks, to the Commission probably in November. So that
5 what you hear is what Steve Hanauer and his colleagues
6 think and not what the management of the NRC Staff
7 thinks, and certainly not what the Commission thinks.
8 And what the ACRS thinks would be a very important part
9 about this decision process.

10 What we now think is that 270 is about right
11 for the present, that the situation is that if 270 is
12 about right, that there is no need for immediate action
13 on any plants, but that within the next small number of
14 years these methods must be refined; and that we will
15 need plant-specific analyses on the top few plants in
16 that list which are getting embrittled into the high
17 200s; and that what needs to be developed -- and this is
18 the biggest hole in everything I have told you today --
19 what needs to be developed is given a plant-specific
20 analysis, which is described in some detail in Chapter 9
21 of our report and which I have a paragraph on, we then
22 have to decide what is acceptable when we get such a
23 plant analysis.

24 And that, gentlemen, is the largest hole in
25 our present work. We have not, since we have gone away

1 from an RT NDT or a single-probability safety goal
2 style, we have yet to develop the critical question of
3 what is accepted as these plants continue to embrittle.

4 Now, it is my opinion that the plants in the
5 high brittle range, in the high 200s, should initiate
6 steps to slow down their embrittlement and steps to
7 decrease the risk from the highest risk contributors
8 which, if it continues to be the small-break LOCA, is
9 perhaps most easily done by warming up the emergency
10 core cooling water. It is rather easy to get 50 degrees
11 out of that with essentially no problems as far as we
12 know.

13 And finally, since we did not pick some
14 design-basis accidents and some evaluation models, it is
15 not clear that some of our older regulations are
16 compatible with what I have told you today and what we
17 propose to do. This is the question that the legal
18 beagles are now working on.

19 Now, what I wanted to do is to talk some more
20 about the plant-specific analysis. And I wish I knew
21 how to talk some more about the acceptance criteria.
22 But I really do not.

23 (Slide.)

24 The plant-specific analysis, we believe,
25 should include these factors. And you will observe,

1 among other things, the operating procedures and
2 training program improvements which need to be done in
3 the fairly short term in some plants, but which need to
4 have a major improvement in connection with the I.C.1
5 TMI-procedure-based improvement.

6 What we think we should from these plants is a
7 much better look at transients and at the vessel. You
8 do a better look at transients by doing plant-specific
9 and, in a way, that encompasses some of these questions
10 that have been discussed today, a study of the
11 overcooling transients which dominate the risk in that
12 particular plant, using the experience of that plant and
13 similar plants as well as the generic experience of all
14 plants, which is all we have done, using the plant
15 configuration and the plant sizes and the plant behavior
16 of that particular plant.

17 We propose this to be done not in 100 plants,
18 but in a small number of plants that have brittle
19 vessels. Similarly, we propose that in such plants, as
20 good a look as can be obtained of the properties of that
21 vessel and of the present state of that particular
22 vessel, should be obtained.

23 Now, you have scheduled a discussion of
24 nondestructive testing. So I will only remark that the
25 code-required in-service inspection is not well directed

1 toward pressurized thermal shock cracks, but that
2 methods are under development and have been developed
3 that can do a lot better job of detecting pressurized
4 thermal shock-type cracks, and that in these vessels
5 there is an obvious place for application of these.

6 Furthermore, what one has to do then is to
7 figure out what to do with the results. When we do
8 these probability curves, in general, we have a crack
9 probability distribution. If you do a good in-service
10 inspection and you find this and that or nothing, then
11 this ought to change for that vessel the crack
12 probability distribution. That is an area where we have
13 not done anything except wave our arms, but clearly it
14 is something that we should do.

15 And then we need to consider flux reduction
16 plant modifications. Your favorite, automatic
17 depressurization, is here, Mr. Chairman. And
18 operating. And finally, for the most brittle vessels,
19 in situ annealing and the basis for continued operation
20 must be considered.

21 We have for annealing an EPRI report. There
22 is a thin report on the feasibility of annealing, and I
23 just got a wheelbarrow-size report with 2800 pages on
24 the metallurgical data that underly the annealing
25 process. And so a fair amount is known about what you

1 can do with annealing, and I will suggest that very
2 little is known on whether annealing is actually a
3 practical possibility. But this report is available to
4 you as well as to me.

5 (Slide.)

6 In the longer term, we think that some generic
7 things ought to be done, too -- the longer-term, meaning
8 not this summer and this fall -- but we think that this
9 procedure program that we have discussed at some length
10 and the training that goes with it are really very
11 important and procedures are not now well cognizant of
12 pressurized thermal shock and need to be in a connected
13 and integrated way so that we do not foul up the plants
14 in some other way in trying to cope with pressurized
15 thermal shock.

16 We think that the generic analyses that I
17 presented here have a very large number of holes in it.
18 The number of holes is somewhat larger than when I
19 brought it in this morning at 9:00 o'clock, and that
20 these topics need to be investigated and we need to have
21 a better generic idea of what is going on, particularly
22 for the Bs and the Cs, because our present analyses is
23 essentially a Westinghouse analysis.

24 We need to improve the in-service inspection.
25 We need to decrease the leakage neutron flux, and we

1 need to do these plant-specific analyses.

2 Now, that is our proposed program. And to the
3 extent that a single discussion of this length can cover
4 it, I have done my best to try to connect it. It should
5 be clear that this is a problem that embraces many
6 different disciplines.

7 And one of the most difficult things in coping
8 with it over the past year has been to make sure all of
9 the disciplines were involved and to avoid going off and
10 working very hard on one particular piece to the
11 detriment of other parts.

12 I give you one example: the heat transfer
13 coefficient is obviously an important point both as
14 regards how we do our thermal hydraulic analysis and as
15 regards how we do our vessel deterministic and
16 probabilistic failure analysis.

17 At some point, the heat transfer coefficient
18 is known well enough so that the other uncertainties
19 will dominate, and we ought not to do for pressurized
20 thermal shock a lot more work than that in the heat
21 transfer coefficient. If you let yourself think too
22 much along these lines, you induce paralysis. And so we
23 have tried to walk the curve between this.

24 This is the end of my prepared discussion. I
25 will be glad to answer any other questions, and call on

1 my colleagues for things I do not know.

2 MR. BENDER: Well, let me say I will entertain
3 a couple of questions and then we will break for lunch
4 and decide whether we want more when we come back.

5 Does anyone want to pose a question?

6 (Pause.)

7 Steve, an observation and not a question. It
8 seems to me that you have come a long way in developing
9 the screening concept, assuming you get the minor
10 disagreements straightened out. It does seem to me that
11 the second step, which requires plants to respond to the
12 screening criteria when a plant gets to the point where
13 it requires some action, is probably not the best way to
14 deal with it.

15 MR. HANAUER: Well, we have proposed that
16 plants for which the screening criterion is predicted in
17 3 years be treated so that there is plenty of time to
18 decide what to do about the plants.

19 MR. BENDER: I see. Okay.

20 Bill.

21 MR. BOCK: It seems that the important thing
22 you are really looking for our opinion on right now is
23 do we agree with the screening criteria, or, if not,
24 what else should we do? And whether or not we agree
25 with the screening criteria depends to a considerable

1 extent on what happens when you reach it.

2 If it simply becomes a level at which point
3 the plant should exhibit some increased concern over the
4 PTS problem, we might have one opinion. But if it were
5 something that when you reached it, you would trigger
6 off a chain of events which would eventually require you
7 to anneal the vessel or do some other drastic
8 modification, our opinion about that might be different.

9 I appreciate the problems in establishing a
10 position. But can you give us anything better to go on
11 as to what you do when you reach the screening limit?

12 MR. HANAUER: Let me describe our present
13 status, as the start of an answer, and to say that I
14 think my own opinion is where we need your advice, you,
15 of course, give whatever advice you think appropriate.

16 I would suggest that we need your advice in
17 the following areas: First of all, is our conclusion
18 that no immediate action is needed acceptable? Do you
19 believe it is correct? You did 6 months ago. You wrote
20 the Commission in that vein. And have we learned
21 anything different, or is this still the correct

22 conclusion in the committee's opinion? That is kind of
23 a threshold thing, that we really do solicit advice on.

24 Secondly, is the screening scheme appropriate,
25 and is the screening value about right? And, of course,

1 Mr. Bock is correct. The question that follows
2 immediately is: is our proposal, to the extent that it
3 is delineated, for what plants should do when they
4 trigger the screening criterion appropriate?

5 Now, where we really need some advice and
6 where we have not made a proposal is what should be the
7 criteria for operation or shutdown of a reactor whose
8 vessel is substantially embrittled? And to pick a
9 sample, I will simply say that a vessel which reaches,
10 according to our formula, 270 degrees must make a
11 showing that operation of this plant is acceptable.

12 Now, there are two general categories of
13 things. One is a general sharpening of the pencil to
14 show that, in fact, if you really look hard at this
15 vessel, it is not a 270 degrees the way you think it is
16 at some lower value. That is one category of responses.

17 Another category of responses is that because
18 of the way this plant is configured, even though this
19 vessel is at 270 degrees in this conservative way, that
20 the risk of pressurized thermal shock is acceptably
21 low. That is also a sharpening of the pencil, but in a
22 somewhat different area.

23 The third thing to do is to improve the safety
24 of the plant by procedural and hardware changes that
25 make the risk acceptable.

1 Now, what I have skirted all around is what is
2 the acceptability of a plant with a substantially
3 embrittled vessel? About this we really are only at the
4 beginning of our consideration.

5 You are quite right, Mr. Bock, we have not
6 adequately done this, because we were working along
7 toward an acceptability criterion that turned into a
8 screening criterion about 2 or 3 months ago.

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 Any advice the subcommittee wishes to give us
2 would be very welcome. I will tell you some early ideas
3 I have on the subject. If, as I expect, the Commission
4 proceeds with some ideas about safety goals and value
5 impact justifications for backfits, we will be, when
6 these things come due in a small number of years,
7 working in probability space. And we will be trying to
8 develop perhaps the first probabilistic acceptance
9 criteria, or perhaps we will use some fairly generic
10 based upon a few plant-specifics to develop
11 deterministic acceptance criteria.

12 I hope and expect that we will not go back to
13 a set of design basis accidents, highly conservative
14 evaluation models and highly fanciful acceptance
15 criteria, the way we have now in emergency core
16 cooling. That is not an answer. I don't a good answer.

17 MR. SHEWMON: Let me make on comment on this.
18 I feel rather comfortable with your 270 and 300 numbers,
19 not because I feel I know what is going to happen there
20 or exactly what you should do, but I feel that by the
21 time the vessels get up there it is fully appropriate
22 that people be looking very seriously at it. And I'm
23 sure the utilities will look at it maybe before they
24 even get there and decide that they would like to slow
25 down. And I think I feel relatively comfortable with it.

1 MR. BENDER: I think there's a point to be
2 made here that goes like this. Somehow or another
3 people think that the NRC has to establish some
4 regulatory action process associated with the point
5 where the screening criteria require some action. The
6 owners own the plants and they have a responsibility,
7 and my inclination is to say that the screening criteria
8 probably show -- if you accept the evidence so far --
9 that there is time to do something.

10 But the initiative is clearly in the owners'
11 camp, and every owner that might find some vulnerability
12 to this thing ought to be thinking about his strategy.
13 Why should the NRC be inventing a strategy for him?

14 Can we break for lunch on that note? And we
15 will reconvene at 1:25.

16 (Whereupon, at 12:25 p.m., the meeting was
17 recessed for lunch, to reconvene at 1:25 p.m. the same
18 day.)

19

20

21

22

23

24

25

AFTERNOON SESSION

1

2

(1:30 p.m.)

3

MR. BENDER: Let's reconvene. I think before proceeding with the presentation on PNL, I would like to find out if there is anything else on Dr. Hanauer's presentation, and if so, we will cover them now. Does anyone have any additional questions to pose to Steve?

8

(No response.)

9

If not, let me --

10

MR. ZUDANS: Mr. Chairman, I would like to raise a question. I'm sure there's no answer for it. Has anyone during this year in the process attempted to precisely identify where concerns exist in this process? You know, you use certain linear fracture mechanics analysis and they're associated with some form of surface. Temperatures were used, a fuel coefficient was used, a whole slew of things.

18

MR. HANAUER: There have been various lists. There is one in Section 8.7 of the report. I have no big, long list and we have no prioritized list.

21

MR. SHEWMON: There has been a sensitivity study.

23

MR. ZUDANS: We, of course, mentioned here this is a concern and that is a concern, but a comprehensive list of everyplace where the whole group

1 thinks that the issues result in a conservative factor.

2 That would be interesting to see.

3 MR. HANAUER: It would, indeed. There are, of
4 course, some non-conservative factors which have to be
5 included.

6 MR. BENDER: Let us leave that as food for
7 thought. I would like to suggest that the working group
8 think during the next hour or so about how it views the
9 proposed screening criteria. Because one of the things
10 I think we will have to respond to is whether we think
11 this approach is a good one.

12 And secondly, I suggest we ought to think
13 about what other kind of recommendations we might make
14 to the Regulatory Commission, reminding ourselves of the
15 original recommendation or the original request which
16 Chairman Palladino made to us, which was to provide any
17 input we could to the staff in time so they could be
18 included in their proposed regulatory effort which would
19 be presented to the Commission. So I will leave you
20 with that opportunity to think.

21 MR. AXTMANN: I do have a question for Dr.
22 Hanauer. How far has the staff gotten into the flux
23 management program?

24 MR. HANAUER: We studied it quite a bit. We
25 have had a contractor do some work for us on it. There

1 is a short summary of this in the report and a longer
2 summary of this in one of the appendices, and there are
3 some technical reports if you would like to see them.

4 MR. AXTMANN: Have the economic aspects been
5 explored very much?

6 MR. HANAUER: Well, we have done very little
7 on that except to write down what people have told us.
8 We don't feel that is really within our purview.

9 MR. BENDER: I think the next item on the
10 agenda was a presentation by PNL on their review of what
11 is known about the pressurized thermal shock issue. Mr.
12 Peterson will be the initial speaker, and I will leave
13 it up to you to introduce the rest of your gang.

14 MR. PEDERSON: Steve is a very tough act to
15 follow, so I brought along quite a bit of help.

16 (Slide.)

17 I am Les Peterson and I will start out with a
18 summary of NUREG-2837, which is the PNL's technical
19 review of the PTS issues, which has now been distributed
20 and only initially submitted in June, and it was issued
21 by the NRC in July. I will also talk briefly about PTS
22 screening criteria, and then Shaw Bian will talk about
23 events in the thermal and the thermal hydraulic issues.
24 Ed Simonen will talk about material properties. Fred
25 Simonen will talk about fracture mechanics issues, and

1 he also will speak some about the actual NDE or
2 in-service inspection and what gains are possible
3 through that. And then on the end there, Tom Taylor
4 will talk about the NDE methodology and applications to
5 in-service inspection.

6 (Slide.)

7 We were asked by the NRC to review the PTS and
8 particularly in the near term to come up with a
9 regulatory position for them. And the source of our
10 information was the 50, 100 and 150-day responses from
11 the licensees, the owners' group submittals and
12 supporting ongoing research at the various laboratories
13 and EPRI and also, consultants that we had onboard that
14 reviewed the material and made comments and
15 suggestions. And I wrote the consultants on this copy
16 and the areas that they were particularly involved with.

17 (Slide.)

18 MR. BENDER: Mr. Peterson, it would help a
19 little bit if when you're talking if you'd stand back
20 from the slide.

21 MR. PEDERSON: In our NUREG-2837, there were
22 three main categories of recommendations that we came
23 with. Initially, we found from our judgment that there
24 was an immediate problem with any of the present plants,
25 but from the reviews that were made by the NRC people

1 and also some of PNL people at the plants reviewing
2 procedures and training and so forth, it seemed quite
3 obvious that there were upgrades in procedures and
4 training and some control room instrumentation that was
5 needed on a near to longer-term basis.

6 Our report gets into more details there on our
7 recommendations for the near term and for the
8 intermediate term and the longer-term periods as far as
9 which procedures and which instruments and so forth
10 should be reviewed on a site-specific basis for
11 upgrading.

12 Secondly, from the analyses that were
13 submitted on the 150-day, they were quite different, and
14 some of them had some deficiencies as far as being
15 accurate or totally acceptable or covering the total
16 problem. And so, we developed some criteria to be used
17 for figuring effective full power years remaining before
18 further corrective actions would be required.

19 And I think these might be particularly useful
20 in the site-specific analysis that will be required when
21 various reactors are triggered by the screening criteria.

22 And lastly, we have recommended improved NDE
23 techniques for in-service inspection, and Tom Taylor, of
24 course, will talk about that further.

25 (Slide.)

1 Now, the screening criterion, of course, as
2 Steve mentioned this morning, was for axial welds, 270
3 degrees F, and for the circumferential welds, 300
4 degrees F, and we searched quite diligently for a basis
5 for that. Initially it started out looking at 10^{-2}
6 for frequency because there was -- looking at a number
7 of them, why, when you use that you get a probability of
8 crack extension of about 10^{-6} .

9 That has changed some, and now the basis of
10 that 270 is a little larger than 10^{-2} . But the crack
11 extension at 10^{-6} , as Steve mentioned, is very
12 difficult. The probabilities are not something that you
13 would want to rely on for regulatory policy, but it is
14 probably the best we have, and the safety goals that are
15 in the comment stage, of course, can be related to about
16 a 10^{-5} or 10^{-6} .

17 Also, the report on the integrity of reactor
18 vessels for lightwater reactors that the ACRS issued in
19 January of 1974 also used a 10^{-5} and 10^{-6} value, so
20 that seems like a pretty good base. But we have to
21 learn how to really apply it. And I have got to admit
22 that we are some distance from that yet.

23 (Slide.)

24 This is one of the earlier curves that Steve
25 showed earlier, and it just shows how at 270 you have a

1 frequency of six or seven to the 10⁻² or 10⁻³.

2 (Slide.)

3 Getting into this particular slide, which I
4 think may have changed a little but I think it is
5 basically the same slide, and I apologize for the
6 reproduction that didn't come out very good. But as we
7 were told not to do -- and I recognize why we shouldn't,
8 because of not having a real good or not having a good
9 handle on these curves, and I'm sure they're going to
10 shift a lot and they will shift even more when people
11 look at it on a site-specific basis.

12 But looking at the 270, you come out to about
13 two times
14 10⁻⁴, which even with a couple of orders of magnitude of
15 unknowns or uncertainty as far as where that is, you still
16 are at least a little hesitant to see it up that high in
17 probability. That is, of course, the NRC staff's curves.

18 (Slide.)

19 On Westinghouse curves, it looks better, but
20 it is still -- you still have the probability in the
21 10⁻⁵ and 10⁻⁶ range.

22 (Slide.)

23 There was one other curve that was in an
24 earlier rendition that now hasn't been used, but I think
25 it says the same thing. This is operating history and

1 the same type of probabilistic analysis, and using that,
2 we would get about 10^{-4} or pretty close to what the
3 NRC staff's calculations are on a PRA basis.

4 (Slide.)

5 So what we asked ourselves is -- excuse me,
6 I'm missing one slide. I guess you will have to look on
7 your handout. The thing we asked was how was
8 probability of a crack of 10^{-6} satisfied, considering
9 those type of data points that we get. And in the NRC
10 staff evaluation of September 13, on page 8.6, it says,
11 and I will read it, "PTS event sequences leading to
12 reactor vessel failure have overall frequency F per
13 reactor year. Figures 8.2 and 8.3 which were the two
14 curves provide an estimate of F. A plant evaluated as
15 described in Sections 5 or 9 and Appendix E to be at the
16 270 degrees screening criteria is likely to have a true
17 RT NDT of 150 to 270. Now, that is based upon the two
18 sigma.

19 Then, for a mean of 210 -- in other words, a
20 mean reference temperature of those reactors would then
21 be 210, and of course, the frequency would be about
22 10^{-6} per reactor year of the NRC curve, and much
23 smaller on the Westinghouse or owners group curve.

24 (Slide.)

25 Looking at those again, we are using the mean

1 value of 210, and you see you would be down here in the
2 -5 to -10 frequency for a crack extension on the staff
3 PRA curve, by using the Westinghouse curve. Of course,
4 you are off of the scale. In other words, quite a bit
5 lower than 10^{-6} , or here again, using the curve from
6 the operating history, you again are in the 10^{-6} ,
7 10^{-6} range.

8 So I guess I look at this and I think for a
9 screening criterion, the PNL people felt that the 270
10 was a good value considering the two sigma conservatism
11 that was talked about. And primarily because of the
12 probability and all of a failure being that low, which
13 is in the range you would hope to have it.

14 Also, you need some criterion for the
15 licensees to come back and show that their procedures,
16 training design fixes and so forth have improved the
17 safety factor to really gain on their reference
18 temperature. So I suggest that that probably is the
19 base that they need to work to.

20 Shaw Bian will now talk about the events in
21 thermal hydraulics.

22 MR. ZUDANS: Could I ask a question? I still
23 have some question relative to the frequency of
24 operating history. As I understand, there were three
25 cases in B&W and four to five cases in Westinghouse.

1 What would those statistics look like if you did not mix
2 the cases? It makes a lot of sense not to mix them
3 because they are completely different reactors. Would
4 the B&W case be much more serious in terms of the
5 statistics?

6 MR. PEDERSON: It would certainly vary the
7 statistics, but of course, there just isn't enough
8 information to really do that and have enough left for a
9 generic basis.

10 MR. ZUDANS: In either case, eight is not
11 enough for a generic basis and three is worse, and five
12 is just as bad. But you see, if you mix apples and
13 oranges, your overall picture might look better than it
14 really is. Say for a class of reactors such as B&W,
15 what would that curve look like for the B&Ws?

16 MR. PEDERSON: I agree it certainly would be
17 different, and I am sure on a plant-specific basis, this
18 point will be treated by the licensees. In B&W's case I
19 am sure they will point out that there have been a lot
20 of retrofitting where they have made design fractions to
21 the instrumentation system which was quite often to
22 blame. And that things are improving.

23 MR. ZUDANS: I see. That may have invalidated
24 the entire portion of the B&W effort.

25 MR. PEDERSON: It very well could be. There

1 is certainly a lot, as Steve mentions, that he wouldn't
2 want to use any of that probability for regulatory, and
3 a lot of this is the very reason he wouldn't want to.

4 On the other hand, it may be the best we have
5 at this time.

6 MR. ZUDANS: It's really not right to say the
7 best we have. I think it is right to say we have
8 nothing at this time in terms of basis for statistics,
9 but it does not stop us from using the statistics to get
10 the sensitivities, and that is all right.

11 MR. PEDERSON: Well, we need to certainly
12 improve on those statistics that we have.

13 MR. BENDER: We don't want to do it by having
14 more PTS events. We need to work on the methodology.
15 Can we proceed with the rest of the presentation?

16 MR. BIAN: My name is Shaw Bian from PNL. I
17 am more involved in thermal hydraulics than the events,
18 but I'm going to cover the area that is mainly done by
19 another person on the initiating events in the area of
20 PRA, as we are talking about just in the last few
21 seconds in the original NRC report.

22 They derive the probability of, say, a steam
23 line break or a small steam line break based on some
24 extrapolated boundaries from the primary side breaks.
25 What was done was that some data on the primary side

1 part piping breaks were taken and then were extrapolated
2 based upon how many times longer of the steam line pipe
3 compared to the primary piping could come up with a new
4 probability because the length of the pipe is longer and
5 so forth.

6 And you may have a lot of uncertainty on that
7 because of certain events and welds, and also, the flow
8 rate of steam is much higher than the primary coolant.
9 So based upon the straight linear extrapolation of the
10 probabilities, there is quite a bit of uncertainty
11 involved in that area.

12 So we said we think that some more work based
13 upon the probability of the break locations, instead of
14 how long the length of the pipe should be, and with that
15 kind of approach the result probably is more acceptable.

16 And the second item on the initiating events
17 is the operation reaction time. In the draft of the
18 staff report there was a discussion about the time
19 allowed for the operator to do certain actions, and we
20 found that there was a lack of discussion on the minimum
21 time required for the operator to take certain actions.

22 For example, from the ANSI standard, N660, we
23 found that general criteria for the operator action is
24 that a minimum of six minutes should be allowed for the
25 operator to start any action and then for each

1 distinctive operation of the control component, one more
2 minute should be allowed. And in one of the submittals
3 by B&W on the small steam line break, they assumed the
4 operator to start to shut the aux feedwater in five
5 minutes, and so this apparently indicates some kind of
6 discrepancy in that area.

7 Next I want to get into the thermal hydraulic
8 area. Right now, on the probabilistic risk analysis the
9 dominant scenario is the small break LOCA with no flow.
10 And we found the approach of using long-term probability
11 for a two-inch to six-inch break. I think we can refine
12 that by doing some more detailed analysis to bracket the
13 exact size that the natural circulation will stop. And
14 then, if we do that, it will depend upon a lot of
15 parameters. So I think the scenario will be the exact
16 size that the small break LOCA would cause the stagnant
17 flow situation is really very much site-dependent or
18 plant-dependent.

19 The reason for the more specific analysis on
20 that is with that, we probably can refine the
21 probability that certain breaks will occur, say, for
22 example, a two-inch or a three-inch. Apparently, if we
23 look at -- I talked to one of the persons at PNL and the
24 comment we have is that a two-inch break to six-inch
25 break probably has an order of magnitude difference on

1 the probability of occurrence. So that will definitely
2 affect your curve of the failure probability, and the
3 curve that Mr. Peterson just showed, the dominating
4 curve, is the small break LOCA.

5 MR. BENDER: Are the natural circulation
6 characteristics grossly different for different
7 systems? That is, would the B&W plants be less likely
8 to lose natural circulation than the Westinghouse
9 plants, for example?

10 MR. BIAN: Without detailed analysis, I would
11 say probably if you have the much higher -- I guess
12 depending upon the different elevations of the two
13 components, if the heat source is much higher you have a
14 much higher driving source of natural circulation. I
15 haven't done the parametric studies on different
16 systems. I really cannot say.

17 But the recommendation is that we should look
18 into more on the exact situation; namely, the break
19 size. And different vendors have -- I mean even within
20 one vendor they have different arrangements of the
21 loop. The elevation difference of the heat sink and
22 heat source. So it is really kind of plant-dependent.

23 MR. THEOFALOUS: Why do you think the
24 elevation difference has anything to do with it? How do
25 you lose natural circulation?

1 MR. BIAN: Okay. As Steve mentioned about the
2 loss of inventory to a certain extent --

3 MR. THEOFALOUS: So what does that have to do
4 with the difference in elevation?

5 MR. BIAN: Okay. That is the point. The
6 point is when did the void form in the higher points.

7 MR. THEOFALOUS: You give me a break and I
8 will find the time in the injection level where you will
9 lose natural circulation.

10 MR. BIAN: But I think it is plant dependent.

11 MR. THEOFALOUS: It's plant dependent to the
12 extent that maybe different plants have different
13 injection rates, and therefore, the optimal size to
14 reach that plateau would depend. Because really, you
15 balance between what you get in and what you get out.
16 But it doesn't have to do with elevations.

17 MR. BIAN: That is a different aspect. That
18 will have an effect on natural circulation, but not in
19 this case.

20 MR. THEOFALOUS: Do you have any feel for what
21 kind of a spread in break sizes would be in the
22 mid-range where it just about balances so the thing
23 could stay up?

24

25

1 MR. BIAN: All we have done is a little
2 research, and one-half inch is about the size. PNL
3 doesn't know, I don't know, but we would like to know
4 that. We do more work by ourselves or the owners
5 group.

6 MR. ZUDANS: It is interesting that Steve's
7 presentation and the present discussion indicates that
8 there is a limiting transient for PDS, and that would be
9 defined as a design basis transient the size of a small
10 break LOCA that leads to natural circulation
11 interaction. This is it.

12 All they have to do is analyze it in great
13 detail and they would have all the information. Nothing
14 worse can happen.

15 MR. THEOFALOUS: Not true, because the small
16 break was analyzed in such a conservative way that that
17 might not be limiting after you do it right. So
18 something else might pop up.

19 MR. CATTON: It would probably fall right on
20 top of the next line, which was below, which I think was
21 the steam line break, if they take out some of the
22 conservatism.

23 MR. ZUDANS: That means that the statement
24 that this is a limiting transient is not necessarily
25 correct.

1 MR. CATTON: It's not, that's right.

2 MR. BENDER: It's very easy to make that
3 particular one go away.

4 MR. CATTON: You can pull it down until it
5 falls on top of the next one.

6 MR. THEOFALOUS: Then you can pull the next
7 one down. And I think really, we have to pull all of
8 these down.

9 MR. CATTON: Theo, I think the lack of natural
10 circulation probably has more conservatism in it.

11 MR. BENDER: Can we move on?

12 MR. BIAN: Okay. The next one is the local
13 mixing in the downcomer, and we did some analysis based
14 on the Levy model. And while I will not go into the
15 detail, I will just show you.

16 (Slide.)

17 I will show you the assumption that the model
18 got from. This model is basically assuming that you
19 have instantaneous mixing of the cold water with the hot
20 water at the no-flow situation, and we believe with this
21 model we can come up with a result which is really close
22 to the NRC result.

23 (Slide.)

24 And so we believe that is basically the
25 approach they used. We got a final temperature of 136

1 degrees and they got 125, and the beta is .13 and theirs
2 is .12.

3 So that leads to the next question: How good
4 the approach is as far as realism is concerned. Of
5 course, there are certain arguments either for or
6 against that. One argument for that is that it is
7 conservative because the way that we do the analysis we
8 didn't allow for the hot water inside the downcomer, I
9 mean below the weld's location, to mix with the cold
10 water up above. And also, it didn't allow for the
11 thermal shield energy to be released.

12 But on the other hand, if you look at the
13 Criari data and also some analysis we did at PNL with
14 our code, we found there's a thermal stratification in
15 the cold leg, that the equation didn't allow for that,
16 the Levy model.

17 By the way, we add the wall heating on that,
18 too. So there is a no on that. Maybe the weld location
19 has an even hotter temperature than the Levy model
20 approach takes, if we allow for the cold water to settle
21 down into the lower part of the cold leg and just flow
22 towards the cold barrier, instead of the vessel side.

23 We don't know. There is certainly uncertainty
24 on that, and I think continued 3-D analysis will
25 probably help the situation to figure out exactly the

1 phenomenon that is involved in it.

2 (Slide.)

3 The last one I would like to go through
4 quickly is heating the ECC water, and I think it is
5 fairly clear that it would be very effective if we have
6 a stagnant flow situation, but it would be not
7 effective, but it is not critical, if the natural
8 circulation is maintained, because you have a continuous
9 source of heating coming from the cold leg.

10 But again, the effects on the core cooling and
11 also, for example, the active containment pressure, the
12 effect on those things really still is not analyzed well
13 enough or not analyzed at all.

14 MR. BENDER: Excuse me. Before you take that
15 off, what do you envision as the problems of heating the
16 ECCS? Are there any limitations that would have to be
17 put on what could be done?

18 MR. BIAN: Now, if we are worried about using
19 the ECC water for the no-flow situation, then we would
20 think that the core cooling probably is not mainly
21 caused by the temperature of the ECC water and it's
22 really mainly caused by the suppression of the water
23 level from the upper head, because of the steam forming
24 and so forth, and it is not the temperature of the ECC
25 water coming in.

1 MR. BENDER: If I wanted to set the ECC water
2 at 150 degrees instead of at the nominal 60 that was
3 used in the previous analysis, would that make the
4 problem go away altogether?

5 MR. BIAN: At least it would bring the small
6 break LOCA curve down, so that it would reduce the
7 probability of failure to maybe 10⁶ or whatever the
8 new number should be, instead of that dominating effect
9 that we see right now.

10 MR. BENDER: And the only problem you see in
11 raising the temperature would be that -- would be what?
12 Would there be any problem except spending money?

13 MR. BIAN: There is a problem that we haven't
14 analyzed. For example, the effect on maintaining active
15 pressure of the containment. You have extra heat source
16 there and that may cause some problems. We don't know.
17 That has to be analyzed, really.

18 And two more comments that are not in the
19 slide, that just came up this morning. One is that the
20 argument on the cold leg temperature measurement against
21 the downcomer temperature measurement, and we know in
22 certain plants that the RDT locations are upstream of
23 the injection location, and in that case the data will
24 be in serious doubt of usage for the analysis. That's
25 all I want to mention on that.

1 And the second is the fuel coefficient. We
2 found that using a constant value probably is not as
3 realistic, depending upon what value it is. If you used
4 a 300 Btu per hour, it probably is not as realistic as
5 using a variable value based upon natural convection for
6 at least the stagnant flow situation, because in the
7 latter part of the transient that's where you have a
8 concern about low temperature.

9 Usually, the delta T is smaller, so that you
10 have much lower H than the constant 300 value.

11 And that is the end of my presentation.

12 MR. SHEWMON: Thank you.

13 (Slide.)

14 MR. SIMONEN: I am Ed Simonen and my
15 responsibility on the PNL assessment of PTS is in the
16 area of material properties. There are three areas
17 which I would like to comment on this afternoon. One
18 has to do with variability and the material property
19 determination and the justification of using
20 conservatisms. The second area deals with our support
21 of the use of statistical-based trend curves and some
22 comments on how we feel they ought to be used in the PTS
23 evaluation. Lastly, we recommend some testing that
24 could be done to enhance the development and application
25 of the statistical trend curves.

1 (Slide.)

2 With regard to the variability in material
3 properties and the conservatism that is assumed, we
4 examined the issue with respect to what is accepted ASME
5 code practice of using lower bound fracture values
6 versus what is used in the PTS evaluation. What is used
7 in the PTS, in addition to using the lower bound K-1R
8 curve, are two contributions to variability. One is
9 from measurement error and the other is from a
10 generalized data base that is used in the development of
11 the statistical trend curves.

12 With regard to the measurement error, there is
13 an added contribution of conservatism that comes in due
14 to the fact that property is determined three times
15 rather than just one time, and it is -- like in the
16 lower bound toughness value, there is measurement error
17 that is incorporated in that lower bound.

18 But in PTS we have an indirect determination
19 of the material property. We have to make measurements
20 on the initial property that has its measurement error,
21 and then the shift that also has a measurement error.
22 So there seems to be a piling on of opportunity of
23 putting in measurement errors that have nothing to do
24 with variability of material property, of real
25 variability in the pressure vessel material.

1 We estimate that this measurement error added
2 conservatism is something less than 30 degrees, and this
3 is based on, if one looks in the literature and finds
4 how well one can determine Sharpey values and the RT
5 NDT, it seems like the best one can do is to come within
6 10 degrees Fahrenheit.

7 The best experiments, where the material
8 property is controlled as best one can, the error never
9 goes down below 10 degrees. And if you add on the 10
10 degrees from the initial property and the 10 degree
11 contribution from the shift and do that square root of
12 the sum of the squares, it comes out to be, I think, 28
13 degrees.

14 So there is an added conservatism in that with
15 regard to the generalized data base because the trend
16 curve is based on a wide range of different types of
17 material, different compositions, different radiation
18 environment spectra, flux. There is a lot of
19 uncertainty that comes into this data base.

20 My point would be that the actual vessel wall
21 has those same kinds of uncertainties with regard to
22 what was the temperature that the wall was radiated at,
23 the flux, the spectra, errors in the assumed
24 composition. So these -- this added conservatism really
25 seems to be justified because the vessel wall itself is

1 subject to that same variability.

2 So the end result is that one looks at the
3 total conservatism between mean value and the upper and
4 lower bound approach; there is something over 100
5 degrees Fahrenheit that is involved between those two
6 estimates, and of that 100 degrees something less than
7 30 degrees seems to be not really justified on real
8 material property variation.

9 This seems to be a minor contribution in the
10 total analysis because these uncertainties are known
11 with some degree of accuracy. There is this large
12 substantial conservatism, but we do understand the
13 uncertainties. We believe that the RT NDT is an
14 appropriate criterion to focus on for identifying plants
15 that are susceptible to PTS conditions.

16 The next comment having to do with
17 conservatisms has to do with the NRC report, in which
18 sigma values are used on the initial property welds, but
19 not used for plates. It would be our recommendation to
20 use -- to identify the appropriate population and
21 uncertainty distribution for each type of material, and
22 always included in the analysis in the welds there is a
23 population density that is accepted by NRC and it is
24 used for the plates.

25 I'm sure a similar distribution could be found

1 with much less uncertainty, but feel that that
2 uncertainty should be included the same way as it is for
3 the welds, just for consistency in the analysis, to make
4 the analysis less complicated.

5 MR. SHEWMON: Do the properties of weights
6 enter into this consideration at all? Is that where the
7 Guthrie data comes from or what?

8 MR. ED SIMONEN: It could. There are some
9 plants in which plates could be limited. I wonder, with
10 the flux distribution, that if plants start
11 redistributing their core so that they redistribute the
12 flux to the welds, that eventually the plate will be
13 limiting.

14 I think what we are advocating here is a
15 consistency in the treatment of material properties, to
16 not make exceptions for this and that, so it is clearest
17 what the policy is.

18 MR. IRWIN: This measurement, by which you are
19 talking about a measurement error, is it a measurement
20 of fracture toughness to yield strength or whatever?

21 MR. ED SIMONEN: I would say that I am
22 particularly thinking of the EPRI round robin
23 experiment, in which they took a plate and chopped up
24 specimens from the same portion of the plate, sent it
25 around to different laboratories and had a whole bunch

1 of tests done on the same material, and then looked at
2 these uncertainties laboratory to laboratory, instrument
3 to instrument.

4 MR. IRWIN: I believe that was pre-CRAC Sharpy
5 testing.

6 MR. ED SIMONEN: Right.

7 MR. IRWIN: That's not a very good comparison
8 from the point of view of the type of measurements
9 actually used in the NRC analysis for pressurized
10 thermal shock calculations.

11 MR. ED SIMONEN: You think the values should
12 be even less than what I'm saying?

13 MR. IRWIN: No. I think that you can't look
14 at a whole bunch of small specimen data. You will
15 always see a very large scatter simply because you pick
16 the tiny specimens. As you get a bigger and bigger
17 crack front, you will see less and less scatter, because
18 the crack front will represent all possible variations
19 to a greater degree.

20 What do you do about that?

21 MR. ED SIMONEN: Well, I guess you would have
22 -- the measurement error in the Sharpy's is greater than
23 it is for actual flux fracture toughness, which is
24 relevant to the PTS issue, so that there is probably
25 maybe a greater conservatism in here that really doesn't

1 represent performance of the vessel wall, that the
2 Sharpy's give more scatter than you would get with
3 appropriate kind of fracture toughness of vessel.

4 MR. IRWIN: Whether or not you can represent
5 the scatter in terms of degrees Fahrenheit is also a
6 question. It depends upon the slope of the curve when
7 you plot that measurement result against temperature.
8 If it is perfectly flat, then your uncertainty in
9 temperature might be 200 degrees.

10 MR. ED SIMONEN: Right. That comment had to
11 deal with all of these uncertainties and the whole
12 analysis of when Sharpy uncertainties are introduced.

13 Another comment with regard to this
14 consistency on how to treat the uncertainty in initial
15 property on the new plants, where the welds are
16 characterized better than they have been in the past:
17 It's a question of how will they be treated, with the
18 same type of sigma uncertainty or will there be -- or
19 will you take the new plant welds that are well
20 characterized and say they are like the plates because
21 they are well characterized.

22 This seems to be an opportunity for
23 misunderstanding as to how NRC will determine these
24 material properties for different examples. It would be
25 good to have a clear, consistent way of treating these

1 in all cases.

2 (Slide.)

3 A second area I would like to discuss had to
4 do with our recommended use of the statistical trend
5 curves. We do believe there are great benefits in the
6 use of the statistical trend curve. It allows the
7 owners to take credit for the low nickel that we would
8 normally be able to assign.

9 We believe that the statistical trend curve
10 should be used to describe all data and a statistical
11 model ought to describe the whole data base
12 satisfactorily, and that the reg guide upper cutoff
13 should not be used, as it is presently proposed, that a
14 statistical model should be identified that includes,
15 that does not make it necessary to put the upper cutoff
16 in the reg guide. And I think there are ways of doing
17 it that George Guthrie is looking at. That I think in
18 the end is what should be done.

19 Another problem with using the upper cutoff of
20 the reg guide is, what happens when new data comes in
21 that exceeds present reg guide line? If a new data
22 point comes in 20 points above the present line, does
23 that mean everything gets shifted up and then there is a
24 dramatic change in the valuation of all of the plants?

25 With the statistical curves, an outlier that

1 occurs like that simply gets incorporated in the whole
2 statistical data base and there is no dramatic change in
3 the evaluation of individual plants.

4 Also, I might point out limits to the
5 statistical curves with regard to our present PTS
6 evaluation, and pointing out that it is least
7 conservative at the extreme values, namely high copper,
8 nickel, and fluence, where copper is greater than .3
9 percent, nickel greater than .5 percent, and fluence
10 greater than 5 times ¹⁸10 .

11 Of the 139 points in the data base with the
12 statistical analysis, 7 satisfied those requirements,
13 which represents 6 percent of the data base. Within our
14 PNL or in the PTS evaluation, you look at the NRC list
15 of plants and the first five plants on the list are in
16 this category of 6 percent of the data base.

17 You must recognize that the uncertainty that
18 is given from the statistical uncertainty is really much
19 greater for these plants, because it is at the extreme
20 edge of the population of the data. So that is a
21 non-conservatism, if you would want to call it that.

22 Also, I might note that the reg guide is used
23 for three of these top five plants as the upper cutoff.
24 That is a serious issue, that many of the plants are
25 affected by that issue by the upper cutoff of the reg

1 guide.

2 (Slide.)

3 The last area I would like to discuss has to
4 do with identifying testing needs that would enhance the
5 development and application of the trend curves with
6 regard to a characterization of these radiated pressure
7 seals other than Sharp testing. In the 1960's, there
8 was a rather ambitious effort to look at properties of
9 vessel materials, namely at Oak Ridge to try to identify
10 submicroscopic -- these mechanisms that are responsible
11 for embrittlement.

12 Since that time there have been many new
13 advanced characterization techniques that have been
14 developed and that ought to be promoted to use these
15 techniques to identify reasons why, for example, this
16 nickel influences embrittlement the way it does. Does
17 low nickel have a unique effect, perhaps, on
18 saturation? Is there a limit to the high nickel effect
19 and how it is supplied in the development of the trend
20 curves?

21 MR. SHEWMON: Now, nickel tends to enhance the
22 effective radiation? Is that the conclusion?

23 MR. ED SIMONEN: Right. It is a product of
24 copper times nickel in the trend curve.

25 MR. SHEWMON: Are you close enough to this to

1 know whether that same effect is found on the other side
2 of the Atlantic? I have heard that there is some
3 question over there, where they use a lot of higher
4 nickel alloys?

5 MR. ED SIMONEN: I don't know. Perhaps George
6 could feel free to comment.

7 MR. GUTHRIE: I think it is still pretty much
8 up in the air.

9 MR. SHEWMON: Do you mean whether their data
10 is different from ours or whether there is an effect of
11 nickel at all?

12 MR. GUTHRIE: Combustion Engineering thinks
13 that there is an effect of nickel.

14 MR. SHEWMON: And it's a deleterious effect?

15 MR. GUTHRIE: Westinghouse I think thinks
16 there is an effect of nickel. People down in Santa
17 Barbara working for EPRI think there's an effect of
18 nickel. Russ Hawthorne thinks there is an effect of
19 nickel, and almost everybody I talk to thinks that there
20 is an interaction.

21 And the way they look at it mostly at this
22 point, people in the United States, is that when nickel
23 gets in there, if you're familiar with the copper-nickel
24 phase diagram, nickel can join a copper cluster and the
25 thing still maintains a copper-like character, or so you

1 would guess from looking at the copper-nickel phase
2 diagram.

3 Nickel is transition metal and it is magnetic,
4 and as you add copper to it it is still a transition
5 alloy and it is still magnetic. And you get up to 60
6 percent copper and it goes over to a copper-like
7 material and it is paramagnetic, and finally in high
8 copper it is diamagnetic. It is not a transition metal
9 any more.

10 If the same thing happens in small clusters,
11 nickel in small amounts joining a copper cluster would
12 make the clusters more numerous or make them bigger, and
13 still be copper-like in their character. If you try to
14 get too much nickel in there with just a little bit of
15 copper, it wouldn't work.

16 So what people think at this point is that
17 nickel is detrimental, especially in a high-copper
18 alloy, because the nickel can join the copper clusters.

19 MR. SHEWMON: In small amounts of nickel?

20 MR. GUTHRIE: In small amounts of nickel. But
21 when you get an awful lot of nickel, so that the nickel
22 can't join the copper clusters without driving them to a
23 transition metal or a nickel-type character, then the
24 additional nickel isn't going to do too much. And
25 people think that nickel by itself, with no copper in

1 there, really isn't all that bad a thing.

2 So that's the way it's looked at in the United
3 States at the present time, or at least that is what I
4 believe. And I have tried to put together models more
5 recently that have this in them.

6 But I noticed in going over the printout
7 sheets that I have with me that it doesn't seem to do a
8 whole lot of good on some of the outliers. And I am
9 beginning to suspect that in the high copper-nickel
10 data, that it is just scattered and we just don't have
11 very much of it.

12 And I agree with Ed, I would sure like to see
13 somebody get some submicroscopic information on what the
14 mechanisms are. And it is very hard to get any
15 mechanistic information on these things. We would feel
16 a lot more comfortable if we had purely mechanistic
17 models that we really believed in, where the parameters
18 had a physical basis for each parameter and where we
19 could then go in and get a least squares adjusted value
20 for each one of these real parameters where the
21 parameters meant something.

22 But we're stuck with trying to put together
23 mathematical models that fit the macroscopic data as we
24 see it and which account for the macroscopic properties
25 as we are aware of them.

1 MR. BENDER: Why don't we move on.

2 MR. ED SIMONEN: I guess I would comment that
3 it took five to ten years to identify copper as being
4 deleterious, and it took another five to ten years to
5 identify nickel. That is kind of through empirical
6 searches for effects, and that is what, 20 years worth
7 of effort. And maybe some key understanding could
8 direct these trend curves to get them on line a lot
9 faster.

10 The last area I would like to comment is on
11 trend curve application. We've talked about in situ
12 characterization of vessels in our report. We've
13 mentioned chemistry measurement on the outside of the
14 vessel. There is also possibilities that in
15 micro-hardness tests on the vessel, some types of
16 information that you can get that reflect mechanical
17 properties on a small scale of actually doing tests in
18 situ on an irradiated vessel.

19 The last area of concern has to do with this:
20 If vessels have to be annealed, there has to be a way of
21 using the trend curve information to establish
22 re-irradiation embrittlement guidelines, that it is not
23 good enough just to use the two isolated surveillance
24 specimens to establish the re-irradiation embrittlement,
25 but one should use the trend curve data base.

1 That is the best knowledge that there is on
2 the effect of radiation on the properties, and one ought
3 to develop the right kinds of tests that allow one to
4 know how the trend curve information will be used in the
5 re-irradiation embrittlement of an annealed vessel.

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. BENDER: Are there any questions?

2 (No response.)

3 MR. BENDER: Let's move on them.

4 ED SIMONEN: Next, my brother, Fred Simonen,
5 will talk about fracture mechanics and probabilistic
6 fracture.

7 (Slide.)

8 MR. FRED SIMONEN: I guess Ed is Mr. Materials
9 today and I am Mr. Mechanics. I would just like to say
10 a few words on my critique of the fracture mechanics
11 issues and statistical rather than probabilistic
12 fracture mechanics. I guess there are really two
13 essential questions.

14 (Slide.)

15 MR. FRED SIMONEN: One is, are the
16 conservatisms in these analyses appropriate, and the
17 other is, what is the significance of these
18 probabilistic fracture mechanics analyses and how do
19 they relate to the more conventional deterministic
20 analyses?

21 (Slide.)

22 MR. FRED SIMONEN: I have tried to sort
23 through some of these questions, and I guess I view it
24 in the way engineers do. Stress analysis, structural
25 integrity analysis. They tend to introduce

1 conservatisms in perhaps three different ways. One is
2 placing bounding values on the input parameters. In
3 this PTS example, talking about putting -- assuming flaw
4 sizes and toughness, we are taking minimum toughness to
5 overbound toughness curves and lower bound and upper
6 bound shift curves and that sort of thing, and the
7 important thing is, these types of conservatisms can be
8 quantified because you have got a data base to work
9 with, and this is addressed in the NRC work through the
10 probabilistic fracture mechanics.

11 There is another class of conservatisms I see
12 as just analytical or modeling assumptions, and in this
13 PTS work. For example, these things are like flaw
14 shape. Is it a short flaw, long flaw? Those things
15 aren't quantified. Clad effects. They are either -- it
16 could be acclused and warm prestress. The conservatisms
17 are not readily quantified, and these are not addressed
18 by the probabilistic fracture mechanics.

19 And as engineers usually perform these, they
20 usually attempt to take these assumptions, or you may
21 make a few non-conservative assumptions, but you always
22 want to make sure you kind of balance it against
23 something you are sure is an overriding conservatism.
24 If you leave something out, make sure you put some other
25 conservatism that is much greater than what you leave

1 out.

2 I guess a final safety factor or conservative
3 simple safety factor which is, if you look at design and
4 pressures according to the ASME code, we do have safety
5 factors from two to three, and in some cases lower, and
6 essentially what these allow for is factors which you
7 really can't quite include in your model, kind of an
8 unknown, unknowns.

9 (Slide.)

10 MR. FRED SIMONEN: Okay, what I have done on
11 this slide is to try to list what I feel some of the
12 unquantified conservatisms are in the NRC analysis.
13 Essentially, these are conservatisms that aren't really
14 reflected in the probabilistic fracture mechanics. They
15 are not quantified, so there may be an additional lower
16 failure probability in my view due to these factors.

17 I have listed the various items on this
18 column. I looked at the various models. I had what the
19 NRC staff fracture mechanics has done. I have listed
20 what the ASME code would give you as guidance. And in
21 our report we went through quite an effort to try to see
22 just how would the ASME code dictate a PTS evaluation.
23 The code really kind of skirts around the issue, so you
24 kind of have to imply what the code would tell you, and
25 I think the reason why you look at the code, this was a

1 set of rules that was written long before this PTS
2 concern arose. So it was, I guess, a set of rules
3 written by the industry when they were looking to
4 justify rules to the public, and showing that these are
5 in fact conservative rules rather than trying to justify
6 the use of a particular vessel, and then I have listed
7 some of the industry's responses.

8 The first item, the safety factor, none of the
9 PTS evaluations have put any kind of engineering type or
10 code type safety factors. The code is very vague on
11 this issue. I would read in the code a factor maybe of
12 about the square root of two, about 1.4, 1.4 for the
13 faulted type loads we are talking here. There are two
14 other factors, clad thermal expansion and flaw length.
15 The code does not require you to prove clad thermal
16 expansion. You can just forget the clad is there.

17 The NRC staff has included this, and this, the
18 values I have seen in the NRC report, I have read
19 something like 17 percent increase in stress intensity
20 factor. The NRC evaluation includes very long flaws,
21 essentially infinitely long flaw where the ASME code and
22 in the Appendix G Section 2 would say a six to one
23 aspect ratio flaw, and the NRC codes would say something
24 like, that would give about a 20 percent enhancement in
25 K.

1 And essentially what I did can compare the
2 code with the NRC approach. The NRC does not include a
3 safety factor. They do have a couple of other minor
4 conservatisms included that are not dictated by any
5 provisions in the code. It is quite interesting. You
6 take the 17 percent, take the 1.17 and multiply it by
7 1.2, and you get a factor of 1.404, which is very nearly
8 close to the code, so I guess the conclusion is that the
9 way NRC is doing their analyses essentially would give
10 us very much the same result, if you follow the code.

11 MR. ZUDANS: The 17 percent is not a
12 conservatism. It is a reality. The 20 percent, yes.

13 MR. FRED SIMONEN: Okay. Well, I guess there
14 is other conservatism. I look at just what is your flaw
15 description. You are assuming the flaw extends through
16 the clad.

17 MR. ZUDANS: Yes, that exercise, although it
18 works out nice, it is not reality. Seventeen percent is
19 a real thing. You have the clad, and it is going to
20 expand thermally, and it is going to change the
21 stresses.

22 MR. FRED SIMONEN: That is given that you have
23 a flaw of two that extends from the base metal through
24 the clad. I agree.

25 MR. BENDER: Let's move along. We are quite a

1 bit behind schedule.

2 MR. FRED SIMONEN: There are a number of other
3 conservatisms I would mention here. There is the vessel
4 life. The flaw description has been based upon flaw
5 size description essentially. There are flaws that were
6 volumetric flaws in the weld. I guess all of the
7 analysis, to take a worst case assumption, that this
8 flaw is located at the vessel ID, and it is oriented
9 normal to maximum stresses, and extends through the
10 clad. The NRC did not include warm prestress. I
11 believe that there are many of these transients where
12 warm prestress will be a factor, and this is not
13 quantified in the probabilistic work. I guess all of
14 the analyses did consider crack arrest. The code does
15 allow crack arrest, although I think it was put in there
16 in the context of a large break LOCA, and applying it to
17 PTS, we would say that you might want to apply it in a
18 somewhat more conservative manner than was written into
19 the code.

20 And I guess the other factor is this question
21 of suppression of crack growth by tough clad. None of
22 the analyses have included that, but there is work at
23 Oak Ridge that will be looking at just that factor, and
24 it may show that this is a rather conservative
25 assumption as far as preventing crack growth

1 lengthwise.

2 (Slide.)

3 MR. FRED SIMONEN: I guess our conclusion is
4 that essentially the NRC staff analyses are essentially
5 consistent with the conservatisms of the ASME code. The
6 probabilistic fracture mechanics does quantify many of
7 the conservatisms in deterministic analysis, but there
8 are many conservatisms that simply are not quantified in
9 this, and the failure probability does not reflect these
10 effects. I guess in looking at the fracture mechanics
11 we also feel that perhaps the greatest uncertainty in
12 all of these analyses is the size and nature of the
13 flaw. The flaw size distributions are, I think, based
14 upon some very limited data.

15 MR. ZUDANS: How much conservatism do you
16 think there is in the fact that all of the stress
17 calculations are based upon a two-dimensional model
18 rather than a three-dimensional, and on the fact that it
19 is assumed that a whole vessel is uniformly cooled down
20 rather than just a limited range in a downcomer? Do you
21 have a feel for that?

22 MR. FRED SIMONEN: I think on initiation
23 perhaps not too much. If you note, most of the crack
24 arrest analyses simply, as they are done in the simple
25 1-D models, simply do not show a big effect of crack

1 arrest in PTS type transients, and I would think that a
2 three-dimensional analysis that would reflect the fact
3 that the embrittlement on the worst, there is a
4 gradation embrittlement down the length of the region.
5 As the crack grows long, it will tend to run into
6 tougher material. Some of the cooling from the
7 downcomer may be very severe on one part of the weld,
8 but may be much less on another part.

9 Perhaps if you were to go in and look at some
10 of these three-dimensional effects, the fracture
11 mechanics analysis may predict arrest in many more
12 situations than they are now. But within the simplistic
13 analyses, you don't seem to predict arrest for very many
14 of these transients when there is pressure,
15 particularly.

16 MR. BENDER: Is that it, Mr. Simonen? Are you
17 about finished?

18 MR. FRED SIMONEN: I have got some other quick
19 things, just kind of leading into the discussion on
20 inspection.

21 (Slide.)

22 MR. FRED SIMONEN: We did some simple
23 calculations to try to estimate what will be the benefit
24 of inspection on vessel reliability. The method, what
25 we did was use some of PNL flaw detection estimates.

1 These were used to modify NRC staff estimates of failure
2 probability, and when the results essentially predict a
3 failure in decreased probability and corresponding
4 allowable increase in RT NDT.

5 (Slide.)

6 MR. FRED SIMONEN: Just to illustrate,
7 essentially you have seen curves like this this morning.
8 These are a replot of some of Jack Strosnider's data.
9 All this shows is that as you increase RT NDT by some
10 amount, the probabilistic analyses show some
11 corresponding increase in failure probability. Factor
12 ten and failure probability correspond to about a 20
13 degree difference in RT NDT.

14 (Slide.)

15 MR. FRED SIMONEN: What we have done, then, is
16 taken -- okay, there is a vu-graph in your package that
17 kind of illustrates some of the details of the
18 calculation. I will skip that in the interest of time
19 here, but what we have done is taken flaw detection
20 estimates that Tom Taylor will be talking about in just
21 a minute. Essentially what they show here is, using an
22 approved inspection technique, this is something above
23 and beyond the type of requirements that are now used as
24 a typical ASME code type inspection. The estimate
25 showed that the detection probability is quite dependent

1 upon clad and surface finish. As you go to smoother, on
2 the upper end, the best detection capabilities for
3 smooth strip clad, about 95 percent flaw detection for
4 flaws greater than a quarter of an inch, and on the
5 worst end for manual unground clad it is down to a level
6 of about 50 percent for flaws even as big as one-half to
7 one inch.

8 Okay, going through the calculations, this is
9 what we predicted on what is the benefit of in-service
10 inspection. The one column is simply the predicted
11 factor of improvement in reliability, and these range
12 from like 16 to 32 on the best clad conditions and down
13 to something, oh, three to five on the very rough clad,
14 and a corresponding increase in RT NDT allowable
15 increase.

16 As I say, these are just rough estimates at
17 this point, and they are intended only to say, is there
18 some real benefit in doing a good in-service
19 inspection. I would not use these at this time for any
20 kind of licensing decision. You would have to do much
21 more detailed evaluation. I guess what the trend shows
22 is that at most you can get maybe a 30-degree benefit on
23 allowable increase in RT NDT for the best conditions.
24 The worst condition is, it may be down as low as ten
25 degrees.

1 (Slide.)

2 MR. FRED SIMONEN: So I guess our conclusion
3 is that improved in-service inspection can justify an
4 increase in allowable NDT, and that under the best
5 conditions, it can be increased up to about 30 degrees
6 Fahrenheit, or even under the worst conditions you can
7 justify increases up to maybe only about ten degrees
8 Fahrenheit.

9 Tom Taylor is next, and will cover just what
10 is behind some of these estimates of flaw detection
11 capability.

12 MR. TAYLOR: My name is Tom Taylor, from PNL,
13 and as Fred has just said, I will discuss the
14 nondestructive testing techniques that are currently
15 used or are currently available for use in pressurized
16 thermal shock.

17 (Slide.)

18 MR. TAYLOR: This vu-graph summarizes the
19 non-destructive testing techniques that are currently
20 proposed or used in the field. This particular
21 technique of dual transducer L-wave techniques was
22 developed by the Germans about ten years ago
23 specifically for interrogating the base metal underneath
24 clad of the reactor vessel. A focus transducer
25 technique has been recently developed by the French,

1 likewise for interrogating other clad crack techniques.
2 These are fabrication defects that this particular
3 technique has been developed for.

4 In the United States, some people have
5 proposed using a single transducer, either an L-wave or
6 a shear wave at a relatively high angle and using a
7 pulse echo or an emersion technique, and another
8 particular vendor has proposed using a full V technique
9 where sound is bounced off the OD surface of the
10 vessel. This is the ID clad surface, and then trying to
11 detect cracks on the ID surface.

12 MR. AXTMANN: What is it bouncing off of?

13 MR. TAYLOR: It is bouncing off the OD
14 surface. The sound is introduced on the ID clad surface
15 of the vessel. It penetrates through to the OD surface
16 and is bounced off at a 45-degree angle, and it is
17 supposed to detect flaws in the clad surface here. To
18 date, our evaluations have shown that this technique has
19 not been evaluated. This technique has, and the
20 subsequent slides are based upon an evaluation of this
21 particular technique that was developed by the Germans
22 several years ago.

23 (Slide.)

24 MR. TAYLOR: The dual probe for the crack
25 detection involves sending a sound beam in with one

1 element and receiving it with another. Both elements
2 are canted at an angle and cross just underneath the
3 clad surface. This helps near surface resolution under
4 clad resolution, and this shows you a schematic diagram
5 of the sound beam directivity pattern of the dual unit
6 transducer.

7 MR. SHEWMON: One of the elements of this is
8 that one is a sender and the other is a receiver?

9 MR. TAYLOR: That is correct, and they are
10 canted at an angle, so that the sound beam would be
11 focused underneath the surface. Any further questions?

12 (No response.)

13 (Slide.)

14 MR. TAYLOR: As Fred has shown earlier, since
15 this is a technique and we know it works, how well does
16 it work? Well, on an internal round robin test at
17 Batelle and with some flaw signal amplitude measurements
18 on various blocks made available to us through EPRI and
19 our own that have been fabricated, these are our
20 estimates of probability of detection for a nice strip
21 ground perpendicular and with the sound beam going both
22 perpendicular and parallel to the direction of the clad.

23 We estimate that there is a 95 percent
24 probability of detecting cracks that are a quarter of an
25 inch in through wall depth and greater.

1 MR. SHEWMON: Are these tight cracks you are
2 looking at?

3 MR. TAYLOR: These are thermal fatigue type
4 cracks. The data is based upon thermal fatigue type
5 cracks and some hydrogen cracking.

6 MR. SHEWMON: Are they put under any
7 compression when you are looking at them? Or are they
8 by their origin under compression?

9 MR. TAYLOR: The only compression would be any
10 compression resulting from cladding. The way the blocks
11 were fabricated was to induce a thermal fatigue crack
12 and then clad over the thermal fatigue crack. As you
13 can see, as the surface roughness, which is what this
14 illustrates, increases, our probability of detection
15 decreases considerably.

16 MR. BENDER: The vessels that we are concerned
17 about now, do they correspond to those at the bottom of
18 the list, or at the middle of the list, or at the top of
19 the list?

20 MR. TAYLOR: That is a very good question, and
21 in large part unknown. What we do know today is that
22 all vessels have to undergo a surface examination so
23 undoubtedly between here and up there have been some
24 kind of surface condition done to them, and Mr. Bender,
25 exactly how much is not known at this point, and it

1 would be incumbent upon the utility to determine that.

2 MR. SHEWMON: Do you mean Robinson won't tell
3 you? You haven't gone to the trouble of asking
4 Westinghouse? Or what?

5 MR. TAYLOR: I mean that often times the
6 utility itself doesn't know what the condition of its
7 vessel is.

8 MR. SHEWMON: They don't know how it was
9 fabrictaed? Nobody knows any more?

10 MR. TAYLOR: They know how it was fabricated.
11 They do not know or have not taken pictures or
12 documented what the inside condition is like.

13 MR. SHEWMON: Do you know how the Robinson
14 vessel was fabricated or how any of the vessels in
15 question were fabricated?

16 MR. TAYLOR: Do I personally know how they
17 were fabricated? They were fabricated to Section 3
18 rules.

19 MR. SHEWMON: When you learn which one of
20 those is, you might come back and tell us some day.

21 MR. TAYLOR: If the information were made
22 available to me, I could tell you.

23 MR. BENDER: I think the staff needs to get a
24 better story on this, and I would just suggest that the
25 story is not very well known right now. Go ahead.

1 MR. TAYLOR: I have also done some studies to
2 show the relative sensitivity of various calibration
3 techniques

4 (Slide.)

5 MR. TAYLOR: In this particular slide, the
6 signal response of a notch or a thermal fatigue crack is
7 plotted as its depth through wall and the response of a
8 three millimeter FBH is plotted here. The response of a
9 Section 11 2 percent notch, which is the current
10 American standard calibration notch, is plotted here.
11 The response of thermal fatigue cracks are plotted here,
12 and the response of through clad notches are plotted
13 here.

14 As you can see, the current Section 11 2
15 percent notch is used in amplitude, is much above or is
16 considerably above the thermal fatigue cracks. If this
17 were used as a calibration reflector, one could have
18 difficulty in detecting thermal fatigue cracks unless
19 one adds gain or goes at some percentage level below the
20 distance amplitude curve achieved by the use of this.

21 MR. SHEWMO : Do you know what the Germans
22 were looking for when they developed this technique and
23 what standards they used?

24 MR. TAYLOR: Yes, the Germans used not a three
25 millimeter but a two millimeter flat bottom hole, and

1 they were looking specifically for under clad cracks as
2 a result of fabrication defects.

3 MR. SHEWMON: So you are saying there is a
4 substantial difference between the ASME notch which the
5 regulatory people in this country accept and what the
6 Germans use as a standard, and they feel reflects what
7 they choose to inspect to? Is that right?

8 MR. TAYLOR: That is correct, yes. I might
9 also add that currently there are no specific code
10 requirements for detection of under clad cracks. It was
11 only intimated in the current vessel Reg. Guide that the
12 cracks near the inner surface are important. Exactly
13 what size one is supposed to detect is not --

14 MR. SHEWMON: That is progress, you have got
15 to admit.

16 MR. TAYLOR: Slight progress.

17 MR. BOCK: Can you tell us anything about
18 ultrasonic imaging technology which is in use in other
19 industries, and whether it has been investigated for
20 reactor vessel inspection?

21 MR. TAYLOR: It has not been extensively
22 investigated for reactor pressure vessels. EPRI
23 currently has a program in which they are going to use
24 some ultrasonic holography for examining the vessel, but
25 to date I don't know of any particular reports.

1 MR. BENDER: Can we move on?

2 (Slide.)

3 MR. TAYLOR: In summary, I would say that the
4 future work is to be in optimizing the detection
5 techniques and developing a standard criteria for
6 calibration reflector and for flaw recording levels that
7 currently does not exist. And finally, one needs to
8 develop criteria for a verification block, and this
9 would be a block with under clad cracks so one could
10 prove one's procedure upon it.

11 MR. BENDER: Let me just put things in
12 context. Some time ago when the staff came in, probably
13 six or eight months ago, something like that, there was
14 some optimism that the techniques available in Europe
15 could be readily translated into application in this
16 country. What is the judgment today?

17 MR. TAYLOR: The judgment is, the techniques
18 are adaptable to our industry.

19 MR. BENDER: What have we done in the last six
20 months to get in a position to use them?

21 MR. TAYLOR: I can't see that there has been
22 any specific requirements done other than these studies
23 that the NRC has through its research to develop the
24 technique that is currently part of the program.

25 MR. BENDER: In order to use them, do we have

1 to establish that the condition of the vessels that they
2 would be used on is such that they would be -- that
3 those inspection techniques would be meaningful?

4 MR. TAYLOR: Yes.

5 MR. BENDER: So you would have to investigate
6 each vessel that is under consideration to determine
7 what its surface condition is and its surface
8 conditions, I presume, would have to be of a certain
9 quality to make the technique usable?

10 MR. TAYLOR: That is correct.

11 MR. BENDER: It might be well if that were
12 written down in some way so it were understandable by
13 somebody.

14 MR. TAYLOR: It is addressed in the report.

15 MR. SHEWMON: The report that what?

16 MR. TAYLOR: It is addressed in Appendix L of
17 the PNL report. There is also a report coming out
18 through the research branch that details more of the
19 under clad crack study that is currently going on at
20 PNL.

21 MR. BENDER: Other questions?

22 (No response.)

23 MR. BENDER: Is that it, Mr. Taylor?

24 MR. TAYLOR: That is it.

25 MR. BENDER: Thank you. Why don't we take a

1 ten-minute break? When we come back, we will listen to
2 the Westinghouse presentation.

3 (Whereupon, a brief recess was taken.)

4

5

6

7

8

9

10

11

12

13

14

15

16

17

18

19

20

21

22

23

24

25

1 MR. BENDER: Can we reconvene, please? Would
2 the people in the back of the room sit down, and we will
3 proceed with the Westinghouse owners group presentation.

4 MR. SPEYER: My name is Daniel Speyer. I'm
5 chairman of the Analysis Subcommittee for the
6 Westinghouse owners group.

7 I would like to point out that this is my last
8 day as chairman of the Analysis Subcommittee for the
9 Westinghouse owners group. Beginning tomorrow Frank
10 Scheuer takes over the reins of the chairman of the
11 Analysis Subcommittee.

12 MR. BENDER: Are you being fired?

13 (Laughter.)

14 MR. SPEYER: No.

15 (Slide.)

16 We have had a chance to go through the draft
17 report from the NRC, and I would like to talk about that
18 report. I would like to tie in as part of that
19 discussion the work that we have been doing -- that is,
20 the Westinghouse owners group -- and then hopefully I
21 can bring out some more perspective on some of the
22 questions that have been raised by the subcommittee. As
23 part of that, please feel free to ask the same kind of
24 questions again of me. And, finally, I'm going to show
25 a slide which the bottom line gives our conclusions

1 about the draft, the screening criteria that have been
2 presented by the NRC.

3 The owners group is in substantial agreement
4 with the work that has been done by the NRC. In
5 particular, we agree with the idea of the use of RT NDT
6 as a screening parameter. In order to come up with
7 screening criteria based on RT NDT the staff used
8 operating experience to select the screening criteria
9 and then used the probabilistic approach to support or
10 give additional support for the screening criteria.

11 We are in agreement with all of that, although
12 we did things in the opposite direction. We used the
13 probabilistic approach first, and then in fact the staff
14 pointed out that our probabilistic approach didn't seem
15 to match the operating experience. We took a look at
16 that and in fact reached a different conclusion. We
17 reached the conclusion that the operating experience in
18 fact just about fell in line with the probalistic stuff
19 we did.

20 We do disagree on some technical details. A,
21 I just mentioned, the consistency of operating
22 experience with the PRA. There is some dialogue about
23 the frequencies that we had in our probabilistic study.
24 NRC came up with different numbers, as you heard -- some
25 higher, some lower -- that I think will be the subject

1 of some ongoing dialogue.

2 With regard to the calculational techniques in
3 fracture analysis, there are two areas that we have some
4 difference. One is the effect of clad. We have
5 basically assumed a neutral posture for the clad in the
6 fracture mechanics calculations. In fact, it is our
7 expectation that this is probably in that benefit of the
8 cladding effect, fitting the clad, keeping it closed, as
9 opposed to residual stresses.

10 The other area is the use of finite flaw for
11 arrest. Historically, the work that's been done by the
12 Westinghouse owners group initially considered finite
13 flaw for initiation and kept a self-similar geometry,
14 and in fact, finite flaw for arrest, in fact, we used
15 something that we called the two flaw criteria. I'm not
16 going to go into the detail of that. But subsequently,
17 rather recently, in fact, after more discussion with the
18 NRC we did switch to continuous flaw for arrest;
19 however, made with the finite flaw for initiation.

20 We believe that is a significant conservatism,
21 and we think the truth lies somewhere in between those
22 two; that is, between the position we had, which was
23 self-similar flaws, 6 to 1 aspect ratio throughout,
24 versus the other end of the assumptions one could make
25 which is a continuous flaw for after-crack initiation.

1 We believe that higher values for the screening criteria
2 can be justified.

3 Let me state these last two bullets I'm going
4 to amplify a little more on at the end of my talk when I
5 give a final conclusion slide, but we do believe higher
6 values for screening criteria could be justified. And
7 as far as the programs for plant-specific evaluations,
8 we think 18 months prior to exceeding this criterion,
9 criteria would be appropriate. And we also point out
10 that those specific analyses should permit event
11 sequence comparisons.

12 I will describe more later on what I mean by
13 that statement.

14 MR. BENDER: Excuse me. It's probably better
15 to ask this question, since you have some differences
16 between yourselves and the staff concerning the flaw
17 geometry.

18 Could you say why you think you are more
19 likely to be right than the staff is?

20 MR. SPEYER: Ted, did you hear the question?
21 I think I will leave that to the fracture mechanics
22 types. May I suggest we hold that and get back to it,
23 because I'm not technically competent.

24 MR. BENDER: I'm willing to wait.

25 MR. SPEYER: Okay. We will get back to that.

1 (Slide.)

2 Very briefly, I'm not going to read from the
3 next two slides except to say they are in the handout
4 which I believe has been brought in. And the slides,
5 the next two slides, go through a progression of reports
6 that we provided to the NRC. I will note a few things
7 on them.

8 A, the first one, WCAP-10019, was the kind of
9 design basis accident evaluation that has been
10 traditionally done that in fact was quite a bit in the
11 past now in terms of where we are today on what has been
12 done for PTS.

13 The May 28th is a significant report. That
14 was the one where we did in fact use the probabilistic
15 approach to come up with probabilities for various event
16 sequences. There was a fluence report. That was the
17 last bullet on that slide.

18 (Slide.)

19 Subsequently, we did a step-by-step review of
20 the owners group emergency response guidelines, the
21 ERGs, relative to the impact on PTS, and you heard about
22 that a little earlier from Steve Hanauer.

23 I would point out the owners group perspective
24 on that is we found out some important things by that
25 review. We found out areas where we think changes are

beneficial. We are going ahead and doing that. We
2 found areas where clarification is useful, notes could
3 be added. We are doing that. However, the bottom line
4 is on the whole we feel the ERGs that we had were in
5 fact quite good and did adequately address PTS, and we
6 are improving them. That is ongoing.

7 MR. SHEWMON: What's the ERGs?

8 MR. SPEYER: The emergency response
9 guidelines. They are the generic procedures that the
10 owners group was comparing. Those were then brought to
11 the plants. The plants should take those and prepare
12 their site specific emergency procedures.

13 MR. SHEWMON: You mean that we heard the
14 Westinghouse procedures misquoted this morning when the
15 statement was made they were fair densities and then
16 take the pressure back up to 2000 psi, or that was
17 indeed the best way to cope with the PTS in those
18 conditions?

19 MR. SPEYER: I guess what I'm saying, A, is
20 that was a bit of an overstatement; B, in fact there are
21 cases where one would like to keep the pressure up. For
22 instance, if you had a transient where you might trip
23 the reactor coolant pumps -- the steam generator tube
24 rupture, for instance, tripping the reactor coolant
25 pumps puts you into a stagnation condition which raises

1 more potential PTS questions than if one were able to
2 keep the reactor coolant pumps running. Keeping the
3 reactor coolant pumps running would be generally
4 synonymous, at least if you forget loss of offsite
5 power, which is a low probability event, and keeping the
6 reactor coolant pressure system up would enable you to
7 keep the pumps running.

8 MR. SHEWMON: But does the NDT go up to 2000
9 psi to keep these pumps running in the plant?

10 MR. SPEYER: Current criteria are on the order
11 of 1250 to 1500 psi. It depends upon the
12 instrumentation used. I would say 1500 psi would be a
13 typical number that we could use for this discussion.

14 MR. SHEWMON: Why does he have to keep it up
15 to 1500 psi?

16 MR. SPEYER: Because of Appendix K questions
17 for the small break LOCA. If the reactor coolant pumps
18 are not tripped at pressures lower than that, and that
19 is, let's say, 1250 plus, this brings you up to 1500.
20 If they are not tripped prior to going to 1250 for very
21 specific break sizes and locations, you get inventory
22 loss that will be fairly significant. And if you lose
23 the pumps at the worst time into their transient, it is
24 a fact you will in fact violate Appendix K; that is,
25 2200 degrees PCT.

1 To be sure you don't lose the pumps at that
2 worst time in the transient, you trip the pumps
3 purposely before you get to that point, before you have
4 gotten significant loss of inventory. The reason for
5 the excess loss of inventory with the pumps running is
6 you tend to keep an elevated two-phase mixture, so you
7 have more mass going out as opposed to steam relief, and
8 yet you have less energy removal out of the break.

9 MR. BENDER: Just to pursue Dr. Shewmon's
10 question a little bit further, if we set aside Appendix
11 K and just say what fuel failures are we subject to by
12 this kind of action, would the depressurization further
13 result in massive fuel failure, or are we just concerned
14 about violating the legal limit?

15 MR. SPEYER: I think it's partly the legal
16 limit B. I think it is a little more than that, and I
17 would not feel too comfortable with small break LOCAs
18 without having the reactor coolant pump criteria in
19 there. I believe it is useful on low pressures, not
20 based on detailed calculation.

21 MR. CATTON: Before you get away from
22 emergency response guidelines, we continually hear about
23 emergency training of operators. Are you doing anything
24 to try to get better methods for the operators to
25 interpret what is going on?

1 MR. SPEYER: You're my straight man, but it's
2 a little early.

3 (Slide.)

4 These are programs, and we'll jump back to
5 this later on, but I would just mention now the slide
6 I'm showing now is current Westinhouse owners group
7 PTS-related programs. Two of them are in fact generic
8 training packages, one in the area of PTS and one in the
9 area of steam turbine tube ruptures, steam generator
10 tube rupture.

11 MR. CATTON: I was thinking of a little bit
12 more than training. In the LOFT program where they
13 monitor pump current, that showed that that could tell
14 them pretty quickly what was going on. There are
15 probably other ways like energy balances on the steam
16 generator or whatever.

17 Is there any research going on at all looking
18 into that?

19 MR. SPEYER: Yes. That is here under the
20 reactor coolant pump trip criteria development; also
21 somewhat related to systematic evaluation effects of
22 stagnant loop transients.

23 Under the reactor coolant pump trip criteria
24 development we are looking at the plants and inspecting
25 the plants and comparing it, doing additional analysis

1 to see can we improve our reactor coolant pump trip
2 criteria so we don't have to trip the pumps. Either we
3 could allow lower pressure, or are there some other
4 symptoms we should be looking at.

5 MR. CATTON: Are you sure the process
6 interpretation in the control rooms is good enough?
7 Maybe we need to do a little bit better. Is that a part
8 of this?

9 MR. SPEYER: I don't know. I don't believe it
10 is. I believe it is based principally on what we have
11 available right now.

12 MR. CATTON: I think there is a real
13 opportunity to improve the operator's awareness of what
14 is going on behind the wall. I don't see owners groups
15 doing it, and I don't see NRC doing it. It is kind of
16 like you're going to live with what you've got, and
17 you're just going to be telling the operators some more.

18 MR. SPEYER: Well, we are as far as the review
19 of procedures. As part of that we are developing these
20 pressure-temperature curves which will tell him when he
21 is getting into a potential challenge, but that is not
22 additional instrumentation. That is an additional
23 diagnostic tool.

24 MR. CATTON: Why aren't things, like I think
25 the time constant of the RT NDTs must be 200 or 300

1 seconds.

2 MR. SPEYER: Of the RT NDTs? I believe
3 they're on the order of a couple of seconds, half a
4 second or two seconds.

5 MR. CATTON: Well, then, you've already got
6 all the instrumentation you need to do a pretty good
7 heat balance in your system.

8 MR. SPEYER: I'm pretty sure the time constant
9 is on the order of two seconds.

10 MR. CATTON: Well, then, you've already got
11 all the instrumentation you need to do a pretty good
12 heat balance in your system.

13 MR. SPEYER: I'm pretty sure the time constant
14 is on the order of two seconds.

15 MR. SHEWMON: I think it is very important
16 that you be able to drop pressure. And you say on one
17 hand you're going to provide your operators with a
18 curve. On the other hand you're going to say if we're
19 going to make him trip his pumps when he hits 1500 psi,
20 so he is going to bleed it on down.

21 MR. CATTON: I think he has to know whether
22 he's overcooled or undercooled.

23 MR. BENDER: Well, let's leave it that we wish
24 the operating procedures and the instrumentation matched
25 up a little better and move on.

1 MR. SPEYER: But we are, to a very serious --

2 MR. CATTON: I was afraid I might have to
3 sneak out.

4 MR. BENDER: Well, I'm going to allow you a
5 few minutes to make your pitch, and you may get some
6 sympathetic ears, but go ahead.

7 MR. SPEYER: The other point is the procedures
8 do in fact provide for termination of safety injection.
9 I believe the pressure is 700 psi -- correct me if I'm
10 wrong -- in the procedures. And that is for RCS
11 temperatures less than 350 degrees. There are other
12 indications that are required in order to do that
13 termination. I think it seems very level, and
14 pressurizer level. But those are specifically in there,
15 they were in there, and we've looked at them again as
16 part of our PTS review to ensure that he doesn't keep
17 the pressure up when he shouldn't. And so if the
18 temperature is less than 350 degrees, that is a
19 potential PTS scenario, and therefore, he does in fact
20 have specific guidance or direction to terminate the SI
21 when the pressure is approximately 700 psi.

22 (Slide.)

23 This is the rest of the outline of the reports
24 that the owners group has provided. I mentioned the
25 review of the emergency response guidelines. Those are

1 the procedures, the generic procedures.

2 Beyond that we have the July 15th, September
3 2nd, those two reports. I'm not going to mention those
4 in this slide. They are on the next slide in more
5 detail.

6 (Slide.)

7 In the May 28th report from the Westinghouse
8 owners group we demonstrated the likelihood of severe
9 cooldown transients was on the order of 10^{-3} . That
10 was, A, for crack initiation; and B, that was simply the
11 probabilistic view of event sequences without any
12 question about probability of flaw extension. There was
13 no combination with what you've heard the NRC
14 subsequently did in that area.

15 The conclusions of this particular study were
16 that RT NDTs in the range of 310 for longitudinal and
17 335 for circumferential flaws were acceptable. That, in
18 part, is why we're saying the current screening criteria
19 are in fact too conservative.

20 Subsequently, the July 15th owners group
21 report combined the 5-28 report with the staff's
22 probabilistic fracture mechanics calculations. We came
23 out with a number of less than 10^{-6} for probability.
24 That is small, and in fact small compared to the
25 proposed safety goals for core melt. That was discussed

1 earlier.

2 I would point out you saw plot of
3 probabilities versus RT NDT, and one was the owners
4 group, Westinghouse owners group, and the other was the
5 staff's; and there was a large discrepancy for small
6 break LOCA. I didn't address that at the time because I
7 wanted to be sure, but the owners group submittal with
8 the low probabilities for small break LOCAs or for small
9 break LOCAs less than two inches. That is, the cases
10 that lead to breakage of natural circulation, that lead
11 to stagnation and therefore lead to questions about
12 mixing and have the potential as far as PTS is concerned
13 were not on that. Those were handled by the
14 deterministic calculations. Those are not on that
15 figure.

16 So that is the reason why you see -- one of
17 the reasons why you see such a divergence in the
18 probabilities between the NRC's plot and the
19 Westinghouse owners group plot. So we used the
20 combination of the probabilistic approach both for event
21 sequences and fracture mechanics to demonstrate plant
22 safety for all Westinghouse vessels.

23 We have done this. I have here the number 270
24 degrees Fahrenheit and 325 for circumferential flaws.
25 This is in part because all of the analysis we did

1 supports higher numbers, quite a bit higher numbers,
2 certainly 30 degrees higher at least for this small
3 break LOCA which is an event that has been termed an
4 outlier; that is, it has a reasonably high probability
5 of getting to very low temperatures because of mixing
6 questions in part, because of stagnation.

7 For that particular transient we did detailed
8 deterministic calculations. We took the worst size --
9 that is, the minimum size -- that leads to the breakage
10 of the natural circulation, and we did detailed
11 deterministic calculations. We did that. The numbers
12 you see here are based on finite flaw for initiation.
13 However, subsequent after initiation they're based upon
14 infinite flaw.

15 That is in conformance with what the NRC
16 requested, and in fact, based on that, using DPA, using
17 warm prestressing, we obtained a number of approximately
18 270 degrees for longitudinal and 325 for
19 circumferential. We believe that is a conservative
20 analysis, in particular because the question about the
21 finite flaw for arrest versus continuous flaw.

22 That fits in any event fairly well with the
23 NRC's proposed screening criteria. So I think that
24 lends credence to their screening criteria. And if you
25 haven't gotten the drift yet, in fact, when I get done

1 my bottom line is going to be we are supporting the NRC
2 screening criteria. We think it is appropriate,
3 although we do believe it is a little bit too
4 conservative.

5 Ted, there was a question raised. Would you
6 like it addressed now?

7 MR. BENDER: Sure. My question has to do with
8 explaining why the Westinghouse owners group disagrees
9 with the staff's concept concerning flaw size and growth
10 characteristics.

11 MR. SPEYER: In particular, I guess --

12 MR. BENDER: The question is continuous versus
13 discontinuous flaw characterization.

14 MR. MEYER: Ted Meyer, Westinghouse. I will
15 handle it in two different ways. One is the flaw
16 initiation and the other is flaw arrest. One is cleaner
17 than the other.

18 For flaw initiation we believe a finite flaw
19 is appropriate, and the NRC is in apparent implicit
20 agreement with that fact, based primarily on data that
21 has been taken from pre-service inspections of vessels
22 during the fabrication process, for flaws that have been
23 found have been found to be either typified or bounded
24 by a 1 to 6 semi-elliptic shaped flaw. In fact, those
25 typically were not surface flaws. They were probably

1 embedded flaws, which adds another degree of
2 conservatism that we haven't taken credit for in this
3 initiation. When it comes to arrest it is not nearly as
4 clean as even that.

5 We do not obviously have a hard empirical
6 basis for using a specified shape finite flaw for
7 arrest. If we had, we probably wouldn't be having this
8 discussion right now. We would have shown our data or
9 whatever and been on with using a fine flaw for arrest.

10 What we do have is more qualitative than
11 quantitative assessments that says the flaw shape should
12 not change from the finite flaw to a continuous flaw upon
13 a first initiation during a thermal shock.

14 Now, there is apparently test data that shows
15 both kinds of things that it goes through continuous
16 flaw, and then it also maintains some finite flaw
17 shape. Some of the tests showing that it goes through
18 continuous flaw do not have what we consider as the
19 benefit of cladding to help constrain the growth of that
20 flaw. So we don't have a hard empirical basis, and that
21 is why for the sake of getting on with the resolution of
22 this subject on an interim basis we did not press the
23 issue, because in fact we don't have a hard basis for
24 it; but in fact we are doing more work, again analytical
25 rather than empirical at this time, to further justify

1 our assumptions, be it a 1 to 6 or 1 to 7 aspect ratio
2 or whatever.

3 In the future apparently Oak Ridge is going to
4 be doing more work on empirical basis for looking at
5 crack growth with the clad and with the assumption of a
6 starting flaw that is finite.

7 MR. BENDER: With regard to the growth of a
8 flaw, does it make a difference if the flaw penetrates
9 the cladding?

10 MR. SHEWMON: Do you mean before it starts to
11 move under the stress?

12 MR. BENDER: Before or during.

13 MR. MEYFR: Well, it does make a difference if
14 the flaw is through the clad or beneath the clad. If it
15 is beneath the clad, it is obviously more constrained
16 than if it is through the clad. If it is through the
17 clad you lose any benefit, or you may lose any benefit
18 that you may assume or calculate for constraint due to
19 clad.

20 MR. BENDER: Well, I want to be a little bit
21 more explicit. If the flaw penetrates the clad do you
22 still argue that there is a limit on the rate of growth,
23 or will it still be an elliptical flaw of relatively
24 short length?

25 MR. MEYER: I don't have a well-founded answer

1 to the question. But, first, I want to clarify what I
2 think the question is: Is it more likely to become or
3 approach a continuous flaw if the flaw is a through clad
4 flaw?

5 MR. BENDER: Yes, that is the question. I'm
6 just asking the question because I know there's one
7 plant that says it is, and I would like to know what
8 Westinghouse's view is.

9 MR. MEYER: I think the only thing that we can
10 say right now is that the probability of going towards a
11 continuous flaw is greater for a through flaw or a
12 through clad flaw than for a flaw that is beneath the
13 clad. I don't know if I could say anything more
14 detailed right here now.

15 MR. BENDER: Okay. That's enough.

16 MR. SHEWMON: I would like to bring up one
17 point. If I wanted to learn about what kinds of flaws
18 are likely to be found or exist in vessels before they
19 went into service or ten years into service, where might
20 I look?

21 Let me talk a little bit more on that. It
22 seems to me that the good news about this is I don't
23 think the flaws are there. The bad news is I'm not sure
24 we could detect with the ASME-approved techniques if
25 they were. And so a lot of this is going to come back

1 down to somebody coming in, or part of it is in saying
2 there are no flaws there of the sort which all fracture
3 mechanics assume to give them a job and get on with what
4 they like to do best.

5 Okay. Any thoughts for one minute would be
6 nice.

7 MR. MEYER: As far as a reference document for
8 summarizing flaws, I personally don't know what the
9 document is. I'm sure there is information that is
10 available in some written form. In fact, some of the
11 code requirements were based on some of that kind of
12 data. I don't know what it is here. We certainly can
13 find out what that is if you want it and provide such
14 information.

15 What was the balance of your question?

16 MR. SHEWMON: That's enough. Thank you.

17 MR. ZUDANS: Your analysis of fracture
18 mechanics was based on through the clad flaws?

19 MR. MEYER: Can you repeat the question? I
20 couldn't hear you.

21 MR. BENDER: Would you speak into your mike?

22 MR. ZUDANS: The analysis that Westinghouse
23 owners group did on fracture mechanics, did you assume
24 the initial crack to be through the clad?

25 MR. MEYER: Westinghouse assumed the flaw was

1 underneath the clad, starting at the base of the clad
2 material. And the clad is intact except we don't take
3 benefit for the fact that the clad is intact. We say
4 there is no negative and no positive effect of the
5 clad. We use the zero effect. Because there are
6 positive and negative effects there that aren't
7 well-quantified at this time, we used a zero effect.

8 MR. ZUDANS: And in the structure model you
9 simply did not have the clad in?

10 MR. MEYER: In a structural model we used a
11 zero effect of clad.

12 MR. BENDER: Can we go on, Mr. Speyer? I want
13 to get done in 10, 15 minutes at the most.

14 MR. SPEYER: The final point I would like to
15 make about the small break LOCA analysis that we did, in
16 the deterministic calculation we did in fact use the
17 better estimate of mixing in that calculation. That was
18 based on the Criari test data.

19 There has been some discussion about the
20 Criari test or in general about the measurement of
21 temperature in the cold leg versus the temperature in
22 the downcomer for conditions of pump running or natural
23 circulation. And I think the general view is that there
24 is pretty good mixing. The condition of stagnation,
25 Criari did some tests into that condition. Mixing is

1 pretty good. In fact, there has been a model developed
2 called a teacup model. It is basically flow into a
3 finite volume and flow out and mixing within that
4 volume. If one defines the volume appropriately, then
5 the data from the Criari test can be predicted pretty
6 well. That in fact is what we used.

7 It is our expectation that in fact of our
8 sources of hot water -- this was discussed in fact at an
9 NRC meeting or an NRP meeting -- there are the sources
10 of hot water that are present, in particular the lower
11 plenum, that were not modeled on the Criari test. So it
12 would be our expectation that there are in fact
13 additional sources of hot water that would make the
14 situation even better.

15 In any event, our analysis assumed a better
16 mixing calculation using the Criari test. It also
17 included heat input from the appropriate heat slabs that
18 were available in the cold leg and in the vessel region.

19 (Slide.)

20 Going on, I would like to touch on the current
21 owners group PTS-related program. As I said, we are
22 developing emergency response guideline modifications.
23 That was based upon the review that we already
24 completed. We are implementing critical safety
25 functions for reactor vessel integrity. That is

1 basically a graph or graphs of pressure versus
2 temperature. As to the reactor pressure, let's hold the
3 pressure fixed for a moment as we drop the temperature
4 in the system. We would approach a curve, and in fact
5 at some point we would cross a curve that would give the
6 operator indication that he is getting into a potential
7 PTS regime.

8 As one went further along this line that I am
9 talking about into a PTS regime, another curve would be
10 crossed. That would tell the operator you are into a
11 PTS situation, go to -- or you are into a potential PTS
12 situation, go to a function restoration guideline, which
13 in essence says simplistically drop everything else; you
14 ought to worry about PTS to get yourself back into an
15 acceptable regime. And that is in fact what would be
16 done as far as a hierarchy. That is the second highest
17 of the function restoration guidelines. The only one
18 that is higher would be inadequate core cooling. In
19 fact, if the operator got into a situation of high core
20 exothermocouples, that would in fact take precedence
21 over PTS, but that would be the only one.

22 So we are developing that, and that is
23 designed to give the operator quantified information
24 that he can use as part of the procedures. Those are
25 going to be developed for various plants based on

1 various full power years. We are doing a generic
2 training package for operator training on PTS. This is
3 to be able to give consistent information and up-to-date
4 information the best we can to all of the plants for
5 their use in training.

6 We're doing the same thing, too, in the steam
7 generator tube rupture because this is a potential PTS
8 transient that has to be looked at. It also happens to
9 be a very complicated event, and that is why it is
10 appropriate to develop a true generic training package
11 for that event as well again for consistency.

12 This is not to mean, by the way, that people
13 like CPOL and others who are in fact upgrading training
14 and have done so and have developed packages -- those
15 are very good packages. This is to provide consistency
16 and provide assistance for all the members of the owners
17 group, which is in fact all of the operating
18 Westinghouse reactors.

19

20

21

22

23

24

25

1 As was mentioned before by Ted Meyer, we are
2 doing testing and analytical work in the area of warm
3 prestressing, specifically with respect to clad effects
4 and flaw shapes.

5 We are working on reactor coolant pump trip
6 criteria, to be able to prevent tripping the reactor
7 coolant pumps under conditions where it is not needed
8 and, in fact, where tripping the pump would be
9 detrimental either because it tends to give more
10 potential to PTS concerns, or, in fact, it removes some
11 of the operator's capability of very effectively
12 terminating transients.

13 Finally, we are doing a systematic evaluation
14 of the effects of stagnant loop transients. To
15 summarize before I put up my final slide or final two
16 slides, the screening criteria of the NRC, even if it is
17 too conservative in the view of the owners group, is in
18 fact reasonable or, to put it another way, is not
19 unreasonable. It enables all of the parties to
20 effectively utilize our resources. It is technically a
21 sound method. And it ensures safety.

22 (Slide.)

23 Therefore, we believe we should go forward
24 with the NRC proposed screening criteria, up to 70
25 degrees for longitudinal and 300 degrees RT NDT for

1 circumferential flaws. Again, we believe the values of
2 approximately 30 degrees greater would be more
3 appropriate, but we think we should go ahead with what
4 the NRC has proposed. Plant-specific programs be
5 developed 18 months in advance of the screening
6 criteria. NRC has proposed 3 years. We believe 18
7 months would be a more appropriate number.

8 We also point out that there needs to be work
9 done on what, in fact, are the requirements to be met in
10 a plant-specific analysis, not what is the analysis that
11 the plant does and how does it do it, but what are the
12 criteria one has to meet? Presumably, that is going to
13 be a probabilistic space. We do not think you could
14 pick a single scenario -- for instance, a small-break
15 LOCA -- and call that the PTS DBA. We think it will be
16 in probabilistic space, but we do think we have to have
17 those criteria developed before we go doing the
18 analysis. And that I think will be a little while in
19 the future. We also think 18 months is sufficient here.

20 MR. CATTON: What is the basis for the 18
21 months rather than 3 years? You just think that is
22 plenty of time to do the job?

23 MR. SPEYER: I think it is plenty of time,
24 yes. B, I think there is some problem if you make it
25 too long.

1 C, in fact, the plants are actively looking at
2 this for other reasons; that would be not necessarily
3 just the safety, but they have the economic questions
4 that, in fact, are more limiting, if you will. If you
5 have a crack that initiates and arrests and you did not
6 have a safety problem, you maybe would have to write off
7 the vessel.

8 So we believe 18 months would represent a
9 balanced amount of time in order for the plant, 18
10 months prior to exceeding the screening criteria, the
11 plant would submit to the NRC the program they are going
12 to use to resolve it.

13 MR. SHEWMON: You are taking as self-evident
14 that the operators or owners at the plant are likely to
15 look down the road 3 to 5 years and wonder about core
16 modification, is that it?

17 MR. SPEYER: I take it, in fact, a little
18 differently than that. I believe the study that EPRI
19 did, looking at all the utilities, found that something
20 like 85 percent of the utilities have, in fact,
21 initiated low leakage patterns. It may be for a
22 multiple of reasons, but almost everybody has done it.

23 As far as the plant-specific programs, we
24 believe you should utilize comparative plant sequence
25 analysis. What I mean by that is we, in fact, have done

1 a generic probabilistic study that considered event
2 sequences. We believe that, A, represents an average
3 Westinghouse plant, if you will. B, it, in fact, is
4 representative of all the Westinghouse plants.

5 And we feel the appropriate way to go is for
6 plants to utilize that study, if they wish, and then
7 tailor it by showing or, first of all, showing that, in
8 fact, it is appropriate for them, making such changes as
9 they would feel better tailored to them.

10 For instance, a plant with low head safety
11 injection pumps would probably take that report and
12 modify the calculational numbers to represent the fact
13 that they do not have high head safety-grade charging
14 pumps.

15 They would also, I think, appropriately take
16 into account operator action -- excuse me -- better
17 operator training, upgraded assistance, upgraded
18 procedures, and then utilize that generic report, tailor
19 it somewhat to the situation, and use that as pposed to
20 a full-blown probabilistic study done by each plant.
21 They can do that, but I do not think that is necessary
22 or appropriate here.

23 Finally, the way one would utilize such a
24 plant-specific analysis, what would one do? Prior to
25 passing a screening criteria analysis would be done

1 either, A, to show, in fact, that a higher screening
2 value was, in fact, appropriate for that plant either
3 because of plant-unique systems, control systems, what
4 have you, or lack of control systems.

5 B, the plant could show that there are some
6 events that fall outside a probability acceptance goal.
7 Both events would then be calculated on a deterministic
8 basis to show whether or not they are acceptable. In
9 fact, exactly the way we did our calculations for the
10 small-break LOCA.

11 And finally, the third level would be if, in
12 fact, it is shown that there are unacceptable results
13 or, in fact, the probabilities are higher than
14 desirable, there would be remedial actions. The
15 remedial actions could extend from, you heard, reheating
16 the fuel and storage tank to other areas.

17 I might point out on that heating storage
18 tank, it is not clear right now that there is a major
19 problem with doing it, but I do not know what is
20 involved in plant-specific cases to do it, number one.

21 Number two, it does have potential impact, at
22 least on containment integrity calculations, and that
23 may raise the pressures above some of the design
24 pressures that are shown in FSARs. I do not know; that
25 would have to be looked at on a plant-specific basis.

1 Finally, we think there are a number of
2 conservatisms present currently in the way the
3 calculations are being done. I think there is probably
4 general agreement about that, although there is
5 different agreement as to quantification of them and
6 should we remove them now or not.

7 We do believe it is important that for the
8 future, given that we are going to use the screening
9 criteria approach as we start to have more results
10 coming in, that definitively would give a basis for or
11 more definitively give a basis for removal of
12 conservatisms.

13 We think it is appropriate to factor that in
14 and, in fact, raise or appropriately adjust the
15 screening criteria to recognize the removal of what were
16 presently less quantified conservatisms than will be
17 more quantified in the near future.

18 That is what I have to present for the
19 Westinghouse Owners Group. Are there questions?

20 (No response.)

21 MR. BENDER: If not, I would like to thank the
22 Westinghouse Owners Group for giving us this
23 presentation. I think it helps us to understand the
24 several views that exist. And we will take those into
25 account when we try to develop some recommendations to

1 put before the full committee.

2 Could we stop the Owners Group presentations
3 for a few minutes so that I can try to solicit comments
4 from the consultants and those members of the committee
5 that might need to leave by 4:00 o'clock, so that at
6 least we have the benefit of a collective set of
7 thoughts at least while everybody is here. Let me start
8 with Ivan Catton.

9 Ivan, you have some thoughts?

10 MR. CATTON: I have several things. Earlier
11 this morning we discussed the A transient. I really
12 think the Staff should analyze this so we can get -- we
13 are using best-estimate techniques -- so we could get a
14 better feel for what kind of conservatisms are involved
15 in the results that they have been showing us.

16 I think Steve made the comment about the
17 operator having to walk between overcooled and
18 undercooled and the desire not to be ultraconservative.
19 I think this emphasizes the need for establishing what
20 symptoms tell us quickest whether we have overcooling or
21 undercooling.

22 And I think it really deserves more attention,
23 and that to try to throw the whole thing into more and
24 better training for the operator might be a mistake.

25 MR. BENDER: You are saying a study of the

1 diagnostic capabilities is in order?

2 MR. CATTON: That is right. The only thing
3 that has been done along those lines is the brief study
4 that was done on LOFT on how well pump current could
5 tell them what is going on.

6 I think they can do a lot of things,
7 particularly if, as was just mentioned, the time
8 constant of the RTDs is 2 seconds. You could surely do
9 a heat balance on the system and know what is happening
10 and be able to tell the operator what is happening. I
11 think just more training is not going to do it. I think
12 it is too much to expect.

13 As far as the four items that Steve mentioned,
14 I think no immediate action is wise, because I think
15 there is still a great deal of conservatism in the Staff
16 position on the thermal hydraulic side as to the spec.
17 There is still a great deal in fracture mechanics, I
18 think that 270 degrees is fine, and with 3 or 4 years
19 before the first plant runs up against the wall, it
20 seems to me there is plenty of time for adjustment if it
21 is not right.

22 I would like to see some magic number where
23 the plant has to shut down and somebody has not done
24 something and have that number fixed so that when the
25 time comes there are no surprises.

1 MR. BENDER: Monroe?

2 MR. WECHSLER: I find myself interested in the
3 question of the calculation of the delta RT NDTs.
4 Following the discussion we had earlier, I find it
5 difficult to understand the wisdom of the kind of
6 two-tier approach that is being used, in which for the
7 higher fluences, I understand that this depends upon
8 copper concentration, but generally for the higher
9 fluences, the Reg Guide 1.99 is used or the Reg Guide
10 1.99 criteria are used, whereas for the lower fluences
11 the Guthrie fit is used.

12 I think consideration should be given to using
13 the Guthrie fit throughout the entire range of fluence
14 values. That is, for the entire population of points
15 obtained from the surveillance samples.

16 MR. BENDER: Do you have any view about this
17 two sigma criteria?

18 MR. WECHSLER: Well, I think the basis for
19 that is fairly well explained in the NRC draft
20 document. And one might argue with the precise values.
21 Certainly, there is nothing sacred about the values to
22 plus or minus 1 degree F., and certainly there is some
23 room for argument there. But I think in general terms
24 the document justifies the basis for introducing that
25 two sigma approach, and I am generally satisfied with it.

1 MR. BENDER: Herb.

2 MR. KOUTS: Well, I certainly agree with what
3 Ivan Catton has said just now and what Theo is going to
4 say on the subject of analyzing these transients. And I
5 think some of this analysis is really under way now. It
6 is just not at the stage where it can be reported. I
7 believe there is Los Alamos work proceeding along these
8 lines.

9 But as this continues, of course, there are
10 some insights that will develop. And one thing that
11 bothers me very much, especially listening to what I
12 have heard today, is how much space is there between
13 what operators are supposed to do if they are subjected
14 to conditions of pressurized thermal shock that they
15 have to worry about, and LOCA. And, you know, you may
16 be put in a position where you are damned if you do and
17 you are damned if you do not.

18 With respect to such things as repressurizing
19 the plant, is there space enough in between the two sets
20 of requirements under these two circumstances, so that
21 trying to get out of trouble in one place you do not get
22 into trouble in another. And I think this needs
23 exploring.

24 Beyond this, I notice that during the day we
25 have not heard anything about elastic plastic fracture

1 analysis and its implications for this problem. It
2 seems to me that this is a fruitful area for research
3 programs to be initiated. I think that NRC really ought
4 to get more heavily involved in the elastic plastic
5 methods.

6 And, in particular, I would like to follow up
7 on some of these comments that Professor Irwin made in
8 the note that he wrote to you on the question of whether
9 or not you get crack arrest in material above the upper
10 shelf if it is initiated in the brittle region. I think
11 this is a very important thing to try to establish:
12 under what conditions this takes place and under what
13 conditions it does not.

14 MR. BENDER: Theo.

15 MR. THEOFALOUS: First, I would like to say
16 that I am very pleased with the progress that the Staff
17 has made in the recent months. And also, I like very
18 much the forceful way in which they presented their
19 approach. I think it is a sound approach, and they are
20 on the right track.

21 I agree for the time being with the screening
22 criterion also. And I like that approach because it is
23 specific because it puts things down so that other
24 people can look at them. And therefore, hopefully, in
25 this way one can keep refining things so eventually you

1 can come to where the truth is.

2 And in that spirit, I would like to suggest
3 that this aspect of refinement not be left completely,
4 but try to be formulated in such a way by the Staff so
5 that it becomes easy and possible by the different
6 interested parties here to keep working on a similar
7 framework instead of everybody working in his corner.

8 And what would help a lot in this direction is
9 if a base case or a set of base cases are documented in
10 a way that they are totally scrutable so you go out and
11 take a look at it and say, I do not agree with that, you
12 had better do it this way; and then if everybody agrees,
13 then you can work on that step. And if everyone was to
14 do that, a lot of the questions we had today, for
15 example, from me and Ivan and so on, they would not be
16 present.

17 So that I do not disappoint Mr. Kouts, yes, I
18 think the analysis of those specific transients, the
19 fact that the only experiments we have should be done,
20 although there are difficulties with such allowances
21 that are to be recognized. I think one can do quite a
22 bit more than saying, I have difficulties, therefore I
23 cannot analyze. And I think we can learn quite a bit
24 from such analysis.

25 I think that this is -- also I want to make a

1 note agreeing with Ivan again that we should come up
2 with procedures for the operators that basically are
3 diagnostic signatures, so that they can recognize the
4 situation and know what to do.

5 MR. BENDER: Zenon.

6 MR. ZUDANS: At this stage, everything has
7 been said. But I have to add some caveats. I
8 personally feel that one should be able, by continuous
9 collapsing and removal of conservatisms, to define what
10 is called PTS design basis. But that is my feeling,
11 although I heard Westinghouse Owners Group saying that
12 that was not a problem. I have no qualms about these
13 criteria the NRC presented. I think they are adequately
14 conservative.

15 I would like to repeat again that I would like
16 to see some of the conservatisms more specifically
17 identified. Some are identified now by the Westinghouse
18 Owners Group. Others were stated by Dr. Hanauer. And,
19 for example, what is the effect of three-dimensional
20 stage of temperature and pressure stress distribution as
21 one compared to one used in these analyses? How
22 important is that aspect? It is not quite clear. It
23 could be significant conservatism, or it could also be
24 none.

25 The other thing is I do not understand the

1 philosophy of excluding cladding from the vessel. It is
2 physically there, and not to have it in all models, heat
3 transfer and structural model, it just does not strike
4 me as being right.

5 MR. SHEWMON: Was it ignored in the heat
6 transfer?

7 MR. CATTON: No. They deal with an effective
8 heat transfer coefficient. That has in it. They put it
9 into the heat transfer.

10 MR. ZUDANS: Did they consider the heat
11 capacity, or just conductivity?

12 MR. CATTON: I think it is considered.

13 MR. ZUDANS: Well, if I am smart enough and
14 considerate enough, I can sit and reason everything out
15 and come up with a clean core. And that is not the
16 case, to show that this is indeed true by analysis.

17 MR. CATTON: That would be easy enough to do.

18 MR. SPEYER: It is excluded implicitly in the
19 Westinghouse Owners Group with its associates for the
20 heat conduction aspects.

21 MR. ZUDANS: All right. I remain unconvinced
22 about statistical basis on operating experience on these
23 events, having three B&W and four or five Westinghouse,
24 and putting them in the same basket and coming up with
25 statistics. One of the two that hurt and the other two

1 got advantages of the first. So I do not know if we
2 should treat Westinghouse separately from B&W. You
3 might come out differently. That's all.

4 MR. BENDER: George.

5 MR. IRWIN: I believe the NRC has made a very
6 good effort insofar in response to this problem. And I
7 also appreciate that the probabilistic work at
8 Westinghouse has been quite useful.

9 Now, with regard to conservatisms, I like
10 conservatisms myself. I am glad to see them. I do not
11 particularly want them to go away. But I would like to
12 know how much they are. And I made a little list of
13 these that are just in the fracture mechanics area.

14 For example, the variation of the mean $K_{I,C}$
15 with crack trunk length, that will be a substantial one
16 because the more rapid the chill the more we are
17 propagating tiny cracks, and the tinier the crack the
18 greater the mean K .

19 A second one was that the crack shape after
20 initiation is definitely not going to remain
21 self-similar, but it is definitely not going to be
22 infinite. And after all, the shell course is only about
23 80 inches, and if you crack goes halfway through an
24 8-inch wall, you have got 4 inches. That is a length of
25 20-to-1. And the calculation of 20-to-1 in a crack

1 halfway through the real reactor vessel is quite
2 significant in its effect on the K value.

3 The third one was warm prestress. Now, that
4 is going to take time. People will have to agree on how
5 to do the experiments. And it may not come soon, but
6 definitely there are benefits of warm prestress which
7 can be ascertained in a straightforward manner -- and
8 should be.

9 And number four was the fully plastic
10 conditions for deep cracks. That has been mentioned
11 before. I am not sure that we will get a great deal on
12 help on that score. But there is an uncertainty there
13 that should be removed and can only be removed by going
14 in and studying the deep cracks on an elastic plastic
15 basis.

16 Number five overlaps the fluid. And I do not
17 know anything about the fluid dynamics. But it does
18 seem odd that you can have cold water coming down like a
19 plume and at the same time chilling 360 degrees of
20 circumference. And I believe that discrepancy was
21 mentioned this morning by Steve Hanauer.

22 Now, that made quite a difference in the
23 fracture mechanics calculation. Whether I cool three
24 wall thicknesses or five wall thicknesses, all the
25 calculation assumes you cool 360 degrees.

1 Well, those are my comments.

2 MR. PENDER: Bill, I will let you have the
3 next word.

4 MR. BOCK: I will keep it short, since you
5 have most of my comments already.

6 Traditionally, what we were faced with in
7 reactor problems, we have always relied on a
8 defense-in-depth approach. And I see us getting away
9 from that, in that right now we are oriented toward
10 placing all of our eggs in one basket; namely, that we
11 believe that the reactor vessel is in a ductile, low RT
12 NDT condition.

13 And we are not approaching at this point any
14 of the other ways around it, which would include, for
15 example, trying to reduce transient frequencies or
16 trying to get better inspection techniques.

17 The way the screening criteria is currently
18 set up, it looks like we are going to defer those until
19 our first line of defense, meaning the ductility of the
20 vessel finally gives up. And I would like to see us
21 pursuing the others perhaps a little more vigorously and
22 perhaps independently of what the current RT NDT of any
23 particular vessel is.

24 MR. BENDER: Forrest.

25 MR. REMICK: Thank you. Just an observation.

1 The operating reactor data base is based on several
2 hundred reactor-years of domestic experience. I would
3 be curious to know what the foreign experience would
4 show. Would that enhance our understanding? Would it
5 improve the data base? Could it be used? Or would it
6 just further complicate our lack of understanding?

7 Also, I wonder very much about the naval
8 reactor operating experience. I do not know if the
9 owners groups know about that. Do they have access to
10 the information? I do not know if the NRC has that
11 access.

12 And along that line, has anybody thought about
13 Shippingport, which I now understand is decommissioned.
14 Is there anything about that vessel? I know some
15 designers who were involved in Shippingport, and we are
16 somewhat glad to see that Shippingport might be
17 decommissioned. Is there any information available, any
18 thought about how that might be used?

19 And if the answer to my questions about do we
20 know what the naval reactor experience is is "No," then
21 maybe the subcommittee or the committee itself might
22 take up the naval reactor people offer for exchange of
23 information and see if this is where they might share
24 some of their thinking?

25 MR. BENDER: Paul or Bob?

1 MR. AXTMANN: I am kind of curious about the
2 seven reactors defined as "at most risk," perhaps the
3 three worst, whether the owners groups or the individual
4 plants have looked seriously at the possibility of
5 changing the fuel loads not 3 years from now but
6 starting today and what the penalties for that might be?

7 I noticed on one of the slides from WOG that
8 they have a report, and I am anxious to see that, but I
9 wonder if any of the involved people have any comments?

10 MR. BENDER: Is there a hand back here?

11 MR. MORRIS: I could comment on that in a
12 minute when I get up there.

13 MR. BENDER: Would you identify yourself?

14 MR. MORRIS: I am Ken Morris of the CE Owners
15 Group. But I can address that when I get up.

16 MR. BENDER: Fine. We will hold it until then.

17 I am in the enviable position of being able to
18 say, having heard all of the comments, I agree with most
19 of them, and I do not think there is much that I want to
20 add to this conversation beyond saying that what I would
21 like to do is collect the set of comments here and put
22 them into some more organized form and presumably pass
23 them on to the committee as the collective views of this
24 working group.

25 Were there any problems that anybody sees in

1 making that kind of presentation? We heard different
2 viewpoints, but I did not hear much dispute about what
3 was presented. And, hopefully, the committee will, in
4 turn, digest them and pass them on in a somewhat similar
5 way to the Regulatory Commission.

6 With that, I think I would like to go back to
7 the CE Owners Group, and we will follow from there.

8
9
10
11
12
13
14
15
16
17
18
19
20
21
22
23
24
25

1 MR. MORRIS: My name is Ken Morris and I'm
2 with the CE owners group of the Omaha Public Power
3 District. Dr. Hanauer has often wondered who I am with,
4 so I was going to try to clear that up to start with.

5 I would like to respond to a question
6 regarding fuel loading patterns. I cannot speak for the
7 owners group; I can speak for Fort Calhoun Station. We
8 are scheduled to go into our refueling outage beginning
9 January 3, 1983, at which time we will go into a low
10 leakage fuel loading, which we currently estimate will
11 make a rather substantial reduction in our fluence;
12 probably a factor of two.

13 I don't have too many of the other CE owners
14 group members here. I am not aware of what their
15 actions are or timing for any changes in their fuel
16 loading patterns.

17 MR. AXTMANN: Do you have a number for what
18 happens with the power level?

19 MR. MORRIS: There is no penalty regarding the
20 power level. There will be some reductions in our
21 operating margins. We do feel we have adequate margins
22 to maintain our currently licensed power.

23 MR. AXTMANN: So the economic penalty is
24 essentially little?

25 MR. MORRIS: That is true. I might say that

1 we will explore methods of making further reductions in
2 that fluence, also, in the future.

3 I would like to say that we do appreciate the
4 opportunity to comment on the staff's evaluation of the
5 reactor pressure vessel thermal shock. The received the
6 report middle of last week and we have performed a
7 preliminary review of that report. We recognize there
8 have been some, we consider, very substantial
9 improvements in the program, in the staff's program
10 since we had seen last spring.

11 We are pleased that the evaluation confirms
12 the staff's and the industry's findings that there is no
13 immediate need for plant modifications to protect
14 against pressurized thermal shock, other than those
15 improvements in procedures and training which are
16 already underway or completed.

17 The NRC proposes to use the screening criteria
18 involving RT NDT as a method to identify those licensees
19 which must perform additional kinds of specific
20 evaluations. The CE owners group believes that proposed
21 approach is rational and conservative, and will serve to
22 identify those plants with potential pressurized thermal
23 shock concerns. Properly applied, we believe this could
24 be a very effective method.

25 The CE owners group has revised the methods of

1 calculating the RT NDT, and agrees with the staff. We
2 believe this method will provide a reasonably accurate
3 and conservative value for RT NDT. We agree that
4 plant-specific evaluations are needed to determine what,
5 if any, plant modifications to equipment, systems and
6 procedures may be required.

7 As stated in the report, more detailed
8 guidance for these evaluations must be provided.
9 Acceptance criteria must also be developed. We urge the
10 staff and their consultants to work closely with the
11 industry on the development of these guidance and
12 acceptance criteria.

13 We believe caution must be used to assure that
14 the guidance and acceptance criteria do not become
15 overly prescriptive and thereby eliminate other
16 activities which could assist in resolving pressurized
17 thermal shock concerns.

18 The CE owners group believes that the timely
19 development of guidance and acceptance criteria, coupled
20 with reasonable schedules for the completion of any
21 additional evaluations, plant-specific or otherwise,
22 will permit an orderly and timely resolution of the
23 pressurized thermal shock concerns.

24 I want you to know that we stand ready to work
25 with the staff and your consultants on the development

1 of the acceptance criteria and the guidelines for
2 resolution PTS. And I do want to make a few comments
3 regarding ongoing activities of the CE owners group.

4 You have heard quite a few comments regarding
5 procedures and operator training that CE owners group is
6 developing. We began sometime ago a training program
7 for PTS. We also have been working for quite a while on
8 emergency procedure guidelines which do incorporate PTS
9 concerns. PTS work has been a major part of our
10 training and our procedural work. We are proceeding
11 with that work as rapidly as we can to assure that it
12 does reflect concerns for LOCA and PTS, and we agree it
13 is something that needs to be clearly defined to the
14 operating people.

15 That is about all I have to say. Everything
16 else has been said today, so there wasn't any point in
17 my repeating it.

18 MR. SHEWMON: Given the comment about what
19 kind of room you feel your operators have for
20 maneuvering or getting confused between PTS and LOCA
21 concerns, have you gotten into that enough to feel that
22 that is not a problem with your present procedures, or
23 assumed procedures?

24 MR. MORRIS: I can't give you an operating
25 parameters that would quantify that margin. We are

1 insuring that the proper people, LOCA, PTS, are involved
2 in the procedure guidelines so that we are not improving
3 one at the same time doing harm to some other set of
4 procedures. There has to be a balance there.

5 The way we believe it has to be done is
6 letting the experts in the areas work hard on those
7 procedures. After that is done, have those procedures
8 and procedure guidelines thoroughly reviewed by the
9 operating people.

10 MR. SHEWMON: You haven't heard any screams
11 from that quarter yet?

12 MR. MORRIS: No, we haven't. We are paying a
13 lot of attention to the procedures and training.

14 MR. BENDER: You will recall that the staff
15 position suggests an 18-month period. Excuse me, three
16 years. My timeframe is fouled up. A three-year period
17 of preparation prior to seeing the bell ring, so to
18 speak. And the Westinghouse group has suggested 18
19 months. What is your view?

20 MR. MORRIS: I guess our view is we are going
21 to proceed. Let me take my owners group hat off now and
22 put on my OPD hat, if you will permit me, because I
23 can't speak for the other utilities on this one. But
24 Omaha Public Power District, our vessel is one of those
25 on the top of the Hit Parade. You can bet we will

1 proceed as timely as possible, consistent with the
2 staff's effort on this to get the proper corrective
3 actions identified and implemented just as soon as we
4 can.

5 I think someone else mentioned commercial
6 interest in this, and we are very sensitive to the
7 commercial interest, also. I just can't hardly see us
8 identifying an action that should be taken to resolve or
9 to reduce the PTS concerns and not taking those actions
10 once we are in a position to implement them. It just
11 doesn't make any sense for us.

12 MR. BFNDER: Other questions for the CE owners
13 group?

14 (No response.)

15 Thank you very much. I guess now we will have
16 the B&W group with the last opportunity.

17 MR. SHORT: I'm Barry Short from B&W, and I am
18 here to represent the B&W owners group at the request of
19 Mr. Lee Pacino. Lee regrets that he couldn't be here
20 today but he had some unexpected business come up at the
21 last minute. So he asked me to just cover a few points
22 here for you.

23 I'm going to keep my comments brief, also.

24 (Slide.)

25 What I want to do is cover three areas. Give

1 you an idea of what the B&W owners group is doing with
2 the thermal shock program, give you a few comments. I
3 have one slide on the first one and four slides on some
4 general comments on the staff's draft report, and then I
5 have a concluding slide that will give you an indication
6 of where the B&W owners group is going to go from here.

7 (Slide.)

8 I guess a most of you know, the B&W has been
9 involved in this issue for quite a while, and what we
10 have done is we have issued some generic reports back in
11 1980. They are basically discussed in the staff's draft
12 report. There is a B&W 1628 and B&W 1648. They are
13 generic reports back in 1980, and they concluded that if
14 you do a generic analysis, first of all, it's
15 unrealistic and you can see some imminent problems in
16 the future.

17 At that time or shortly thereafter, we started
18 some plant-specific analyses and in fact, we had planned
19 just prior to the staff issuing their August 21st letter
20 to do the plant-specific analyses. The August 21st
21 letter kind of target Oconee-1 and GPU, TMI-1, so we
22 were already doing those plant-specific analyses and
23 basically concluded that those two plants are acceptable
24 for the thermal shock issue.

25 Now, in the process of going from generic to

1 plant specific we learned a lot. In fact, in that
2 process -- well, I guess we've always known the small
3 break LOCA was a limiting event, but if you can solve
4 that problem you may end up with a different limiting
5 event, so you can't just pick small break LOCA and say
6 that's what your problem is.

7 Between the Duke Power Company and the GPU
8 analysis, we learned a lot about mixing, and that
9 report, the TMI-1 report. We have used a COMEX code
10 mixing analysis which shows quite a bit of margin for
11 the small break LOCA analysis, or small break LOCA
12 transient.

13 Those plant-specific reports were submitted
14 back in early 82 for Duke Power and July of 82 for GPU,
15 and basically, the two owners are waiting for the
16 staff's review of that in detail. And as a result of
17 that, the other plants have told us to just put
18 everything else on hold. So in this regard, nothing
19 else is being done by the B&W owners group as far as
20 plant-specific analysis.

21 Let me just comment. I have four overheads
22 here to comment on the staff's draft report.

23 (Slide.)

24 In general, it is a very comprehensive
25 report. I think they have done an admirable job of

1 putting everything in one place. I do have some
2 specific comments.

3 Like I said, first on the approach, we agree
4 that the screening criterion is an acceptable way of
5 targeting to determine when or if plant-specific
6 analyses should be performed. However, you've got to
7 watch out for a couple of things, and I just want to get
8 a couple of points across here.

9 We do believe that the values are
10 conservative, and that is based on what we know today.
11 One of the key things that we've got to keep in mind is
12 that we should, in my opinion and several of the other
13 owners, we shouldn't establish a limit for RT NDT today
14 and not be flexible. So flexibility is a key point here
15 because we know that even in the past year things have
16 changed. We have seen it go from where we have only
17 had, say, two or three years left and now we've got
18 maybe four or five years. B&W analyses show that you've
19 got somewhere beyond 30 years.

20 So I think technology is going to advance. We
21 have seen examples of that in the mixing area. We know
22 that fracture toughness is being worked on. Elastic
23 plastic techniques. And we also know that experience
24 enters into this.

25 The staff is using a rather limited experience

1 base, but as time goes on, that experience base is going
2 to change. And if we really believe we have told the
3 operators to watch out for the certain type of events,
4 hopefully in the future, we're not going to see any
5 operator errors. So flexibility is a key that I think we
6 ought to be considering.

7 Somewhere -- I guess it's in Chapter 10 or
8 maybe the recommendations -- it says the RT NDTs must be
9 calculated, or should be calculated, in accordance with
10 the way it is shown in Appendix E, or whatever it is.
11 I'm not really sure. But again, in the lines of
12 flexibility, if there are other ways of calculating RT
13 NDT and the B&W owners group is working on some of this,
14 we shouldn't close our minds to that.

15 So screening criterion is an okay way to go,
16 but let's be flexible about it. In a couple of years we
17 may have a new criterion. Maybe it is 300 for
18 longitudinal, maybe 350 for circumferential. We don't
19 know.

20 Item 2 suggests that the staff maybe just
21 clarify what their sequence of events are, and this I
22 think is on page 1.4. Or maybe it's 4.1. Screening
23 criterion is acceptable. You move from that into a
24 plant-specific evaluation. Depending upon what you find
25 in that plant-specific evaluation will determine what

1 you do next. Plant modifications may or may not be
2 required. There should be a three-step process here, as
3 opposed to a two-step process.

4 Third, we talk about -- I guess it's talked
5 about the report, -- a technical basis for if you
6 have to do a plant-specific analysis, you have to have a
7 technical basis for the remainder of the plant's life,
8 and I think basically, this issue of thermal shock is a
9 reactor vessel integrity issue, much like the issues
10 that Appendix G of 10 CFR 50 already talk about. And I
11 think the goal there is to make sure we stay ahead of it.

12 If a plant-specific evaluation can show that
13 this plant has no problem for 20 years and the plant is
14 at five years now, that may be acceptable. That plant
15 may not want to make modifications yet. I think that is
16 the philosophy behind Appendix G.

17 I know the staff has referenced Appendix G
18 several times in their report. I think it is a pretty
19 smart philosophy. It is kind of tied in with keeping
20 flexible and making sure that you watch out as
21 technology advances that you are ready to make the
22 changes as appropriate.

23 (Slide.)

24 As far as acceptance criteria goes, I had a
25 problem when I was reading the report and I wasn't quite

1 sure what failure was. It is talked about several times
2 as being no crack initiation. Very extensively it went
3 into crack arrest. There were safety goals that talked
4 about radiation releases, core melts or whatever. I did
5 not get a clear impression -- and this was relayed to me
6 by a couple of other owners, also -- of what the
7 criterion was when the RT NDT of 270 was calculated.
8 The word "failure" is used. I think maybe that ought to
9 be clarified

10 I think it was no initiation of crack, but as
11 I got further along I am not quite sure if it wasn't
12 arrest. It doesn't really matter, I guess, as long as
13 we know what it is.

14 And secondly here, the point that Steve made
15 this morning, one of the key things, and one of the
16 reasons why the B&W owners have put the plant-specific
17 evaluations on hold, is that we don't have an
18 agreed-upon acceptance criterion. We shouldn't waste
19 time doing plant-specific analyses without knowing what
20 is going to be acceptable. And like I say, that is one
21 of the main reasons why the rest of the B&W plants are
22 on hold right now.

23 MR. BENDER: There is something illogical
24 about that statement. It generally follows that people
25 do some analyses before they try to set acceptance

1 criteria in order to get some understanding of
2 uncertainties or how to allow for them, what options are
3 available.

4 I think essentially what you are suggesting is
5 that the NRC staff go back to its old generic basis. I
6 find that very discomforting, and if the position which
7 the B&W owners group is taking is that the staff has to
8 have arbitrary criteria before it will do any work, I
9 think we ought to make the criteria very conservative in
10 order to make sure the work starts early. What's wrong
11 with that logic?

12 MR. SHORT: Let me explain what I meant by
13 that. The B&W owners group has already submitted two
14 plant-specific analyses. We have a criterion in there,
15 and that is the criterion that we have used. And based
16 upon those analyses extrapolating, if you will, to the
17 other B&W plants, we don't see that there's going to be
18 any problem even with the other plants.

19 What we would like to see is we would like to
20 see some kind of evaluation done of the acceptance
21 criteria that we have chosen prior to the staff --

22 MR. THEOFALOUS: What have you chosen?

23 MR. SHORT: We chose in those two reports
24 within one quarter of the thickness of the vessel wall
25 crack arrest. And for a regulatory purpose, that may be

1 acceptable.

2 I guess what I'm saying is we want to get some
3 feedback on those reports. It's not that you sit by and
4 don't do anything. We have done something, and for that
5 reason, the other reports are on hold. I don't know if
6 that answers your question.

7 MR. BENDER: In addition to submitting the
8 reports, was there a specific request for a critique of
9 items within the report? Or did you just send the
10 report in and say, what do you think of this?

11 MR. SHORT: I don't know if you've seen the
12 reports, but the reports cover everything. We've
13 related to pressurized thermal shock. Everything we
14 know today.

15 MR. BENDER: Are they more comprehensive than
16 those which the staff prepared?

17 MR. SHORT: Do you mean the draft report?

18 MR. BENDER: The draft report, yes.

19 MR. SHORT: I commended the staff for being in
20 such agreement with what we have. Yes. They have
21 covered every area. I see nothing left out. We did not
22 go quite as extensively into the probabilistic or safety
23 goal area.

24 MR. BENDER: Do you think that is unimportant?

25 MR. SHORT: I think in the future -- I think

1 if you can show that you've got, with nominal
2 calculations, 30 or 40 years on a plant today, granted
3 there are a lot of uncertainties, but it certainly tells
4 you that there is a margin there.

5 In one of my later slides I'm going to show
6 you what the B&W owners are planning to do now. It's
7 not like we're sticking our heads in the sand.

8 MR. BENDER: Well, why don't you go ahead with
9 the remainder?

10 (Slide.)

11 MR. SHORT: I just want to continue some
12 comments here, looking at the applicability of the
13 methodology and the results. As we have been hearing
14 all day, the results are based largely on a lot of input
15 from the Westinghouse owners group, and there are some
16 basic differences in the plants. I know this was talked
17 about earlier, and I have a couple of examples here.
18 The vent valves and the once-through steam generator.

19 And I guess what the B&W owners group would
20 comment on is the significance of those differences
21 ought to be at least evaluated before the report is
22 considered a final report. And I think they've got
23 that. The staff has as a recommendation in Section 10,
24 so I would agree with that.

25 (Slide.)

1 My last of the general comments on the report
2 is on timing. I know we talked a little bit about this,
3 today as well. I think it might need some
4 clarification, and I think maybe some other people are
5 thinking along the same line. If we go ahead and begin
6 plant-specific evaluations three years prior to
7 exceeding some criteria, that's fine, we have no problem
8 with that.

9 Somehow, though, that report must be accepted
10 by the staff at some point in time because someone has
11 to make a judgment on what those plant-specific
12 evaluations are; if they are good or bad. And that is a
13 time factor that is missing. And I would say maybe a
14 year ahead of time. I don't know.

15 Based upon our experience, we have had the
16 staff reviewing the Oconee and GPU report or the TMI
17 report, and maybe a year is good enough. I don't know.
18 I think it is something that is missing as far as timing
19 goes.

20 MR. BENDER: Well, have you thought about what
21 you might have to do in the course of that year in order
22 to avoid being shut down? Do you expect the staff to
23 think that out for you, or are you going to do it
24 yourself?

25 MR. SHORT: If you do a report three years

1 ahead of time and the report comes out and says hey, I'm
2 good for 30 years and you submit it, --

3 MR. SHEWMON: Maybe no news is good news. You
4 don't understand what I'm saying. I mean, the staff
5 obviously is worrying about PTS. If they aren't on your
6 back maybe it is because they figure somebody else has
7 more of a problem than you do.

8 MR. SHORT: That could be. We have suggested
9 just adding a column, which I saw was added earlier
10 today, just talking about calendar years and not
11 effective full power years. And I saw that that column
12 was added in Steve's presentation this morning. Not
13 exactly as it is labeled here, but the column was there.

14 (Slide.)

15 My last slide talks about where do we go now.
16 And as I mentioned before, the remainder of the B&W
17 plants are on hold. We're trying to just find out
18 whether it's acceptable or unacceptable.

19 The B&W owners are continuing with their
20 reactor vessel materials program. This is a program
21 geared to find out as much as we can about the reactor
22 vessel. It has several phases to it. The phases talk
23 about the actual chemistries, the RT NDTs, the actual
24 fracture toughness, enhanced ISI techniques and also, in
25 the dosimetry area which is also an important area.

1 And then I just want to conclude with a couple
2 of statements here that Table P-1 at the end of the
3 report, it was suggested to me that -- I think the
4 statement was made here that the staff get the values of
5 RT NDT from the licensees. I believe that is one of the
6 recommendations of Section 10, Number 4. Moving back to
7 what I suggested before is that screening criteria is
8 fine, but as we learn more and more about it, maybe we
9 should be a little flexible with it, and a few years
10 from now that criterion may change up or down as we know
11 more.

12 Again, the B&W owners, we have basic
13 differences in the reactors, and I think they were
14 acknowledged in the report, in Section 10. I guess
15 there is something that is being looked at in that
16 area. And the last comment, I guess, is that again I
17 think the staff's report is good and very
18 comprehensive. I think the approach is good. I have
19 suggested a couple of areas to be clarified here, and I
20 think maybe a little bit more time -- we've only had
21 about a week to look at this thing -- a little bit more
22 time might be appropriate to get some more detailed
23 comments. That is all I want to say, and I will answer
24 any questions.

25 MR. BENDER: Are there any questions?

1 (No response.)

2 MR. BENDER: I would like to pose a couple. I
3 think we have not seen from the B&W Owners Group an
4 assessment of operator actions and the diagnostic
5 information that is needed to make sure that the
6 operator actions are the correct ones to avoid
7 pressurized thermal shock. Is there a study of how the
8 operators will respond, what kind of symptoms they have
9 available to them, and some kind of emergency guidelines
10 that are understandable to the operators?

11 The last time I heard somebody discuss this,
12 it was pretty much the operator's judgment as to which
13 way to move.

14 MR. SHORT: I am not sure if you are familiar
15 with the B&W ATOG program.

16 MR. BENDER: I can say I am not familiar with
17 it.

18 MR. SHORT: It is a program that has been
19 under way ever since TMI, and it is addressing the
20 issues of thermal shock. There have been guidelines
21 issued to all of the B&W utilities. I think the closest
22 thing that could come to what you are looking for is
23 simulator training.

24 MR. BENDER: Well, that is not very good
25 unless the simulators are capable of simulating the kind

1 of conditions that we have expressed concern for. I am
2 not convinced that the B&W Owners Group has really taken
3 the problem as seriously as they ought to take it, and I
4 think the fact that you are giving the kind of answers
5 you are giving to what seems to be a crucial issue of
6 operator behavior suggests that you ought to go back and
7 give some more thought to the problem.

8 I personally would like to see a much more
9 positive response than just, we think maybe simulator
10 behavior is the right way to study this thing. I still
11 have my doubts about whether the simulators are capable
12 of simulating the situation.

13 MR. SHORT: We don't want to have any actual
14 PTS events. What I am saying is that the owners have
15 recognized this for quite a while, the B&W owners. They
16 do have an active ATOG program under way.

17 MR. BENDER: Isn't it true that the 30-year
18 presumption you have on life is very much dependent upon
19 operators doing certain things in a certain way?

20 MR. SHORT: Yes. We do take credit for
21 operator action.

22 MR. BENDER: And if I were to take issue with
23 your assumptions, I might prove that the 30 years is
24 more like three. If that were the case, what would you
25 do?

1 MR. SHORT: Well, I don't think that is the
2 case, but if you could prove it --

3 MR. BENDER: I understand that.

4 MR. SHORT: If you could prove it, I would
5 like to know how.

6 MR. BENDER: Well, there is a lot of
7 subjective judgment in this business.

8 MR. SHORT: There are a lot of uncertainties,
9 and we came up with a list one time that was almost 20
10 areas of potential uncertainty, and one of the reasons
11 why we are talking here so long about it, I guess, is
12 because if you go worst case in every one of those
13 areas, you get yourself into a problem, and we have done
14 that, and so I am not standing back and saying we
15 haven't done it. We have done that.

16 MR. SHEWMON: Sir, one of the other reasons we
17 are here is that B&W plants are real hot-shot items, and
18 they have generated enough of these events so that we
19 realize it is a problem. So maybe they are a lot better
20 than they used to be, but we are here because of P&W
21 plants to a fair degree.

22 Now, you come out looking good by the staff's
23 current criteria, but your reactors don't, or your
24 automatic control systems don't, and maybe you can
25 handle them now, and you've got your operators trained

1 to where they can, but it is not immediately obvious,
2 given the past experience.

3 MR. BENDER: Well, let's not overreact to the
4 statements we are making. I guess my reaction is to
5 say, you are pretty blase about the whole thing, and it
6 is discomforting to hear it presented that way. Perhaps
7 we have misinterpreted the view, but I think, just
8 speaking for myself, I would be happier to see a more
9 positive kind of attitude rather than one which says,
10 look, we have shown there is 30-year life in this plant,
11 go away and leave us alone.

12 MR. SHORT: That is not the attitude, and I
13 didn't want to get that across. That is why I showed
14 the last slide, that we were doing things actively to
15 stay ahead of the issue. This is not the only vessel
16 integrity concern, and I think there has been a lot of
17 thought that has gone into it, and I think the B&W
18 owners are taking it seriously.

19 MR. BENDER: Thank you. Are there questions?

20 (No response.)

21 MR. BENDER: Does the working group have any
22 other thoughts, or would the staff like to add
23 anything?

24 MR. HANAUER: Mr. Chairman, I wouldn't like to
25 add anything, but I would like to get either now or

1 later some guidance on what you want in the full
2 committee meeting in October.

3 MR. BENDER: Well, that is a good thought. I
4 think the Committee was very well disposed toward the
5 presentation you made this morning, and while it might
6 not be necessary to present all of it, I think it would
7 be helpful if you would provide as condensed a version
8 as you could.

9 MR. HANAUER: Do you want the Committee to
10 hear either the Pacific Northwest or the Owners Groups?

11 MR. BENDER: Well, I was going to get to that
12 point separately. I think we need some kind of story
13 about the capabilities of a nondestructive examination
14 presented in a way that is more explicit than we heard
15 today, and one which speaks to what can be done about
16 the existing vessels, and states explicitly what the
17 uncertainties are associated with nondestructive
18 examination.

19 With the knowledge we have of the vessels
20 today, I think that would probably be enough to
21 enlighten the Committee from the staff's point of view.

22 MR. ZUDANS: I think at that point it would be
23 important to analyze the state of vessel cladding and
24 see which of these methods potentially could be used.
25 Nobody knew what the state of cladding is.

1 MR. BENDER: What I am hoping is that the
2 staff would be able to get somebody to tell us what they
3 know and what else they can learn in the period of time
4 between now and X, whatever that is. I think I will
5 leave it to the discretion of the Owners Groups as to
6 whether they would like to make a presentation.

7 Now, we have some time available for them.

8 MR. IGNE: We have three hours, and I think
9 Steve wanted two hours, and that left an hour for the
10 others.

11 MR. MORRIS: I just want to make a comment.
12 We do not have any, I believe need is the right word, to
13 make a presentation at the full Committee meeting. I
14 don't really see where it would serve any purpose for us
15 unless it would help someone else.

16 MR. BENDER: My suggestion is, the Owners
17 Groups have representatives there to respond to
18 questions, but if they would like to make presentations,
19 we would allocate some time. Does anybody see a need
20 for another kind of presentation? If not, let me
21 suggest first that those consultants that feel like they
22 would like to hear this again, they are cordially
23 invited to attend the full Committee meeting, but what I
24 intend to do is to convey to the Committee the
25 collective recommendations that we have had, and

1 hopefully they will be taken in the spirit of thought in
2 which they were developed, and they will be passed along
3 in an appropriate way.

4 MR. SHEWMON: Your criteria at this point in
5 time take no account of the kind of plant or the kind of
6 control system or the kind of experience? Is that true?

7 MR. HANAUER: That is quite correct.

8 MR. SHEWMON: Well, maybe at the full
9 Committee meeting we could discuss it further, then,
10 whether you think that properly reflects the effective
11 mass or whatever you use or the acceleratability of
12 these things.

13 MR. HANAUER: It does not. We just haven't
14 seen enough data to do anything different up to the
15 present time.

16 MR. SHEWMON: Thank you.

17 MR. BENDER: If there are no other comments,
18 this seems like a good time to adjourn this meeting. I
19 thank everyone for coming and contributing.

20 (Whereupon, at 4:45 p.m., the meeting was
21 adjourned.)

22

23

24

25

NUCLEAR REGULATORY COMMISSION

This is to certify that the attached proceedings before the

in the matter of: ACRS/Metal Components Working Group

Date of Proceeding: September 30, 1982

Docket Number: _____

Place of Proceeding: Washington, D. C.

were held as herein appears, and that this is the original transcript thereof for the file of the Commission.

Ray Heer

Official Reporter (Typed)

Ray Heer

Official Reporter (Signature)


PRESSURIZED THERMAL SHOCK
PRESENTATION TO
ACRS METAL COMPONENT SUBCOMMITTEE

SEPTEMBER 30, 1982

STEPHEN H. HANAUER

OUTLINE

- o GENERAL APPROACH
- o EVALUATION OF EXPERIENCE
- o SCREENING CRITERION
- o APPLICATION TO PLANTS
- o PROBABILISTIC EVALUATION
- o CONCLUSIONS AND RECOMMENDATIONS



EXPERIENCE

PRA

"TAIL"

OUTLIER (x)

PROBABILITY

TEMPERATURE

H.B. ROBINSON SLB 04/28/70





FIGURE 2-1

RANCHO SECO NNI/ICS 03/20/78





FIGURE 2-7

R.E. GINNA SGTR + PORV 01/25/82






FIGURE 2-12

$$T(t) = T_f + (T_0 - T_f) \text{EXP}(-\beta t)$$

P (t) = CONSTANT




FREQUENCY BASED ON OPERATING HISTORY
FINAL FLUID TEMPERATURE



EDT/MPC/08-24-82

FIGURE 2-14

FIGURE 3-3
GENERIC CALCULATION OF CRACK
INITIATION FOR STYLIZED TRANSIENTS



FREQUENCY BASED ON OPERATING HISTORY
 CRITICAL RTNDT VALUE (OCA RESULTS) AND FINAL FLUID TEMPERATURE




FIGURE 4-1

SCREENING CRITERION

- o LONGITUDINAL CRACK 270°F
- o CIRCUMFERENTIAL CRACK 300°F


EVALUATING A SPECIFIC VESSELL

$$RT_{NDT} = RT_0 \quad (\text{BEST ESTIMATE})$$


$$+ \Delta RT \quad (\text{BEST ESTIMATE - GUTHRIE})$$

$$+ 2 \sqrt{\sigma_0^2 + \sigma_{\Delta}^2}$$

LIMITED BY RG 1.99 + $2\sigma_0$



ΔRTNOT



EXAMPLE OF NRC PRESCRIPTION FOR RT_{NDT} (FOR ASSUMED
RT_{NDT} (o) OF 0°F)

(14)


PLANT STATUS AS OF DECEMBER 31, 1981

PLANT	RT ₀₂ OF	ART OF	$2(\sigma^2 + \delta^2)$	RT _{NDF}	DATE SCREENING CRITERION EXCEEDED
ROBINSON - W/CE	CIRCUM -56 AXIAL -56	295 151	34 59	281 154	February, 1987
LEFT CALHOUN - CE/CE	CIRCUM -56 AXIAL -56	264 248	34 34	242 226	April, 1990
TURKEY POINT - W/B&W	A CIRCUM 0 NO AXIAL	200	59	259	July, 1988
TURKEY POINT - W/B&W	3 CIRCUM 0 NO AXIAL	200	59	259	July, 1988
MAINE YANKEE - CE/CE	CIRCUM -56 AXIAL -56	248 238	34 34	226 216	September, 1995
ALBERT CLIFFS - W/CE	CIRCUM -56 AXIAL -56	135 212	59 59	138 215	October, 1989
INDIAN POINT - W/CE	3 CIRCUM 74 AXIAL 74	90 90	48 48	212 212	December 2002
PLATE GOVERNS					
YANKEE ROWE - W/B&W	CIRCUM 30 AXIAL 30	133 133	48 48	211 211	December 2033

SIGNIFICANT PTS EVENT SEQUENCES

- o SECONDARY (STEAM SIDE) DEPRESSURIZATION
- o MAIN STEAM LINE BREAK
- o SMALL STEAM LINE BREAK (OR STUCK OPEN STEAM GENERATOR SAFETY/RELIEF VALVE)
- o SMALL BREAK LOSS-OF-COOLANT ACCIDENT
- o STEAM GENERATOR TUBE RUPTURE

FREQUENCY BASED ON PRA STUDIES FINAL FLUID TEMPERATURE



EDT/NRC/88-24-82

FIGURE 8-1




FIGURE 7-1
CFP AS FUNCTION OF T_f -MEAN VALUE OF RT_{NDT}

$\beta = 0.15 \text{ Min}^{-1}$

Conditional Failure Probability for a Single Longitudinal Beltline Weld




FIGURE 7-2
CFP AS FUNCTION OF PRESSURE

P=1000 psig

Conditional Failure Probability for a Single Longitudinal Beltline Weld





FIGURE 7.3
CFP AS FUNCTION OF COOLDOWN RATE, Min^{-1}

β, min^{-1}

LONGITUDINAL CRACK EXTENSION NO ARREST


10⁻² WESTINGHOUSE OWNERS GROUP PRA RESULTS



MRC/EDT 09/08/82

FIGURE 8-2


LONGITUDINAL CRACK EXTENSION NO ARREST NRC STAFF PRA RESULTS



NRC/EDT 09/08/82

FIGURE 8-3

LONGITUDINAL CRACK EXTENSION NO ARREST NRC STAFF PRA RESULTS



NRC/EET 09/08/82

FIGURE 8-3

SAFETY GOAL

F VESSEL CRACK

X CORE MELT IF VESSEL CRACKS

Y SIGNIFICANT RELEASE IF CORE MELTS

CORE MELT XF $\leq 10^{-5}$

RISK XFY $\leq 5 \times 10^{-8}$

UNCERTAINTIES

- o OPERATING EXPERIENCE
- o OPERATION ACTIONS
- o FLAWS AND CRACKS
- o STRESSES
- o MATERIAL PROPERTIES
- o FRACTURE MECHANICS
- o PROBABILISTIC CALCULATIONS

SHORT TERM

1. NO NEED FOR IMMEDIATE ACTION
2. NEED PLANT-SPECIFIC ANALYSIS OF SELECTED PLANTS
3. SCREENING CRITERION
4. ACCEPTANCE CRITERIA FOR FUTURE PLANT-SPECIFIC ANALYSES ARE NEEDED
5. REGULATION CHANGES MAY BE NEEDED

PLANT-SPECIFIC PTS EVALUATION

- o EVALUATION OF OVERCOOLING EVENT SEQUENCES
- o VESSEL MATERIALS PROPERTIES
- o DETERMINISTIC FRACTURE MECHANICS EVALUATIONS
- o FLUX REDUCTION PROGRAM
- o INSERVICE INSPECTION AND NONDESTRUCTIVE EVALUATION PROGRAM
- o PLANT MODIFICATIONS
 - INSTRUMENTATION AND CONTROLS
 - AUTOMATIC DEPRESSURIZATION LOGIC
 - INCREASED EMERGENCY CORE COOLING WATER AND
EMERGENCY FEEDWATER TEMPERATURES
- o OPERATING PROCEDURES AND TRAINING PROGRAM IMPROVEMENTS
- o IN-SITU ANNEALING
- o BASIS FOR CONTINUED OPERATION

LONG TERM

1. IMPROVE PROCEDURES AND TRAINING
2. IMPROVE AND EXTEND GENERIC ANALYSIS
 - o INDUSTRY AND NRC
 - o BETTER EVALUATION OF EXPERIENCE
 - o BETTER PROBABILISTIC ANALYSIS EXTEND
TO B&W, CE
3. IMPROVE ISI OF HIGH RT_{NDT} VESSELS
4. DECREASE LEAKAGE NEUTRON FLUX

ACRS SUBCOMMITTEE MEETING 9-30-82

PNL AGENDA

- SUMMARY - NUREG/CR-2837 AND NRC PTS
SCREENING CRITERION L. T. PEDERSEN
- EVENTS AND THERMAL HYDRAULIC ISSUES S. H. BIAN
- MATERIAL PROPERTIES ISSUES E. P. SIMONEN
- FRACTURE MECHANICS ISSUES F. A. SIMONEN
- NDE METHODOLOGY AND APPLICATION TO ISI T. T. TAYLOR

PNL Technical Review of Pressurized Thermal Shock Issues

Manuscript Completed: June 1982
Date Published: July 1982

Prepared by
L.T. Pedersen, W.J. Apley, S.H. Bian, L.J. Defferding, M.H. Morgenstern,
P.J. Pelto, E.P. Simonen, F.A. Simonen, D.L. Stevens, T.T. Taylor

Pacific Northwest Laboratory
Richland, WA 99352

Prepared for
Division of Safety Technology
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555
NRC File B2510

ACRS SUBCOMMITTEE MEETING 9-30-82

NUREG/CR-2837 RECOMMENDATIONS

- UPGRADE PROCEDURES, TRAINING AND CONTROL ROOM INSTRUMENTATION ON A SITE SPECIFIC BASIS IN THE NEAR- TO LONG-TERM PERIOD.
- DEVELOP UNIFORM CRITERIA FOR FUTURE ANALYSES USED TO EVALUATE THE EFFECTIVE FULL POWER YEARS (EFPY) REMAINING BEFORE FURTHER CORRECTIVE ACTIONS ARE REQUIRED.
- ADAPT IMPROVED NDE TECHNIQUES DURING FUTURE INSERVICE INSPECTIONS, ISI.

ACRS SUBCOMMITTEE MEETING 9-30-82

NRC SCREENING CRITERION


RT_{NDT} FOR AXIAL WELDS - 270°F

RT_{NDT} FOR CIRCUMFERENTIAL WELD - 300°F

BASIS

- FREQUENCY OF OCCURRENCE FROM OPERATING DATA $\sim 10^{-2}$
- PROBABILITY OF CRACK EXTENSION $\sim 10^{-6}$

FREQUENCY BASED ON OPERATING HISTORY
CRITICAL RTNDT VALUE (OCA RESULTS)




DRAFT

Figure 4-1

DRAFT

LONGITUDINAL CRACK EXTENSION NO ARREST
NRC STAFF PRA RESULTS




NRC/EST 09/08/82

FIGURE 8-3

DRAFT

LONGITUDINAL CRACK EXTENSION NO ARREST

WESTINGHOUSE OWNERS GROUP PRA RESULTS



NRC/EDT 09/08/82


FIGURE 8-2

FIGURE 2

replace with later version

PROBABILISTIC VESSEL FAILURE

STAFF PRA VERSUS OPERATING HISTORY



ACRS SUBCOMMITTEE MEETING 9-30-82

HOW IS PROBABILITY OF CRACK
EXTENSION OF $\approx 10^{-6}$ SATISFIED

FROM DRAFT NRC STAFF EVALUATION OF PRESSURIZED THERMAL SHOCK,
SEPTEMBER 13, 1982, PAGE 8-6.

1. PTS EVENT SEQUENCES LEADING TO RPV FAILURE HAVE OVERALL FREQUENCY F PER REACTOR-YEAR. FIGURES 8-2 AND 8-3 PROVIDE A VERY APPROXIMATE ESTIMATE OF F. A PLANT EVALUATED (AS DESCRIBED IN SECTION 5 OR 9 AND APPENDIX E) TO BE AT THE 270°F SCREENING CRITERION IS LIKELY TO HAVE A TRUE RT_{NDT} OF 150-270°F (TWO SIGMA ≈ 60 °F). FOR THE MEAN OF 210°F, $F \approx 10^{-6}$ PER REACTOR-YEAR ON THE NRC CURVE (FIGURE 8-3), AND MUCH SMALLER ON THE WOG CURVE (FIGURE 8-2).

EVENTS AND THERMAL-HYDRAULIC ISSUES

- INITIATING EVENTS
 - ESTIMATION OF FREQUENCIES
 - OPERATOR ACTION TIME - ANSI STANDARD N660
- LOSS OF NATURAL CIRCULATION - CONDITIONS LEADING TO IT
NEED CLEAR DEFINITION (SITE-SPECIFIC)
- LOCAL MIXING IN DOWNCOMER

9/30/82

- HEATING ECC WATER - VERY EFFECTIVE UNDER STAGNANT FLOW CONDITION, NOT EFFECTIVE AND NOT CRITICAL IF LOOP CIRCULATION IS MAINTAINED. FURTHER INVESTIGATION NEEDED ON OTHER EFFECTS (E.G., CORE COOLING).

LOCAL MIXING UNDER STAGNANT FLOW CONDITION

USING ENERGY BALANCE WITH WALL HEATING:

$$T = (T_0 - T_F) \text{EXP} (-\beta t) + T_F$$

$$H_F = H_{HPI} + \frac{\dot{Q}'' A}{W_{HPI}}$$

(ENTHALPY AT 50 MINUTES INTO TRANSIENT IS TAKEN AS FINAL ENTHALPY)

$$T_F = F (H_F, P_{SYS})$$

$$\beta = \frac{W_{HPI}}{M}$$

LOCAL MIXING UNDER STAGNANT FLOW CONDITION

RESULTS:

PNL: $T_F = 136^\circ\text{F}$ $\beta=0.13$ (W 4-LOOP)

NRC: $T_F = 125^\circ\text{F}$ $\beta=0.12$

DOWNCOMER TEMPERATURE VS. ECC TEMPERATURE

$T_{HPI} (^{\circ}F)$	$T_F (^{\circ}F)^*$
60	136
80	154
100	174
120	194
140	213
160	233
180	253
200	270

* FOR W 4-LOOP STAGNANT FLOW

MATERIAL PROPERTIES ISSUES

PNL ASSESSMENT (9/30/82)

*VARIABILITY JUSTIFIES CONSERVATISMS

*STATISTICAL TREND CURVES RECOMMENDED

*TESTING TO ENHANCE TREND CURVES

(DEVELOPMENT AND APPLICATION)

VARIABILITY JUSTIFIES CONSERVATISMS

*NEED FOR ADDED CONSERVATISM

- MEASUREMENT ERROR

 - (<30 F CONTRIBUTION)

- GENERALIZED DATA BASE

 - (CONSERVATISM JUSTIFIED)

*NEED FOR NRC CONSISTENCY

- WELDS VS PLATES/FORGINGS

- OLD VS NEW PLANT WELDS

STATISTICAL TREND CURVES RECOMMENDED

*BENEFITS OF STATISTICAL CURVES

-DESCRIBE ALL DATA

-INSENSITIVE TO NEW DATA

*LEAST CONSERVATIVE AT EXTREMES

-HIGH C_u , N_i , FLUENCE IS 6% OF DATA

($C_u > .3$) ($N_i > .5$) ($F > 5e18$)

-WORST FIVE PLANTS

(HBR2/FC/TP4/TP3/MY)

TESTING TO ENHANCE TREND CURVES

- *TREND CURVE DEVELOPMENT

- SUBMICROSCOPIC CHARACTERIZATION

- (EFFECTIVE FOCUS ON PARAMETERS)

- (ADD CONFIDENCE IN MODEL)

- *TREND CURVE APPLICATION

- IN SITU CHARACTERIZATION OF VESSELS

- REIRRADIATION EMBRITTLEMENT

CRITIQUE OF FRACTURE MECHANICS AND
STATISTICAL ISSUES

F. A. SIMONEN

SEPTEMBER 30, 1982

BATTELLE
PACIFIC NORTHWEST LABORATORY

ESSENTIAL QUESTIONS

- ARE CONSERVATISMS IN FRACTURE MECHANICS ANALYSES APPROPRIATE?
- WHAT IS THE SIGNIFICANCE OF PROBABILISTIC FRACTURE MECHANICS CALCULATIONS?

CONSERVATISMS IN FRACTURE MECHANICS ANALYSES

I. BOUNDING VALUES ON INPUT PARAMETERS

- EXAMPLES ARE FLAW SIZE AND TOUGHNESS
- CONSERVATISM CAN BE QUANTIFIED
- ADDRESSED BY PROBABILISTIC FRACTURE MECHANICS

II. ANALYTICAL ASSUMPTIONS

- EXAMPLES ARE FLAW SHAPE, CLAD EFFECTS, WPS
- CONSERVATISM NOT READILY QUANTIFIED
- NOT ADDRESSED BY PROBABILISTIC FRACTURE MECHANICS
- ASSUMPTIONS SELECTED TO GIVE NET DECREASE IN FAILURE PROBABILITY

III. SAFETY FACTORS

- ALLOW FOR FACTORS NOT EVEN IDENTIFIED IN ANALYTIC MODEL

UNQUANTIFIED CONSERVATIVE FACTORS

FACTOR	ANALYTICAL MODEL		
	NRC STAFF	ASME CODE	INDUSTRY
SAFETY FACTOR	NONE	1.414	NONE
CLAD THERMAL EXPANSION	YES (K INCREASED 17%)	NO	YES (CE) NO (W, B&W)
FLAW LENGTH	VERY LONG (K INCREASED 20%)	6 X DEPTH	VERY LONG (CE) 6XDEPTH (W, B&W)
FLAW DESCRIPTION	AT VESSEL ID NORMAL TO STRESS EXTENDS THRU CLAD	SAME	SAME
WARM PRESTRESS	NO	NO	YES
CRACK ARREST	YES	LOCA, YES PTS, ?	YES
SUPPRESSION OF CRACK GROWTH BY CLAD	NO	NO	NO

CONCLUSIONS

- NRC STAFF ANALYSES CONSISTENT WITH ASME CODE (I.E., CODE SAFETY FACTOR OF 1.414 ACCOMMODATED BY CONSERVATISMS NOT REQUIRED BY CODE)
- PROBABILISTIC FRACTURE MECHANICS QUANTIFIES ONLY SOME OF CONSERVATISM IN FRACTURE MECHANICS MODEL
- GREATEST UNCERTAINTY IN ALL FRACTURE MECHANICS MODELS IS SIZE AND NATURE OF FLAW


BENEFIT OF INSPECTION ON
VESSEL RELIABILITY

OBJECTIVE - ESTIMATE INCREASE IN VESSEL RELIABILITY
THAT CAN BE ACHIEVED BY USING IMPROVED
ISI TECHNIQUES

METHOD - PNL FLAW DETECTION ESTIMATES WERE USED
TO MODIFY NRC STAFF ESTIMATES OF VESSEL
FAILURE PROBABILITY

RESULTS - DECREASE IN FAILURE PROBABILITY
- ALLOWABLE INCREASE IN RT_{NDT}

TRENDS IN VESSEL FAILURE PROBABILITY
(BASED ON NRC STAFF PTS ANALYSES)



EXAMPLE CALCULATION FOR BENEFIT OF INSPECTION

A	P(A)	P _{ND}	P(F/A)	Failure Probability	
				P(A)•P(F/A) (without ISI)	P(A)•P _{ND} •P(F/A) (with ISI)
0.125	8.3×10^{-1}	0	0	0	0
0.25	1.6×10^{-1}	0.10	1.5×10^{-4}	2.4×10^{-5}	2.4×10^{-6}
0.50	4.2×10^{-3}	0.05	1.0×10^{-2}	4.2×10^{-5}	2.1×10^{-6}
1.0	4.1×10^{-4}	0.05	5.4×10^{-2}	2.2×10^{-5}	1.1×10^{-6}
1.5	1.3×10^{-4}	0.05	5.6×10^{-2}	7.3×10^{-6}	3.6×10^{-7}
2.0	4.2×10^{-5}	0.05	4.5×10^{-2}	1.9×10^{-6}	9.5×10^{-8}
2.5	1.3×10^{-5}	0.05	-	~0	~0
3.0	5.0×10^{-6}	0.05	-	~0	~0
3.5	3.3×10^{-6}	0.05	-	~0	~0

$$P_o(F) = 9.7 \times 10^{-5} \quad P(F) = 6.1 \times 10^{-6}$$

- Notes: (1) Based on data from status report by Jack Strosnider on "Failure Probability of a RPV Subject to Pressurized Thermal Shock," March 5, 1982
- (2) For "Rancho Seco Transient Reference Case," mean copper = .34, initial $RT_{NDT} = 0.0$ and mean fluence = 3.0×10^{19}
- (3) Probability of flaw nondetection (P_{ND}) for smooth strip clad

A = Flaw depth

P(A) = Probability of a flaw of depth A in the critical weld

P(F/A) = Probability of failure for the Rancho Seco transient given the presence of a flaw of depth A

P_{ND}(A) = Probability of not detecting a flaw of depth A based on PNL estimates

P(A)•P(F/A) = Probability of failure without ISI given the occurrence of the Rancho Seco transient

P(A)•P(F/A)•P_{ND} = Probability of failure with ISI given the occurrence of the Rancho Seco transient

ESTIMATED INCREASES IN ALLOWABLE RT_{NDT}

<u>CLAD/FINISH/FLAW DIRECTION</u>	PROBABILITY OF DETECTION (A = FLAW DEPTH, INCH)	FACTOR OF IMPROVEMENT (1) IN RELIABILITY	ALLOWABLE INCREASE IN RT_{NDT} , %
STRIP/SMOOTH/PERPENDICULAR AND PARALLEL	} 95%, A > 0.25	16 to 32	24 to 31
THREE WIRE/SMOOTH AND UNGROUND/PERPENDICULAR			
STRIP/UNGROUND/PERPENDICULAR	} 85%, A = 0.25 TO 0.5 90%, A > 0.5	7.5 to 15	17 to 24
SINGLE WIRE/SMOOTH/PARALLEL			
STRIP/UNGROUND/PARALLEL	} 80%, A = 0.25 TO 0.5 85%, A > 0.5	5.5 to 11	15 to 21
MANUAL/GROUND/PERPENDICULAR AND PARALLEL			
SINGLE WIRE/UNGROUND/PERPENDICULAR AND PARALLEL	} 75%, A = 0.25 TO 0.5 80%, A > 0.5	4.3 to 8.5	12 to 19
MANUAL/UNGROUND/PERPENDICULAR AND PARALLEL			
	} 50%, A = 0.5 TO 1.0 75%, A > 1.0	2.8 to 5.6	10 to 15

(1) FACTOR OF IMPROVEMENT = PROBABILITY OF FAILURE WITHOUT INSPECTION/PROBABILITY OF FAILURE WITH INSPECTION.


LOWER BOUND ASSUMES FLAWS ARE ISOLATED AND INDEPENDENT OCCURRENCES. UPPER BOUND ASSUMES POSSIBLE OCCURRENCE OF MULTIPLE FLAWS IN A GIVEN WELD (I.E., ONLY HALF OF FLAWS ARE RANDOM OCCURRENCES).

CONCLUSIONS REGARDING BENEFITS OF
IMPROVED ISI TECHNIQUES


- IMPROVED ISI CAN JUSTIFY AN INCREASE IN ALLOWABLE RT_{NDT}
- UNDER IDEAL CONDITIONS (SMOOTH STRIP CLAD) RT_{NDT} LIMIT CAN BE INCREASED UP TO 30°F
- EVEN UNDER ADVERSE CONDITIONS (UNGROUND - MANUAL) AN INCREASE OF 10 TO 15°F CAN BE JUSTIFIED

'PTS' INSPECTION TECHNIQUES


DUAL TRANSDUCER (L-WAVE)




FOCUSED TRANSDUCER (L-WAVE)





SINGLE TRANSDUCER



FULL VEE (S-WAVE)




DUAL PROBE FOR UNDERCLAD CRACK DETECTION



UNDERCLAD CRACK DETECTION STUDY

<u>CLAD</u>	<u>FINISH</u>	<u>FLAW DIRECTION WITH RESPECT TO CLAD</u>	<u>SINGLE CRACK PROBABILITY OF DETECTION</u>
STRIP	GROUND	PERPENDICULAR AND PARALLEL	95% 0.25" AND GREATER FLAWS
THREE WIRE STRIP	GROUND UNGROUND	PERPENDICULAR PERPENDICULAR	85%, 0.25"-0.5" FLAW 90%, 0.5" OR GREATER FLAW
SINGLE WIRE STRIP MANUAL	GROUND UNGROUND GROUND	PARALLEL PARALLEL PERPENDICULAR AND PARALLEL	80%, 0.25"-0.5" FLAWS 85%, 0.5" OR GREATER FLAWS
SINGLE WIRE MANUAL	UNGROUND	PERPENDICULAR AND PARALLEL	75%, 0.25"-0.5" FLAW 80%, 0.5" OR GREATER FLAW
MANUAL	UNGROUND	PERPENDICULAR AND PARALLEL	50%, 0.5"-1.0" FLAW 75%, 1.0" OR GREATER FLAW



FUTURE WORK

- **OPTIMIZE DEFLECTION TECHNIQUES**
- **DEVELOP STANDARD CRITERIA FOR CALIBRATION REFLECTOR AND FLAW RECORDING LEVELS**
- **DEVELOP CRITERIA FOR VITRIFICATION BLOCKS**

MOG COMMENTS ON NRC POSITION

(NRC STAFF EVALUATION OF PTS)

- IN SUBSTANTIAL AGREEMENT WITH OVERALL APPROACH, METHODOLOGY, TECHNIQUES, CONCLUSIONS.
 - USE OF RT_{NDT} AS "SCREENING" PARAMETER
 - SELECTION OF SCREENING CRITERIA UTILIZING OPERATING EXPERIENCE.
 - USE OF ~~PROBABILISTIC~~ APPROACH TO SUPPORT OPERATING EXPERIENCE.

- DISAGREE ON CERTAIN TECHNICAL DETAILS
 - CONSISTENCY OF OPERATING EXPERIENCE WITH PRA.
 - FREQUENCIES OF SOME EVENT SEQUENCES.
 - CALCULATIONAL TECHNIQUES IN FRACTURE ANALYSES - EFFECT OF CLAD, USE OF FINITE FLAW FOR ARREST.

- BELIEVE THAT HIGHER VALUES FOR "SCREENING" CRITERIA CAN BE JUSTIFIED.

- PROGRAMS FOR PLANT SPECIFIC EVALUATIONS SHOULD
 - BE REQUIRED 18 MONTHS PRIOR TO EXCEEDING THE SCREENING CRITERIA
 - PERMIT EVENT SEQUENCE COMPARISONS

PRESSURIZED THERMAL SHOCK ISSUE ELEMENTS OF WOG PROGRAMS

- WCAP-10019 (12/81)
 - Responds to NUREG-0737, Item 2.K.2.13
 - Analyses of design bases transients
 - Conclusion: No near-term safety concerns
- May 28, 1982 Report
 - Provides assessment of frequency of occurrence of cooldown transients
 - Supports WCAP-10019
 - Establishes temperature limit criteria for potential flaw initiation
 - Conclusion: No near-term safety concerns for > 5 EFPY
- June 16, 1982 Report
 - Provides an assessment of benefits and penalties of fuel-management techniques to reduce vessel fluence

PRESSURIZED THERMAL SHOCK ISSUE ELEMENTS OF WOG PROGRAMS (Cont)

- June 22, 1982 Report
 - Step-by-step review of WOG Emergency Response Guidelines relative to impact on PTS
- July 15, 1982 Report
 - WOG assessment of relationship between 5/28/82 report Transient Event Sequence Results and NRC Probabilistic Fracture Mechanics Analysis
 - WOG recommendations for future regulatory activities, and Plant-Specific Programs
- September 2, 1982 Report
 - WOG approach to "outliers"
 - WOG interpretation of plant experience

W O G A P P R O A C H T O P T S

- WOG 5/28 REPORT DEMONSTRATES THAT THE LIKELIHOOD THAT A SEVERE COOLDOWN TRANSIENT WOULD OCCUR WHICH COULD LEAD TO FLAW INITIATION IS OF THE ORDER OF 10^{-3} PER REACTOR YEAR FOR VESSELS WITH RT_{MDT} IN THE RANGE OF 310°F (LONGITUDINAL) AND 335°F (CIRCUMFERENTIAL).
- WOG 7/15 REPORT DEMONSTRATES THAT VESSELS WITH MEAN RT_{MDT} OF ~300°F EXHIBIT FLAW EXTENSION PROBABILITIES $< 10^{-6}$ PER REACTOR YEAR WHEN SUBJECTED TO TRANSIENTS OF 5/28 REPORT (WITH EXCEPTION OF A CLASS OF SBLOCAs IN THE 2" - 6" RANGE).
- COMBINATION OF PROBABILISTIC APPROACH IN 7/15 REPORT AND DETERMINISTIC ANALYSES FOR SMALL NUMBER OF TRANSIENTS THAT LIE OUTSIDE PRA RESULTS DEMONSTRATES PLANT SAFETY FOR ALL W VESSELS FOR RT_{MDT} ~ 270°F (LONGITUDINAL) AND 325°F (CIRCUMFERENTIAL).

CURRENT WOG PTS-RELATED PROGRAMS

- DEVELOPMENT OF EMERGENCY RESPONSE GUIDELINE MODIFICATIONS TO ADDRESS PTS.
- IMPLEMENTATION OF CRITICAL SAFETY FUNCTION FOR R. V. INTEGRITY AND SUBSEQUENT FUNCTION RESTORATION GUIDELINES INTO THE WOG EMERGENCY RESPONSE GUIDELINES.
- DEVELOPMENT OF GENERIC TRAINING PACKAGE FOR OPERATOR TRAINING FOR PTS.
- DEVELOPMENT OF GENERIC TRAINING PACKAGE FOR OPERATOR TRAINING FOR STEAM GENERATOR TUBE RUPTURE.
- TESTING AND ANALYTICAL WORK IN THE AREA OF WARM PRE-STRESSING (FLAW SHAPE AND CLAD EFFECTS).
- REACTOR COOLANT PUMP TRIP CRITERIA DEVELOPMENT.
- "SYSTEMATIC EVALUATION OF EFFECTS OF STAGNANT LOOP TRANSIENTS.

WOG SUPPORTS/RECOMMENDS

- GO FORWARD WITH NRC PROPOSED SCREENING CRITERIA OF:

270°F RTNDT - LONGITUDINAL
300°F RTNDT - CIRCUMFERENTIAL

ALTHOUGH WE BELIEVE VALUES APPROXIMATELY 30°F GREATER, WOULD BE MORE APPROPRIATE.

- PLANT-SPECIFIC PROGRAMS BE DEVELOPED 18 MONTHS IN ADVANCE OF EXCEEDING THE SCREENING CRITERIA
- PLANT-SPECIFIC PROGRAMS UTILIZE COMPARATIVE PLANT SEQUENCE ANALYSIS AND DETERMINISTIC FRACTURE MECHANICS EVALUATIONS OF SIGNIFICANT EVENTS.
- FUTURE REMOVAL OF CONSERVATISMS SHOULD BE UTILIZED IN INCREASING THE SCREENING CRITERIA.

PRESSURIZED THERMAL SHOCK ISSUE WOG POSITION

- NRC should use 7/15/82 "screening values" of RT_{NDT} to prioritize attentions to operating plants
- Plant-Specific Programs can be prepared ~18 months in advance of exceeding "screening limit"
- Programs could include
 - Comparative plant sequence analysis
 - Plant-specific RT_{NDT} calculations
 - Deterministic fracture mechanics evaluation of contributing transients
 - Enhanced training
 - Procedure modifications
 - Evaluation of potential remedial actions

B&W OWNERS GROUP

- THERMAL SHOCK PROGRAM
- GENERAL COMMENTS ON NRC STAFF'S 9-13-82
DRAFT REPORT
- WHERE TO NOW?

B&W THERMAL SHOCK PROGRAM

- GENERIC REPORTS
 - BAW-1628 (DECEMBER 1980)
 - BAW-1648 (NOVEMBER 1980)

- PLANT SPECIFIC
 - DPCo OCONEE-1 SUBMITTAL (JANUARY 1982)
 - GPUN TMI-1 SUBMITTAL (JULY 1982)
 - OTHERS ON HOLD

COMMENTS ON THE STAFF'S DRAFT REPORT

APPROACH (PG. 1-4)

1. SCREENING CRITERION IS AN ACCEPTABLE WAY OF INDICATING WHEN/IF PLANT SPECIFIC EVALUATIONS ARE REQUIRED
 - A. VALUES ARE CONSERVATIVE, BASED ON TODAY'S KNOWLEDGE
 - B. MUST BE FLEXIBLE TO ACCOUNT FOR TECHNOLOGICAL ADVANCES. (E.G. MIXING, FRACTURE TOUGHNESS, EXPERIENCE)
 - C. SHOULD NOT LIMIT CALCULATION OF RT_{NDT} TO METHODS SHOWN (OTHER METHODS SHOULD BE ALLOWED IF SOUND)

2. SUGGEST CLARIFICATION OF SEQUENCE:
 - A. SCREENING CRITERIA
 - B. PLANT SPECIFIC EVALUATIONS (EFPY)
 - C. IF NECESSARY, EVALUATE MODIFICATIONS/IMPROVEMENTS

3. NOT NECESSARY TO PROVIDE THE TECHNICAL BASIS FOR THE REMAINDER OF PLANTS DESIGN LIFE. STAYING ADEQUATELY AHEAD (SIMILAR TO 10CRF50, APPENDIX G) IS ALL THAT'S REQUIRED.

COMMENTS (CONT'D.)

ACCEPTANCE CRITERIA

1. SUGGEST A CLEAR DEFINITION OF "FAILURE" FOR REGULATORY PURPOSES. (CRACK INITIATION, CRACK ARREST, CORE MELT, RADIATION RELEASE)
2. PLANT-SPECIFIC CRITERIA SHOULD BE ESTABLISHED BEFORE ANY EFFORT IS "WASTED" ON EVALUATIONS.

COMMENTS (CONT'D.)

APPLICABILITY OF METHODOLOGY AND RESULTS

1. RESULTS BASED ON INPUT FROM WESTINGHOUSE OWNERS GROUP
2. THERE ARE SOME BASIC DIFFERENCES IN THE B&W PLANT
(E.G. VENT VALVES, OTSG)
3. THE SIGNIFICANCE OF THESE DIFFERENCES SHOULD BE
DETERMINED

COMMENTS (CONT'D.)

TIMING - NEEDS SOME CLARIFICATION

1. BEGIN PLANT SPECIFIC EVALUATION 3 YEARS PRIOR TO REACHING SCREENING CRITERIA
2. MUST BE SUBMITTED TO STAFF 2 YEARS PRIOR TO REACHING CRITERIA
3. SUGGEST ADDING A COLUMN TO TABLE P.1:
"RT_{NDT} AFTER 3 ADDITIONAL CALENDAR YEARS"

WHERE TO NOW?

1. REMAINDER OF B&W PLANTS ON "HOLD" UNTIL OCONEE-1 AND TMI-1 EVALUATIONS ARE DETERMINED TO BE ACCEPTABLE OR UNACCEPTABLE
2. B&W OWNERS CONTINUING WITH R.V. MATERIALS PROGRAM
3. SUGGEST STAFF OBTAIN ALL VALUES IN TABLE P-1 FROM LICENSEES BEFORE FINALIZING REPORT
4. SCREENING CRITERIA SHOULD BE PERIODICALLY RE-EVALUATED BASED ON EXPERIENCE AND/OR EMERGING TECHNOLOGIES
5. B&W BASIC DIFFERENCES SHOULD BE ACKNOWLEDGED BEFORE FINALIZING THE REPORT
6. TIME SHOULD BE ALLOWED FOR DETAILED REVIEW