



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

September 24, 1982

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-017/03L-0
ER 100450 FILE 841-23
PLA- 1317

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-017/03L-0. This event was determined to be reportable, per Technical Specification 6.9.1.9.b in that the sprinkler system for Fire Zone 1-5A was out of service without the cognizance of, or proper response by shift personnel.

H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/cw

Attachment

cc: A. Schwencer
Division of Licensing,
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8210040086 820924
PDR ADOCK 05000387
S PDR

IER2