



Pennsylvania Power & Light Company

Two North Ninth Street • Allentown, PA 18101 • 215/770-5151

September 24, 1982

Mr. R.C. Haynes
Director, Region I
U.S. Nuclear Regulatory Commission
631 Park Avenue
King of Prussia, PA 19406

SUSQUEHANNA STEAM ELECTRIC STATION
LICENSEE EVENT REPORT 82-012/01T-0
ER 100450 FILE 841-23
PLA- 1316

Docket No. 50-387
License No. NPF-14

Dear Mr. Haynes:

Attached please find a copy of Licensee Event Report No. 82-012/01T-0. This event was determined to be reportable, per Technical Specification 6.9.1.8.i, in that there existed the potential for overload of the Class IE electrical system due to concurrent loading of Emergency Service Water pumps and either Residual Heat Removal or Core Spray pumps during a medium size LOCA.

H.W. Keiser
Superintendent of Plant-Susquehanna

LAK/cw

Attachment

cc: A. Schwencer
Division of Licensing
U.S. Nuclear Regulatory Commission
Washington, DC 20555

G. Rhoads
Resident Inspector
U.S. Nuclear Regulatory Commission
P.O. Box 52
Shickshinny, PA 18655

8210040118 820924
PDR ADDCK 05000387
S PDR

IE 22