LICENSEE EVENT REPORT

	LICENSEE EVENT REPORT
	CONTROL BLOCK: PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION
0 1	1 L D R S 3 2 0 0 - 0 0 0 0 - 0 0 3 4 1 1 1 1 1 1 6 57 CAT 58
0 1 7 8	SOURCE L 6 0 5 0 0 0 2 4 9 7 0 9 0 5 8 2 8 0 9 1 6 8 2 9
	EVENT DESCRIPTION AND PROBABLE CONSEQUENCES 10
0 2	During normal unit operations, weekly control rod drive exercising was being performed
0 3	When CRD H-4 (30-15) was tested for overtravel, the overtravel alarm came up and posi-
0 4	tion indication was lost, thus indicating uncoupling of the control blade from the
0 5	drive. This was of minimal safety significance since adequate shutdown margin was
0 6	maintained at all times and no fuel preconditioning limits were exceeded. No effect
0 7	on public health or safety. Previous occurrence reported by R.O. 82-21 on Docket
0 8	50-249.
0 9 7 8	SYSTEM CAUSE CODE SUBCODE COMPONENT CODE SUBCODE SUBCO
	17 REPORT 8 2 SEQUENTIAL REPORT NO. OCCURRENCE CODE NO.
	ACTION FUTURE COMPONENT SUBMITTED FORM SUB. X 18 C 19 Z 20 Z 21 0 0 0 0 0 0 0 0 0
[1]0	Probable cause is the CRD inner filter becoming detached. First attempts to recouple
m	CRD were unsuccessful. The rod was then fully inserted and electrically disarmed.
1 2	CRD was successfully recoupled on 9/9/82 and returned to service. CRD H-4 will be
1 3	replaced at the next refueling outage. Weekly CRD exercising and CRD inner filter
1 4	pull tests during rebuild will continue.
1 5	ACILITY STATUS 30 METHOD OF DISCOVERY DESCRIPTION 32 E 28 0 6 9 29 N/A B 31 Routine surveillance
	LEASE OF RELEASE AMOUNT OF ACTIVITY 35 LOCATION OF RELEASE 36 N/A
1 7	PERSONNEL EXPOSURES NUMBER TYPE DESCRIPTION 39 N/A PERSONNEL EXPOSURES N/A N/A
1 8	PERSONNEL INJURIES NUMBER DESCRIPTION 41 0 0 0 40 N/A
	OSS OF OR DAMAGE TO FACILITY 43
1 9	Z 42 N/A
8 9	PUBLI PDR ADJUK 05000249 80 NRC USE ONLY
2 0	N 44 PDR N/A
	NAME OF PREPARER

Commonwealth Edison DEVIATION REPORT DVR NO. 12 3 82 59

5 IME
STING
NO
that CRD
ive per
were un-
The sym-
4
NO NO
Just Just
9/5 /82
0800
TIME
TIME
1230
TIME
`
7
1