


James A. FitzPatrick
Nuclear Power Plant
P.O. Box 41
Latham, New York 12093
315 342-3840



William Fernandez II
Resident Manager

October 11, 1990
JAFF 90-0742

U.S. Nuclear Regulatory Commission
Mail Station P1-137
Washington, D.C. 20555

Attention: Document Control Desk

SUBJECT: JAMES A. FITZPATRICK NUCLEAR POWER PLANT
DOCKET NO. 50-333
PRIMARY CONTAINMENT INTEGRATED LEAKAGE RATE TEST
REPORT

Reference: 1) NYPA letter J. C. Brons to the NRC (JPN-88-012), "Request for Exemption from Containment Integrated Leak Rate Test-Retest Schedule" dated April 8, 1988

Attachments: I) Reactor Containment Building Integrated Leakage Rate Test, June 1990
II) Containment Isolation Valve Replacement Program Report, October 1990

Dear Sir:

The Authority is enclosing two reports relating to the FitzPatrick primary containment testing program. Attachment I is the Reactor Containment Building Integrated Leakage Rate Test Report for the June, 1990 PCILRT test. This report is submitted in accordance with the requirements of 10 CFR 50 Appendix J, §V.B.1. Included in this report is the local leakage rate test summary analysis for the "as-found" condition of the containment prior to the PCILRT test. Analysis of the test results indicates that the FitzPatrick containment exhibited satisfactory leak tightness in both the "as-found" and "as-left" conditions.

Attachment II (Containment Isolation Valve Replacement Program Report) is an evaluation of the effectiveness of the Authority's containment isolation valve improvement corrective action plan. This evaluation is submitted as discussed in Reference (1), Attachment II. The corrective action plan has achieved its stated purpose of reducing the "as-found" containment leakage rate to an acceptable value and improving the effectiveness of containment isolation valve repairs.

9010230014 901011
PDR ADOCK 05000333
P PNU

00088


A017
11 Cent No
P229764A27

U.S. Nuclear Regulatory Commission
Attn: Document Control Desk
SUBJECT: JAMES A. FITZPATRICK NUCLEAR
POWER PLANT
DOCKET NO. 50-333
PRIMARY CONTAINMENT INTEGRATED
LEAKAGE RATE TEST REPORT

October 11, 1990
JAFP 90-0742
Page -2-

Should you have any questions regarding this matter, please contact Mr. P. Swinburne of my staff at (315) 349-6563.

Very truly yours,



WILLIAM FERNANDEZ

WF:PGS:ls
Attachments

CC: L. Guaquil, WPO
R. Beedle, WPO
W. Josiger, WPO

J. Ellmers, WPO
RMS, WPO
DCC

USNRC (1)
475 Allendale Road
King of Prussia, PA 19405

Office of the Resident Inspector (1)
USNRC
P.O. Box 136
Lycoming, NY 13093

Mr. David E. LaBarge (2)
Project Directorate I-1
Divisions of Reactor Projects-I/II
USNRC
Mail Station 14 B2
Washington, D.C. 20555