(7 77)

U. S. NUCLEAR REGULATORY COMMISSION

LICENSEE EVENT REPORT

CONTROL BLOCK: | | | | | | | (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

0 1	M I D C C 1 (2) LICENSEE CODE; 0 0 0 0 0 0 0 0 0 0 0 (3) LICENSE NUMBER; 4 1 1 1 1 (4) LICENSE TYPE; (5) CAT
CON'T 0 1	REPORT SOURCE L (6) 0 5 0 0 0 3 1 5 (7) DOCKET NUMBER; 0 8 2 5 8 2 (8) EVENT DATE; 0 9 2 4 8 2 (9) REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

0 2 ON AUGUST 25, 1982, AN UNPLANNED GAS RELEASE WAS DETECTED BY AN ELEVATED UNIT 1

0 3 VENT STACK GASEOUS MONITOR (R-26) READING. THIS EVENT CONTINUED FOR ABOUT 2 HOURS.

0 4 A TOTAL OF 3.221 CI WAS RELEASED AT A RATE OF 4.26 E-5 CI/SEC, WHICH IS 0.072% OF

0 5 THE TECH SPEC LIMIT. THE MAXIMUM RELEASE RATE WAS 1.47 E-3 CI/SEC, WHICH IS 2.47%

0 6 OF THE TECH SPEC LIMIT. THIS RELEASE OCCURED WITHOUT THE SAMPLING AND ANALYTICAL

0 7 REQUIREMENTS OF TECH.SPEC, APPENDIX B, 2.4.4.E.

0 8

0 9	SYSTEM CODE	CAUSE CODE	CAUSE SUBCODE	COMPONENT CODE	COMP SUBCODE	VALVE SUBCODE
	M A (11)	X (12)	Z (13)	Z Z Z Z Z Z (14)	Z (15)	Z (16)

(17) LER/RO REPORT NUMBER	EVENT YEAR		SEQUENTIAL REPORT NO.		OCCURRENCE CODE	REPORT TYPE		REVISION NO.
	8 2	—	0 7 8	/	0 3	L	—	0

ACTION TAKEN	FUTURE ACTION	EFFECT ON PLANT	SHUTDOWN METHOD	HOURS (22)	ATTACHMENT SUBMITTED	NPRD-4 FORM SUB.	PRIME COMP. SUPPLIER	COMPONENT MANUFACTURER
Z (18)	Z (19)	Z (20)	Z (21)	0 0 0 0	N (23)	N (24)	Z (25)	Z 9 9 9 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

1 0 AN EXHAUSTIVE SEARCH FOR THE SOURCE OF THE RELEASE WAS CONDUCTED. THE SOURCE WAS

1 1 FOUND TO BE WATER OVERFLOWING FROM THE LIQUID WASTE HOLDUP TANKS INTO THE ROOM.

1 2 THE ROOM VENTS TO THE PLANT VENT SYSTEM. NO FURTHER ACTION PLANNED.

1 3

1 4

1 5	FACILITY STATUS	% POWER	OTHER STATUS (30)	METHOD OF DISCOVERY	DISCOVERY DESCRIPTION (32)
	H (28)	0 0 0 (29)	NA	A (31)	RADIATION MONITORING ALARM

1 6	ACTIVITY RELEASED	CONTENT OF RELEASE	AMOUNT OF ACTIVITY (35)	LOCATION OF RELEASE (36)
	G (33)	N (34)	3.22 CI OF XE-133	LIQUID WASTE TANK ROOM TO PLANT VENT

PERSONNEL EXPOSURES

1 7	NUMBER	TYPE	DESCRIPTION (39)
	0 0 0 (37)	Z (38)	NA

PERSONNEL INJURIES

1 8	NUMBER	DESCRIPTION (41)
	0 0 0 (40)	NA

LOSS OF OR DAMAGE TO FACILITY (43)

1 9	TYPE	DESCRIPTION
	Z (42)	NA

PUBLICITY

2 0	ISSUED	DESCRIPTION (45)	NRC USE ONLY
	N (44)	NA	

NAME OF PREPARER DANIEL KRAUSE PHONE (616) 465-5901 ext. 1097

GPO 917-926

8210040203 820924
PDR ADOCK 05000315
S PDR