



6200 Oak Tree Boulevard  
Independence OH  
216-447-3153  
Fax 216-447-3123

Mail Address:  
P.O. Box 94661  
Cleveland, OH 44101-4661

Donald C. Shelton  
Senior Vice President  
Nuclear

Docket Number 50-346

License Number NPF-3

Serial Number 2213

April 5, 1994

United States Nuclear Regulatory Commission  
Document Control Desk  
Washington, D. C. 20555

Subject: Proposed Modification to the Davis-Besse Nuclear Power Station (DBNPS) Operating License NPF-3, Appendix A Technical Specifications to Revise Technical Specifications 3/4.7.1.2 - Auxiliary Feedwater System, and 3/4.7.1.7 - Motor Driven Feedwater Pump System

Gentlemen:

Enclosed is an application for an amendment to the DBNPS Unit Number 1 Operating License Number NPF-3, Appendix A, Technical Specifications to reflect the changes attached. The proposed changes involve Technical Specifications (TS) 3/4.7.1.2, Auxiliary Feedwater System, 3/4.7.1.7 - Motor Driven Feedwater Pump System, and their associated Bases.

This application proposes changes to the TS that clarify the requirements for operation of the Auxiliary Feedwater System and Motor Driven Feedwater Pump System in conformance with the DBNPS design. Changes are proposed to extend the surveillance intervals for testing the steam turbine driven auxiliary feedwater pumps and the electric motor driven feedwater pump from monthly to quarterly. These proposed changes are line item improvements recommended by the NRC Technical Specification Improvement Program (TSIP) and are in conformance with Generic Letter 93-05, Line-Item Technical Specifications Improvements to Reduce Surveillance Requirements for Testing During Power Operation.

110007

Operating Companies:  
Cleveland Electric Illuminating  
Toledo Edison

9404130160 940405  
PDR ADOCK 05000346  
P PDR

ADD 1

Docket Number 50-346  
License Number NPF-3  
Serial Number 2213  
Page 2

Changes are also proposed to modify requirements regarding the stationing of an individual locally at re-aligned Auxiliary Feedwater System and Motor Driven Feedwater Pump System valves during surveillance testing. These proposed changes reflect the installation of the Motor Driven Feedwater Pump.

A proposed change to Bases Section 3/4.7.1.2 will relocate the specific total feedwater flow and pressure parameters from the present Technical Specification Bases to the Updated Safety Analysis Report. This proposed change is administrative and in conformance with NRC NUREG-1430, Improved Standard Technical Specifications - Babcock and Wilcox Plants.

Toledo Edison requests that the NRC approve and issue these changes by October 1, 1994.

Should you have any questions or require additional information, please contact Mr. William T. O'Connor, Manager - Regulatory Affairs, at (419) 249-2366.

Very truly yours,



FWK/la

Enclosure

cc: J. B. Martin, Regional Administrator, NRC Region III  
G. West Jr., DB-1 NRC/NRR Project Manager  
S. Stasek, NRC Region III, DB-1 Senior Resident Inspector  
J. R. Williams, Chief of Staff, Ohio Emergency Management Agency,  
State of Ohio (NRC Liaison)  
Utility Radiological Safety Board