

OPERATING DATA REPORT

DOCKET NO. 50-266

DATE: 03/01/94

COMPLETED BY: Richard F. Arnold

TELEPHONE: (414) 755-6193

OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 1 . NOTES
2. REPORTING PERIOD: February - 1994
3. LICENSED THERMAL POWER (MWT): 1518.5
4. NAMEPLATE RATING (GROSS MWE): 523.8
5. DESIGN ELECTRICAL RATING (NET MWE): 497.0
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.0
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 485.0
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:  
NA
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA
10. REASONS FOR RESTRICTIONS, (IF ANY):  
NA

	THIS MONTH	YEAR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	672.0	1,416.0	204,384.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	672.0	1,416.0	170,134.9
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	667.3
14. HOURS GENERATOR ON LINE	667.4	1,411.4	167,051.6
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	846.9
16. GROSS THERMAL ENERGY GENERATED (MWH)	982,233	2,110,584	235,592,354
17. GROSS ELECTRICAL ENERGY GENERATED	332,400	714,830	79,568,960
18. NET ELECTRICAL ENERGY GENERATED (MWH)	318,383	685,229	75,840,819
19. UNIT SERVICE FACTOR	99.3%	99.7%	81.7%
20. UNIT AVAILABILITY FACTOR	99.3%	99.7%	82.1%
21. UNIT CAPACITY FACTOR (USING MDC NET)	97.7%	99.8%	76.2%
22. UNIT CAPACITY FACTOR (USING DER NET)	95.3%	97.4%	74.7%
23. UNIT FORCED OUTAGE RATE	0.0%	0.0%	1.6%
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): Refueling Outage, 04/02/94, 30			
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA			

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

9404130202 940405  
 PDR ADDCK 05000266  
 PDR

POINT BEACH NUCLEAR PLANT  
AVERAGE DAILY UNIT POWER LEVEL  
 MONTH FEBRUARY - 1994

DOCKET NO. 50-266  
 UNIT NAME Point Beach, Unit 1  
 DATE March 1, 1994  
 COMPLETED BY R. F. Arnold  
 TELEPHONE 414/755-6193

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL MWe NET</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL MWe NET</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL MWe NET</u>
1	<u>493</u>	11	<u>492</u>	21	<u>494</u>
2	<u>494</u>	12	<u>493</u>	22	<u>493</u>
3	<u>492</u>	13	<u>490</u>	23	<u>494</u>
4	<u>494</u>	14	<u>496</u>	24	<u>493</u>
5	<u>490</u>	15	<u>495</u>	25	<u>493</u>
6	<u>128</u>	16	<u>493</u>	26	<u>494</u>
7	<u>329</u>	17	<u>494</u>	27	<u>492</u>
8	<u>486</u>	18	<u>499</u>	28	<u>495</u>
9	<u>481</u>	19	<u>489</u>		
10	<u>493</u>	20	<u>495</u>		

POINT BEACH NUCLEAR PLANT  
UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH FEBRUARY - 1994

Docket No. 50-266  
 Unit Name Point Beach, Unit 1  
 Date March 1, 1994  
 Completed By R. F. Arnold  
 Telephone No. 414/755-6193

No.	Date	Type <sup>1</sup>	Duration	Reason <sup>2</sup>	Method of Shutting Down	Licensee Event	System	Component	Cause and Corrective Action
1	2/6/94	S	4.6	H	6	NA	CJ	VALVEF	The unit was reduced to 2% power to facilitate identification of a primary system leak. Although the leak rate did not require shutdown per Technical Specifications, the power reduction was made to address ALARA concerns about dose rates in the primary loops. Two 2" globe valves were found approximately 1/4 turn open. The valves are on a drain line to the reactor coolant drain tank off of the excess letdown line on the "A" loop. The valves were shut, which terminated the leak. The unit was then returned to 100% power. Investigation is in progress to determine how the valves became partially open.

<sup>1</sup>F: Forced  
 S: Scheduled

<sup>2</sup>Reason:  
 A - Equipment Failure (explain)  
 B - Maintenance or Testing  
 C - Refueling  
 D - Regulatory Restriction  
 E - Operator Training & Licensing Exam  
 F - Administrative  
 G - Operational Error (explain)  
 H - Other (explain)

<sup>3</sup>Method:  
 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Continuation of Previous Shutdown  
 5 - Reduced Load  
 6 - Other (explain)

<sup>4</sup>Exhibit G - Instructions for preparation of data entry sheets LER file (NUREG-0161)

<sup>5</sup>Exhibit I - Same Source

DOCKET NO. 50-266  
UNIT NAME Point Beach Unit 1  
DATE March 1, 1994  
COMPLETED BY R. F. Arnold  
TELEPHONE 414/755-6193

Unit 1 operated at an average of 474 MWe net for the report period and experienced one significant load reduction. The load reduction facilitated the identification and subsequent isolation of a primary system leak.

An Unusual Event was declared as a result of having both emergency diesel generators declared out of service. A Notice Of Enforcement Discretion was granted to suspend a dual unit shutdown as required by Technical Specifications while one of the emergency diesel generators was repaired and returned to service. LER 266/301 94-002-00 is being submitted to describe this event.

Safety-related maintenance included:

1. Completed the annual maintenance overhaul of both G01 and G02 emergency diesel generators.
2. Repaired the pump to motor shaft coupling on the G01 emergency diesel generator DC fuel oil pump.
3. A jumper wire for the brush rigging assembly for the DC excitor for the G01 emergency diesel generator was replaced. The jumper wire lugs were replaced during the annual maintenance overhaul and problems associated with cable re-installation resulted in voltage fluctuations during load testing.
4. Replaced the 4.16 KV safeguards buses A05 and A06 degraded voltage relays with relays that have better accuracy and improved reset characteristics. The Agastat time delay relays for the associated degraded voltage relays were adjusted to minimum time as an interim measure in order to improve safety margin while addressing analytical questions associated with the relays.
5. Installed a 4-rotor limit switch and thermal overload on the emergency diesel generator day tank inlet second-off motor operated isolation valve operator.

6. Replaced 26 480 VAC molded case circuit breakers as part of the breaker upgrade program.
7. Replaced and calibrated the bistable for steam generator 1B loop low-low/high level controller.

OPERATING DATA REPORT

DOCKET NO. 50-301

DATE: 03/01/94

COMPLETED BY: Richard F. Arnold

TELEPHONE: (414) 755-6193

OPERATING STATUS

1. UNIT NAME: POINT BEACH NUCLEAR PLANT - UNIT 2 . NOTES
2. REPORTING PERIOD: February - 1994
3. LICENSED THERMAL POWER (MWT): 1518.5
4. NAMEPLATE RATING (GROSS MWE): 523.8
5. DESIGN ELECTRICAL RATING (NET MWE): 497.0
6. MAXIMUM DEPENDABLE CAPACITY (GROSS MWE): 509.0
7. MAXIMUM DEPENDABLE CAPACITY (NET MWE): 485.0
8. IF CHANGES OCCUR IN CAPACITY RATINGS (ITEMS 3 THROUGH 7) SINCE LAST REPORT, GIVE REASONS:  
NA
9. POWER LEVEL TO WHICH RESTRICTED, IF ANY (NET MWE): NA
10. REASONS FOR RESTRICTIONS, (IF ANY):  
NA

	THIS MONTH	YEAR TO DATE	CUMULATIVE
11. HOURS IN REPORTING PERIOD	672.0	1,416.0	189,169.0
12. NUMBER OF HOURS REACTOR WAS CRITICAL	672.0	1,416.0	165,616.6
13. REACTOR RESERVE SHUTDOWN HOURS	0.0	0.0	233.9
14. HOURS GENERATOR ON LINE	672.0	1,416.0	163,282.7
15. UNIT RESERVE SHUTDOWN HOURS	0.0	0.0	302.2
16. GROSS THERMAL ENERGY GENERATED (MWH)	992,516	2,106,235	234,477,419
17. GROSS ELECTRICAL ENERGY GENERATED	340,260	721,600	79,745,860
18. NET ELECTRICAL ENERGY GENERATED (MWH)	325,847	691,165	76,021,805
19. UNIT SERVICE FACTOR	100.0%	100.0%	86.3%
20. UNIT AVAILABILITY FACTOR	100.0%	100.0%	86.5%
21. UNIT CAPACITY FACTOR (USING MDC NET)	100.0%	100.6%	82.3%
22. UNIT CAPACITY FACTOR (USING DER NET)	97.6%	98.2%	80.9%
23. UNIT FORCED OUTAGE RATE	0.0%	0.0%	1.0%
24. SHUTDOWNS SCHEDULED OVER NEXT 6 MONTHS (TYPE, DATE, AND DURATION OF EACH): NONE			
25. IF SHUTDOWN AT END OF REPORT PERIOD, ESTIMATED DATE OF STARTUP: NA			

DATA REPORTED AND FACTORS CALCULATED AS REQUESTED IN NRC LETTER DATED SEPTEMBER 22, 1977

POINT BEACH NUCLEAR PLANT  
AVERAGE DAILY UNIT POWER LEVEL  
 MONTH FEBRUARY - 1994

DOCKET NO. 50-301  
 UNIT NAME Point Beach, Unit 2  
 DATE March 1, 1994  
 COMPLETED BY R. F. Arnold  
 TELEPHONE 414/755-6193

<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL MWe NET</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL MWe NET</u>	<u>DAY</u>	<u>AVERAGE DAILY POWER LEVEL MWe NET</u>
1	<u>492</u>	11	<u>491</u>	21	<u>492</u>
2	<u>493</u>	12	<u>493</u>	22	<u>493</u>
3	<u>494</u>	13	<u>470</u>	23	<u>491</u>
4	<u>493</u>	14	<u>493</u>	24	<u>493</u>
5	<u>492</u>	15	<u>492</u>	25	<u>492</u>
6	<u>491</u>	16	<u>494</u>	26	<u>489</u>
7	<u>492</u>	17	<u>493</u>	27	<u>327</u>
8	<u>488</u>	18	<u>500</u>	28	<u>488</u>
9	<u>481</u>	19	<u>487</u>		
10	<u>492</u>	20	<u>495</u>		

POINT BEACH NUCLEAR PLANT

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH FEBRUARY - 1994

Docket No. 50-301  
 Unit Name Point Beach, Unit 2  
 Date March 1, 1994  
 Completed By R. F. Arnold  
 Telephone No. 414/755-6193

No.	Date	Type <sup>1</sup>	Duration (Hours)	Reason <sup>2</sup>	Method of Shutting Down Reactor <sup>3</sup>	Licensee Event Report No.	System Code <sup>4</sup>	Component Code <sup>5</sup>	Cause and Corrective Action To Prevent Recurrence
1	2/27/94	S	0	B	5	NA	CH	PUMPB	Power was reduced to 52% to facilitate the repair of a main feedwater pump. The outboard motor bearing seal was replaced because of oil leakage. The oil was leaking on the inner seal and blowing oil into the motor windings. The seal was replaced and the unit was returned to 100% power.

<sup>1</sup>F: Forced  
 S: Scheduled

<sup>2</sup>Reason:  
 A - Equipment Failure (explain)  
 B - Maintenance or Testing  
 C - Refueling  
 D - Regulatory Restriction  
 E - Operator Training & Licensing Exam  
 F - Administrative  
 G - Operational Error (explain)  
 H - Other (explain)

<sup>3</sup>Method:  
 1 - Manual  
 2 - Manual Scram  
 3 - Automatic Scram  
 4 - Continuation of Previous Shutdown  
 5 - Reduced Load  
 6 - Other (explain)

<sup>4</sup>Exhibit G - Instructions for preparation of data entry sheets LER file (NUREG-0161)

<sup>5</sup>Exhibit I - Same Source



DOCKET NO. 50-301  
UNIT NAME Point Beach Unit 2  
DATE March 1, 1994  
COMPLETED BY R. F. Arnold  
TELEPHONE 414/755-6193

Unit 2 operated at an average of 485 MWe net for the report period with one significant load reduction. The load reduction facilitated the repair of a main feedwater pump motor bearing seal.

Safety-related maintenance included:

1. Replaced the 4.16 KV safeguards buses A05 and A06 degraded voltage relays with relays that have better accuracy and improved reset characteristics. The Agastat time delay relays for the associated degraded voltage relays were adjusted to minimum time as an interim measure in order to improve safety margin while addressing analytical questions associated with the relays.
2. The inner seal of the outboard motor bearing on the "B" main feedwater pump was replaced. The seal was leaking and was blowing oil into the motor windings.
3. Replaced two 480 VAC molded case circuit breakers as part of the breaker upgrade program.
4. Replaced the packing, brass and one new plunger on P-002A charging pump.