

TABLE 3.6-1 (Cont.)

CONTAINMENT ISOLATION VALVES

<u>PENETRATION NUMBER</u>	<u>VALVE NUMBER</u>	<u>FUNCTION</u>	<u>ISOLATION TIME (SEC)</u>
C. MANUAL (Cont.)			
2C3	2CV-5432#	Fuel Transfer Tube Isolation (outside)	N.A.
D. OTHER (Check Valves)			
2P9	2N <sub>2</sub> -18	H.P. Nitrogen to SI Tanks (inside)	N.A.
2P39	2CVC-78	Quench Tank Makeup & Demin Water Supply (inside)	N.A.
2P40	2FS-37	Fire Water Isolation (inside)	N.A.
2P41	2N <sub>2</sub> -1	L.P. Nitrogen Supply Isolation (inside)	N.A.
2P43	2SA-69	Service Air Supply Isolation (inside)	N.A.
2P46	2BA-216	Breathing Air Supply Isolation (inside)	N.A.
2P51	2AC-49	Chilled Water Supply Isolation (inside)	N.A.
2P52	2CCW-38	CCW to RCP Coolers Isolation (inside)	N.A.

# Not subject to Type C leakage tests.

\*May be opened on an intermittent basis under administrative control.

9010230197 901009  
PDR ADDCK 05000368  
PNU

ARKANSAS - UNIT 2

3/4 6-21