

September 29, 1982

Docket No. 50-245
LS05-82-09-084

Mr. W. G. Council, Vice President
Nuclear Engineering and Operations
Northeast Nuclear Energy Company
Post Office Box 270
Hartford, Connecticut 06101

Dear Mr. Council:

SUBJECT: SEP TOPIC V-6, REACTOR VESSEL INTEGRITY
MILLSTONE NUCLEAR POWER STATION, UNIT NO. 1

By letter dated March 5, 1980, we forwarded to you our safety evaluation report of SEP Topic V-6 for the Millstone 1 facility. In the enclosed report to that letter (NUREG-0569, Evaluation of the Integrity of SEP Reactor Pressure Vessels) the staff stated that the facility technical specifications did not contain a vessel material surveillance program with a capsule withdrawal schedule meeting the requirements of the 10 CFR 50 Appendix H.

Part of Amendment 62 to Provisional Operating License No. DPR-21 for the Millstone Nuclear Power Station, Unit 1 dated June 1, 1979, authorized revisions to the facility technical specifications to ensure compliance with the material surveillance program required by 10 CFR 50 Appendix H; therefore, we conclude that Millstone 1 meets current criteria regarding SEP Topic V-6.

This evaluation will be a basic input to the integrated safety assessment of your facility. The evaluation may be revised if NRC criteria relating to this topic is modified before completion of the integrated safety assessment.

SEO4

DSU USE(27)

Sincerely,

ADD:

D. PERSINKO

James Shea, Project Manager
Operating Reactors Branch #5
Division of Licensing

cc: See next page

WTR
SEPB:DL
WRussell
9/27/82

8210040233 820929
PDR ADOCK 05000245
P PDR

9/29/82

OFFICE	SEPB:DL MBoyle:dk	SEPB:DL DPersinko	SEPB:DL CGrimes	ORB#5:PM JShea	ORB#5:BG DCWitchfield	AD:SA:DL FMiraglia
SURNAME						
DATE	9/29/82	9/29/82	9/27/82	9/28/82	9/28/82	9/29/82

Mr. W. G. Council

cc

William H. Cuddy, Esquire
Day, Berry & Howard
Counselors at Law
One Constitution Plaza
Hartford, Connecticut 06103

State of Connecticut
Office of Policy & Management
ATTN: Under Secretary Energy
Division
80 Washington Street
Hartford, Connecticut 06115

Ronald C. Haynes, Regional
Administrator
Nuclear Regulatory Commission
Region I Office
631 Park Avenue
King of Prussia, Pennsylvania 19406

Northeast Nuclear Energy Company
ATTN: Superintendent
Millstone Plant
P. O. Box 128
Waterford, Connecticut 06385

Mr. Richard T. Laudenat
Manager, Generation Facilities Licensing
Northeast Utilities Service Company
P. O. Box 270
Hartford, Connecticut 06101

Resident Inspector
c/o U. S. NRC
P. O. Box Drawer KK
Niantic, Connecticut 06357

First-Selectman of the Town
of Waterford
Hall of Records
200 Boston Post Road
Waterford, Connecticut 06385

John F. Opeka
Systems Superintendent
Northeast Utilities Service Company
P. O. Box 270
Hartford, Connecticut 06101

U. S. Environmental Protection Agency
Region I Office
ATTN: Regional Radiation Representative
JFK Federal Building
Boston, Massachusetts 02203