

SEP 27 1982

Docket No. 50-322

Long Island Lighting Company
ATTN: Mr. M. S. Pollock
Vice President - Nuclear
175 East Old Country Road
Hicksville, New York 11801

Gentlemen:

Subject: Inspection Nos. 50-322/82-10; 50-322/82-11

This refers to your letter dated July 1, 1982, in response to our letter dated May 24, 1982, and to your letter dated July 19, 1982, in response to our letter dated June 18, 1982.

The Local Leakage Rate Test flow measuring and test equipment (rotometers) calibrations which were the subject of the violation in inspection Report 50-322/82-10 are used to satisfy the regulatory requirements of 10 CFR 50.54(o) and Appendix J to Part 50. The rotometers are test instruments used in an activity affecting quality and as such should have been controlled in accordance with 10 CFR 50, Appendix B, Criterion XII. This violation stands.

In your response to the violation resulting from Inspection Report 50-322/82-11, you state that periodic maintenance and testing of three batteries is provided for, using written and approved interim Operating Instructions. You further state that the batteries will be subject to service testing in accordance with the Plant Staff surveillance program commencing prior to initial fuel load. This testing program appears satisfactory. The violation is withdrawn.

Thank you for informing us of the corrective and preventive actions documented in your letters. These actions will be examined during a future inspection of your licensed program.

Your cooperation with us is appreciated.

Sincerely,

Original Signed By: *T. Martin*

Thomas T. Martin, Director
Division of Engineering and
Technical Programs

OFFICIAL RECORD COPY

8210040258 820927
PDR ADDCK 05000322
Q PDR

1001

cc:

J. Rivello, Plant Manager
 J. L. Smith, Manager of
 Special Projects
 Director, Power Division
 Edward M. Barrett, Esq.
 Jeffrey L. Futter, Esq.
 T. F. Gerecke, Manager, QA Department
 Public Document Room (PDR)
 Local Public Document Room (LPDR)
 Nuclear Safety Information Center (NSIC)
 NRC Resident Inspector
 State of New York

bcc:

Region I Docket Room (with concurrences)
 L. Narrow, Region I
 Chief, Operational Support Section

Handwritten signature
 RI:DETP
 Pullani/lp
 8/13/82
 8/16/82

Handwritten signature
 RI:DETP
 Nicholas
 8/14/82

Handwritten signature
 RI:DETP *for* RI:DETP
 Bettenhausen Ebnetter
 8/16/82 9/3

Handwritten signature
 MARTIN
 9/24/82

OFFICIAL RECORD COPY