

# Duquesne Light Company

Beaver Valley Power Station  
P.O. Box 4  
Shippingport, PA 15077-0004

JOHN D. SIEBER  
Vice President - Nuclear Group

(412) 393-5255

October 1, 1990

U. S. Nuclear Regulatory Commission  
Attn: Document Control Desk  
Washington, DC 20555

Reference: Beaver Valley Power Station, Unit No. 2  
Docket No. 50-412, License No. NPF-73  
Proposed Operating License Change Request No. 16  
(TAC No. 77640)

Gentlemen:


Enclosed please find:

1. Application for amendment to the above operating license. The amendment would revise Specification 3/4.3.4 by eliminating monthly testing of low pressure turbine reheat stop and intercept valves.

This change has been reviewed by the OSC and ORC and was determined to be safe and does not involve an unreviewed safety question.

2. Documents designated Attachments A, B, and C which set forth the change in Technical Specifications, the safety analysis, including the no significant hazard evaluation, and the replacement Technical Specification pages.
3. Additional information designated Attachments D, E, F, and G which set forth the Updated Final Safety Analysis Report changes, a report on turbine component damage at Unit 1, a report on moisture separator reheater status, and an analysis of the probability of a nuclear turbine reaching destructive overspeed.

Sincerely,

  
J. D. Sieber  
Vice President  
Nuclear Group

cc: Mr. J. Beall, Sr. Resident Inspector  
Mr. T. T. Martin, NRC Region I Administrator  
Mr. A. W. DeAgazio, Project Manager  
Mr. R. Saunders (VEPCO)

9010240017 901001  
PDR ADDCK 05000412  
PNU  
P

00028

A001  
11

UNITED STATES OF AMERICA  
NUCLEAR REGULATORY COMMISSION

In the Matter of ) UNIT NO. 2  
 ) Docket No. 50-412  
Duquesne Light Company ) License No. NPF-73  
Beaver Valley Power Station )

APPLICATION FOR AMENDMENT  
TO OPERATING LICENSE

Pursuant to Section 50.90 of the regulations of the U.S. Nuclear Regulatory Commission, Duquesne Light Company hereby requests that the Technical Specifications set forth in Appendix A of the above referenced license be amended to eliminate monthly testing of low pressure turbine reheat stop and intercept valves.

The proposed Technical Specification changes are set forth in Attachment A to this Application. A Safety Analysis and No Significant Hazard Evaluation is set forth in Attachment B. Replacement pages for the Technical Specifications are contained in Attachment C.

Based on the guidance provided by the Commission, the proposed changes have been determined to involve no significant hazards consideration in accordance with 10 CFR 50.92.


WHEREFORE, Applicant respectfully requests that Appendix A to this Operating License be amended in the form attached hereto as Attachment A.

Duquesne Light Company

By J. D. Sieber  
J. D. Sieber  
Vice President, Nuclear Group

Subscribed and sworn to before me  
on this 1st day of October, 1990

Tracy A. Baczek



Member, Pennsylvania Association of Notaries