

CATAWBA NUCLEAR STATION
MONTHLY OPERATING STATUS REPORT

August 1990

1. Personnel Exposure -

For the month of August, no individual(s) exceeded 10 percent of their allowable annual radiation dose limit.

2. The total station liquid release for July has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this limit.

The total station gaseous release for August has been compared with the Technical Specifications maximum annual dose commitment and was less than 10 percent of this list.

9010240152 901015
PDR ADOCK 05000413
R PDC