

NOTICE OF DEVIATION

Commonwealth Edison Company
LaSalle County Station
Units 1 and 2

Docket Nos. 50-373 and 50-374
License Nos. NPF-11 and NPF-18
EA 93-300

During an NRC inspection conducted on November 29 through December 21, 1993, a deviation from your Final Safety Analysis Report (FSAR) was identified. In accordance with the "General Statement of Policy and Procedure for NRC Enforcement Action", 10 CFR Part 2, Appendix C, the deviation is listed below: Section 2.a of the licensee's response to FSAR Question 031.278 states that the nominal operating range of the Electrical Power Assembly (EPA) independent trip units is 0.1 and 3.0 seconds for qualification testing.

Contrary to the above, as of November 29, 1993, the licensee had been setting the EPA independent trip unit time delays above 3.0 seconds and as high as 4.69 seconds.

Please provide to the U.S. Nuclear Regulatory Commission, ATTN: Document Control Desk, Washington, D.C. 20555, with a copy to the Regional Administrator, Region III, 801 Warrenville Road, Lisle, Illinois 60532-4351, and a copy to the NRC Resident Inspector at the LaSalle County Station in writing within 30 days of the date of this Notice, the reason(s) for the deviation, the corrective steps which have been taken and the results achieved, the corrective steps which will be taken to avoid further deviations, and the date when your corrective action will be completed. Where good cause is shown, consideration will be given to extending the response time.

Dated at Lisle, Illinois
this 4th day of April 1994