NRC FORM 366
(7-77)

U. S. NUCLEAR REGULATORY COMMISSION

# LICENSEE EVENT REPORT

CONTROL BLOCK: (1) (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

01 | CASO2 (2) | 00-0000-00 (3) | 4 1 1 1 1 (4) | (5)
LICENSEE CODE — LICENSE NUMBER — LICENSE TYPE — CAT

CON'T 01 | REPORT SOURCE L (6) | 0 5 0 0 0 3 6 1 (7) | 0 9 0 1 8 2 (8) | 0 8 2 4 8 2 (9)
DOCKET NUMBER — EVENT DATE — REPORT DATE

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES (10)

02 While in Mode 2, the condensate storage tank T-121 water level fell below the
03 Technical Specification 3.7.1.3 limit. There was no consequence to the public
04 health and safety since there was no significant decay heat in the core.
05
06
07
08

09 SYSTEM CODE HH (11) | CAUSE CODE B (12) | CAUSE SUBCODE A (13) | COMPONENT CODE ZZZZZZ (14) | COMP. SUBCODE Z (15) | VALVE SUBCODE Z (16)

(17) LER/RO REPORT NUMBER: EVENT YEAR 82 — SEQUENTIAL REPORT NO. 104 — OCCURRENCE CODE 03 — REPORT TYPE L — REVISION NO. 0

ACTION TAKEN X (18) | FUTURE ACTION F (19) | EFFECT ON PLANT Z (20) | SHUTDOWN METHOD Z (21) | HOURS 0000 (22) | ATTACHMENT SUBMITTED N (23) | NPRD-4 FORM SUB. N (24) | PRIME COMP. SUPPLIER Z (25) | COMPONENT MANUFACTURER Z999 (26)

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS (27)

10 Inadequate makeup water control to tank T-121 and a more restrictive than necessary
11 Technical Specification limit were the cause. Corrective actions include a proposed
12 Technical Specification change and a design change to install automatic level control
13 systems (expected to be installed prior to 100% power operation).
14

15 FACILITY STATUS B (28) | % POWER 000 (29) | OTHER STATUS (30) NA | METHOD OF DISCOVERY A (31) | DISCOVERY DESCRIPTION (32) Operator Observation

16 ACTIVITY RELEASED Z (33) | CONTENT OF RELEASE Z (34) | AMOUNT OF ACTIVITY (35) NA | LOCATION OF RELEASE (36) NA

17 PERSONNEL EXPOSURES NUMBER 000 (37) | TYPE Z (38) | DESCRIPTION (39) NA

18 PERSONNEL INJURIES NUMBER 000 (40) | DESCRIPTION (41) NA

19 LOSS OF OR DAMAGE TO FACILITY TYPE Z (42) | DESCRIPTION (43) NA

8210050032 820924
PDR ADOCK 05000361
S PDR

20 PUBLICITY ISSUED N (44) | DESCRIPTION (45) NA

NRC USE ONLY

NAME OF PREPARER H. B. Ray HBRay / RWMarsh PHONE: 714/492-7700

GPO 817-928