



UNITED STATES  
NUCLEAR REGULATORY COMMISSION  
WASHINGTON, D. C. 20555-0001

POWER AUTHORITY OF THE STATE OF NEW YORK

DOCKET NO. 50-333

JAMES A. FITZPATRICK NUCLEAR POWER PLANT

AMENDMENT TO FACILITY OPERATING LICENSE

Amerdment No. 209  
License No. DPR-59


1. The Nuclear Regulatory Commission (the Commission) has found that:
  - A. The application for amendment by Power Authority of the State of New York (the licensee) dated December 28, 1993, complies with the standards and requirements of the Atomic Energy Act of 1954, as amended (the Act) and the Commission's rules and regulations set forth in 10 CFR Chapter I;
  - B. The facility will operate in conformity with the application, the provisions of the Act, and the rules and regulations of the Commission;
  - C. There is reasonable assurance (i) that the activities authorized by this amendment can be conducted without endangering the health and safety of the public, and (ii) that such activities will be conducted in compliance with the Commission's regulations;
  - D. The issuance of this amendment will not be inimical to the common defense and security or to the health and safety of the public; and
  - E. The issuance of this amendment is in accordance with 10 CFR Part 51 of the Commission's regulations and all applicable requirements have been satisfied.
2. Accordingly, the license is amended by changes to the Technical Specifications as indicated in the attachment to this license amendment, and paragraph 2.C.(2) of Facility Operating License No. DPR-59 is hereby amended to read as follows:

(2) Technical Specifications

The Technical Specifications contained in Appendices A and B, as revised through Amendment No. 209, are hereby incorporated in the license. The licensee shall operate the facility in accordance with the Technical Specifications.

3. This license amendment is effective as of the date of its issuance to be implemented within 30 days.

FOR THE NUCLEAR REGULATORY COMMISSION



Robert A. Capra, Director  
Project Directorate I-1  
Division of Reactor Projects - I/II  
Office of Nuclear Reactor Regulation

Attachment:  
Changes to the Technical  
Specifications

Date of Issuance: April 6, 1994

ATTACHMENT TO LICENSE AMENDMENT NO. 209

FACILITY OPERATING LICENSE NO. DPR-59

DOCKET NO. 50-333

Revise Appendix A as follows:

Remove Page  
120

Insert Page  
120

JAFNPP

3.5 (cont'd)

during such time, the HPCI System is operable.

2. If the requirements of 3.5.D.1 cannot be met, the reactor shall be placed in the cold condition and pressure less than 100 psig, within 24 hr.
  
3. Low power physics testing and reactor operator training shall be permitted with inoperable components as specified in 3.5.1.a and 3.5.1.b above, provided that reactor coolant temperature is  $\leq 212^{\circ}\text{F}$  and the reactor vessel is vented or reactor vessel head is removed.
  
4. The ADS is not required to be operable during hydrostatic pressure and leakage testing with reactor coolant temperatures below  $300^{\circ}\text{F}$  and irradiated fuel in the reactor vessel provided all control rods are inserted.

4.5 (cont'd)

2. A logic system functional test.
  - a. When it is determined that one valve of the ADS is inoperable, the ADS subsystem actuation logic for the operable ADS valves and the HPCI subsystem shall be verified to be operable immediately and at least weekly thereafter.
  
  - b. When it is determined that more than one relief/safety valve of the ADS is inoperable, the HPCI System shall be verified to be operable immediately.