

JUN 23 1981

MEMORANDUM FOR: Darrell G. Eisenhut, Director
 Division of Licensing

FROM: G.C. Lainas, Assistant Director
 for Safety Assessment
 Division of Licensing

SUBJECT: SUMMARY OF THE OPERATING REACTOR EVENTS MEETING
 ON JUNE 17, 1981

On June 17, 1981, an Operating Reactor Event meeting was held to brief the Office Director, the Division Directors, and their representatives on events which occurred since the last meeting. The list of meeting attendees is included as Attachment 1.

The events discussed and the significant elements of these events are presented in Attachment 2. In addition to these events, the assignment of follow-up review responsibility was discussed. The assignments made during this meeting and the status of previous assignments are presented in Attachment 3.

The next Operating Reactor Events meeting is scheduled for June 24, 1981.

G.C. Lainas
 G.C. Lainas, Assistant Director
 for Safety Assessment
 Division of Licensing

Attachments:
 As stated

cc w/attachments:
 Meeting Attendees

ORAB Members	G. Zech
H. Denton	T. Novak
E. Case	G. Lainas
R. Mattson	R. Tedesco
R. Vollmer	J. Olshinski
S. Hanauer	G. Holahan
T. Murley	H. Thompson

8210050135 820628
 PDR FOIA
 UDELL82-261 PDR

A63
 (17)

OFFICE	DL:ORAB <i>2</i>	DL:ORAB/ <i>SA</i>	DL:ORAB/BC	DL:AD/SA		
SURNAME	IAhmed:sah	GHolanan:sah	JOlshinski	GLainas		
DATE	6/22/81	6/22/81	6/22/81	6/22/81		

MEETING ATTENDEES

G. Holahan
E. Case
T. Murley
G. Lainas
R. Baer
T. Ippolito
R. Capra
G. Vissing
K. Herring
J. Thoma
C. Graves
T. Speis
P. Erickson
S. Miner
W. Ross
P. O'Connor
G. Meyer
H. Ornstein
R. Scholl
W. Lanning
B. Ward
J. Fair
R. Herman
D. Chaney
J. Hannon
G. Schwenk
R. Woods
B. Mills
J. Kramer
J. Olshinski
L. Rubenstein
I. Ahmed

OPERATING REACTOR EVENTS MEETINGJUNE 17, 1981

- CRYSTAL RIVER 3, JUNE 16 - LOSS OF OFFSITE POWER (IE)
 - DG FAILURE ON B-SIDE
 - 480V BUS ON B-SIDE POWERED FROM FOSSIL UNIT
 - OFFSITE POWER RESTORED IN 5 HOURS

- CALVERT CLIFFS - PRIMARY SYSTEM LEAK (16 GPM), UNUSUAL EVENT (IE)

- DRESDEN - SEISMIC DESIGN OF SCRAM DISCHARGE VOLUME (IE)

- BEAVER VALLEY - UPDATE ON POSSIBLE SABOTAGE (IE)

- SALEM UNIT 1 - JUNE 11, SERVICE WATER LEAK IN CONTAINMENT (IE)

- SALEM UNIT 1 - PROBLEM WITH LOOSE PARTS (PM)

- SALEM UNIT 2 - JUNE 11, REACTOR TRIP ON STEAM GENERATOR HI-HI LEVEL (ORAB)
(16TH TRIP IN 3 WEEKS)
 - SHUTDOWN FOR PIPING PROBLEM FIX

- COOK UNIT 2 - JUNE 11, INVERTER FAILURE (ORAB)
 - LOSS OF 120V AC SAFETY BUS
 - REACTOR TRIP ON INDICATION OF RCP TRIP

- GENERIC REVIEW - DRYWELL PRESSURE SETPOINT CAUSING UNNECESSARY (DSI)
ECCS CHALLENGE, FOLLOW UP ON 12/10/81 OPERATING REACTOR
EVENTS MEETING (QUAD CITIES - 2 EVENT)

OFFICE OF INSPECTION AND ENFORCEMENT

Items of Interest

Week Ending June 12, 1981

1. The following Notification of Significant Enforcement Action was dispatched during the past week:
 - a. EN-81-20 Consumers Power Company (Palisades) - A Notice of Violation was issued to subject licensee on June 12, 1981 based on alleged violations associated with isolation of the station batteries during plant operation on January 6, 1981. The violations include: 1) Failure to implement appropriate procedures and 2) Inadequate administrative procedures.
2. Preliminary Notifications relating to the following actions were dispatched during the past week:
 - a. PNO-II-81-39 Duke Power Company, McGuire 1 - Development of Steam Void Under Vessel Head During Cooldown
 - b. PNO-II-81-40 Browns Ferry Unit 1 - Overexposure of a Minor
 - c. PNO-II-81-41 Eastern Biological Laboratories, Inc. - Potential Contamination of Members of the Public
 - d. PNO-III-81-53B General Electric, Morris Operation and Dairyland Power Cooperative, LACBWR - Contaminated Spent Fuel Cask - Update
 - e. PNO-III-81-54 Bicron Corporation, Newbury, OH - Lost Cesium-137 Sealed Source (98.1 Microcurie)
 - f. PNO-III-81-55 Clinton Station (Illinois Power Co.) - Potential News Media Interest in Allegations
 - g. PNO-V-81-33 San Onofre Nuclear Generating Station, Unit No. 1 - Partial Clogging of Component Cooling Water Heat Exchanger by Seal Mollusks
 - h. PNS-I-81-11 Beaver Valley Power Station, Unit 1 - Manual Suction Valve for High Head Safety Injection (HHSI) Pump Found Mispositioned
 - i. PNS-I-81-12 Maine Yankee Atomic Power Station - Implied Plot to Harm the Facility