



MISSISSIPPI POWER & LIGHT COMPANY

Helping Build Mississippi

P. O. BOX 1640, JACKSON, MISSISSIPPI 39205

September 28, 1982

USNRC REGION II
ATLANTA, GEORGIA
SEP 29 11:42

NORRIS L. STAMPLEY
SENIOR VICE PRESIDENT

Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Region II
101 Marietta St., N.W., Suite 3100
Atlanta, Georgia 30303

Attention: Mr. J. P. O'Reilly, Regional Administrator

Dear Mr. O'Reilly:

SUBJECT: Grand Gulf Nuclear Station
Unit 1
Docket No. 50-416
License No. NPF-13
File 0260/L-835.0
Flange Temperature Measurement During
Stud Tensioning
Reference: LER 82-047/03 L-0
AECM-82/430

During tensioning of reactor vessel head studs on August 30, 1982, reactor vessel flange and head flange temperatures were monitored at inconsistent time intervals. This event is being reported pursuant to GGNS Technical Specification 4.4.6.1.4b. Attached is LER 82-047/03 L-0 with supplementary information.

Yours truly,

NLS:sap
Attachment

cc: Mr. R. B. McGehee (w/o)
Mr. T. B. Conner (w/o)
Mr. G. B. Taylor (w/o)

Mr. Richard C. DeYoung, Director (w/a)
Office of Inspection & Enforcement
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Document Control Desk (w/a)
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

OFFICIAL COPY

1022

8210050193 820928
PDR ADDCK 05000416
S PDR