

LICENSEE EVENT REPORT

CONTROL BLOCK: (PLEASE PRINT OR TYPE ALL REQUIRED INFORMATION)

LICENSEE CODE: I L D R S 2; LICENSE NUMBER: 000-000000-000; LICENSE TYPE: 41111; CAT: 58

REPORT SOURCE: L; DOCKET NUMBER: 5005000237; EVENT DATE: 082982; REPORT DATE: 092282

EVENT DESCRIPTION AND PROBABLE CONSEQUENCES

During normal unit operation, MSIV timing was performed under the MSIV timing surveillance (DOS 1600-1). Valves 2-203-1C and 2-203-1D had closed times of 2.25 and 2.67 seconds respectively (T.S. Table 3.7.1). Minimal effect upon public health and safety because remaining MSIV closure times were within Tech. Spec. limits and all the safety relief valves were operable. The last similar event was reported by R.O. 81-65 on Docket 50-237.

SYSTEM CODE: C D; CAUSE CODE: E; CAUSE SUBCODE: B; COMPONENT CODE: VALVEX; COMP. SUBCODE: F; VALVE SUBCODE: D; LER/RO REPORT NUMBER: 82; EVENT YEAR: 82; SEQUENTIAL REPORT NO.: 038; OCCURRENCE CODE: 03; REPORT TYPE: L; REVISION NO.: 0; ACTION TAKEN: E; FUTURE ACTION: Z; EFFECT ON PLANT: Z; SHUTDOWN METHOD: Z; HOURS: 000; ATTACHMENT SUBMITTED: N; NPRO-4 FORM SUB.: N; PRIME COMP SUPPLIER: N; COMPONENT MANUFACTURER: C665

CAUSE DESCRIPTION AND CORRECTIVE ACTIONS

MSIV's 2-203-1C and 2-203-1D timing mechanisms drifted during normal plant operation. MSIV's 2-203-1C and 2-203-1D were adjusted within Tech. Spec. limits. The quarterly timing surveillance will continue to be performed to ensure proper closure times are maintained.

FACILITY STATUS: E; % POWER: 045; OTHER STATUS: N/A; METHOD OF DISCOVERY: B; DISCOVERY DESCRIPTION: Surveillance Test

ACTIVITY CONTENT RELEASED OF RELEASE: Z; AMOUNT OF ACTIVITY: N/A; LOCATION OF RELEASE: N/A

PERSONNEL EXPOSURES NUMBER: 000; TYPE: Z; DESCRIPTION: N/A

PERSONNEL INJURIES NUMBER: 000; DESCRIPTION: N/A

LOSS OF OR DAMAGE TO FACILITY TYPE: Z; DESCRIPTION: N/A

PUBLICITY ISSUED DESCRIPTION: N/A

8210050233 820922 PDR ADOCK 05000237 S PDR

NRC USE ONLY

NAME OF PREPARER: Sang Rhee

PHONE: 815-942-2920, X-548



Commonwealth Edison

DEVIATION REPORT

DVR NO. 12 STA 2 UNIT 82 YEAR 58 NO.

PART 1 TITLE OF DEVIATION MSIV 1C And 1D Closure Time Less Than 3 Seconds OCCURRED 8/29/82 0300 DATE TIME

SYSTEM AFFECTED 203 MSIV PLANT STATUS AT TIME OF EVENT MODE Run PWR(MWT) 1210 LOAD(MWE) 366 TESTING YES NO

DESCRIPTION OF EVENT During DOS-1600-1, MSIV 1C closed in 2.25 seconds and 1D MSIV closed in 2.67 seconds. Tech. Spec. limit of between 3 and 5 seconds was exceeded.

EQUIPMENT FAILURE N/A RESPONSIBLE SUPERVISOR Bob Herbert DATE 8/29/82

PART 2 OPERATING ENGINEER'S COMMENTS Load was decreased on Unit 2 to 200 MWe, the drywell was de-inerted, and the 1C and 1D MSIV timing was adjusted to within limits.

Event of Public Interest, Tech. Spec. Violation, Non Reportable Occurrence, 14 Day Reportable/T.S., 30 Day Reportable/T.S. 6.6.B.2.b, Annual/Specl Report Req'd, 24-hour NRC Notification Req'd, 5-day Written Report Req'd per 10CFR21

Preliminary Report Completed and Reviewed John M. Almer 8/30/82 OPERATING ENGINEER DATE

Investigated Report & Resolution Accepted by Station Review J. Brunner 9/24/82 John M. Almer 9/28/82

Resolution Approved and Authorized for Distribution Douglas J. Witt 9/28/82 STATION SUPERINTENDENT DATE