

DUKE POWER COMPANY

P.O. BOX 33189
CHARLOTTE, N.C. 28242

TELEPHONE
(704) 373-4531

HAL B. TUCKER
VICE PRESIDENT
NUCLEAR PRODUCTION

September 27, 1982

Mr. Harold R. Denton, Director
Office of Nuclear Reactor Regulation
U. S. Nuclear Regulatory Commission
Washington, D. C. 20555

Attention: Ms. E. G. Adensam, Chief
Licensing Branch No. 4


Re: Catawba Nuclear Station
Docket Nos. 50-413 and 50-414

Dear Mr. Denton:

On April 6 and 7, 1982 (in Bethesda) and April 19-22, 1982 (in Charlotte) representatives from Duke Power, Westinghouse, the NRC Mechanical Engineering Branch (MEB), and Pacific Northwest Labs (MEB consultant) met to discuss agenda items transmitted by Ms. E. G. Adensam's letter of January 29, 1982.

Attached is the meeting summary which discusses all agenda items except 35, 63, 77, 78, 86, 96, and 117-121, which will be provided later. The response to Item 109 contains proprietary information and is being transmitted by separate letter.

Very truly yours,



Hal B. Tucker

ROS/php
Attachment

cc: (w/o attachment)
Mr. James P. O'Reilly, Regional Administrator
U. S. Nuclear Regulatory Commission
Region II
101 Marietta Street, Suite 3100
Atlanta, Georgia 30303

Mr. P. K. Van Doorn
NRC Resident Inspector
Catawba Nuclear Station

Mr. Robert Guild, Esq.
Attorney-at-Law
314 Pall Mall
Columbia, South Carolina 29201

Boo1
Limited Dist

8210050264 820927
PDR ADOCK 05000413
A PDR

Mr. Harold R. Denton, Director
September 27, 1982
Page 2

cc: (w/o attachment)
Palmetto Alliance
2135½ Devine Street
Columbia, South Carolina 29205

Mr. Jesse L. Riley
Carolina Environmental Study Group
854 Henley Place
Charlotte, North Carolina 28207

Mr. Henry A. Presler, Chairman
Charlotte-Mecklenburg Environmental Coalition
943 Henley Place
Charlotte, North Carolina 28207

(w/attachment)
Mr. Gordon Beeman
Pacific Northwest Laboratories
P. O. Box 999
Richland, Washington 99352

MEB Review Meeting
April 19, 1982

<u>Name</u>	<u>Organization</u>
M. L. Childers	Duke - Design/SRAL
L. B. Castles	Duke - Design/MDPE
R. R. Weidler	Duke - Design/MDPE
R. W. Ouellette	Duke - Steam/Licensing
D. P. Norkin	NRC
D. Terao	NRC - MEB
Bob Bosnak	NRC - MEB
H. L. Brammer	NRC - MEB
C. L. Hartzell	Duke - Catawba
R. O. Sharpe	Duke - Steam/Licensing
T. F. Wyke	Duke - Design/Mechanical&Nuclear
H. E. Vanpelt	Duke - Design/Catawba SAG
D. L. Caldwell	Duke - Design/CSAG
C. L. Ray	Duke - Design/Mechanical&Nuclear
G. D. Marr	PNL/MEB-NRC
G. H. Beeman	PNL/MEB-NRC

MEB Review
Attendance List
April 20, 1982

<u>Name</u>	<u>Organization</u>
M. L. Childers	Duke - Design/SRAL
R. W. Ouellette	Duke - Steam/Licensing
C. B. Cheezem	Duke - QA
R. R. Weidler	Duke - Design M/N
L. B. Castles	Duke - MDPE
Bob Bosnak	NRC/MEB
Jim Brammer	NRC/MEB
David Terao	NRC/MEB
Gordon Beeman	PNL/NRC-MEB
Grant Marr	PNL/NRC-MEB
D. P. Norkin	NRC/IE
C. L. Ray	Duke - Design M/N
R. M. Dulin	Duke - Design M/N
D. L. Caldwell	Duke - Design M/N
R. W. Bonsall	Duke - Design M/N
H. E. Vanpelt	Duke - Design M/N
C. L. Hartzell	Duke - Catawba P&L
D. H. Stout	Duke - Design M/N
D. L. Ward	Duke - Design M/N

MEB Review
Attendance List
April 21, 1982

<u>Name</u>	<u>Organization</u>
M. L. Childers	Duke - Design/SRAL
R. W. Ouellette	Duke - Steam/Licensing
Bob Bosnak	NRC - MEB
Jim Brammer	NRC - MEB
David Terao	NRC - MEB
Gordon Beeman	PNL - NRC/MEB
Grant Marr	PNL - NRC/MEB
C. L. Ray	Duke - Design/M&N
D. L. Rehn	Duke - Design/C/E
M. C. Green	Duke - Design/C/E
R. W. Bonsall	Duke - Design/M&N
M. H. Jansen	Duke - Design/M&N
E. C. Rodabaugh	Consultant/ORNL/NRC
S. E. Moore	ORNL
C. H. Boyd	<u>W</u> - SEED
R. W. Beer	<u>W</u> - Equipment Eng.
C. B. Gilmore	<u>W</u> - SEED
J. S. Galembush	<u>W</u> - Nuclear Safety-RCSC
N. R. Singleton	<u>W</u> - SEED
I. C. Ratsep	<u>W</u> - Duke Projects Licensing
K. N. Jabbour	NRC/DOL/LB#4

MEB Review
April 22, 1982
Attendance List

<u>Name</u>	<u>Organization</u>
M. L. Childers	Duke - Design/Licensing
R. W. Ouellette	Duke - Steam/Licensing
R. A. Jones	Duke - Catawba/Steam
W. R. McCollum	Duke - Catawba/Steam
K. N. Jabbour	NRC/DL/LB#4
H. L. Brammer	NRC/DL/MEB
Bob Bosnak	NRC/MEB
David Terao	NRC/MEB
Gordon Beeman	PNL-NRC/MEB
D. L. Caldwell	Duke - Design
R. M. Dulin	Duke - Design
G. E. Hedrick	Duke - Design
R. C. Gamberg	Duke - Design
C. L. Hartzell	Duke - Steam/Station Licensing

Item 1 - Table 3.2.1, page 1

Explain the reasons behind the classification of the "Waste Evaporator Feed" and the "Vent. Unit Cond. Drain".

Response:

Applying the criteria in NRC Regulatory Guide 1.26, Revision 3, the Waste Evaporator Feed Tank and Ventilation Unit Condensate Drain Tank are in NRC Quality Group D and, consequently, are not required to be seismically designed. However, to minimize the impact of a seismic event on the plant environment, these tanks are seismically Designed at Catawba.

Table 3.2.1-2 (page 1) will be revised (as attached) to show these tanks as Duke Seismic Category II equipment, with qualification to OBE and SSE criteria. This corresponds to Duke Class F equipment.

Table 3.2-2 (Page 15)
Summary of Process Equipment

Equipment	Size	Quality Assurance Required	(Note 1) Category	Elev.	Location	(Note 2) Haz. Source	Seismic		Tornado		Remarks - Including Any Environmental Requirements
							ORR	SSE	Wind	Missile	
Cranes											
Containment Polar Crane	D	X	I	As applicable	C	-	X	X	-	-	Containment Accident Pressure, Dead and Equipment, Live Loads, Hold Down Device, Note 1
Cask Crane	D	X	I	As applicable	AB	-	X	X	-	-	Dead and Equipment, Live Loads, Hold Down Device, Note 1
Cranes (Excluding Reactor Building and Fuel Handling)	D	-	III	As applicable	-	-	-	-	-	-	Dead and Equipment, Live Loads
Refueling Machine	W	X	I	As applicable	C	-	X	X	-	-	
Fuel Handling Machine	W	X	I	As applicable	AB	-	X	X	-	-	
Tanks											
Recycle Monitor	D	-	III	ASME VIII	AB	-	-	-	-	-	Class E
Laundry and Hot Shower	D	-	III	ASME VIII	AB	-	-	-	-	-	Class E
Waste Monitor	D	-	III	ASME VIII	AB	-	-	-	-	-	Class E
Mixing and Settling	D	-	III	ASME VIII	AB	-	-	-	-	-	Class E
Mixing and Settling Reagent	D	-	III	ASME VIII	AB	-	-	-	-	-	Class E
Floor Drain	D	-	III	ASME VIII	AB	-	-	-	-	-	Class E
Chemical Drain	D	-	III	ASME VIII	AB	-	-	-	-	-	Class E
BCP Motor Oil Drain	D	X	I	ASME VIII	C	-	-	-	-	-	See our Table 3.2.2-2
Waste Gas Decay	D	X	I	ASME III	AB	-	X	X	-	-	
Waste Drain	D	X	I	ASME III	AB	-	X	X	-	-	
Waste Evaporator Feed	D	X	I	ASME VIII	AB	-	X	X	-	-	Class F
Went. Unit Cond. Drain	D	X	I	ASME VIII	AB	-	X	X	-	-	Not Code Stamped
Spent Resin Storage	D	X	I	ASME III	AB	-	X	X	-	-	Class F
Refueling water Storage	D	X	I	ASME III	YD	-	X	X	X	-	
Reactor Makeup Water Storage	D	-	III	ASME VIII	YD	-	-	-	X	-	Not Code Stamped
Boron Recycle Holdup	D	X	I	ASME III	AB	-	X	X	See Note (4)	See Note (4)	
Boric Acid	D	X	I	ASME III	AB	-	X	X	See Note (4)	See Note (4)	
Fuel Oil Storage	D	X	I	ASME III	YD	-	X	X	-	-	Buried - Not Code Stamped
Component Cooling Surge	D	X	I	ASME III	YB	-	X	X	-	-	
Steam Gen. Blowdown	D	-	III	ASME VIII	TB	-	-	-	-	-	
Backwash	D	-	III	ASME VIII	TB	-	-	-	-	-	Not Code Stamped
Upper Surge	D	-	III	ASME VIII	TB	-	-	-	-	-	
Condensate Storage	D	-	III	ASME VIII	TB	-	-	-	-	-	Not Code Stamped
Upper Surge Dome	D	-	III	ASME VIII	TB	-	-	-	-	-	
Evap. Concentrate Holdup	D	-	III	ASME VIII	AB	-	-	-	-	-	Class E - Not Code Stamped
Demin. Water Storage	D	-	III	ASME VIII	SB	-	-	-	X	-	
Heater Blowoff	D	-	III	ASME VIII	TE	-	-	-	-	-	
Hot Water Drain	D	-	III	ASME VIII	TB	-	-	-	-	-	
RW Storage	D	-	III	ASME VIII	SB	-	-	-	-	-	Not Code Stamped
Turbine Oil Transfer	D	-	III	ASME III	TB	-	-	-	-	-	Not Code Stamped
Five Ventilation Air Surge	D	-	III	ASME VIII	SP	-	-	-	-	-	
Filtering Water	D	-	III	ASME VIII	SR	-	-	-	X	-	Not Code Stamped
K-1 Sulfuric Acid	D	-	III	ASME VIII	YD	-	-	-	X	-	Not Code Stamped
Evap. Concentrate Patch	D	-	III	ASME VIII	AB	-	-	-	-	-	Class F - Not Code Stamped

Attachment Item #1

Item 2 - Table 3.2.1 page 2

Provide safety related category for RCP Motor Oil Fill Tank.

Response:

Refer to response to Item 117.

Item 3 - 3.2.2.1, page 3.2-3

Where has an orifice of size 3/8" ID been used to protect a component in the reactor coolant pressure boundary?

Response:

The criteria used to define the Class 1/Class 2 interface for the reactor coolant system were briefly discussed. It was identified that a 3/8" orifice is used to define the Class 1/Class 2 boundary because a break downstream of the orifice can be handled by the normal charging system. The Staff concerns involved what type of piping was downstream of the orifice. It was verified that Class 2 piping was connected downstream of any 3/8" reactor coolant system pressure boundary orifice. Based on the above discussions, this item was closed.

Item 4 - 3.2.2.1, page 3.2-4

The applicant states that Safety Class 2 applies to components of the reactor coolant pressure boundary not covered in Safety Class 1.

What components of the reactor coolant pressure boundary are not Safety Class 1?

Response:

This item was discussed in conjunction with Item 3 and relates to the classification of certain components which make up the reactor coolant pressure boundary as Class 2. It was pointed out that when a 3/8" orifice is used to define the Class 1 RCS pressure boundary, components downstream of the orifice (which are part of the RCS pressure boundary) are Class 2. Typically, such Class 2 components consist of small piping and valves. It was also pointed out that there are no Class 2 components in the RCS pressure boundary unless they are located on the Class 2 side of the Class 1/Class 2 pressure boundary interface as defined in Section 3.2 of the Catawba FSAR. Based on the above discussions, this item was resolved.

Item 5 - Table 3.2.2-2, page 1

Auxiliary Steam System references Note 22. Where is Note 22? It is also referenced on pages 3, 7, 8, 11, 13, and 14.

Response:

Note 22 is provided (see attached).

Table 3.2.2-2 (Page 16)

NOTES (Cont'd)

- (9) X = Protected by virtue of location in a structure designed for tornado wind and missiles
- (10) As Applicable
- (11) Tank is provided with diaphragm membrane for oxygen exclusion
- (12) Performance test required
- (13) Redundant electric heaters are supplied
- (14) AMCA Class III and performance tested in accordance with AMCA Standard Test Code for air moving devices.
- (15) United Laboratories
- (16) Tanks are designed for all external forces due to soil and water, including buoyancy
- (17) ASME Code Case 1205
- (18) The Diesel Generator Engine and engine mounted components and piping are Seismic Category I, seismically qualified in accordance with IEEE Standard 344-1975. The seismic qualification stems from a modal analysis based on mathematical model derived from experimentally generated data from low level impedance test performed by the manufacturer. Tests were conducted under two excitation spectrums (2-13 Hz and 9-35 Hz) to cover the relevant frequency band of the seismic disturbance. The results of the modal analysis, published by Delaval in report number 75017-705 Volumes I, II, and III, constitutes the seismic qualification.
- (19) ASME, C13
- (20) See Table 6.2.5-1
- (21) As documented in Engineering Justification Report SES-JR-10, the one inch containment isolation valves for this system were purchased as Duke Class F instead of Duke Class B. This was necessary due to the high system design pressure (8000 psig) which exceeded the pressure/temperature ratings of the ASME Section III Code.
- (22) Seismically qualified per IEEE Standard 344.
- (23) Exceptions:
 - a. Evaporator vessels are seismic.
 - b. Steam supply piping is seismic and built to ANSI-B31.1.0 (1967).
 - c. Component cooling water supply piping is built to ASME III, Class 3.

Item 6 - Table 3.2.1-2, page 4

Explain the reasons behind the ASME Code and Safety Class classifications of Fuel and Control Rod Assemblies and Burnable Poison Rod Assemblies and Control Rod Drive Mechanisms.

Response:

The classification of various components in Table 3.2.2-2 were discussed and clarified as follows:

- a. Fuel Assemblies - It was pointed out that the criteria used to clarify components in ANS 18.2 are presently geared to fluid systems components and that fuel assemblies did not specifically fit into this criteria. Thus, ANS safety classification for fuel assemblies in the Catawba FSAR were defined as N/A (not applicable). However, if you apply a broad interpretation of the ANS criteria to fuel assemblies they can be classified as ANS Safety Class 2 because they are used to direct flow through the core and remove heat from the core. It was also pointed out that the fuel assemblies for Catawba are designed and fabricated in accordance with requirements for an ANS Safety Class 2 component. Based on the above, Table 3.2.2-2 (attached) has been revised to reflect an ANS Safety Class 2 classification.
- b. Control Rod Assemblies - The classification in Table 3.2.2-2 was correct and no further clarification of this item was required.
- c. Burnable Poison Rods - This component is defined as non-nuclear safety (NNS) because it does not perform any function required to shutdown the plant. Consequently, the ANS Safety Classification (NNS) in Table 3.2.1-2 is correct. Based on the above, this item was resolved.
- d. Control Rod Drive Mechanisms (CRDM's) - The classification of this component was discussed in detail. The CRDM pressure housing should be classified as ANS Safety Class 1 and ASME Code Class 1. The non-pressure boundary portions

of the CRDM's are classified as non-nuclear safety (NNS). Table 3.2.2-2 (attached) has been revised to reflect the above classification. Based upon the above, this item was resolved.

Based on the above discussions and the attached revisions to Table 3.2.2-2 this item was resolved.

ATTACHMENT 10 ITEM 6

Table 3.2.2-2 (Page 4a)

Summary of Criteria - Mechanical System Components

(1)	(2)	(3)	(4)	(5)	(6)	(7)	(8)	(9)
	Scope	Safety Class	Code	QA Req.	Location	Rad. Source	Seismic DBE DNE	Tornado Wind Missile
6	Fuel Assemblies	M, 2		X	C	X	X	X
	Control Rod Assemblies	2		X	C	X	X	X
	Burnable Poison Rod Assemblies	MNS			C	X	X	X
7	Reactor Vessel Internals	2	III-2	N/A	C	X	X	X
	Control Rod Drive Mechanisms (NON PRESSURE BOUNDARY)	MNS	III-1	X	C	X	X	X
	Reactor Coolant Pumps	1	III-1	X	C	X	X	X
	Steam Generators (tube)	1	III-2	X	C	X	X	X
	Steam Generators (shell)	2	III-1	X	C	X	X	X
	Pressurizer Relief Valves	1	III-1	X	C	X	X	X
	Pressurizer Safety Valves	1	III-1	X	C	X	X	X
	Pressurizer Relief Tank	MNS	VIII	X	C	X	X	X
	RC Pump Motor Drain Tank	MNS	VIII	X	C	X	X	X
	RC Pump Motor Drain Tank Pump	MNS	VIII	X	C	X	X	X
	Valves	1, 2, 3, MNS	III-1, 2, 3 B31.1.0	X	C, AB	X	X	X
	Pressurizer Relief Tank Sump Vessel	MNS	(10)		AB	X	X	X
6	CONTROL ROD DRIVE MECHANISM (PRESSURE HOUSING)		ASME III-1	X	CD		X	X

Item 7 - Table 3.2.1-2, page 4

Explain the ASME Code and Safety Class classification of the reactor vessel internals.

Response:

The reactor internals for the Catawba plant were fabricated prior to implementation of sub-section NG of the ASME Code. However, the reactor internals were designed and fabricated consistent with the requirements of the ASME Code but do not have a specific code stress report or stamp. In order to reflect the actual as-built criteria for the reactor internals, Table 3.2.2-2 (attached) has been revised to indicate that the ASME Code is not applicable. Additionally, Section 3.9.3 has been revised as discussed in Item 113 to indicate that the above criteria are applicable to the reactor internals. It was also pointed out that the reactor internals designation includes core support structures. Based on the above and the revised FSAR sections, this item was resolved.

ATTACHMENT TO ITEM 1

Table 3.2.2-2 (Page 4a)

Summary of Criteria - Mechanical System Components

(2) Scope	(3) Safety Class	(4) Code	(5) QA Req'd.	(6) Location	(7) Rad. Source	(8) Seismic OBE DBE	(9) Tornado Wind Missile
A	M		X	C	M	X	X
1	M		X	C	M	X	X
7	M	III-2	N/A	C	M	X	X
1	M	III-1	X	C	M	X	X
1	M	III-1	X	C	M	X	X
1	M	III-2	X	C	M	X	X
1	M	III-1	X	C	M	X	X
1	M	III-1	X	C	M	X	X
1	M	III-1	X	C	M	X	X
1	M	VIII	X	C	M	X	X
1	M	VIII	X	C	M	X	X
1	M	III-1,2,3	X	C, AB	M	X	X
1	M	III-1,2,3	X	C, AB	M	X	X
1	M	ASME III-1	X	AB	M	X	X
1	M			CD	M	X	X

System Component of System

Fuel Assemblies
 Control Rod Assemblies
 Surtable Fuel Rod Assemblies
 Reactor Vessel Internals
 Control Rod Drive Mechanisms (NON PRESSURE BOUNDARY)
 Reactor Coolant Pumps
 Steam Generators (shell)
 Pressurizer
 Pressurizer Relief Valves
 Pressurizer Safety Valves
 Pressurizer Relief Tank
 RC Pump Motor Drain Tank
 SC Pump Motor Drain Tank
 Valves
 Pressurizer Relief Tank Sump Vessel
 CONTROL ROD DRIVE MECHANISM (PRESSURE HOUSING)

Item 8 - Table 3.2.2-2, page 6

The table shows the Nuclear Sampling System as NNS, Code III-3 but not seismically designed. Is this consistent?

Response:

Listing the Nuclear Sampling System as NNS, Code III-3 but not seismically designed is not consistent. The Sample coolers are B31.1 (non-seismic). Table 3.2.2-2 (page 6) will be revised accordingly (as attached).

Question # 8

Table 3.2.2-2 (Page 6)

Summary of Criteria - Mechanical System Components

System	Component or System	(2) Scope	(3) Safety Class	(4) Code	(5) QA Req.	(6) Location	(7) Rad. Source	(8) Seismic OBE DBE	(9) Tornado Wind Missile
	Valves	D&W	1,2,3	III-1,2,3	X	C,AB	P	X X	X X
	Gas/Water Inter. Membrane	W	2	III-2	X	AB	-	X X	X X
NM	<u>Nuclear Sampling System</u>								
	Sample Vessels	D	NNS	(10)	-	AB	X	- -	X X
	Sample Heat Exchanger (tube)	D	NNS	E-1,1,1	-	AB	X	- -	X X
	(shell)	D	NNS	E-1,1,1	-	AB	X	- -	X X
	Delay Coil	D	2	III-2	X	C	X	X X	X X
	Valves	D	2,3	III-2,3	X	C,AB	X	X X	X X
NR	<u>Boron Thermal Regeneration System</u>								
	Heat Exchangers								
	Moderating (tube)	W	3	III-3	X	AB	X	X X	X X
	(shell)	W	3	III-3	X	AB	X	X X	X X
	Lakedown Chiller (tube)	W	3	III-3	X	AB	X	X X	X X
	(shell)	W	NNS	VIII	-	AB	-	- -	X X
	Lakedown Reheat (tube)	W	2	III-2	X	AB	X	X X	X X
	(shell)	W	3	III-3	X	AB	X	X X	X X
	Chiller Units	W	NA	-	-	AB	-	- -	X X
	Chiller Surge Tanks	W	NNS	VIII	-	AB	-	- -	X X
	Boron Chiller Pumps	W	NA	III-3	-	AB	-	- -	X X
	NR Thermal Regeneration Demineralizers	W	3	III-3	X	AB	X	X X	X X
	Valves	D	2,3	III-2,3	X	AB	X	X X	X X
NS	<u>Containment Spray System</u>								
	Containment Spray Pumps	D	2	III-2	X	AB	X	X X	X X
	Containment Spray HX (tube)	D	2	III-2	X	AB	X	X X	X X
	(shell)	D	3	III-3	X	AB	P	X X	X X
	Containment Spray Nozzles	D	2	-	X	C	P	X X	X X
	Valves	D	2	III-2	X	C	P	X X	X X
NV	<u>Chemical and Volume Control System</u>								
	Pumps								
	Reciprocating Charging	W	2	III-2	X	AB	X	X X	X X
	Centrifugal Charging	W	2	III-2	X	AB	X	X X	X X
	Boric Acid Transfer	W	3	III-3	X	AB	-	X X	X X
	Heat Exchangers								
	Regenerative	W	2	III-2	X	C	X	X X	X X
	Lakedown (tube)	W	2	III-2	X	AB	X	X X	X X
	(shell)	W	3	III-3	X	AB	P	X X	X X
	Excess Lakedown (tube)	W	2	III-2	X	C	X	X X	X X
	(shell)	W	2	III-2	X	C	P	X X	X X
	Seal Water (tube)	W	2	III-2	X	AB	X	X X	X X
	(shell)	W	3	III-3	X	AB	P	X X	X X

Agenda Item # 8 - Attachment

Item 9 - Table 3.2.1-2, page 9

In the Diesel Generator Engine Starting Air System the starting air tanks are seismically designed yet the air compressors are not. How many starts can be provided by the air tanks?

Response:

FSAR section 9.5.6.2.1 addresses this concern. The starting air storage capacity of each redundant diesel engine is sufficient for a minimum of five successful engine starts without the use of the air compressors.

Item 10 - Table 3.2.1-2, page 15

Footnote 21 references Engineering Justification Report SES-JR-10. Provide a copy of this report.

Response:

A copy of Engineering Justification Report Number SES-JR-10 is attached.

DUKE POWER COMPANY
DESIGN ENGINEERING - SYSTEMS AND EQUIPMENT SECTION
ENGINEERING JUSTIFICATION REPORT

Date: February 17, 1978

Report No: SES-JR-10

To: R. L. Dick

Originated By: V. H. Shellhorse 2-20-78

Station: Catawba 1-2

Checked By: E. D. Lindsay 2-20-78

System: Equipment Decontamination (WE)

Approved By: R. E. Miller 2-21-78

File No: CN-1205.01

QA Approval: C. A. Bell 3-7-78

Variation Reported By and Date: R. C. Bucy - January 30, 1978

Description of Variation:

Valves tagged 1,2/WE/20, 22 appear on flow diagrams CN-1568-1.0 and CN-2568-1.0. These valves have design conditions of 8000 psig @ 120°F, and are shown as Duke Safety Class B. Because of the high pressure class required, these valves cannot be purchased to ASME III, Class 2.

Engineering Analysis Required:

Review the system requirements and service to verify design conditions and Duke Safety Class. Identify alternate design code or standard, if appropriate.

Calculations:

None

Engineering Conclusion:

The valves are used in a containment isolation application which normally requires conformance with ASME III. The equipment decontamination system (WE) is not frequently used and will not be used within the containment during reactor operation. Valves designed for an internal pressure of 8000 psig and seismic loading provide adequate assurance of containment isolation under conditions of containment pressure following postulated LOCA. Purchase the valves to the best available codes and standards as Duke Safety Class F.

S. K. Blackley, Jr., Chief Engineer
Mechanical & Nuclear Division



By: V. H. Shellhorse, Engineer Associate

/ah

cc: D. G. Beam (2)
D. G. Gardner
J. M. Warren

C. H. Favor
R. F. Wardell
G. Fincher (Orig)

R. C. Bucy
H. E. Edwards
J. W. Kosko (Catawba - AI)

Item 11 - Table 3.2.2-3

Footnote 1 states that Duke Power Company established an "effective code date" for the station in accordance with 10 CFR 50.55a, reviews and may elect to comply with portions or all the latest versions of the above codes. This is acceptable as long as different versions of the ASME Code are not used for evaluation of the same system or component. Provide a commitment to this effect.

Response:

Table 3.2.2-3 will be revised (as attached) to provide the following commitment:

Specific provisions of ASME Code editions and Addenda later than those identified on the above table may be utilized with the mutual consent of Duke Power and the N Type Certificate Holder (if other than Duke). Whenever specific provisions of a later code are utilized, all related requirements will also be satisfied.

Item 12 - In the primary loop, what size breaks are postulated for the design of pipe whip restraints? What size breaks are postulated in the primary loop for determination of compartment pressurization and asymmetric loads? If breaks for either case are less than full size, provide justification.

Response:

Westinghouse presented information on the size of pipe breaks in the RCS which were assumed in the design and analysis. For breaks at the reactor vessel nozzle a break opening area of 85 square inches was assumed. All other circumferential breaks postulated in the RCS were full double-ended breaks. The above break sizes were used in the design of restraints, mass and energy release calculations (see FSAR Section 6.2.1.2), and reactor coolant system analysis including asymmetric LOCA load analyses.

The design of the RCS restraints was performed by Duke. Consequently, routine design information such as restraint stiffnesses, gaps, and loads were routinely exchanged as design information between Westinghouse and Duke. In the case of the reactor vessel nozzle restraints Westinghouse calculated break opening areas based on the Duke design. The results of this analysis were presented at the meeting. Actual break opening areas are less than 40 square inches. Thus, the assumed value of 85 square inches was conservative.

Based on the above, this item was resolved.

Item 13 - The FSAR states that breaks are postulated at locations where the cumulative usage factor exceeds 0.2 for normal and upset operating conditions.

(a) Breaks are to be postulated where the cumulative usage factor exceeds 0.1.

Show that your analysis complies with the SRP.

(b) The criteria is evaluated under loadings resulting from normal and upset operating conditions including the OBE. Change this to comply with the SRP.

Response 13a:

The basis for a cumulative usage factor of 0.2 was discussed. Specifically, this factor was accepted by the Staff as part of their review and acceptance of WCAP 8082 on the basis that a sufficient number of breaks were postulated for the RCS. Westinghouse agreed to revise the FSAR and replace the specific cumulative usage factor of 0.2 with a reference to WCAP 8082 in the text of Section 3.6.

Based on the above discussion and the attached FSAR changes, this item was resolved

Response 3b:

As identified in Item 51, OBE loads are considered under the upset condition. Appropriate FSAR changes were made relative to Item 51.

Based on the above and Item 51, this item was resolved.

ATTACHMENT TO ITEM 13a

CNS

- c) Damage to the high head safety injection lines connected to the other leg of the affected loop or to the other loops is prevented.
- d) Propagation of the break to high head safety injection line connected to the affected leg is prevented if the line break results in a loss of core cooling capability due to a spilling injection line.

3.6.2.1.1.1 Postulated Piping Break Locations and Orientations

In each leg of the Reactor Coolant System, a minimum of three postulated rupture locations shall be selected in the following manner:

INSERT A
~~Breaks shall be postulated at the terminal end points and at all locations in a run or branch in which the cumulative usage factor exceeds 0.2 for normal and upset operating conditions or in which the range of primary plus secondary stress intensity for normal and upset operating conditions exceeds 80 percent of the ASME Section III Code allowable on an elastic basis (2.4.5). In the event that a location between the terminal end points cannot be chosen in this manner, the point of highest fatigue usage shall be used to obtain a total of three break locations.~~

At each possible break location, consideration must be given to the occurrence of either a circumferential or longitudinal break. As discussed in Reference 1, a circumferential rupture is more likely than a longitudinal rupture for reactor coolant piping. Only in the case of one elbow is a longitudinal rupture postulated.

Circumferential breaks are perpendicular to the longitudinal axis of the pipe.

Longitudinal breaks are parallel to the longitudinal axis of the pipe. Certain longitudinal break orientations may be excluded on the basis of the state of stress at the location considered.

For the main reactor coolant piping system, eleven discrete break locations were determined by stress and fatigue analyses. The locations are given in Table 3.6.2-1 and shown in Figure 3.6.2-2. The postulated locations conform to the criteria stated above and are discussed in Reference 1.

Break type at each discrete break location are presented in Table 3.6.2-1. The results of the analyses which lead to the break orientations are discussed in Reference 1.

3.6.2.1.1.2 Postulated Piping Break Sizes

For a circumferential break, the break area is the cross-sectional area of the pipe at the break location, unless pipe displacement is shown to be limited by analysis, experiment or physical restraint.

For a longitudinal break, the break area is the cross sectional area of the pipe at the break location unless analytically or experimentally shown otherwise. A longitudinal break area less than the cross sectional area of the

INSERT A
[For the reactor coolant system breaks are postulated as described in WCAP BOSZ Reference 1.]

Item 14 - 3.6.2.1.1.2, page 3.6-9

Identify the analysis, experimental data or physical restraint characteristics which have been used to limit pipe displacement. For and breaks with areas other than the full cross-sectional area of the pipe.

Response:

As discussed in Item 12, limited breaks are assumed and justified at the reactor vessel nozzle. All other circumferential breaks are full double-ended breaks.

Based on the above and Item 12, this item was resolved.

Item 15 - 3.6.2.1.1, page 3.6-10

Item (b) mentions encased or jacketed piping. Where has it been used? Show that the required inservice inspection can be performed.

Response:

Duke provided drawings of the Main Steam Guard Pipe during the review meeting.

Duke agreed to provide drawings which define break exclusion regions (as attached).

Attached drawings show weld locations which will be subject to inservice inspection

to comply with the break exclusion region requirements. For welds not marked,

breaks will be postulated if required in accordance with FSAR Section 3.6.

This item was closed.

SEE

APERTURE

CARDS

AVAILABILITY PDR CF HOLD

NUMBERS OF PAGES. 8

Item 16 - 3.6.2.1.1, page 3.6-11

Item j) provides criteria for describing the effects an impingement jet has on various sizes of target pipe.

It is the staff's position that this criteria has not yet been demonstrated to be valid when applied to jet impingement. Therefore, either:

- 1) Remove this criteria from the FSAR and provide a commitment to properly evaluate the cases where it was used; or
- 2) Demonstrate through experimental and analytical data that such criteria are, in fact, conservative and correct. (Note: The comparison to the whipping pipe recently proposed on the McGuire docket is not acceptable.)

Response:

Duke's present criteria state that no unacceptable interactions occur when a target pipe is hit by jet impingement from a source pipe of equal or smaller nominal pipe size and wall thickness. The NRC's Standard Review Plan, Section 3.6.1, and the American Nuclear Society's Standard ANS 58.2 either state or imply that no unacceptable interaction occurs when a target pipe is impacted by a source pipe of equal or smaller size and wall thickness. Since neither of the aforementioned documents places limits on the system conditions, e.g., temperature, pressure, materials, impact velocity, moment arm or support considerations, the case of impact rather than jet impingement becomes the limiting or more severe condition for the following reasons:

1. The load on the target pipe will be less for the jet impingement case by an amount equal to the source pipe's impacting mass.
2. The maximum jet force is on the broken source pipe and not on any target in the path of the jet. This is true for the following reasons:
 - a. The source pipe reacts to the full jet thrust associated with the break.
 - b. Any target pipe intercepts only a portion of the jet.
 - c. Thermodynamic and drag losses begin immediately upon jet issuance from the broken pipe.

- d. The jet impingement energy will be dissipated due to jet deflection off the target pipe, i.e., the pipe being a cylindrical target only receives the maximum jet load at a single point along its surface the remaining jet loading is deflected by the curved surface at varying angles.

Conversely, by using the present, accepted NRC and ANS criteria for a whipping pipe, if an acceptable interaction is identified when a target pipe of same or larger size and wall thickness is struck by a source pipe, it is assumed that the target pipe arrests the whip from the source pipe. When this occurs the maximum steady state jet force will then be transmitted to the target pipe for the duration of blowdown.

Based upon the foregoing, it is Duke Power Company's position that the loading conditions resulting from pipe whip are more severe than those from pure jet impingement for both impact and steady state conditions. Therefore, the present Duke criteria are conservative and adequate for evaluation of the acceptability or unacceptability of piping as jet impingement targets and consistent with industry practice.

Item 17 - 3.6.2.1.2, page 3.6-11

Item j) indicates that certain exceptions to the criteria may be taken. In addition to indicating where these exceptions are taken, provide the analytical or experimental bases(es) for the exceptions.

Response:

No exceptions to the criteria are currently being used based on experimental or analytical data for a whipping pipe or jet considered capable of developing throughwall leakage cracks in equal or larger nominal pipe sizes with thinner wall thickness. Page 3.6-11 will be revised (as attached) to ensure that exceptions will be documented when they develop.

Attachment item 17

CNS

- 3) Seismic loadings equivalent to the Operating Basis Earthquake (OBE) are used in the analysis of piping systems for the purpose of postulating break locations. Protective structures are designed to withstand the effects of the postulated piping failure in combination with loadings associated with the Operating Basis Earthquake (OBE) and Safe Shutdown Earthquake (SSE) within the respective design load limits for the structures.
- e) Consideration is given to the potential for a random single failure of an active component subsequent to the postulated pipe rupture. Where the postulated piping break is assumed to occur in one of two or more redundant trains of a dual-purpose moderate-energy essential system (i.e., one required to operate during normal plant conditions as well as to shut down the reactor and mitigate the consequences of the piping rupture), single failures of components in the other train or trains of that system only are not assumed; provided the system is designed to seismic Category I standards, is powered from both offsite and onsite sources, and is constructed, operated, and inspected to quality assurance, testing, and in-service inspection standards appropriate for nuclear safety systems.
- f) In the event of a postulated break in the piping in one unit, safe reactor shutdown of the affected unit cannot preclude the capability for safe shutdown of the reactor of the unaffected unit(s).
- g) Containment structural integrity is maintained by limiting the combination of break sizes and types to the design basis capability (i.e., temperature, pressure, and leakage rate) of the containment.
- h) For those postulated breaks classified as a loss-of-reactor coolant, the design leak tightness of the containment fission product barrier shall be maintained.
- i) The conditions within the control room or any other location where manual action is required to assure safe shutdown to the cold condition are such as to assure habitability and comply with the requirements of General Design Criterion 19.
- j) A whipping pipe or jet is assumed not to cause failure of other pipes of equal or greater size and equal or greater thickness. Smaller and thinner pipes are assumed to encounter unacceptable damage upon impact. A whipping pipe or jet is considered capable of developing through-wall leakage cracks in equal or larger nominal pipe sizes with thinner wall thicknesses, except where experimental or analytical data for the expected range of impact energies demonstrate the capability to withstand the impact without failure.
- k) Piping Breaks Within The LOCA Boundary (See Figure 3.6.2-1)
- 1) All LOCA breaks are allowed to damage any non-LOCA line except essential systems, and steam and feedwater lines.

If an exception is taken, the basis of the exception will be documented in file material.

Item 18 - 3.6.2.1.2.1, pages 3.6-13 to 16

This pipe break criteria is not in compliance with the latest version of SRP 3.6.2 (NUREG-0800).

Response:

Juke will revise FSAR page 3.6-14 (as attached) to assure that break locations will be calculated whenever the cumulative factor, u , is greater than .1. Documentation is provided for NRC review. This item was closed.

Question # 18

CNS

Terminal ends are considered as piping originating at structures or components (such as vessel and equipment nozzles and structural piping anchors) that act as rigid constraint to the piping thermal expansion. Typically, the anchors assumed for the piping code stress analysis would be terminal ends. The branch connection to the main run is one of the terminal ends of a branch run, except intersections of runs of comparable size and fixity which have a significant effect on the main run need not be considered terminal ends when the stress analysis model includes both the run and branch piping and the intersection is not rigidly constrained to the building structure.

a) Breaks in Duke Class A piping are postulated at the following locations (see Table 3.2.2-3 for class correlations):

- 1) The terminal ends of the pressurized portions of the run.
- 2) At intermediate locations selected by either one of the following methods:
 - i) At each weld location of potential high stress or fatigue, such as pipe fittings (elbows, tees, reducers, etc.), valves, flanges, and welded attachments, or
 - ii) At all intermediate locations between terminal ends where the following stress and fatigue limits are exceeded,
 - a) The maximum stress range shall not exceed $2.4 S_m$ except as noted below.
 - b) The maximum stress range between any two load sets (including the zero load set) shall be calculated by Eq. (10) in Paragraph NB-3653, ASME Code, Section III, for normal and upset plant conditions and an operating basis earthquake (OBE) event transient.

If the calculated maximum stress range of Eq. (10) exceeds the limit ($2.4 S_m$) but is not greater than $3 S_m$, the limit of $U < 0.1$ shall be met.

If the calculated maximum stress range of Eq. (10) exceeds $3 S_m$, the stress ranges calculated by both Eq. (12) and Eq. (13) in Paragraph NB-3653 shall not exceed $2.4 S_m$ or the limit of $U < 0.1$.

where:

S_n = primary-plus secondary stress-intensity range, as calculated from Equation (10) in Subarticle NB-3600 of the ASME Boiler and Pressure Vessel Code, Section III.

{c) U shall not exceed 0.1

Question # 18

The following is a list of problems which have no Equation 10 stresses between 2.4 and 3.0 S_m .

NI-04
NI-05
NI-12
NC-10
NC-11
NC-13
NC-25
NC-26

Component types are as follows:

FGBW - flush ground butt weld
AWBW - as-welded butt weld
FILW - fillet weld
AWTT - as-welded tapered transition joint
BELB - butt welded elbow
SELB - socket welded elbow
STEE - socket welded tee
SRED - socket welded reducer
BRED - butt welded reducer
CRVP - curved pipe

					Duke Power Company
					Catawba Unit 1
REV	BY	DATE	CHECKED	DATE	

310 5/26/82 07 5-16

PAGE
OF

PROBLEM CC-NI-01

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
43/66W	2.614	16,292	42,587	AWBW
94/160W	2.942	16,292	47,931	FILW
69/99W	2.480	16,328	40,493	AWBW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
80/11/03. 15.25.40

Duke Power Company					PAGE 1 OF 1
Catawba Unit #1					
REV	BY	DATE	CHECKED	DATE	
-	CLS	5/26/82	JRT	5-26-82	

PROBLEM CC-NI-02

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
52/93W	2.562	16,292	41,740	AWTT
55/97W	2.563	16,292	41,756	AWBW
71,71A/ 132R,133L	2.780	16,328	45,392	BELB
71A/133L	2.756	16,328	45,000	AWTT
73/135W	2.725	16,292	44,396	AWTT
75/139W	2.564	16,292	41,773	AWBW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:

Computer Seq. #

80/10/31. 17.24.28.

					Duke Power Company
					Catawba Unit #1
	ULS	5/26/92	OPM	5-2-12	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NI-03

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
19/20W	2.770	20,000	55,400	FILW
24/26W	2.419	20,000	48,380	FILW
25/27W	2.466	20,000	49,320	FILW
25,26/ 27R, 28L	2.989	20,000	59,780	SELB
26/28W	2.474	20,000	49,480	FILW
42/55W	2.743	20,000	54,860	FILW
44/58R	2.699	20,000	53,980	SELB
44A/59W	2.539	20,000	50,780	FILW
38/93B	2.665	20,000	53,300	STEE

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
80/10/09. 18.47.03.

					Duke Power Company
					Catawba Unit #1
REV	BY	DATE	CHECKED	DATE	
	CLS	5/26/91		5/22/91	

PROBLEM CC-NI-06

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
13/34W	2.503	17,430	43,627	AWTT
A14/36W	2.510	17,430	43,749	AWBW
18/47W	2.866	17,430	49,954	AWTT
C07B/30L	2.791	17,430	48,647	BELB

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
81/04/27. 15.51.51

					Duke Power Company
					Catawba Unit #1
	OLE	5/19/82	J. J. J.	5-19-82	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NI-07

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
AA2B/8W	2.504	17,430	43,645	FGBW
45/15W	2.406	20,000	48,120	AWTT
45A/16W	2.447	20,000	48,940	AWTT

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
81/04/27. 17.02.28.

					Duke Power Company
					Catawba Unit #1
0	CLE	5/19/92	ORJ	5-13-92	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NI-20

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
10A/10W	2.949	16,820	49,602	AWBW
12B, 13/ 14R, 15L	2.480	16,820	41,714	BRED
13/15W	2.471	16,820	41,562	FILW
15A/17W	2.429	20,000	48,580	FILW
16/20W	2.482	20,000	49,640	FILW
17/21W	2.472	20,000	49,440	FILW
17AA/22W	2.427	20,000	48,540	FILW
148/135W	2.997	16,820	50,410	FILW
149D/141R	2.843	16,820	47,819	CRVP
149E/142L	2.986	16,820	50,225	CRVP

S_n -Equation 10 stress

S_m -allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:

Computer Seq. #

81/02/09. 17.29.36.

					Duke Power Company
					Catawba Unit #1
0	JLC	5/26/92	QCY	5/26/92	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NI-21

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
98/92W	2.466	16,820	41,478	FILW
98,99/ 92R,93L	2.479	16,820	41,697	SRED
181D/144W	2.784	20,000	55,680	FILW
185A/146W	2.879	20,000	57,580	FILW
187/148W	2.666	16,820	44,842	FILW
187,187A/ 148R,149L	2.663	16,820	44,792	SRED
189B/153W	2.876	16,820	48,375	AWBW
193/158W	2.616	16,820	44,001	AWBW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
81/01/30. 08.40.56

Duke Power Company				
Catawba Unit #1				
REV	BY	DATE	CHECKED	DATE

PROBLEM CC-ND-01

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
C01A/4W	2.435	19,800	48,213	AWBW
69A/87R	2.787	20,000	55,740	BELB
70/88L	2.810	20,000	56,200	BELB

S_n -Equation 10 stress

S_m -allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #

82/02/04. 19.04.55

					Duke Power Company
					Catawba Unit #1
REV	BY	DATE	CHECKED	DATE	
	OLE	5/26/92	JED	5-2-92	

PROBLEM CC-ND-02

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
C31A/4W	2.706	19,800	53,579	AWBW
C71A/86R	2.531	20,000	50,620	CRVP
C71B/87L	2.581	20,000	51,620	CRVP

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
82/02/04. 19.05.13

					Duke Power Company	
					Catawba Unit #1	
0	CLS	5/26/90	JFJ	5/27/90		
REV	BY	DATE	CHECKED	DATE	PAGE 1 OF 1	

PROBLEM CC-NC-03

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
34A/74W	2.455	16,820	41,293	AWBW
36/76B	2.716	20,000	54,320	BTEE
50A/85W	2.824	16,862	47,618	AWTT
C15A/86W	2.527	16,862	42,610	AWTT
C15A/86R	2.432	16,862	41,008	BELB
C15B/87L	2.638	16,862	44,482	BELB
C14A/90W	2.625	16,820	44,153	AWBW
C14B/91WR	2.898	16,820	48,744	AWBW
44/94R	2.599	16,862	43,824	BELB
42/96L	2.692	16,862	45,393	BELB
C11A/98W	2.713	16,820	45,633	AWBW
C11B/99W	2.645	16,820	44,489	AWBW
C18A/107W	2.586	16,820	43,496	AWBW
C18B/108W	2.677	16,820	45,027	AWBW
66/113R	2.585	16,862	43,588	BELB

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
82/04/14. 07.02.18

					Duke Power Company
					Catawba Unit #1
0	CLS	5/17/82	0.7	5-17-82	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NC-03

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
68/115L	2.573	16,862	43,386	PELB
C21A/117W	2.924	16,820	49,182	AWBW
C21B/118W	2.700	16,820	45,414	AWBW
C22A/121W	2.664	16,862	44,920	AWTT
C22A/121R	2.722	16,862	45,898	BELB
C22B/122L	2.550	16,862	42,998	BELB
C22B/122W	2.617	16,862	44,128	AWTT
73A/123W	2.992	16,862	50,451	AWTT

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
82/04/14. 07.02.18

					Duke Power Company
					Catawba Unit #1
0	CLS	5/19/82	OPD	5/26/82	PAGE OF 2 2
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NC-07

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
4/4R	2.447	16,840	41,207	BELB
7AA/9R	2.549	16,840	42,925	BELB
7BB/10L	2.489	16,840	41,915	BELB
7CC/11R	2.439	16,840	41,073	BELB
7DD/12L	2.506	16,840	42,201	BELB
8/14R	2.591	16,840	43,632	BELB
9/15L	2.614	16,840	44,020	BELB
16/28R	2.949	16,532	48,753	BELB
17/29L	2.944	16,532	48,670	BELB
20W/36W	2.653	16,520	43,828	AWTT
20C/39R	2.864	16,532	47,348	BELB
80/48K	2.854	16,292	46,497	CRVP
81/49L	2.871	16,292	46,774	CRVP
81C/50R	2.832	16,328	46,241	BELB
81E/52L	2.810	16,328	45,882	BELB
81D/51W	2.917	16,328	47,629	AWBW
83/56W	2.403	16,292	39,150	AWBW
66/114W	2.981	16,820	50,140	FILW
65/115W	2.776	20,000	55,520	FILW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
82/03/26. 17.03.29.

					Duke Power Company	
					Catawba Unit #1	
0	TW	5/25/82	CLS	3/16/82		
REV	BY	DATE	CHECKED	DATE		

PROBLEM CC-NC-07

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
B4B/123R	2.517	16,820	42,336	CRVP
B4C/124L	2.532	16,820	42,588	CRVP
45B/144L	2.460	16,800	41,328	CRVP
46A/146R	2.644	16,800	44,419	CRVP
46B/147L	2.663	16,800	44,738	CRVP
47A/149R	2.627	16,800	44,134	CRVP
47B/150L	2.472	16,800	41,530	CRVP
50/156R	2.545	16,800	42,756	CRVP
71/183W	2.794	20,000	55,880	FILW
72/184W	2.773	20,000	55,460	FILW
117/192W	2.552	16,292	41,577	AWBW
142/226R	2.989	16,800	50,215	BRED
145/230L	2.826	16,800	47,476	BRED

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #

82/03/26. 17.03.29

Duke Power Company				
Catawba Unit #1				
0	TW	5/15/82	CLS	5/26/92
REV	BY	DATE	CHECKED	DATE

PROBLEM CC-NC-08

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/	S_n/S_m	S_m	S_n	Comp. type
31/32	2.975	16,328	48,576	BELB
32M	2.623	16,328	42,828	BELB
32N	2.582	16,328	42,159	BELB
32O	2.748	16,328	44,869	BELB
32P	2.834	16,328	46,274	BELB
33	2.877	16,292	46,872	CRVP
34	2.770	16,292	45,129	CRVP
35	2.555	16,328	41,718	BELB
36	2.585	16,328	42,208	BELB
62	2.560	16,328	41,800	BELB
63	2.888	16,840	48,634	BELB
69	2.980	16,840	50,183	BELB
75A	2.842	16,520	46,950	AWTT
78B	2.588	16,520	42,754	AWTT
101Z	2.823	16,800	47,426	AWRW
101Y	2.414	16,800	40,555	AWBW
101A	2.854	16,800	47,947	CRVP
101C	2.723	16,800	45,746	CRVP
101I	2.700	16,800	45,360	AWBW
117	2.885	20,000	57,700	FILW
112	2.554	16,292	41,610	AWBW
118	2.774	20,000	55,480	FILW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
82/03/23. 17.47.35

					Duke Power Company
					Catawba Unit #1
0	TL	5/25/82	CLS	5/26/82	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NC-08

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
126	2.766	20,000	55,320	FILW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
82/03/23. 17.47.35

					Duke Power Company	
					Catawba Unit #1	
0	TL	5/25/82	CLC	5/26/82		
REV	BY	DATE	CHECKED	DATE		

PROBLEM CC-NC-12

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
83,83/ 50R,51L	2.985	20,000	59,700	BELB
107,108/ 81R,82L	2.624	18,040	47,337	BRED
108/82W	2.422	16,830	40,762	AWBW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
80/09/29. 16.55.38

Duke Power Company					PAGE 1 OF 1
Catawba Unit #1					
0	CLS	5/19/82	DM	5-1-82	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NV-09

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
88/123W	2.580	20,000	51,600	FILW
89/124W	2.870	20,000	57,400	FILW
94/130W	2.508	20,000	50,160	FILW
95/131B	2.750	20,000	55,000	STEE
104/137W	2.602	20,000	52,040	FILW
110/148W	2.456	20,000	49,120	FILW
110,111/ 148R,149L	2.877	20,000	57,540	SELB
111/149W	2.442	20,000	48,840	FILW
118,118A/ 157R,158L	2.751	20,000	55,020	SELB
118B/159W	2.404	20,000	48,080	FILW
118B,120/ 159R,160L	2.888	20,000	57,760	SELB
120/160W	2.534	20,000	50,680	FILW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
82/01/11. 17.13.12.

					Duke Power Company
					Catawba Unit #1
0	CLG	5/11/82	JRD	5/11/82	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NV-10

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
S4/4W	2.511	20,000	50,220	FILW
S6/8W	2.681	20,000	53,620	FILW
S7/9W	2.734	20,000	54,680	FILW
S20/25W	2.467	20,000	49,340	FILW
S31/39W	2.531	20,000	50,620	FILW
S35/44W	2.835	20,000	56,700	FILW
S36/45W	2.594	20,000	51,880	FILW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
81/08/13. 20.06.49.

					Duke Power Company	
					Catawba Unit #1	
D	CLS	5/17/82	JPT	5-17-82		
REV	BY	DATE	CHECKED	DATE		

PROBLEM CC-NV-11

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
81C/7W	2.662	20,000	53,240	FILW
77/10W	2.778	20,000	55,560	FILW
76/11W	2.847	20,000	56,940	FILW
74/13W	2.999	20,000	59,980	FILW
73/15W	2.810	20,000	56,200	FILW
72/16W	2.757	20,000	55,140	FILW
70,71/ 17R,18L	2.390	20,000	51,800	SELB
69,68/ 19R,20L	2.668	20,000	53,360	SELB
65/24W	2.645	20,000	52,900	FILW
63L/25W	2.597	20,000	51,940	FILW
63/37B	2.402	20,000	48,040	STEE
62/38W	2.502	20,000	50,040	FILW
61,60/ 39R,40L	2.755	20,000	55,100	SELB
59/41W	2.430	20,000	48,600	FILW
58/42W	2.815	20,000	56,300	FILW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:
Computer Seq. #
81/08/13. 18.48.05.

Duke Power Company					PAGE 1 OF 1
Catawba Unit #1					
0	ULS	5/14/82	JRF	5-1-82	
REV	BY	DATE	CHECKED	DATE	

PROBLEM CC-NV-12

The following are nodes which have Equation 10 stresses between 2.4 and 3.0 S_m

DCP/SOP	S_n/S_m	S_m	S_n	Comp. type
67/9R, 10L	2.454	20,000	49,080	SELB
12/16W	2.845	20,000	56,900	FILW
13/17W	2.617	20,000	52,340	FILW
14, 15/ 18R, 19L	2.523	20,000	50,460	SELB
16, 17/ 20R, 21L	2.968	20,000	59,360	SELB
17/21W	2.531	20,000	50,620	FILW
21/28W	2.541	20,000	50,820	FILW
31/40W	2.422	20,000	48,440	FILW
16/20W	2.412	20,000	48,240	FILW

S_n - Equation 10 stress

S_m - allowable stress

S_n and S_m stresses are given in psi.

REFERENCE:

Computer Seq #

81/08/14. 02.07.58.

					Duke Power Company	
					Catawba Unit #1	
						PAGE
						1
						OF
						1
REV	BY	DATE	CHECKED	DATE		
	CLS	5/24/82	JD	5-27-82		

Item 19 - 3.6.2.1.2.1, page 3.6-16

Item c)2)i) indicates the criteria for selecting intermediate pipe break locations in Duke Class E, G, and H piping systems.

It is the staff's position that, since Table 3.2.2-3 indicates that these piping systems are not designed for seismic loadings, pipe breaks should be postulated so as to clearly demonstrate that failure of the system will not result in any loss of capability of essential systems and components to withstand the further effects of any single active component failure and still perform all functions required to shutdown the reactor and mitigate the consequences of the postulated piping failure. Therefore, provide a commitment to meet this position.

Response: The attached revision to FSAR page 3.6-16 clarifies Duke's position.

#19

CNS

break locations is determined separately for the normal plant condition load combination and for that upset plant condition which has the highest stress.

c) Breaks in Duke Class E, F, G and H piping are postulated at the following locations (See Table 3.2.2-3 for class correlations)

- 1) The terminal ends of the pressurized portions of the run.
- 2) At intermediate locations selected by one of the following methods:

i) For Class E, F, G, and H Piping:

intermediate At each weld location of potential high stress or fatigue, ~~such as pipe fittings (elbows, tees, reducers, etc.), valves, flanges, and welded attachments;~~ or

ii) For Class F Piping:

At all locations where the stress, S , Exceeds $0.8 (1.2 S_h + S_A)$, where:

S = stresses under the combination of loadings associated with the normal and upset plant condition loadings and an OBE event, as calculated from the sum of equations (9) and (10) in subarticle NC-3600 of the ASME Boiler and Pressure Vessel Code, Section III.

S_h = basic material allowable stress at maximum (hot) temperature, per ANSI B31.1.0.

S_A = allowable stress range for expansion stresses, per ANSI B31.1.0.

3) For Class F Piping:

If there are not at least two intermediate locations where S exceeds $0.8 (1.2 S_h + S_A)$, a minimum of two separate locations are chosen based upon highest stress. Intermediate breaks are not postulated in sections of straight pipe where there are no pipe fittings, flanges, valves or welded attachments.

3.6.2.1.2.2 Postulated Piping Break Locations For Moderate-Energy Piping Systems

Systems identified as containing moderate-energy piping are examined by detailed drawing review for postulated through-wall cracks as defined below. Systems analyzed for consequences of postulated piping cracks are listed in Table 3.6.1-2.

Item 20 - 3.6.2.1.2.3, page 3.6-17

Item a)3 states circumferential breaks are assumed to result in pipe separation of one diameter displacement of ruptured piping sections unless physically limited by piping restraints. Show where piping restraints are used to limit pipe displacements.

Response:

Limited break areas have not, to date, been used for temperature or pressure calculations. Neither have limited break areas been used for whip or jet impingement analyses. Page 3.6-17 will be revised (as attached) to commit Duke to provide an example of limited break areas when used.

Attachment item 20

CNS

- a) Cracks in Duke Class B, C and F piping are postulated at the following locations:
- 1) The terminal ends of the pressurized portions of the run.
 - 2) At intermediate individual locations of potential high stress or fatigue (e.g. pipe fittings, valves, flanges and welded attachments) that result in the maximum effects from fluid spraying, flooding or environmental conditions except in portions of piping where the maximum stress range is less than $0.4 (1.2 S_B + S_A)$ as defined in items b)2)ii) and c)2)ii) of Section 3.6.2.1.2.1.
- b) Cracks in Duke Class E, G and H piping are postulated at the following locations:
- 1) The terminal ends of the pressurized portions of the run.
 - 2) At intermediate individual locations of potential high stress or fatigue (e.g. pipe fittings, valves, flanges and welded attachments) that result in the maximum effects from fluid spraying, flooding or environmental conditions.

3.6.2.1.2.3 Postulated Break Type, Size, and Orientation

a) Circumferential Pipe Breaks

The following circumferential breaks are postulated in high-energy fluid system piping at the locations specified in Section 3.6.2.1.2.1.

- 1) Circumferential breaks are postulated in fluid system piping and branch runs exceeding a nominal pipe size of 1 inch, except where the maximum stress range exceeds the limits of Section 3.6.2.1.2.1, items b) and c)2)ii) but the circumferential stress range is at least 1.5 times the axial stress range.
- 2) Where break locations are selected in fittings in accordance with Section 3.6.2.1.2.1 without the benefit of detailed stress calculations, breaks are postulated at each weld, in piping greater than one inch NPS, to the fitting, valve, or welded attachment. Alternately, a single break location at the section of maximum stress range may be selected as determined by detailed stress analyses or tests on a pipe fitting.
- 3) Circumferential breaks are assumed to result in pipe severance and separation amounting to at least a one-diameter lateral displacement of the ruptured piping sections unless physically limited by piping restraints. *If credit is taken for a limited break area due to piping restraints, then each case will be documented in the file material.*

Item 21 - 3.6.2.1.2.3, page 3.6-18

Identify in Item a)4 where limited pipe displacement, line restrictions, flow limiters, positive pump - controlled flow, and the absence of energy reservoirs are used to reduce the jet discharge.

Response:

Duke provided drawings of limited reservoirs and an analysis example. This information was found acceptable and the item was closed.

Item 22 - 3.6.2.1.2.3, page 3.6-18

In Item a)5 are all possible targets of the whipping pipe examined?

Response:

Duke has unrestrained whipping pipe inside containment as follows:

- A. Two break locations in the normal letdown line from penetration M-347 to the regenerative heat exchanger nozzle D. (2")
- B. One break location in the seal water injection line from penetration M-344 to reactor coolant pump 1C nozzle C. (2")

Please note that both breaks in item A above are inside the regenerative heat exchanger room and thus totally separated from any other systems.

Item 23 - 3.6.2.1.2.3, page 3.6-19

In Item c)4 elaborate on the statement, "Throughwall cracks are not postulated inside containment."

Response:

We will revise page 3.6-19 (as attached) to state that both moderate and high energy leakage cracks are enveloped by high energy line brakes inside containment. For this reason throughwall cracks are not postulated inside containment.

Attachment Item 23

CNS

- 5) Piping movement is assumed to occur in the direction of the jet reaction unless limited by structural members, piping restraints, or piping stiffness as demonstrated by inelastic limit analysis. For the purpose of analysis, breaks are assumed to reach full size one millisecond after break initiation.

c) Through-Wall Leakage Cracks

The following through-wall leakage cracks should be postulated in moderate-energy fluid system piping at the locations specified in Section 3.6.2.1.2.2.

- 1) Cracks are postulated in moderate-energy fluid system piping runs exceeding a nominal pipe size of one inch.
- 2) Fluid flow from a crack is based on a circular opening of area equal to that of a rectangle one-half pipe diameter in length and one-half pipe wall thickness in width.
- 3) The flow from the crack is assumed to result in an environment that wets all unprotected components within the compartment, with consequent flooding in the compartment and communicating compartments.
- 4) Cracks are not postulated in portions of Duke Class B, C, or F piping where the stresses are less than $0.4 (1.2 S_h + S_A)$. Throughwall cracks are not postulated inside containment because environmental consequences are enveloped by high energy circumferential breaks.

3.6.2.1.3

Failure Consequences

The interactions that are evaluated to determine the failure consequences are dependent on the energy level of the contained fluid. They are as follows:

a) High-Energy Piping

1) Circumferential Breaks and Longitudinal Splits

- a) Pipe Whip (displacement)
- b) Jet Impingement
- c) Compartment Pressurization
- d) Flooding
- e) Environmental Effects (Temperature, humidity)

b) Moderate-Energy Piping

1) Through-wall leakage cracks

- a) Flooding
- b) Environmental Effects (Temperature, humidity)
- c) Water Spray

3.6.2.2 Analytical Methods to Define Forcing Functions and Response Models

3.6.2.2.1 Reactor Coolant System Dynamic Analysis

- 2) Throughwall leakage cracks
 - a) Environmental Effects (Temperature, Humidity)
 - b) Flooding

Item 24 - 3.6.2.2.1, page 3.6-21

The computer codes SATAN-IV and THRUST should be included in the list of computer codes in Section 3.9.1.2.3

Response:

In the reactor coolant loop piping analysis the computer codes SATAN IV and STHRUST were used to calculate the blowdown forces for postulated pipe breaks. The computer code THRUST was not used for Catawba. Additionally, the SATAN IV code has been added to the list of codes identified in Section 3.9.1.1. Based on the above discussion and the attached FSAR revisions, this item was resolved.

ATTACHMENT TO ITEM 24

SATAN II - SPACE TIME DEPENDENT ANALYSIS OF LOSS OF COOLANT ACCIDENT THAT TREATS ALL PHASES OF BLOWDOWN LOADS.

CNS

4. STHRUST - hydraulic loads on loop components from blowdown information.
5. WECAN - finite element structural analysis.
6. DARI - WOSTAS - dynamic transient response analysis of reactor vessel and internals.
- 7.

3.9.1.3 Experimental Stress Analysis

No experimental stress analysis methods have been used for the Catawba project.

3.9.1.4 Considerations for the Evaluation of the Faulted Condition

3.9.1.4.1 Loading Conditions

The reactor coolant loop piping is evaluated in accordance with the criteria of ASME III, NB-3650 and Appendix F. The loads included in the evaluation result from the SSE, deadweight, pressure, and LOCA loadings (loop hydraulic forces, asymmetric subcompartment pressurization forces, and reactor vessel motion).

The structural stress analyses performed on the reactor coolant system consider the loadings specified as shown in Table 3.9.1-2. These loads result from thermal expansion, pressure, dead weight, Operating Basis Earthquake (OBE), Safe Shutdown Earthquake (SSE), design basis loss of coolant accident, and plant operational thermal and pressure transients.

3.9.1.4.2 Analysis of the Reactor Coolant Loop

The loads used in the analysis of the reactor coolant loop piping are described in detail below.

Pressure

Pressure loading is identified as either membrane design pressure or general operating pressure, depending upon its application. The membrane design pressure is used in connection with the longitudinal pressure stress and minimum wall thickness calculations in accordance with the ASME Code.

The term operating pressure is used in connection with determination of the system deflections and support forces. The steady-state operating hydraulic forces based on the system initial pressure are applied as general operating pressure loads to the reactor coolant loop model at change in direction or flow area.

Dead Weight

A dead weight analysis is performed to meet Code requirements by applying a 1.0 g load downward on the complete piping system. The piping is assigned a distributed mass or weight as a function of its properties. This method provides a distributed loading to the piping system as a function of the weight of the pipe and contained fluid during normal operating conditions.

Item 25 - 3.6.2.2.2.1, page 3.6-23

Is the discharge coefficient equal to something other than 1.0 for any conditions?

Response:

The discharge coefficient is assumed to be 1.0 in the absence of analytical results or experimental data for calculating the dynamic force of the jet discharge. No values other than 1.0 have been used. If values less than 1.0 are used, justification will be provided in the FSAR.

Item 26 - 3.6.2.2.2.3, page 3.6-25

In the first paragraph, the applicant states that a dynamic load factor of 2.0 shall be used in the absence of an analysis justifying a lower value. What kind of analysis is performed? How low a value is used? Justify any values less than 2.0.

Response:

Duke has not used a value less than 2.0 for dynamic load factor to date. If a lesser value is used in the future, an analytical justification will be provided. This item was closed.

Item 27 - 3.6.2.3.1, page 3.6-25

In Item 1) of General Criteria for Pipe Whip Evaluation, what kind of analysis justifies a value lower than 2.0?

In Item 2) nonlinear pipe and restraint material properties may be used as applicable. Where have nonlinear properties been used and what values are used?

In Item 3) all targets of a whipping pipe must be looked at. Provide assurance that this has been done.

Response:

A lower value than 2.0 is justified in systems where crush pipes are used and a rigorous time history analysis is done (by computer programs viz. PRTHRUST and PIPERUP); and also if the backup structure is shown to be rigid* compared to the crush pipe, in most cases a DLF of less than 2.0 can be anticipated.

*Tests for rigidity for backup structure:

- A) The natural frequency of the backup structure should be more than 33 Hz.
- B) The elastic stiffness of backup structure is at least 3 times that of the crush pipe.

Type of analysis outlined above justifies using a value less than 2. As of this date we have not used a value less than 2.

CNS

The ratio A_i/A_j represents the portion of the total mass flow from the jet which is intercepted by target structure. A dynamic load factor of 2.0 shall be used in the absence of an analysis justifying a lower value.

3.6.2.3 Dynamic Analysis Methods to Verify Integrity and Operability

3.6.2.3.1 General Criteria for Pipe Whip Evaluation

- 1) The dynamic nature of the piping thrust load shall be considered. In the absence of analytical justification, a dynamic load factor of 2.0 is applied in determining piping system response.
- 2) ~~Nonlinear~~ ^(Elastic - perfectly plastic) (elastic-plastic strain hardening) pipe and ~~restraint~~ ^{crushable} material properties may be considered as applicable. *Consideration for crushable materials is described in table 3-6.2-3.*
- 3) Pipe whip is considered to result in unrestrained motion of the pipe along a path governed by the hinge mechanism and the direction of the thrust force. A maximum of 180° rotation may take place about any hinge.
- 4) The effect of rapid strain rate of material properties is considered. A 10 percent increase in yield strength is used to account for strain rate effects.

3.6.2.3.2 Analysis Methods

The pressure time history, jet impingement load on targets, and the thrust resulting from the blowdown of postulated ruptures in piping systems is determined by thermal and hydraulic analyses or conservative simplified analyses.

In general, the loading that may result from a break in piping is determined using either a dynamic blowdown or a conservative static blowdown analysis. The method for analyzing the interaction effects of a whipping pipe with a restraint will be one of the following:

- 1) Equivalent static method
- 2) Lumped parameter method
- 3) Energy balance method

In cases where time history or energy balance method is not used, a conservative static analyses model will be assumed.

The lumped parameter method is carried out by utilizing a lumped mass model. Lumped mass points are interconnected by springs to take into account inertia and stiffness properties of the system. A dynamic forcing function or equivalent static loads may be applied at each postulated break location with unacceptable pipe whip interactions. Clearances and inelastic effects are considered in the analyses.

27

CNS

The energy balance method is based on the principle of conservation of energy. The kinetic energy of the pipe generated during the first quarter cycle of movement is assumed to be converted into equivalent strain energy, which is distributed to the pipe or the support. The strain in the restraint is limited to 50 percent of the ultimate uniform strain.

3.6.2.3.3 Pipe Whip Restraint Design

When required, restraints are designed to protect essential components from the dynamic effects of pipe whip and jet impingement. The loadings on the restraint are determined by one of the methods outlined in Sections 3.6.2.2 and 3.6.2.3. The design of these restraints follows the guidelines of AISC (Ref. 4); however, since pipe rupture is associated with the faulted plant condition, higher stress allowables are permitted as identified in Table 3.6.2-3. Where a restraint is also designed to function as a piping support, the discussion in Section 3.9.3.1.5 is applicable.

Rupture loads with a dynamic load factor of 2.0 shall be added to the faulted loads and the support designed for faulted condition per table 3.9.3-11.

3.6.2.4 Mechanical Penetrations

Mechanical penetrations are treated as fabricated piping assemblies meeting the requirements of ASME Section III, Subsections NC and NE and which are assigned the same classification as the piping system that includes the assembly (i.e., Class A through H as defined in Table 3.2.2-3 except that Class C through H lines are upgraded to Class B between Containment isolation valves).

The process line making up the pressure boundary is consistent with the system piping materials, fabrication, inspection, and analysis requirements of ASME Section III, Subsection NC.

Critical high temperature lines and selected engineered safety system and auxiliary lines (regardless of temperature) require the "Hot Penetration" assembly as shown on Figure 3.6.2-8 which features the exterior guard pipe for the purpose of returning any fluid leakage to the Containment and for protection of other penetrations in the building annular space. Other lines are treated as cold penetrations since a leak into the annular space would not cause a personnel hazard or damage other penetrations in the immediate area.

Penetration assemblies and their anchorages are analyzed in accordance with Table 3.2.2-3 and applicable response spectra curves (0.5 percent damping) as developed from the method described in Section 3.7.2 and enveloped for conservatism. Loading combinations and stress criteria for penetrations are shown in Table 3.6.2-2. The design of guard pipes considers the simultaneous effects of pressure and jet loadings resulting from a rupture within the guard pipe and the SSE loadings.

3.6.2.4.1 General Design Information for All Mechanical Penetrations

The following definitions are utilized to distinguish the categories of mechanical penetrations.

Item 28 - 3.6.2.3.3, page 3.6-26

The last sentence references Section 3.9.3.1.5 for a discussion of where restraints have been designed to function as supports. Provide the design criteria and an example of the analysis techniques used for these dual function supports.

Response:

As mentioned in Section 3.9.3.1.5, Table 3.9.3-11 is used to combine pipe rupture loads with pipe support loads in faulted condition only. A dynamic load factor of 2.0 is used on the pipe rupture loads. The design criteria is same as the pipe-support design in faulted condition.

An example of this design is lower elbow restraint on the main steam system in Reactor Building.

This item is closed.

Item 29 - 3.6.2.4, page 3.6-26

The second paragraph discusses the process pipe making up the pressure boundary.
What size is the process pipe?

Response:

For most cases, size of process pipe would be same as header of main piping where process piping is attached.

Item 30 - 3.6.2.4.2, page 3.6-28

Provide details of field welds between the guard pipe attachment and reactor building anchor section as discussed in Item b.

Response:

Drawings were provided during 4-19-82 review meeting which supply the necessary details.

Item 31 - 3.6.2.4.4, page 3.6-29

This section refers to Section 6.6 for a discussion of access for inservice inspection. Item 3) of Section 6.6.8 (page 6.6-2) indicates that access ports will be provided where possible. In addition to indicating which welds are not examinable because of a lack of access, provide an engineering basis for why the ports are not possible.

Are there any "break exclusion" regions used in any seismic Category I piping systems?

Response:

Refer to the response to item 15. This item was closed.

Item 32 - Table 3.6.1-1

Provide details of the Safety Injection System and Main Steam System relative to the pipe break protection method (c).

Response:

Refer to the response for item 15. This item was closed.

Item 33 - Table 3.6.1-3, page 2

Explain comparison of SAR Section 3.6.1.1.2 with NRC criteria. What analyses have been performed to show insufficient energy to develop sudden failure? In Item a) are the consequences of breaks in the excluded lines considered? What criteria are used to postulate breaks and cracks, and in which systems?

Response:

Regarding the first part of this question, the NRC Staff states in question No. 110.2 of Attachment 1 that it conceded that such systems (in Table 3.6.1-3, page 2 of Catawba FSAR) may not have sufficient energy to develop sudden, catastrophic failures. Regarding the second part, the consequences of these failures are enumerated in FSAR section 3.6.1.1.2.

It is our position that the NRC Staff has accepted the criteria in Table 3.6.1-3, p. 2 provided that all the effects mentioned above are to be included in the station analyses. Since these analyses are specified no further action is required.

Criteria used to postulate breaks for these systems are the same as those used for a moderate energy system. Example: AS System is the only system to which this criteria has been applied (50 psig and 298°F).

Item 33-Attachment #1

ATTACHMENT 1

Review to N.F. 4-5-8
RMS

110 MECHANICAL ENGINEERING BRANCH

110.1
(3.6.1.1) The first paragraph of Section 3.6.1.1.1 (page 3.6-1) implies that precluding the formation of plastic hinges will result in jet impingement effects not causing unacceptable consequences to essential components. Indicate how this is accomplished.
RMS

→ 110.2
(3.6.1.1) The fourth paragraph of Section 3.6.1.1.2 (second full paragraph on page 3.6-2) and Table 3.6.1-3 (pages 2 and 7) indicate that non-liquid piping systems with a pressure less than 275 psig are not considered high energy regardless of the temperature.
(Table 3.6.1-3)
(RSP)

RMS
The staff concedes that such systems may not have sufficient energy to develop sudden, catastrophic failures. However, it is the staff's position that such an approach does not properly consider the consequences should a limited failure occur. These would include jet impingement and the environmental effects of pressure, temperature, humidity, and wetting of equipment. Therefore, either:

- (1) Remove this criteria from the FSAR and provide a commitment to properly evaluate the cases where it was used; or
- (2) As a minimum, provide assurance that the above concerns have been addressed.

110.3
(3.6.1.1) The seventh paragraph of Section 3.6.1.1.2 (fifth full paragraph on page 3.6-2 and item c(4) of section 3.6.1.2.2 (sic)(page 3.6-1b indicate that systems which do not contain mechanical pressurization equipment are not considered moderate energy.
(RSP)

RMS
It is the staff's position that such an approach does not properly consider the consequences should a failure occur. These would include the normal moderate energy effects of flooding, spray, and wetting of equipment. Therefore, provide a commitment to include these systems as moderate energy.

110.4
(3.6.1.1) The first paragraph of item b) of Section 3.6.1.1.2.1 (pages 3.6-2 and 3) is unclear in indicating when jet impingement interactions are considered. In addition to correcting the typographical omission, provide examples of how each of the criteria assures that the safety function is not impaired.
RMS

110.5
(3.6.1.1) The second paragraph of item b) of Section 3.6.1.1.2.1 (first full paragraph on page 3.6-3) indicates that you assume that jet impingement will not effect concrete structural integrity. Provide the basis(es) for this assumption.
RMS

Item 34 - Table 3.6.1-3, pages 2 and 3

This item notes Duke's exception to postulating terminal end breaks at the shut off valve which separates the pressurized and non-pressurized portions of a piping run.

It is the staff's position that this is the only logical location for such a terminal end. Postulating the break elsewhere in the pressurized side limits the length of whipping pipe available. Postulating the break anywhere in the nonpressurized side would not result in a release of energy. Therefore, provide a commitment to meet this position or alternatively, treat the entire piping system as if it were a high energy piping system and postulate breaks and provide protective measures accordingly (i.e., assume the shut off valve to be normally open.)

Response:

A terminal end is considered at piping which is rigidly constrained in regards to thermal expansion. Piping stresses either side of the closed valve will be approximately the same, therefore terminal end classification based on constraint and high stresses is not applicable. If the stress analysis indicates that an intermediate break is required at the valve then the normal analyses will be performed for that break.

Item 35a - Table 3.6.1-3, pages 3 and 4, SAR Section 3.6.2.1.2.1

The criteria is a deviation from the SRP. A minimum of two break locations is required.

Response:

Table 3.6.1-3, pages 3 and 4 will be revised (as attached) to delete the reference to not postulating intermediate breaks in Class B, C piping, where stress intensity is less than $0.4 (1.2 S_h + S_A)$.

to this closed valve.

MEB 3-1, Section B.1.b(6)

Section B.1.b(6) requires that guard pipe assemblies between containment isolation valves meet the following requirements:

- a. The design pressure and temperature should not be less than the maximum operating temperature and pressure of the enclosed pipe under normal plant conditions.
- b. The design stress limits of Paragraph NE-3131(c) should not be exceeded under the loading associated with design pressure and temperature in combination with the safe shutdown earthquakes.
- c. Guard pipe assemblies should be subjected to a single pressure test at a pressure equal to design pressure.

MEB 3-1, Sections B.1.c(1) and B.1.d(1)

Intermediate breaks in Class 2 and 3 piping are postulated where the stresses exceed $0.8 (1.25 S_h + S_A)$ but at not less than two locations based on highest stress. Where the piping consists of a

ting at structure or components that act as rigid constraint to the piping thermal expansion. Typically, the anchors assumed for the code stress analysis would be terminal ends. Stresses in the system either side of the closed valve will be about the same; therefore, terminal end classification based on constraint and high stresses are not applicable. Duke reviews these closed valve locations to assure high stresses are not developed as a result of rigid constraint from nearby anchors of component connections in the non-pressurized portion of the piping.

SAR Section 3.6.2.4

Duke criteria is different from NRC criteria as described and justified below:

Guard pipes provided between containment isolation valves are designed in accordance with SAR Section 3.6.2.4. Guard pipes are subjected to a pressure test as required by the material specification before welding to the penetration assembly.

It is impractical to test guard pipes in the finished penetration assembly due to the configuration and potential damage to internal process pipe and associated insulation. Independent design analysis have been conducted to provide assurance that Duke penetration designs are acceptable. In addition, the extent of NDT conducted on guard pipes to flued head butt weld is such to assure integrity of design.

~~SAR Section 3.6.2.1.2.1~~

~~Duke criteria is different from NRC criteria as described and justified below:~~

~~Intermediate breaks in Class B and C piping are~~

Attachment item 35a

Table 3.6.1-3 (Page 4)

straight run without fittings, welded attachments, and valves, and all stresses are less than $0.8(1.2S_h + S_A)$, a minimum of one location should be chosen based on highest stress.

MEB 3-1, Sections B.1.c(2) and B.1.d(2)

Breaks in non-nuclear piping should be postulated at the following location:

- a. Terminal ends,
- b. At each intermediate pipe fitting, welded attachment, and valve.

MEB 3-1, Section B.2.e

Through-wall cracks may be postulated instead of breaks in those fluid systems that qualify as high energy fluid systems for short operational periods. This operational period is defined as

~~not postulated at locations where the stresses are less than $0.4(1.2S_h + S_A)$. Breaks in such low stressed piping are not considered credible. Breaks are not postulated in straight runs of pipe that contains no fittings, flanges, valves, or welded attachments.~~

SAR Section 3.6.2.1.2.1

Duke criteria is generally equivalent to NRC criteria as described and justified below:

Breaks in Duke Class F piping (non-nuclear, seismic) are postulated at terminal ends and at intermediate locations based on the use of ASME Section III analysis techniques, the same as Duke Class B and C piping. Duke Class F piping is constructed in accordance with ANSI B31.1 and is dynamically analyzed and restrained for seismic loadings similar to ASME Section III piping. Materials are specified, procured, received, stored, and issued under Duke's QA program similar to ASME Section III materials except that certificate of compliance in lieu of mill test reports are acceptable on minor components, and construction documentation for erected materials is not uniquely maintained. Construction documentation for erected materials is generically maintained. MTR are required for the bulk of piping materials.

SAR Section 3.6.1.1.2

Duke criteria is generally equivalent to NRC criteria as clarified below:

The operational period that classifies such sys-

Item 36 - Table 3.6.2-1

In Item 11 are there no intermediate breaks postulated in the pressurizer surge line?

Response:

There are 2 intermediate breaks postulated in the pressurizer surge line. We will revise the title of Table 3.6.2-1 (as attached) to indicate the Table refers to the Main Coolant Loop.

Attachment item 36

Table 3.6.2-1

Postulated Break Locations For The Main
Coolant Loop

<u>Location of Postulated Rupture</u>	<u>Type</u>
1. Reactor Vessel Inlet Nozzle	Circumferential
2. Reactor Vessel Outlet Nozzle	Circumferential
3. Steam Generator Inlet Nozzle	Circumferential
4. Steam Generator Outlet Nozzle	Circumferential
5. Reactor Coolant Pump Inlet Nozzle	Circumferential
6. Reactor Coolant Pump Outlet Nozzle	Circumferential?
7. 50° Elbow on the Intrados	Longitudinal
8. Loop Closure Weld in Crossover Leg	Circumferential
9. Residual Heat Removal (RHR) Line/Primary Coolant Loop Connection	Circumferential (Viewed from the RHR line)
10. Accumulator (ACC) Line/Primary Coolant Loop Connection	Circumferential (Viewed from ACC line)
11. Pressurizer Surge (PS) Line/Primary Coolant Loop Connection	Circumferential (Viewed from the PS line)

Item 37 - Table 3.6.2-2

Are all penetrations Duke Class B? If not, are they evaluated for emergency conditions?

Response:

We will revise Table 3.6.2-2 (as attached) to clarify that no Class 1 piping penetrates containment. All mechanical piping penetrations of the Containment Vessel are Duke Class B. No Class 1 piping is routed through mechanical piping penetrations. When piping, "rated" less than Class B, is routed through the containment vessel the pipe is upgraded to Class B in the area of the penetration.

Table 3.6.2-2

Stress Criteria For
Reactor Containment Mechanical Penetrations
Duke Class B²

<u>CONDITION</u>	<u>PIPING LOADS</u>	<u>CRITERIA</u>
1. Normal	Thermal Displacement +Pressure +Weight	ASME III, NC-3600
2. Upset	Thermal Displacement +OBE (Displacement) +Pressure +Weight +OBE (Inertia)	ASME III, NC-3600
3. Faulted	Thermal Displacement(1) +SSE (Displacement)(1) +Pressure +Weight +SSE (Inertia) +Pipe Rupture	ASME CODE CASE 1606

NOTES:

(1) For the faulted condition, the displacement induced stresses are considered primary stresses.

(2) All mechanical piping penetrations of the Containment Vessel are Duke Class B

Item 38 - Table 3.6.2-3

Define variables -- for example, F_y , F_t , F_e , etc.

Response:

- F_t - Allowable tensile stress
- F_a - Axial stress permitted in the absence of bending moment
- F_b - Bending stress permitted in the absence of axial forces
- F_u - Allowable shear stress
- F_e - Euler stress divided by a factor of safety
- F_y - Minimum yield stress for the type of steel used

Item 39 - Table 3.6.2-3

This table provides stress allowables for pipe rupture restraints.

It is the staff's position that the strain limit for such restraints is one half of the ultimate uniform strain. Therefore, provide assurance that your stress based criteria is always as conservative as the above strain criteria.

Response:

All pipe rupture restraints are elastically designed. The strain ratio of ultimate to elastic limit is approximately 10. Hence, per NRC requirement we can stretch steel up to 5 times beyond elastic limit. Thus, our stress based criteria is at least 5 times more conservative than NRC staff's strain criteria. This item was closed.

Item 40 - Table 3.6.2-6, page 1

Provide stresses for rerouted pipe at break locations 1NI-122-048, -049, -050, and 1NI121-050, -051, -052, -053.

Response:

Table 3.6.2-6, page 1 will be revised (as attached) to include the following information:

<u>Break</u>	<u>Equation 10 (psi)</u>	<u>Equation 12 (psi)</u>	<u>Equation 13 (psi)</u>	<u>Usage Factor</u>
1NI122-048	42763			.0
1NI122-049	41718			.0
1NI122-050	Break Location Deleted			
1NI121-051	37750			.0
1NI121-052	Break Location Deleted			
1NI121-053	37114			.0

TABLE 3.6.2-6 (Page 1)

SUMMARY OF STRESS AT BREAK LOCATIONS
FOR SAFETY INJECTION (SI) LINES FOR UNIT 1
INSIDE CONTAINMENT CLASS A PIPE

Figure No.	Piping Location Figure No. (1)	Break No.	Equation 10 S_n (psi)(2)	Equation 12 S_e (psi)(2)	Equation 13 S (psi)(2)	Usage Factor U(3)	Location Criteria(4)
3.6.2-22	3.6.2-40	1NI-011-023	50326	8211	16373	.001	TE
		1NI-011-024	53425	9274	26321	.0	IB
3.6.2-23	3.6.2-40	1NI-011-025	52020	8749	16797	.002	TE
		1NI-011-026	55695	9993	26892	.0	IB
3.6.2-24	3.6.2-40	1NI-021-028	54862	8735	27790	.0	IB
		1NI-021-029	51532	8162	17107	.0	TE
3.6.2-25	3.6.2-40	1NI-021-030	54846	7119	27023	.0	IB
		1NI-021-031	51580	7950	17009	.0	TE
3.6.2-26	3.6.2-39	1NI-041-032	84692	4364	25455	.052	TE
		1NI-041-033	87185	5787	25029	.039	IB
		1NI-041-034	79707	4636	20724	.029	IB
3.6.2-27	3.6.2-39	1NI-051-036	92327	6798	24421	.080	TE
		1NI-051-037	112005	7931	23147	.065	IB
		1NI-051-038	100676	4689	19469	.043	IB
3.6.2-28	3.6.2-39	1NI-061-040	124248	12745	27228	.190	TE
		1NI-061-041	118472	14571	24454	.099	IB
		1NI-061-042	98044	11940	19452	.075	IB
3.6.2-29	3.6.2-39	1NI-071-044	132715	11719	26915	.177	TE
		1NI-071-045	112511	10545	23931	.078	IB
		1NI-071-046	88980	10197	18580	.061	IB
3.6.2-30	3.6.2-39	1NI-122-048	42763			.0	TE
		1NI-122-049	41718			.0	IB
		1NI-122-050	Break Location Deleted			.0	IB
3.6.2-31	3.6.2-39	1NI-121-051	37750			.0	IB
		1NI-121-052	Break Location Deleted			.0	IB
		1NI-121-053	37114			.0	TE
3.6.2-32	3.6.2-39	1NI-202-054	93031	2304	14886	.607	TE
		1NI-202-055	80517	3532	18132	.128	IB
		1NI-202-056	57726	11606	43883	.024	IB
		1NI-202-057	57121	12380	43782	.025	IB
		1NI-202-058	57171	10933	42538	.023	IB
3.6.2-33	3.6.2-39	1NI-201-059	94158	4676	14617	.742	TE
		1NI-201-060	84588	7048	17392	.205	IB

Attachment from 40

Item 41 - Table 3.6.2-6, pages 1 and 2

What are the allowable stresses?

Response:

<u>Break No.</u>	<u>Allowable Stress (psi)</u>
1NI-011-023	16292
1NI-011-024	15328
1NI-011-025	16292
1NI-011-026	16328
1NI-021-028	16328
1NI-021-029	16292
1NI-021-030	16328
1NI-021-031	16292
1NI-041-032	17387
1NI-041-033	17430
1NI-041-034	17430
1NI-051-036	17430
1NI-051-037	17430
1NI-051-038	17430
1NI-061-040	17387
1NI-061-041	17430
1NI-061-042	17430
1NI-071-044	17387
1NI-071-045	17430
1NI-071-046	17430
1NI-122-048	16328
1NI-122-049	16328
1NI-122-050	Break Location Deleted
1NI-121-051	16328
1NI-121-052	Break Location Deleted
1NI-121-053	16328
1NI-202-054	16820
1NI-202-055	16820
1NI-202-056	16820
1NI-202-057	16820
1NI-202-058	16820
1NI-201-059	16820
1NI-201-060	16820
1NI-215-061	16820
1NI-215-062	16820
1NI-211-063	16820
1NI-211-064	16820
1NI-211-065	16820
1NI-031-066	19982
1NI-031-067	20000
1NI-031-068	20000
1NI-031-069	20000

Item 42 - Table 3.6.2-8, page 4

Provide information on rerouted pipe for break locations noted above.

Response:

Table 3.6.2-8, page 4 will be revised as attached.

TABLE 3.6.2-8 (Page 4)

SUMMARY OF PROTECTIVE REQUIREMENTS INSIDE CONTAINMENT
 CATAWBA NUCLEAR STATION UNIT 1
 PIPING SYSTEM SAFETY INJECTION (NI)

Break No.	Break Type(1)	Thrust Direction(1)	Whip Formed(2)	Effect on Required Components	Acceptable/Unacceptable	Required Fix
INI-071-046	Circ.	Upstream	Yes	Jet impingement on: 3" RTD Line, 3" NC Charging Line Pipe whip into safety related cable trays	Unacceptable due to the loss of minimum engin- eered safety features.	Restraint INI-R-46A
		Downstream	Yes	Jet impingement on: 2" NV Sealwater Line, Safety Related Cable Trays Pipe whip into 3" RTD Line, 3" NC Charging Line	Unacceptable due to more than 120% break propaga- tion in affected loop, loss of minimum engineered safety features	Restraint INI-R-46B
INI-122-048	Circ.	Downstream	No	Jet impingement on: 2" BB Sample Line, Safety Related Cable Trays	Unacceptable due to the loss of minimum engineered safety features	Jet Deflection Shielding Provided
INI-122-049	Circ.	Upstream	No	Jet impingement on: 4" NC Line, 2" RTD Hot Leg, Cranewall.	Unacceptable due to more than 120% break propagation in affected loop.	Jet Deflection Shielding Provided
		Downstream	No	Jet impingement on: 2" NI Line, S.G. 1A Support Struct., 3" RTD Line, 3/4" NC Line, Cranewall	Unacceptable due to more than 120% break propagation in affected loop.	Jet Deflection Shielding Provided
INI-122-050	Break Location Deleted					

Attachment
Item 42

TABLE 3.6.2-8 (Page 4A)

SUMMARY OF PROTECTIVE REQUIREMENTS INSIDE CONTAINMENT
CATAWBA NUCLEAR STATION UNIT 1
PIPING SYSTEM SAFETY INJECTION (NI)

Break No.	Break Type(1)	Thrust Direction(1)	Whip Formed(2)	Effect on Required Components	Acceptable/Unacceptable	Required Fix
INI-121-051	Circ.	Downstream	No	Jet impingement on: 2" BB Sample Line, Safety Related Cable Trays	Unacceptable due to the loss of minimum engineered safety features	Jet Deflection Shielding Provided
INI-121-052	Break Location Deleted					
INI-121-053	Circ.	Upstream	No	Jet impingement on: 3" NC Charging Line, Refueling Tunnel Wall, 1½" NI Boron Line, 2" RTD Line.	Unacceptable due to more than 120% break propa- gation in affected loop	Jet Deflection Shielding Provided
		Downstream	No	Jet impingement on: 2" NI Line, S.G. 1A Support Structure, Cranewall, 3" RTD Line.	Unacceptable due to more than 120% break propagation in affected loop	Jet Deflection Shielding Provided

Item 43 - Figures 3.6.2-6, -7, -8

Provide details of welds in penetration areas.

Response:

Drawings were provided during 4-19-82 review meeting which supplied the necessary details.

Item 44 - 3.7.1.3, page 3.7-3

Justify critical damping values for bolted steel structures.

Response:

This agenda item was deleted.

Item 45 - 3.7.1.3, page 3.7-3

The fourth paragraph discusses the CRDMs and their seismic supports. What portions of the CRDMs are seismically designed?

Response:

As discussed in Item 7, the CRDM pressure housing is an ANS Safety Class 1 and ASME Code Class 1 component which is seismically designed. Additionally, Section 3.9 (Page 3.9-57) identifies the CRDM pressure housing as a Class 1 component. Based on the above discussions and the revisions to Table 3.2.2-2 identified in Item 7, this item was resolved.

Item 46 - 3.7.3, page

What criteria is used for determining significant modes for piping systems?

Response:

Section 3.7.3.8.2, page 3.7-30 of the FSAR defines significant modes as all modes having a period greater than .0303 seconds.

Item 47 - 3.7.2.5, page 3.7-14

The applicant states "When the ground response spectra are used the acceleration values corresponding to 20 Hz are used as a minimum value for the design of piping and components. The acceleration values at 20 Hz are greater than the values corresponding to a rigid system and therefore are conservative." Provide an example for this design method for piping and components.

Response:

The statement cited in the above item was included in the FSAR only to emphasize what acceleration values are used as a minimum. The acceleration values at 20Hz are greater than those above 20 Hz. All seismic analysis problems use the acceleration values at 20 Hz for frequencies above 20 Hz thereby generating conservative results. The acceleration values used for frequencies below 20 Hz relate to the response spectra curves.

Item 48 - 3.7.2.7, page 3.7-15

The method of combining modal responses is acceptable only if the absolute value of "the product of the responses of the modes in each group of closely spaced modes and a coupling factor ϵ " is added to the square root of the sum of the squares of all modes. The equation should be:

$$R_T^2 = \sum_{i=1}^N R_i^2 + 2 \sum_{j=1}^S \sum_{K=M_j}^{N_j} \sum_{\ell=K+1}^{N_j} |R_K R_\ell| \epsilon_{K\ell}$$

Response:

The equation identified in Section 3.7.2.7 contained a typographical error which was discussed and corrected at this meeting. During this discussion it was also agreed that absolute value signs should be added to this equation. The attached FSAR change has been made to Section 3.7.2.7 of the Catawba FSAR to correct this equation. Based on the above and the attached FSAR change, this item was resolved.

ATTACHMENT TO ITEM 48

CNS

3.7.2.7 Combination of Modal Responses

The overall structural response for Duke designed structures is obtained by combining the modal contributions of all the modes considered. This accomplished using the square root of the sum of the squares as discussed in Section 3.7.2.1. The provisions of Regulatory Guide 1.92 are not applicable to the design of the Catawba Nuclear Station structures.

For analysis under the Westinghouse scope, the total unidirectional seismic response is obtained by combining the individual modal responses utilizing the square root of the sum of the squares method. For systems having modes with closely spaced frequencies, this method is modified to include the possible effect of these modes. The groups of closely spaced modes are chosen such that the difference between the frequencies of the first mode and the last mode in the group does not exceed 10 percent of the lower frequency. Groups are formed starting from the lowest frequency and working towards successively higher frequencies. No one frequency is included in more than one group. Combined total response for systems which have such closely spaced modal frequencies is obtained by adding to the square root of the sum of the squares of all modes the product of the responses of the modes in each group of closely spaced modes and a coupling factor ϵ . This can be represented mathematically as:

$$R_T^2 = \sum_{i=1}^N R_i^2 + 2 \sum_{j=1}^S \sum_{K=M_j}^{N_j-1} \sum_{L=K+1}^{N_j} |R_K R_L| \epsilon_{KL}$$

Where:

R_T = total unidirectional response

R_i = absolute value of response of mode i

N = total number of modes considered

S = number of groups of closely spaced modes

M_j = lowest modal number associated with group j of closely spaced modes

N_j = highest modal number associated with group j of closely spaced modes

ϵ_{KL} = coupling factor with

$$\epsilon_{KL} = \left[1 + \left(\frac{\omega_K - \omega_L}{(\beta_K \omega_K + \beta_L \omega_L)} \right)^2 \right]^{-1} \quad (3.7.2-1)$$

Item 49 - 3.7.2.7, page 3.7-15

What is the duration of the operating basis earthquake?

Response:

This item was clarified by the Staff in that the question was directed toward the time duration used for the OBE in the modal response equations contained in Section 3.7.3.1.2 (Pages 3.7-15/16) of the FSAR. Westinghouse indicated that in all cases a minimum of 5 OBE's with a minimum duration of 10 cycles or 10 seconds was used in the analysis of components and piping systems. This minimum duration is consistent with the OBE duration identified in Standard Review Plan 3.7.2. Based on the above discussions, this item was resolved.

Item 50 - 3.7.3.1.2, page 3.7-20

Several referenced figures, Figures 3.7.3-1, 3.7.2-1, are missing. Provide a timetable for their inclusion in the FSAR.

Response:

The referenced figures 3.7.3-1 and 3.7.2-1 are already included.

Item 51 - 3.7.3.2, page 3.7-28

How many earthquake cycles are postulated for BOP piping?

The number of cycles for NSSS components is not given in Table 3.9.1-1 as stated in the first paragraph. Provide this information.

Response:

Page 3.7-28 will be revised (as attached) to include the following:

3.7.3-2 Determination of Number of Earthquake Cycles

(A) NSSS System

Where fatigue analysis of mechanical systems and components within Westinghouse scope are required, Westinghouse specifies, in the equipment specification, the number of cycles of the OBE to be considered. The number of cycles for NSSS components is given in Table 3.9.1-1.

(B) ASME, Section III, Class I piping other than NSSS

For the design of Class I piping, an average of 5 equivalent operational basis earthquakes (OBE) and a total of 200 stress cycles for piping systems will be used for the full plant lifetime. One safe shutdown earthquake (SSE) with 100 stress cycles for piping systems will be used.

Table 3.9.1-1 will be revised (as attached) to provide the missing information (number of cycles for NSSS components).

CNS

F = the total right hand side of the equation of motion (Equation (3.7.3-22) or (3.7.3-23))

$$\Delta t = t_{n+2} - t_{n+1} = t_{n+1} - t_n$$

The value of β is chosen equal to 1/3 in order to provide a margin of numerical stability for nonlinear problems. Since the numerical stability of Equation (3.7.3-24) is mostly determined by the left hand side terms of that equation, the right hand side terms were replaced by F_{n+2} . Furthermore, since the time increment may vary between two successive time substeps, Equation (3.7.3-24) may be modified as follows:

$$\frac{2}{(\Delta t + \Delta t_1)} [M] \left\{ \frac{x_{n+2} - x_{n+1}}{\Delta t} - \frac{x_{n+1} - x_n}{\Delta t_1} \right\} + \frac{1}{(\Delta t + \Delta t_1)} [C] \{x_{n+2} - x_n\}$$

By factoring x_{n+2} , x_{n+1} , and x_n , and rearranging terms, Equation (3.7.3-25) is obtained as follows:

$$\begin{aligned} \{C_5 [M] + C_3 [C] + (1/3) [K]\} \{x_{n+2}\} &= \{F_{n+2}\} \\ &+ \{C_7 [M] - (1/3) [K]\} \{x_{n+1}\} \\ &+ \{C_2 [M] + C_3 [C] - (1/3) [K]\} \{x_n\} \end{aligned} \quad (3.7.3-26)$$

where

$$C_2 = \frac{2}{\Delta t_1 (\Delta t + \Delta t_1)}$$

$$C_3 = \frac{1}{\Delta t + \Delta t_1}$$

$$C_5 = \frac{2}{\Delta t (\Delta t + \Delta t_1)}$$

$$C_7 = C_2 + C_5$$

The above set of simultaneous linear equations is solved to obtain the present values of nodal displacements $\{x_n\}$ in terms of the previous (known) values of the nodal displacements. Since $[M]$, $[C]$, and $[K]$ are included in the equation, they can also be time or displacement dependent.

3.7.3.2 Determination of Number of Earthquake Cycles

Where fatigue analyses of mechanical systems and components within Westinghouse scope are required, Westinghouse specifies, in the equipment specification, the

(A) NSSS System

(B) ASME, Section III, Class I piping other than NSSS

For the design of Class I piping, an average of 3 equivalent operational basis earthquakes (OBE) and a total of 200 stress cycles for piping systems will be used for the full plant lifetime. One safe shutdown earthquake (SSE) with 100 stress cycles for piping systems will be used.

CNS

number of cycles of the OBE to be considered. The number of cycles for NSSS components is given in Table 3.9.1-1. ~~The fatigue analyses are performed and presented as part of the components stress report.~~

~~For Duke Class B, C, and F piping, the number of postulated earthquake cycles is well below the levels for which the stress range reduction factor (f) would have a value other than unity.~~

3.7.3.3 Procedure Used for Modeling

Refer to Section 3.7.3.1.2 for modeling procedures for subsystems in Westinghouse scope of responsibility.

Seismic piping other than the NSSS is analyzed as a number of seismic subsystems. The response of the supporting structure (a seismic system) is an input to these analyses.

3.7.3.4 Basis for Selection of Frequencies

In theory, the seismic response of piping can be reduced by designing it to have a fundamental frequency much different from that of the supporting structure. In application, the range of practical piping frequencies is limited by other factors. Too flexible a system can have excessive sag, weight stresses, and vibration during normal operation; too rigid a system results in a congested and costly array of supports, particularly where thermal expansion is present. For these reasons, the piping typically has some dynamic modes at high - response forcing frequencies of the structure. The piping analysis methods described in Section 3.7.3.8 account for this, and the piping is designed to withstand the resulting loads.

The analysis of equipment subjected to seismic loading in the Westinghouse scope involves several basic steps, the first of which is the establishment of the intensity of the seismic loading. Considering that the seismic input originates at the point of support, the response of the equipment and its associated supports based upon the mass and stiffness characteristics of the system, will determine the seismic accelerations which the equipment must withstand.

Three ranges of equipment/support behavior which affect the magnitude of the seismic acceleration are possible:

1. If the equipment is rigid relative to the structure, the maximum acceleration of the equipment mass approaches that of the structure at the point of equipment support. The equipment acceleration value in this case corresponds to the low-period region of the floor response spectra.
2. If the equipment is very flexible relative to the structure, the equipment will show very little response.
3. If the periods of the equipment and supporting structure are nearly equal, resonance occurs and must be taken into account.

ATTACHMENT TO ITEM 51

Table 3.9.1-1

Page 3

NOTES:

1. This column presents the design transients which have been analyzed for the Class 1 piping systems and the Reactor Coolant nozzles. All transients are assumed to occur at full power except the following:

<u>Plant Condition</u>	<u>Power Level</u>
Heatup/Startup	0%
Cooldown/Shutdown	0%
Unit Loading at 5% per min.	15%
Step Load Increase of 10%	90%
Inadvertent Actuation of SI	0%
All Test Conditions	0%
Steam Line Break	0%

2. Conditions are defined as the following:

Normal - any condition in the course of system startup, operation in the design power range, hot standby and system shutdown, other than Upset, Emergency, Faulted, or Test Conditions.

Upset - any deviation from normal conditions anticipated to occur often enough that design should include a capability to withstand the conditions without operational impairment, including transients caused by a fault in a system component requiring its isolation from the system, transients resulting from any single operator error or control malfunction, and transients caused by a loss of load or power. Upset conditions also include any abnormal incidents not resulting in a forced outage and also forced outages for which the corrective action does not include any repair of mechanical damage.

INSERT A → Emergency - (infrequent incidents) - Those deviations from normal conditions which require shutdown for correction of the conditions or repair of damage in the system. The conditions have a low probability of occurrence but are included to provide assurance that no gross loss of structural integrity will result as a concomitant effect of any damage developed in the system.

Faulted (Limiting Faults) - Those combinations of conditions associated with extremely-low-probability, postulated events whose consequences are such that the integrity and operability of the nuclear station may be impaired to the extent that considerations of public health and safety are involved.

Test - Test conditions are those tests in addition to the 10 hydrostatic or pneumatic tests permitted by NB-6222 and NB-6322 (ASME Section III) including leak tests or subsequent hydrostatic tests.

ATTACHMENT TO ITEM 51

Table 3.9.1-1

Page 4

3. Number of occurrences is the calculated or postulated number of occurrences based on a 40 year plant design life.
4. X - transient analyzed for this system
- - transient not analyzed for this system

- INSERT A -

AS A MINIMUM, 5 OBE'S WERE POSTULATED OVER THE LIFE OF THE PLANT. EACH OBE CONTAINED AT LEAST 10 CYCLES AT MAXIMUM STRESS LEVELS.

Item 52 - 3.7.3.5, page 3.7-29

For which seismic piping has the equivalent static load method of analysis been used? Provide an example of this analysis.

Response:

There has been no use to date of the equivalent static load method of analysis for seismic Category I piping. Page 3.7.29 will be revised (as attached) to commit Duke to provide an example of the equivalent static load method if used for seismic Category I piping.

CNS

In all cases, equipment under earthquake loadings is designed to be within code allowable stresses.

Also, as noted in Section 3.7.3.1, rigid equipment/support systems have natural frequencies greater than 33 Hz.

3.7.3.5 Use of Equivalent Static Load Method of Analysis

For seismic piping, the equivalent static load method involves the multiplication of the total weight of the equipment or component member by the specified seismic acceleration coefficient. The magnitude of the seismic acceleration coefficient is established on the basis of the expected dynamic response characteristics of the component. Components within Westinghouse scope which can be adequately characterized as a single degree of freedom systems are considered to have a modal participation factor of one. Seismic acceleration coefficients for multi-degree of freedom systems which may be in the resonance region of the amplified response spectra curves are increased by 50 percent to account conservatively for the increased modal participation. *If the equivalent*

static load method is used for seismic category I piping, an example will be provided to the NRC.

3.7.3.6 Three Components of Earthquake Motion

Methods used to account for three components of earthquake motion for Westinghouse subsystems are given in Section 3.7.2.6.

For seismic piping other than NSSS, analysis is performed using simultaneous three-direction excitation. Directional responses are combined into a total response by taking the square root of the sum of the squares (SRSS) of individual responses. This method conforms fully to the recommendations of Regulatory Guide 1.92.

3.7.3.7 Combination of Modal Responses

Methods used to combine modal responses for subsystems in Westinghouse's scope of responsibility are given in Section 3.7.2.7.

For seismic piping other than the NSSS, modal responses are combined into a total response by taking the square root of the sum of the squares (SRSS) of individual responses. The responses from groups of closely spaced modes, defined as having frequencies between the lowest frequency in the group and a frequency ten percent higher, are combined by absolute summation; the resulting response for each group is then combined by SRSS with the remaining responses from the modes which are not closely spaced. This method conforms fully to the recommendations of Regulatory Guide 1.92.

3.7.3.8 Analytical Procedures for Piping

The criteria for determining which piping is to be seismic are discussed in Section 3.2.1. All seismic piping is classified Seismic Category I. The specific analytical procedures used in qualifying the pipe depend on its size, temperature, structural frequency, and other factors as discussed in this section.

Item 53 - 3.7.3.8, page 3.7-29

The applicant states that the specific analytical procedures used in qualifying the pipe depend on its size, temperature, structural frequency, and other factors as discussed in this section. What criteria is used in qualifying the pipe?

Response:

Table 3.7.3-1 only lists alternate piping, assuming all other piping to be rigorous piping (analyzed rigorously). The attached matrix is provided as a reference to easily distinguish alternate scope piping from rigorous scope piping.

DESIGN CLASSIFICATION

SIZE	CLASS	TYPE OF ANALYSIS ***		
		SCH.	RIGOROUS ANALYSIS	ALTERNATE ANALYSIS METHODS
TUBING* 1/4" 3/8" 1/2" 3/4"	B, C	ALL ALL ALL ALL	---	ALL ALL ALL ALL
PIPE 1/2" To 1"	A B, C	ALL 10S 40 80 160	ALL ≥ 301° or ≥ 276 PSI ≥ 301° or ≥ 686 PSI ≥ 651° or ≥ 2486 PSI ≥ 651° or ≥ 2486 PSI	--- ≤ 300° and ≤ 275 PSI ≤ 300° and ≤ 685 PSI ≤ 650° and ≤ 2485 PSI ≤ 650° and ≤ 2485 PSI
1 1/2" To 4"	A B, C	ALL 10S 40 80 160	ALL ≥ 301° or ≥ 276 PSI ≥ 301° or ≥ 686 PSI ≥ 301° or ≥ 1486 PSI ≥ 301° or ≥ 1486 PSI	--- ≤ 300° and ≤ 275 PSI ≤ 300° and ≤ 685 PSI ≤ 300° and ≤ 1485 PSI ≤ 300° and ≤ 1485 PSI
5" To 22"	A B C	ALL ALL ALL	ALL ALL ALL	--- --- ---
24" And Larger	A B C	ALL ALL ALL	ALL ALL ALL	--- --- ---

FOOT NOTE

≥ EQUAL TO OR GREATER THAN

≤ EQUAL TO OR LESS THAN

* SAFETY RELATED INSTRUMENT & PROCESS TUBING

** HIGH ENERGY LINES ARE RIGOROUS

*** PIPING WHICH WITHIN THE ALTERNATE ANALYSIS METHODS MAY BE ANALYZED AS RIGOROUS

Item 54 - 3.7.3.8.1, page 3.7-30

A period of 0.033 seconds corresponds to a frequency of 30.3 cps. In Regulatory Guide 1.60 the cutoff is 33 cps. Justify the use of the lower frequency as the cutoff.

Response:

Duke will revise FSAR Sections 3.7.3.8.1 and 3.7.3.8.2 as attached. This change establishes the cutoff between flexible and as 33 cps.

The third paragraph of 3.7.3.8.2 states that typically all modes having a period greater than 0.033 seconds are used in the analysis. The 0.033 seconds should be changed to 0.0303 seconds. All piping analysis work with the exception of Class 2/3 has been analyzed using 0.0303 seconds. The class 2/3 piping has been done using 0.033 seconds and 0.0303 seconds. Our experience has been that there is essentially no difference between analysis work performed with either 0.0303 seconds or 0.033 seconds.

The example problem shown in the FSAR (CAF) was run using 0.033 seconds as a cutoff. The stress ratios and support loads for CAF using 0.0303 seconds as a cutoff are attached to justify the position that there is essentially no difference.

This item was closed.

Attachment item 54

3.7.3.8.1 Static Analysis of Rigid Piping 0.0303

Piping subsystems with a period of less than 0.033 seconds are considered rigid. This piping is designed for a uniform static coefficient equal to the maximum floor acceleration at the appropriate location in the structure.

3.7.3.8.2 Rigorous Analysis of Flexible Piping

Piping subsystems with a period greater than 0.033^{0.0303} seconds are considered flexible. Some of this piping can be handled by the simplified, conservative alternate analysis described in Section 3.7.3.8.3 below. The remaining flexible pipe is analyzed using the modal response spectrum method, as follows:

Each pipe is idealized as a mathematical model consisting of lumped masses connected by elastic members. Lumped masses are located at carefully selected joints in order to adequately represent the dynamic and elastic characteristics of the pipe system. Using the elastic properties of the pipe, the flexibility matrix for the pipe is determined. The flexibility calculations include the effects of the torsional, bending, shear, and axial deformations. In addition, for curved members, the stiffness is decreased in accordance with ASME III for applicable nuclear piping systems.

Once the flexibility and mass matrices of the mathematical model are calculated the frequencies and mode shapes for all significant modes of vibration are 0.0303 determined. Typically, all modes having a period greater than 0.033 seconds are used in the analysis. In cases where the seismic model for a particular pipe is very large, a lesser number of modes may be used, provided the omitted modes lie in the flat region (rigid side) of the applicable response spectrum. This assures that the results include all significant contributions.

The mode shapes and frequencies are solved in accordance with the following equation:

$$(K - \omega_n^2 M) \phi_n = 0$$

in which:

K = square stiffness matrix of the pipe loop

M = mass matrix for the pipe loop

ω_n = frequency for the n^{th} mode

ϕ_n = mode shape matrix of the n^{th} mode

After the frequency is determined for each mode, the corresponding spectral acceleration is read from the appropriate response spectrum for the pipe. Using these spectral accelerations, the response for each mode is found by solving the following equation:

BOX 100 ATUL PATEL *** CH1CAF30-W/ 33 HZ. *** ** * * * C A F * * * * *
AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** * * * REV-3A * * * * *
PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** * * * UNIT-1 * * * * *
WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

* VERIFICATION OF COMPUTER RESULTS *

* THIS COMPUTER ANALYSIS COVERS ITEMS RELATED *
* TO NUCLEAR SAFETY. THE QUALITY HAS BEEN ASS- *
*URED IN ACCORDANCE WITH PROCEDURES SET FORTH *
* IN THE EDS QUALITY ASSURANCE MANUAL ESTABLISHED *
* TO COMPLY WITH THE REQUIREMENTS CONTAIN- *
* ED IN 10 CFR 50, APPENDIX B, AND ASME BOILER *
* AND PRESSURE VESSEL CODE, SECTION III. *

CLASS 2 AND 3 STRESS
SUMMARY

CLASS 2 AND 3 STRESS
SUMMARY

* THE PROGRAM USED HAS BEEN DEVELOPED, DOCUM- *
* ENDED AND VERIFIED FOR PRINCIPAL USE IN ACC- *
* ORDANCE WITH PROCEDURES SET FORTH IN THE EDS *
* QUALITY ASSURANCE MANUAL *

* THE PROGRAM INPUT AND OUTPUT FOR THIS ANAL- *
* YSIS HAVE BEEN PREPARED, CHECKED AND APPROV- *
* ED IN ACCORDANCE WITH PROCEDURES SET FORTH *
* IN THE APPROPRIATE QUALITY ASSURANCE MANUAL *
* AS NOTED BELOW *

* PREPARED BY _____ DATE _____ *

* CHECKED BY _____ DATE _____ *

* APPROVED BY _____ DATE _____ *

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12;RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 8 SUSTAINED LOADS. ALLOWABLE STRESS = 1.05H UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRES (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
1	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3813.56	0.254		
2	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	4177.17	0.278		
3	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	4203.44	0.280		
4	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3892.36	0.259		
5	A2	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	4383.18	0.292		
6	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3839.04	0.256		
7	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3994.86	0.266		
8	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3864.30	0.258		
9	A3	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	4230.71	0.282		
10	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3891.36	0.259		
11	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	4048.98	0.270		
12	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3869.25	0.258		
13	A4	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	4274.94	0.285		
14	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3855.99	0.257		
15L	E01A	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3916.82	0.261		
15W	E01A	A1	AWBW	AWBW	AWBW	1.800	STCK	1800.00	160.0	15000.00	3952.96	0.264		
15R	E01A	E01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	15000.00	3916.82	0.261		
16L	E01B	E01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	15000.00	3908.62	0.261		
16W	E01B	E01	AWBW	AWBW	AWBW	1.800	STCK	1800.00	160.0	15000.00	3941.90	0.263		
16R	E01B	E01	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	3908.62	0.261		
17	A6	1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	15000.00	4102.66	0.274		

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F *** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A *** **
 PROBLEM NO - RCD-6-30-78 AUX-BLDG / INSIDE D.H. *** UNIT-1 *** **
 WT-1, TH-S, SAM-12, RSA-4, ENDFEORC & DSPLJ, ST. CK., RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	CORP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
18			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	3941.13	0.263
19	A7		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4208.68	0.281
20			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	3996.30	0.266
21			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4184.73	0.279
22			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4056.93	0.270
23	AB		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4079.25	0.272
24			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	3909.02	0.261
25			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	3962.04	0.264
26			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4374.48	0.292
27	1		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	5145.82	0.343
28			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4243.94	0.283
29L	C01A		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4019.30	0.268
29W	C01A			AWBW			1.800	STCK	1800.00	160.0		15000.00	4091.30	0.273
29R	C01A	C01	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		15000.00	4019.30	0.268
30L	C01B		C01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		15000.00	4070.63	0.271
30W	C01B			AWBW			1.800	STCK	1800.00	160.0		15000.00	4160.61	0.277
30R	C01B		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4070.63	0.271
31	2		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4215.98	0.281
32L	C02A		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4184.71	0.279
32W	C02A			AWBW			1.800	STCK	1800.00	160.0		15000.00	4314.62	0.288

RUN1 (CONTD.)

BOX 100 ATUL PATEL *** CH1CAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG / INSIDE D.H. ** **
 UNIT-1 ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	STF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
32R	C02A	C02	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		15000.00	4184.71	0.279
33L	C02B	C02	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		15000.00	4158.70	0.277
33W	C02B		AWBW				1.800	STCK	1800.00	160.0		15000.00	4279.50	0.285
33R	C02B	3	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4158.70	0.277
34		3	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4116.21	0.274
35L	C03A	3	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4437.38	0.296
35W	C03A		AWBW				1.800	STCK	1800.00	160.0		15000.00	4655.72	0.310
35R	C03A	C03	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		15000.00	4437.38	0.296
36L	C03B	C03	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		15000.00	4582.80	0.306
36W	C03B		AWBW				1.800	STCK	1800.00	160.0		15000.00	4852.04	0.323
36R	C03B	4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4582.80	0.308
37	3	4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4584.23	0.306
38		4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4408.19	0.294
39		4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4232.35	0.282
40		4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4057.12	0.270
41		4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	3887.02	0.259
42	4	4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	3930.22	0.262
43	5	4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	3949.07	0.263
44	6	4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	3987.08	0.266
45		4	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		15000.00	4024.24	0.268

RUN1
(CONTD.)

04/05/82

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F *** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A *** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** ** **
 WT-1; TH-6; SAM-12-RSA-4; ENDL(FORC & DSPL); ST. CK... RUPTURE AND SUPP. SUMM. *** ** **

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
47	6A	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4061.53	0.271
48L	C04A	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4098.88	0.273
48W	C04A	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4101.04	0.273
48R	C04A	4	BELB	AWBW	AWBW	1.800	STCK	1800.00	160.0			15000.00	4201.65	0.280
49L	C04B	4	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			15000.00	4101.04	0.273
49W	C04B	4	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			15000.00	4450.58	0.297
49R	C04B	5	STRP	AWBW	AWBW	1.800	STCK	1800.00	160.0			15000.00	4673.54	0.312
50	7	5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4450.58	0.297
51		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4917.47	0.328
52		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4022.57	0.268
53		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4047.63	0.270
54	8	5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4017.08	0.268
55L	C05A	5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4121.06	0.275
55W	C05A	5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	3938.76	0.263
55R	C05A	5	STRP	AWBW	AWBW	1.800	STCK	1800.00	160.0			15000.00	3982.58	0.266
56L	C05B	5	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			15000.00	3938.76	0.263
56W	C05B	5	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			15000.00	3890.37	0.259
56R	C05B	5	BELB	AWBW	AWBW	1.800	STCK	1800.00	160.0			15000.00	3917.26	0.261
57		6	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	3890.37	0.259
		6	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			15000.00	4185.46	0.279

BOX 100 ATUL PATEL *** CH1CAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** **
 WT-1, TH-6; SAM-12, RSA-4; ENDL(FORC & DSP); ST. CK.; RUPTURE AND SUPP. SUMM.

TRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CALCULATED STRESS (PSI)	STRESS RATIO
58			6	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	4205.91	0.280
59L	C06A		6	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	3940.99	0.263
59W	C06A			AWBW			1.800	STCK 1800.00	1800.00	160.0		15000.00	3985.59	0.266
59R	C06A		C06	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0		15000.00	3940.99	0.263
60L	C06B		C06	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0		15000.00	3916.75	0.261
60W	C06F			AWBW			1.800	STCK 1800.00	1800.00	160.0		15000.00	3952.86	0.264
60R	C06B		7	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	3916.75	0.261
61	9		7	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	4379.92	0.292
62L	C07A		7	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	3869.78	0.258
62W	C07A			AWBW			1.800	STCK 1800.00	1800.00	160.0		15000.00	3869.47	0.259
62R	C07A		C07	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0		15000.00	3869.78	0.258
63L	C07B		C07	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0		15000.00	3976.93	0.265
63W	C07B			AWBW			1.800	STCK 1800.00	1800.00	160.0		15000.00	4034.12	0.269
63R	C07B		8	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	3976.93	0.265
64			8	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	4312.38	0.287
65			8	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	4407.31	0.294
66L	C08A		8	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0		15000.00	4223.98	0.282
66W	C08A			AWBW			1.800	STCK 1800.00	1800.00	160.0		15000.00	4367.63	0.291
66R	C08A		C08	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0		15000.00	4223.98	0.282
67L	C08B		C08	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0		15000.00	4126.18	0.275

RUN CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-9A ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./ INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDLIFORC & DSPLE; ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
67W	C08B		AWBW	AWBW			1.800	STCK	1800.00	160.0		15000.00	4235.60	0.282
67R	C08B	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	4125.18	0.275
68	10	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	4131.37	0.275
69		9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	4355.30	0.290
70	11	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	4586.81	0.306
71L	C09A	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	4611.94	0.307
71W	C09A		AWBW	AWBW			1.800	STCK	1800.00	160.0		15000.00	4691.37	0.326
71R	C09A	C09	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0		15000.00	4611.94	0.307
72L	C09B	C09	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0		15000.00	4619.23	0.308
72W	C09B		AWBW	AWBW			1.800	STCK	1800.00	160.0		15000.00	4901.22	0.327
72R	C09B	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	4619.23	0.308
73	12	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	4629.39	0.309
74		10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	4843.49	0.323
75		10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	5441.12	0.363
76L	13	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		15000.00	5825.71	0.388
76W	13		AWTT	AWTT			1.900	STCK	1800.00	160.0		15000.00	6580.87	0.445
76R	13	11	VALV	4S160	SA106 B		N/A							
77	14	11	VALV	4S160	SA106 B		N/A							
78L	15	11	VALV	4S160	SA106 B		N/A							
78W	15		AWTT	AWTT			1.900	STCK	1800.00	600.0		15000.00	6027.99	0.402

(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ***
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. ***
 WT-1; IH-6; SAM-12;RSA-4; ENDL(FORC & DSPL); ST,CK... RUPTURE AND SUPP. SUMM. ***
 C A F ***
 REV-3A ***
 UNIT-1 ***

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	STF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
78R	15	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			15000.00	5367.55	0.358
79		12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			15000.00	4739.20	0.316
80	16	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			15000.00	6655.82	0.444
81	16A	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			15000.00	5589.13	0.373
82L	17	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			15000.00	4755.96	0.317
82W	17		AWTT	AWTT		1.900	STCK	1800.00	600.0			15000.00	5156.48	0.344
82R	17	13	VALV	4S160	SA106 B	N/A								
83	18	13	VALV	4S160	SA106 B	N/A								
84L	19	13	VALV	4S160	SA106 B	N/A								
84W	19		AWTT	AWTT		1.900	STCK	1800.00	600.0			15000.00	5758.16	0.384
84R	19	14	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0			15000.00	4330.73	0.289
85L	20	14	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0			15000.00	4371.00	0.291
85W	20		AWTT	AWTT		1.900	STCK	1400.00	600.0			15000.00	7438.09	0.496
85R	20	15	BTEE-R	4S80	SA106 B	N/A								
863L	21	15	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0			15000.00	6616.13	0.443
86BR	21	15	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0			15000.00	6354.75	0.424
87L	22	15	BTEE-R	4S80	SA106 B	N/A								
87W	22		AWBW	AWBW		1.800	STCK	1400.00	600.0			15000.00	6362.84	0.459
87R	22	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	6310.07	0.421
88		16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5953.37	0.397

RUNT
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 IIZ. *** ** * * * C A F ** * * *
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** * * * REV-3A ** * * *
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** * * * UNIT-1 ** * * *
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK ; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MAT NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
RINT (CONTD.)														
		24	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		15000.00	6287.68	0.419
90L	C10A		16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		15000.00	5993.29	0.400
90C	C10A			AWBW	AWBW		1.800	STCK	1400.00	600.0		15000.00	6435.19	0.430
90R	C10A	C10	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0		15000.00	6154.16	0.410
91L	C10B	C10	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0		15000.00	6241.30	0.416
91W	C10B			AWBW	AWBW		1.800	STCK	1400.00	600.0		15000.00	6560.05	0.437
91R	C10B		17	BTEE-R	4S80	SA106 B	N/A							
92BL	25		17	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0		15000.00	6114.55	0.408
92BR	25		17	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0		15000.00	5574.83	0.372
93L	26		17	BTEE-R	4S80	SA106 B	N/A							
93W	26			AWTT	AWTT		1.900	STCK	1400.00	600.0		15000.00	5893.79	0.393
93R	26		18	VALV	4S80	SA106 B	N/A							
94	27		18	VALV	4S80	SA106 B	N/A							
95L	28		18	VALV	4S80	SA106 B	N/A							
95W	28			AWTT	AWTT		1.900	STCK	1400.00	600.0		15000.00	4930.92	0.329
95R	28		19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		15000.00	4654.18	0.324
96	29		19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		15000.00	5034.29	0.336
97L	30		19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		15000.00	5529.21	0.369
97BL	30	74	FTEE-R	4X2-S160	SA105		3.030	STCK	1400.00	600.0		17500.00	6617.86	0.378
97BR	30	74	FTEE-R	4X2-S160	SA105		3.030	STCK	1400.00	600.0		17500.00	6617.95	0.378

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-G-30-78 AUX-BLDG./INSIDE D.H.
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

*** ** **
 ** ** ** C A F ** ** **
 ** ** ** REV-3A ** ** **
 ** ** ** UNIT-1 ** ** **

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME NO.	SOP NAME	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
97R	30	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	5529.26	0.369		
98	30A	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	6270.16	0.418		
99L	31	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	5524.35	0.368		
99W	31	AWTT	AWTT	4S80	SA106 B	1.900	STCK	1400.00	600.0	15000.00	5985.92	0.392		
99R	31	20	VALV	4S80	SA106 B	N/A								
100	32	20	VALV	4S80	SA106 B	N/A								
101L	C11A	20	VALV	4S80	SA106 B	N/A								
101W	C11A	AWTT	AWTT	4S80	SA106 B	1.900	STCK	1400.00	600.0	15000.00	5423.86	0.362		
101R	C11A	C11	BELB	4S80-FL	SA106 B	1.320	STCK	1400.00	600.0	15000.00	5200.09	0.347		
102L	C11B	C11	BELB	4S80-FL	SA106 B	1.320	STCK	1400.00	600.0	15000.00	5206.94	0.347		
102W	C11B	AWBW	AWBW	4S80	SA106 B	1.800	STCK	1400.00	600.0	15000.00	5393.62	0.360		
102R	C11B	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	5206.94	0.347		
103	33A	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	5516.55	0.368		
104L	C70A	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4645.96	0.323		
104W	C70A	AWBW	AWBW	4S80	SA106 B	1.800	STCK	1400.00	600.0	15000.00	4906.29	0.327		
104R	C70A	C70	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	15000.00	4666.97	0.324		
105L	C70B	C70	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	15000.00	4704.66	0.319		
105W	C70B	AWBW	AWBW	4S80	SA106 B	1.800	STCK	1400.00	600.0	15000.00	4807.25	0.320		
105R	C70B	21B	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4772.59	0.318		
106		21B	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4762.64	0.318		

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC. & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM. ** ** **

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.05H UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	STF	LOAD SET	FRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
107L	C71A	21B	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4756.21	0.317		
107W	C71A	AWBW	AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	15000.00	4755.13	0.319		
107R	C71A	C71	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	15000.00	4766.28	0.318		
108L	C71B	C71	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	15000.00	4766.31	0.318		
108W	C71B	AWBW	AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	15000.00	4787.57	0.319		
108R	C71B	21C	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4758.02	0.317		
109	33B	21C	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4774.38	0.318		
110L	C72A	21C	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4810.18	0.321		
110W	C72A	AWBW	AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	15000.00	4857.98	0.324		
110R	C72A	C72	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	15000.00	4826.83	0.322		
111L	C72B	C72	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	15000.00	4893.62	0.326		
111W	C72B	AWBW	AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	15000.00	4938.35	0.329		
111R	C72B	21D	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4869.71	0.325		
112	C72B	21D	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4853.97	0.324		
113L	C73A	21D	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	4842.44	0.323		
113W	C73A	AWBW	AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	15000.00	4901.54	0.327		
113R	C73A	C73	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	15000.00	4863.02	0.324		
114L	C73B	C73	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	15000.00	5166.12	0.344		
114W	C73B	AWBW	AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	15000.00	5266.27	0.351		
114R	C73B	21E	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	15000.00	5112.61	0.341		

RUN (CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 WT-1, TH-6, SAM-12, RSA-4, ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

C A F ***
 REV-3A ***
 UNIT-1 ***

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
115	33	21E	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		15000.00	5322.91	0.355
116	34	21E	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		15000.00	5432.20	0.362
117L	C74A	21E	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		15000.00	5172.48	0.345
117W	C74A		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	5347.09	0.356
117R	C74A	C74	BE 3	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		15000.00	5233.29	0.349
118L	C74B	C74	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		15000.00	4981.37	0.332
118W	C74B		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	5043.95	0.336
118R	C74B	21F	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		15000.00	4947.93	0.330
119L	C75A	21F	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		15000.00	4954.39	0.330
119W	C75A		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	5052.67	0.337
119R	C75A	C75	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		15000.00	4968.62	0.333
120L	C75B	C75	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		15000.00	4831.00	0.322
120W	C75B		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	4863.01	0.324
120R	C75B	21	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		15000.00	4813.90	0.321
121L	C12A	21	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		15000.00	5174.98	0.345
121W	C12A		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	5350.47	0.357
121R	C12A	C12	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		15000.00	5236.10	0.349
122L	C12B	C12	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		15000.00	5309.19	0.354
122W	C12B		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	5438.42	0.363
122R	C12B	22	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		15000.00	5240.13	0.349

RUNT (CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG / INSIDE D.H. ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDF (FORC & DSP); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
123	35	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5244.94	0.350
124L	36	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5248.77	0.350
124BL	36	60	FTEE-R	4X2-S80	SA105	3.030	STCK	1400.00	600.0			17500.00	5960.58	0.342
124BR	36	60	FTEE-R	4X2-S80	SA105	3.030	STCK	1400.00	600.0			17500.00	5751.35	0.329
124R	36	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5147.89	0.343
125L	C13A	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5237.68	0.349
125W	C13A		AWBW	AWBW		1.800	STCK	1400.00	600.0			15000.00	5435.11	0.362
125R	C13A	C13	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0			15000.00	5306.43	0.354
126L	C13B	C13	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0			15000.00	5516.37	0.366
126W	C13B		AWBW	AWBW		1.800	STCK	1400.00	600.0			15000.00	5687.73	0.379
126R	C13B	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5424.80	0.362
127	37	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5424.11	0.362
128	38	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5423.88	0.362
129		23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5420.95	0.361
130L	39	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5418.26	0.361
130W	39		AWBW	AWBW		1.800	STCK	1400.00	600.0			15000.00	5678.69	0.379
130R	39	24	BRCH-B	18X4-S80	SA106 B	N/A								
131	40	24	BRCH-B	18X4-S80	SA106 B	1.000	STCK	1400.00	600.0			15000.00	5356.02	0.358

MAXIMUM STRESS RATIO FOR THIS RUN = 0.496 AT SOP NO. 85W

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
294W	C64A		FILW	FILW	FILW		2.100	STCK	1400.00	600.0		15000.00	4030.15	0.272
294R	C64A	C64	SELB	2S80	SA105		1.786	STCK	1400.00	600.0		17500.00	4040.17	0.231
295L	C64B	C64	SELB	2S80	SA105		1.786	STCK	1400.00	600.0		17500.00	3872.42	0.221
295W	C64B		FILW	FILW			2.100	STCK	1400.00	600.0		15000.00	3882.86	0.259
295R	C64B	77	STRP	2S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	3857.38	0.257
296	93	77	STRP	2S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	4876.63	0.325

RUN9
(CONTD.)

MAXIMUM STRESS RATIO FOR THIS RUN = 0.325 AT SOP NO. 296

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
297	25	78	BTEE-B	4S80	SA106 B		1.128	STCK	1400.00	600.0		15000.00	5269.29	0.351
298L	C36A	78	BTEE-B	4S80	SA106 B		N/A							
298W	C36A		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	5445.85	0.363
298R	C36A	C36	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0		15000.00	5315.37	0.354
299L	C36B	C36	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0		15000.00	5281.34	0.352
299W	C36B		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	5404.91	0.360
299R	C36B	79	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	5215.31	0.348
300L	E36A	79	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	5162.25	0.345
300W	E36A		AWBW	AWBW			1.800	STCK	1400.00	600.0		15000.00	5360.29	0.357
300R	E36A	E36	BFLB	4S80	SA106 B		1.496	STCK	1400.00	600.0		15000.00	5244.26	0.350
301L	E36B	E36	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0		15000.00	5226.34	0.348

RN10

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-9A ***
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ***
 WT-1: IH-6: SAM-12:RSA-4: ENDL(EORC & DSPL): ST,CK.: RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 8 (CONTD.) SUSTAINED LOADS. ALLOWABLE STRESS = 1.0SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	CMP NAME	CMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
301W	E36B		AVBW	AVBW			1.800	STCK	1400.00	600.0		15000.00	5338.73	0.356
301R	E36B	C37	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0		15000.00	5225.34	0.348
302L	C37B	C37	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0		15000.00	5232.90	0.349
302W	C37B		AVBW	AVBW			1.800	STCK	1400.00	600.0		15000.00	5346.62	0.356
302R	C37B	80	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	5172.13	0.345
303		80	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	5086.31	0.339
304L	94A	80	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	4964.32	0.331
304W	94A		AWTT	AWTT			1.900	STCK	1400.00	600.0		15000.00	5087.88	0.339
304R	94A	81	STRP	4S160	SA106 B		1.000	STCK	1400.00	600.0		15000.00	3176.64	0.212
305L	94	81	STRP	4S160	SA106 B		1.000	STCK	1400.00	600.0		15000.00	3211.18	0.214
305W	94		AWTT	AWTT			1.900	STCK	1400.00	600.0		15000.00	3315.34	0.221
305R	94	82	NONS	4S160	SA105		N/A							
306	95	82	NONS	4S160	SA105		N/A							
307L	96	82	NONS	4S160	SA105		N/A							
307W	96		AWTT	AWTT			1.900	STCK	1400.00	600.0		15000.00	3698.88	0.247
307R	96	83	STRP	4S160	SA106 B		1.000	STCK	1400.00	600.0		15000.00	3460.33	0.232
308L	96A	83	STRP	4S160	SA106 B		1.000	STCK	1400.00	600.0		15000.00	3662.68	0.244
308W	96A		AWTT	AWTT			1.900	STCK	1400.00	600.0		15000.00	6044.28	0.403
308R	96A	84	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	5635.48	0.376
309	97	84	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0		15000.00	6199.42	0.413

RN:O
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 UNIT-1 *** ** **
 WT-1; IH-6; SAM-12.RSA-4; ENDFEORC & DSPL; ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
1	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3813.55	0.212		
2	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	4245.43	0.236		
3	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	4280.87	0.238		
4	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3970.16	0.221		
5	A2	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	4502.87	0.250		
6	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3940.49	0.219		
7	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	4084.90	0.227		
8	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3958.98	0.220		
9	A3	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	4355.37	0.242		
10	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3958.92	0.220		
11	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	4104.97	0.228		
12	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3933.03	0.219		
13	A4	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	4339.50	0.241		
14	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3924.37	0.218		
15L	E01A	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3991.70	0.222		
15W	E01A	AWBW	AWBW	AWBW	AWBW	1.800	STCK	1800.00	160.0	17999.98	4054.05	0.225		
15R	E01A	E01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	17999.98	3991.70	0.222		
16L	E01B	E01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	17999.98	3972.49	0.221		
16W	E01B	AWBW	AWBW	AWBW	AWBW	1.800	STCK	1800.00	160.0	17999.98	4028.11	0.224		
16R	E01B	1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	3972.49	0.221		
17	A6	1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	17999.98	4207.61	0.234		

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WI-1, IH-6, SAM-12, RSA-4, ENDL(FORC. & DSPL), ST, CK., RUPTURE AND SUPP. SUPPL.

TRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
18			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4041.26	0.225
19	A7		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4389.32	0.244
20			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4121.66	0.229
21			1	SIRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4364.37	0.242
22			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4351.10	0.242
23	A8		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4491.61	0.250
24			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4216.04	0.234
25			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4521.98	0.251
26			1	STRP	4S160-NI	SA106 B	1.000	SICK	1300.00	160.0		17999.98	5351.36	0.297
27	1		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	6504.77	0.361
28			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5018.11	0.279
29L	C01A		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	6616.54	0.368
29W	C01A			AWBW			1.800	STCK	1800.00	160.0		17999.98	7597.59	0.422
29R	C01A	C01		BELB	4S160-NI	SA106 B	1.037	SICK	1800.00	160.0		17999.98	6616.54	0.368
30L	C01B	C01		BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		17999.98	6612.75	0.378
30W	C01B			AWBW			1.800	STCK	1800.00	160.0		17999.98	7862.47	0.437
30R	C01B		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	6812.75	0.378
31	2		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	6905.54	0.384
32L	C02A		2	SIRP	4S160-NI	SA106 B	1.000	SICK	1800.00	160.0		17999.98	6797.48	0.378
32W	C02A			AWBW			1.800	STCK	1800.00	160.0		17999.98	7841.85	0.436

RUN1
CONTD.)

BOX 100 ATUL PATEL *** CNICAF20-W/ 33 HZ. *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-10 REV-3A ***
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. UNIT-1 ***
 WT-1; IH-6; SAM-12;RSA-4; ENDL(FORC & DSPL); ST,CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
32R	C02A	C02	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	6797.48	0.378
33L	C02B	C02	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	6521.21	0.368
33W	C02B		AWBW			1.800	STCK	1800.00	160.0			17999.98	7603.68	0.422
33R	C02B	3	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	6621.21	0.369
34		3	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5438.95	0.302
35L	C03A	3	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	4729.04	0.263
35W	C03A		AWBW			1.800	STCK	1800.00	160.0			17999.98	5049.46	0.281
35R	C03A	C03	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	4729.04	0.263
36L	C03B	C03	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	5100.18	0.283
36W	C03B		AWBW			1.800	STCK	1800.00	160.0			17999.98	5550.49	0.308
36R	C03B	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5100.18	0.283
37	3	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5418.18	0.301
38		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5483.09	0.305
39		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5300.27	0.299
40		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	4791.29	0.266
41		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	4735.94	0.263
42	4	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5207.35	0.289
43	5	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5226.44	0.290
44	6	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5255.33	0.292
45		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5063.78	0.281

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG / INSIDE D.H. *** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPLE); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
46			4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4759.64	0.264
47	6A		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4405.25	0.250
48L	C04A		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4470.43	0.248
48W	C04A			AWBW			1.800	STCK	1800.00	160.0		17999.98	4700.34	0.261
48R	C04A		C04	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		17999.98	4470.43	0.248
49L	C04B		C04	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		17999.98	4547.71	0.275
49W	C04B			AWBW			1.800	STCK	1800.00	160.0		17999.98	5344.66	0.297
49R	C04B		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	4947.71	0.275
50	7		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5461.62	0.303
51			5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5174.44	0.287
52			5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5567.69	0.316
53			5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5897.44	0.323
54	8		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5992.31	0.327
55L	C05A		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5627.83	0.313
55W	C05A			AWBW			1.800	STCK	1800.00	160.0		17999.98	6252.82	0.348
55R	C05A		C05	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		17999.98	5627.83	0.313
56L	C05B		C05	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0		17999.98	5562.37	0.298
56W	C05B			AWBW			1.800	STCK	1800.00	160.0		17999.98	5904.46	0.328
56R	C05B		6	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5362.37	0.298
57			6	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0		17999.98	5009.43	0.278

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.25H UNLESS MODIFIED

RUN NAME NO.	SOP NAME	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
58		6	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	4654.27	0.259
59L	C06A	6	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	4277.47	0.238
59W	C06A		AWBW											
59R	C06A	C06	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	4439.84	0.247
60L	C06B	C06	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	4243.22	0.236
60W	C06B		AWBW											
60R	C06B	7	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	4243.22	0.236
61		9	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5293.85	0.294
62L	C07A	7	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	4654.37	0.259
62W	C07A		AWBW											
62R	C07A	C07	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	4654.37	0.259
63L	C07B	C07	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	5013.64	0.279
63W	C07B		AWBW											
63R	C07B	8	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5013.64	0.279
64		8	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	5511.93	0.306
65		8	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	6596.92	0.366
66L	C08A	8	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0			17999.98	8205.98	0.456
66W	C08A		AWBW											
66R	C08A	C08	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	9743.32	0.541
67L	C08B	C08	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0			17999.98	8205.98	0.456
												17999.98	7932.39	0.441

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ***
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG /INSIDE D.H. *** UNIT-1 ***
 WT-1: IH-6: SAM-12:RSA-4: ENDLIFORC. & DSP... SI,CK... RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
67W	C08B			AWBW	AWBW		1.800	STCK	1800.00	160.0		17999.98	9373.98	0.521
67R	C08B	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	7932.39	0.441
68	10	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	7352.57	0.408
69		9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	7051.36	0.392
70	11	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	6820.71	0.379
71L	C09A	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	5780.31	0.321
71W	C09A		AWBW	AWBW			1.800	STCK	1800.00	160.0		17999.98	6368.68	0.359
71R	C09A	C09	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0		17999.98	5780.31	0.321
72L	C09B	C09	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0		17999.98	5695.16	0.316
72W	C09B		AWBW	AWBW			1.800	STCK	1800.00	160.0		17999.98	6353.71	0.353
72R	C09B	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	5695.16	0.316
73	12	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	5803.58	0.323
74		10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	6141.31	0.341
75		10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	6936.35	0.385
76L	13	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0		17999.98	7620.58	0.423
76W	13		AWTT	AWTT			1.900	STCK	1800.00	600.0		17999.98	9238.56	0.513
76R	13	11	VALV	4S160	SA106 B		N/A							
77	14	11	VALV	4S160	SA106 B		N/A							
78L	15	11	VALV	4S160	SA106 B		N/A							
78W	15		AWTT	AWTT			1.900	STCK	1800.00	600.0		17999.98	8435.68	0.469

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 UNIT-1, IH-6; SAM-12; RSA-1, ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

TRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
78R	15	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			17999.98	7057.16	0.392
79	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0				17999.98	6211.56	0.345
80	16	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			17999.98	7944.39	0.441
81	16A	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			17999.98	6986.71	0.388
82L	17	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0			17999.98	6262.34	0.348
82W	17		AWTT	AWTT		1.900	STCK	1800.00	600.0			17999.98	7303.08	0.406
82R	17	13	VALV	4S160	SA106 B	N/A								
83	18	13	VALV	4S160	SA106 B	N/A								
84L	19	13	VALV	4S160	SA106 B	N/A								
84W	19		AWTT	AWTT		1.900	STCK	1800.00	600.0			17999.98	8938.36	0.491
84R	19	14	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0			17999.98	6492.28	0.361
85L	20	14	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0			17999.98	6577.45	0.365
85W	20		AWTT	AWTT		1.900	STCK	1400.00	600.0			17999.98	11779.84	0.654
85R	20	15	BTEE-R	4S80	SA106 B	N/A								
86BL	21	15	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0			17999.98	9741.02	0.541
86BR	21	15	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0			17999.98	10158.47	0.564
87L	22	15	BTEE-R	4S80	SA106 B	N/A								
87W	22		AWBW	AWBW		1.800	STCK	1400.00	600.0			17999.98	11708.11	0.650
87R	22	16	SIRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	9884.35	0.549
88	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0				17999.98	7953.77	0.442

RUN1
CONTD.)

BOX 100 ATUL PATEL *** CHICAF30-W/ 33 HZ. *** ** * * * * C A F ** * * * *
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-ID ** * * * * REV-3A ** * * * *
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** * * * * UNIT-1 ** * * * *
 WT-1; IH-6; SAM-12;RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
RUN1 (CONTD.)														
89	24	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	8051.67	0.447
90L	C10A	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	7694.49	0.427
90W	C10A		AWBW	AWBW		1.800	STCK	1400.00	600.0			17999.98	8751.81	0.486
90R	C10A	C10	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0			17999.98	8062.73	0.448
91L	C10B	C10	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0			17999.98	8114.62	0.451
91W	C10B		AWBW	AWBW		1.800	STCK	1400.00	600.0			17999.98	8814.25	0.490
91R	C10B	17	BTEE-R	4S80	SA106 B	N/A								
92BL	25	17	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0			17999.98	7860.06	0.437
92BR	25	17	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0			17999.98	7196.22	0.400
93L	26	17	BTEE-R	4S80	SA106 B	N/A								
93W	26		AWTT	AWTT		1.900	STCK	1400.00	600.0			17999.98	8277.90	0.460
93R	26	18	VALV	4S80	SA106 B	N/A								
94	27	18	VALV	4S80	SA106 B	N/A								
95L	28	18	VALV	4S80	SA106 B	N/A								
95W	28		AWTT	AWTT		1.900	STCK	1400.00	600.0			17999.98	8429.79	0.468
95R	28	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	7309.52	0.406
96	29	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	7779.04	0.432
97L	30	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	8255.38	0.459
97BL	30	74	FTEE-R	4X2-S160	SA105	3.030	STCK	1400.00	600.0			20999.98	12812.60	0.610
97BR	30	74	FTEE-R	4X2-S160	SA105	3.030	STCK	1400.00	600.0			20999.98	12765.56	0.608

BOX 100 ATUL PATEL *** CN1CAF30-M/ 33 HZ *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG. / INSIDE D.H. *** UNIT-1 ** **
 WT-1 TH-6, SAH-12, RSA-4, ENDL(FORC & DSPL); ST. CK., RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.25H UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
97R	30	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	8234.68	0.457
98	30A	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	8975.41	0.499
99L	31	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	8352.44	0.464
99W	31		AWTT	AWTT		1.900	STCK	1400.00	600.0			17999.98	9915.95	0.551
99R	31	20	VALV	4S80	SA106 B	N/A								
100	32	20	VALV	4S80	SA106 B	N/A								
101L	C11A	20	VALV	4S80	SA106 B	N/A								
101W	C11A		AWTT	AWTT		1.900	STCK	1400.00	600.0			17999.98	10086.66	0.560
101R	C11A	C11	BELB	4S80-FL	SA106 B	1.320	STCK	1400.00	600.0			17999.98	8472.23	0.471
102L	C11B	C11	BELB	4S80-FL	SA106 B	1.320	STCK	1400.00	600.0			17999.98	8671.10	0.482
102W	C11B		AWBW	AWBW		1.800	STCK	1400.00	600.0			17999.98	10070.22	0.559
102R	C11B	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	8671.10	0.482
103	33A	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	9054.36	0.503
104L	C70A	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	7792.50	0.433
104W	C70A		AWBW	AWBW		1.800	STCK	1400.00	600.0			17999.98	8864.11	0.494
104R	C70A	C70	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0			17999.98	8172.68	0.454
105L	C70B	C70	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0			17999.98	7654.91	0.425
105W	C70B		AWBW	AWBW		1.800	STCK	1400.00	600.0			17999.98	8261.07	0.459
105R	C70B	21B	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	7330.98	0.407
106		21B	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0			17999.98	6485.95	0.360

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CH1CAF30-W/ 33 HZ. *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ***
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG / INSIDE D.H. *** UNIT-1 ***
 MI-1; IH-6; SAM-12; RSA-4; EHDLI FORC. & DSPL.; ST. CK.; RUPTURE AND SUFP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DGP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
107L	C71A	21B	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	5718.27	0.318
107W	C71A		AWBW	AWBW			1.600	STCK	1400.00	600.0		17999.98	6083.91	0.338
107R	C71A	C71	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	5845.61	0.325
108L	C71B	C71	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	6166.20	0.343
108W	C71B		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	6469.68	0.359
108R	C71B	21C	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6004.02	0.334
109	33B	21C	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6170.90	0.343
110L	C72A	21C	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6387.32	0.355
110W	C72A		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	6987.13	0.388
110R	C72A	C72	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	6596.22	0.366
111L	C72B	C72	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	6746.16	0.375
111W	C72B		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	7167.55	0.398
111R	C72B	21D	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6520.97	0.362
112		21D	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6240.73	0.347
113L	C73A	21D	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6762.23	0.377
113W	C73A		AWBW	AWBW			1.600	STCK	1400.00	600.0		17999.98	7520.25	0.418
113R	C73A	C73	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	7039.26	0.391
114L	C73B	C73	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	7376.01	0.410
114W	C73B		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	7925.46	0.440
114R	C73B	21E	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7082.39	0.393

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** ** **
 UNIT-1 ** ** **
 WT-1; TH-6; SAM-12;RSA-4; ENDL(FORC. & DSPL); SI.CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
115	33	21E	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7207.73	0.400
116	34	21E	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7282.13	0.405
117L	C74A	21E	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6923.33	0.385
117W	C74A		AWBW	AWBW	SA106 B	SA106 B	1.800	STCK	1400.00	600.0		17999.98	7710.74	0.428
117R	C74A	C74	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	7197.57	0.400
118L	C74B	C74	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	6656.96	0.370
118W	C74B		AWBW	AWBW	SA106 B	SA106 B	1.800	STCK	1400.00	600.0		17999.98	7060.22	0.392
118R	C74B	21F	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6441.46	0.358
119L	C75A	21F	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6140.21	0.341
119W	C75A		AWBW	AWBW	SA106 B	SA106 B	1.800	STCK	1400.00	600.0		17999.98	6653.52	0.370
119R	C75A	C75	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	6318.98	0.351
120L	C75B	C75	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	5959.83	0.331
120W	C75B		AWBW	AWBW	SA106 B	SA106 B	1.800	STCK	1400.00	600.0		17999.98	6221.35	0.346
120R	C75B	21	SJRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	5820.08	0.323
121L	C12A	21	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6695.96	0.372
121W	C12A		AWBW	AWBW	SA106 B	SA106 B	1.800	STCK	1400.00	600.0		17999.98	7403.75	0.411
121R	C12A	C12	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	6042.48	0.386
122L	C12B	C12	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	7247.55	0.403
122W	C12B		AWBW	AWBW	SA106 B	SA106 B	1.800	STCK	1400.00	600.0		17999.98	7770.88	0.432
122R	C12B	22	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6967.88	0.387

RUN1
 CONTD.)

90X 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-10 REV-3A ***
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG / INSIDE D.P. ** ** **
 WI-1, IH-6, SAM-12, RSA-4, ENDLIFORC & DSPFL, S.L.C. RUIPURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
123	35	22	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6970.60	0.387
124L	36	22	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6889.95	0.383
124BL	36	60	FTEE-R	4X2-S80	SA105	SA105	3.030	STCK	1400.00	600.0		20999.98	9709.89	0.462
124BR	36	60	FTEE-R	4X2-S80	SA105	SA105	3.030	STCK	1400.00	600.0		20999.98	10135.09	0.483
124R	36	22	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7077.07	0.393
125L	C13A	22	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7144.88	0.397
125W	C13A		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	3009.83	0.445
125R	C13A	C13	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17999.98	7446.12	0.414
126L	C13R	C13	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0		17532.98	7562.82	0.420
126W	C13B		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	8150.25	0.453
126R	C13B	23	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7248.90	0.403
127	37	23	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6999.96	0.389
128	38	23	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6930.05	0.385
129		23	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7217.81	0.401
130L	39	23	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	9025.55	0.501
130W	39		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	10548.73	0.586
130R	39	24	BRCH-B	18X4-S80	SA106 B	SA106 B	N/A							
131	40	24	BRCH-B	18X4-S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	9517.11	0.529

MAXIMUM STRESS RATIO FOR THIS RUN = 0.654 AT SOP NO. 85W

BOX 100 ATUL PATEL *** CHNCAF30 W/ 37 HZ. *** C A F *** ** ** **
 AUXILIARY FIELD WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A *** ** **
 PROJECT NO. -RCO-6-30-78 AUX-BLDG./THE D.H. *** UNIT-1 *** ** **
 WT-1; JH-6; SA1-12; RSA-4; ENDL(EORC & DSFL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DOP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	FRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CRITICAL STRESS (PSI)
294W	C64A		C64	FILW	FILW	SA105	2.100	STCK	1400.00	600.0		17999.98	6071.43
294R	C64A		C64	SELB	2S80	SA105	1.786	STCK	1400.00	600.0		20999.98	5735.93
295L	C64B		C64	SELB	2S80	SA105	1.786	STCK	1400.00	600.0		20999.98	5067.20
295W	C64B		C64	FILW	FILW	SA105	2.100	STCK	1400.00	600.0		17999.98	6229.67
295R	C64B		77	STRP	2S80	SA106 B	1.000	STCK	1400.00	600.0		17999.98	5246.91
296	93		77	STRP	2S80	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6522.63

RUN9
 (CONTD.)

MAXIMUM STRESS RATIO FOR THIS RUN = 0.423 AT SOP NO. 279W

RUN NAME	SOP NO.	DOP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	FRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CRITICAL STRESS (PSI)
297	25		7	BTEE-B	4S80	SA106 B	1.128	STCK	1400.00	600.0		17999.98	6291.77
298L	25A		78	BTEE-B	4S80	SA106 B	N/A						
298W	C36A		C36	AMBW	AMBW	SA106 B	1.800	STCK	1400.00	600.0		17999.98	6678.67
298R	C36A		C36	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0		17999.98	6339.88
299L	C36B		C36	BELB	4S80	SA106 B	1.495	STCK	1400.00	600.0		17999.98	6153.23
299W	C36B		C36	AMBW	AMBW	SA106 B	1.800	STCK	1400.00	600.0		17999.98	6454.22
299R	C36B		79	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		17999.98	5992.50
300L	E36A		79	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		17999.98	5625.04
300W	E36A		C36	AMBW	AMBW	SA106 B	1.800	STCK	1400.00	600.0		17999.98	6223.12
300R	E36A		E36	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0		17999.98	5765.46
301L	E36B		E36	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0		17999.98	5956.57

RN10

BOX 100 ATUL PATEL *** CHICAGO W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-10 ** ** ** REV-2A ** **
 FIGURE NO. 60-78 ABA BLDG./HALL D.H. ** ** ** UNIT-1 ** **
 WT-1, 11-6, SA1-12, RSA-4, LMDL(FORC & DPL), ST. CK., RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SUP NO.	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
301W	E36D		AWDW	AWDW		1.800	STCK	1400.00	600.0		17999.98	6217.42	0.345
301R	E36B	C37	BELB	4S60	SA106 B	1.496	STCK	1400.00	600.0		17999.98	5951.57	0.331
302L	C37B	C37	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0		17999.98	6132.80	0.341
302V	C37B		AWDW	AWDW		1.800	STCK	1400.00	600.0		17999.98	6429.49	0.357
302R	C37B	80	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		17999.98	5974.25	0.332
303		80	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6184.05	0.344
304L	94A	80	STRP	4S60	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6495.71	0.360
304W	94A		AWTT	AWTT		1.900	STCK	1400.00	600.0		17999.98	7255.87	0.403
304R	94A	81	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0		17999.98	4270.40	0.238
305L	94	81	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0		17999.98	4445.02	0.247
305W	94		AWTT	AWTT		1.900	STCK	1400.00	600.0		17999.98	5073.56	0.282
305R	94	82	NONS	4S160	SA105	N/A							
306	95	82	NONS	4S160	SA105	N/A							
307L	96	82	NONS	4S160	SA105	N/A							
307W	96		AWTT	AWTT		1.900	STCK	1400.00	600.0		17999.98	5728.81	0.318
307R	96	83	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0		17999.98	4004.05	0.222
308L	96A	83	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0		17999.98	5160.23	0.287
308W	96A		AWTT	AWTT		1.900	STCK	1400.00	600.0		17999.98	8991.11	0.500
308R	96A	84	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7703.43	0.428
309	97	84	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0		17999.98	8490.49	0.472

RNTO
(CONTD.)

BOX 100 ATRE PATEL *** CRITICAL 30 W/ 33 HZ ***
 AUXILIARY FLOW WATER PUMPS TO STEAM GENERATOR-1D ***
 MODEL NO. C-06-30-78 AXD BELTS / INSIDE D.H. ***
 M-11, U-63, SAE-12, RSA-4, EMBL (FLOIC & DPL); ST. CK.; RUCTURE AND SUPP. SUMM. ***

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.25H UNLESS MODIFIED

RUN NO.	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	FRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CORRECTED STRESS (PSI)	RAIO
310	98	84	STRP	4580	SA106 B	1.000	STCK 1400.00	600.0		17999.98	8700.63	0.493
311L	99	84	STRP	4580	SA106 B	1.000	STCK 1400.00	600.0		17999.98	6121.15	0.340
311W	99		AMBW			1.800	STCK 1400.00	600.0		17999.98	6627.80	0.369
311R	99	85	BRED-E	6X4-S80	SA106 B	2.000	STCK 1400.00	600.0		17999.98	5644.94	0.380
312L	100	85	BRED-E	6X4-S80	SA106 B	2.000	STCK 1400.00	600.0		17999.98	6304.91	0.350
312W	100		AMBW			1.800	STCK 1400.00	600.0		17999.98	6211.17	0.345
312R	100	86	STRP	6580	SA106 B	1.000	STCK 1400.00	600.0		17999.98	5992.43	0.333
313	100A	86	STRP	6580	SA106 B	1.000	STCK 1400.00	600.0		17999.98	6296.63	0.350
314I	C39A	86	STRP	6580	SA106 B	1.000	STCK 1400.00	600.0		17999.98	6511.80	0.362
314W	C38A		AMBW			1.800	STCK 1400.00	600.0		17999.98	6912.32	0.304
314R	C38A	C38	BELB	6580	SA106 B	1.643	STCK 1400.00	600.0		17999.98	6777.41	0.377
315L	C38B	C38	BELB	6580	SA106 B	1.643	STCK 1400.00	600.0		17999.98	6949.57	0.366
315W	C38B		AMBW			1.800	STCK 1400.00	600.0		17999.98	7100.73	0.294
315R	C38B	C7	STRP	6580	SA106 B	1.000	STCK 1400.00	600.0		17999.98	6631.37	0.370
316		87	STRP	6580	SA106 B	1.000	STCK 1400.00	600.0		17999.98	6640.35	0.363
317L	C39A	C7	STRP	6580	SA106 B	1.000	STCK 1400.00	500.0		17999.98	6691.52	0.372
317W	C39A		AMBW			1.800	STCK 1400.00	600.0		17999.98	7155.07	0.299
317R	C39A	C39	BELB	6580	SA106 B	1.643	STCK 1400.00	600.0		17999.98	6998.91	0.309
318L	C39B	C39	BELB	6580	SA106 B	1.643	STCK 1400.00	600.0		17999.98	7026.53	0.300
318W	C39B		AMBW			1.800	STCK 1400.00	600.0		17999.98	7105.28	0.309

RN10
 (CONTD.)

BOX 100 ATUL FATEL *** CHICAGO W/ 03 HZ. *** C A F ** ** **
 AUXILIARY FLOW WATER PUMPS TO STEAM GENERATOR-1D ** ** ** RLV-3A ** ** **
 PUMPER NO. -RCD-0-90-70 ADD-BLDG/INCLUDE D.H. ** ** ** UNIT-1 ** ** **
 WT-1; III-6; SA1-12, R5A-4; EMDL (FORC. & D.S.P.); ST. CLK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.25H UNLESS MODIFIED

RUN NAME	SUP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COEFFIC. STRESS (PSI)
318R	C39B	80	STRP	6580	SA106 B	1.000	STCK	1400.00	600.0	17999.98	6714.00	0.373	
319I	C40A	80	STRP	6580	SA106 B	1.000	STCK	1400.00	600.0	17999.98	6713.83	0.373	
319W	C40A		AWBW			1.800	STCK	1400.00	600.0	17999.98	7185.14	0.399	
319R	C40A	C40	BELB	6580	SA106 F	1.643	STCK	1400.00	600.0	17999.98	7026.41	0.390	
320L	C40B	C40	BELB	6580	SA106 F	1.643	STCK	1400.00	600.0	17999.98	6936.03	0.393	
320W	C40B		AWBW			1.800	STCK	1400.00	600.0	17999.98	7065.99	0.394	
320R	C40B	89	STRP	6580	SA106 B	1.000	STCK	1400.00	600.0	17999.98	6041.19	0.369	
321		89	STRP	6580	SA106 B	1.000	STCK	1400.00	600.0	17999.98	6026.21	0.383	
322	101	89	STRP	6580	SA106 B	1.000	STCK	1400.00	600.0	17999.98	7045.16	0.425	
323L	C41A	89	STRP	6580	SA106 B	1.000	STCK	1400.00	600.0	17999.98	7088.74	0.394	
323W	C41A		AWBW			1.800	STCK	1400.00	600.0	17999.98	7691.19	0.427	
323P	C41A	C41	BELB	6580	SA106 B	1.643	STCK	1400.00	600.0	17999.98	7463.27	0.416	
324L	C41B	C41	BELB	6580	SA106 B	1.643	STCK	1400.00	600.0	17999.98	7545.26	0.419	
324W	C41B		AWBW			1.800	STCK	1400.00	600.0	17999.98	7752.83	0.431	
324R	C41B	90	STRP	6580	SA106 B	1.000	STCK	1400.00	600.0	17999.98	7135.00	0.396	
325L	C42A	90	STRP	6580	SA106 B	1.000	STCK	1400.00	600.0	17999.98	7136.82	0.396	
325W	C42A		AWBW			1.800	STCK	1400.00	500.0	17999.98	7756.08	0.431	
325R	C42A	C42	BELB	6580	SA106 B	1.643	STCK	1400.00	600.0	17999.98	7547.49	0.419	
326L	C42B	C42	BELB	6580	SA106 B	1.643	STCK	1400.00	600.0	17999.99	7641.09	0.425	
326W	C42B		AWBW			1.800	STCK	1400.00	600.0	17999.99	7856.63	0.437	

RN10
 (CONTD.)

*** CHICAGO-97 22 HZ *** C A F ***
 *** AUXILIARY FIELD WATER PUMPS TO STEAM GENERATOR-10 *** REV-3A ***
 *** PROBLEM NO - RCD-6-20-70 AUX-PUMPS / FUELIE D.H. *** UNIT-1 ***
 *** WI-1, TH-6, SAM-12, SSA-4, EHDUCORC & D3PL1; ST. CK.; RUPRUPE AND SUPP. SUPPL. ***

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS, ALLOWABLE STRESS = 1.25H UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRSS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (FSI)	SUPERS FATID
326R	C42B	91	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7212.79	0.401
327L	C43A	91	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7119.45	0.395
327W	C43A		AWDW	AWDW			1.800	STCK	1400.00	600.0		17999.98	7727.24	0.429
327R	C43A	C43	BELB	6580	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	7521.17	0.416
328L	C43B	C43	BELB	6580	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	7683.15	0.427
328W	C43B		AWDW	AWDW			1.000	STCK	1400.00	600.0		17999.98	7904.71	0.439
328R	C43B	92	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7536.51	0.403
329		92	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7314.89	0.409
330	102	92	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7329.50	0.407
331L	C44A	92	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7336.91	0.408
331W	C44A		AWDW	AWDW			1.800	STCK	1400.00	600.0		17999.98	8929.97	0.445
331R	C44A	C44	BELB	6580	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	7795.59	0.413
332L	C44B	C44	BELB	6580	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	8000.29	0.414
332W	C44B		AWDW	AWDW			1.800	STCK	1400.00	600.0		17999.98	8252.16	0.458
332R	C44B	93	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7504.21	0.417
333	103	93	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7532.29	0.420
334	104	93	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7626.01	0.421
335	105	93	STRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7052.45	0.392
336L	C45A	93	SIRP	6580	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7051.97	0.392
336W	C45A		AWDW	AWDW			1.800	STCK	1400.00	600.0		17999.98	7641.40	0.425

RN10
(CONTD.)

BOX 100 AHH PATEL *** CH1CAF30-W/ 30 HZ *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-ID *** REV-3A ** **
 PROBLEM NO. BCD 6-30-78 AUX-DLDG./INSIDE D.H. *** WHIT-1 ** **
 WT-1; TH-5; SAI 12; RSA-4; EMDL(FORC & DSPL); SI, CK, ; RUPTURE AND SUPP. SUMM. ***

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS, ALLOWABLE STRESS = 1.2SH UNIFESS MODIFIED

UNIT NAME	SUP. NO.	DEF. NAME	COUP. NAME	COUP. TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CALCULATED STRESS (PSI)	RATIO
336R	C45A	C45	BELB	6S00	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	7442.03	0.413
337L	C45B	C45	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	7516.01	0.417
337W	C45B		AWDW	AMDW			1.800	STCK	1400.00	600.0		17999.98	7715.02	0.429
337F	C45B	94	STRP	6S00	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7105.39	0.395
336		94	STRP	6S00	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6898.71	0.388
339L	C46A	94	STRP	6S00	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6823.79	0.379
333W	C45A		AWDW	AWDW			1.800	STCK	1400.00	600.0		17999.98	7333.56	0.407
335R	C46A	C46	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	7161.82	0.396
340F	C46B	C46	BFLB	6S90	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	7373.38	0.409
340W	C46B		AWDW	AWDW			1.800	STCK	1400.00	600.0		17999.98	7526.05	0.416
340R	C46B	95	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	6967.09	0.387
341		95	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7229.16	0.402
342		95	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	7673.95	0.426
343L	C47A	95	STRP	6S00	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	8271.07	0.460
343W	C47A		AWDW	AWDW			1.800	STCK	1400.00	600.0		17999.98	9287.32	0.516
343R	C47A	C47	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	6943.02	0.407
344F	C47B	C47	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0		17999.98	8936.98	0.497
344W	C47B		AWDW	AWDW			1.800	STCK	1400.00	600.0		17999.98	9280.71	0.516
344F	C47B	96	STRP	6S90	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	8266.17	0.459
345	107	96	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	9190.31	0.511

RATIO (CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** ** REV-3A ** ** **
 PROBLEM NO. - ICD-6-30-78 AUX-BLDG / INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; EHDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	CORP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	FRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
346L	108	96	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	8825.02	0.490
346UL	108	107	BRCH-R	6X3/4S80	SA105		1.000	STCK	1400.00	600.0		20999.98	8825.02	0.420
346R	108	107	BRCH-R	6X3/4S80	SA105		1.000	STCK	1400.00	600.0		20999.98	8823.27	0.420
346R	108	96	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	8823.27	0.490
347L	C48A	96	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	8114.50	0.451
347W	C48A		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	9075.95	0.504
347R	C48A	C48	BELB	6580	SA106 B		1.643	STCK	1400.00	600.0		17999.98	8752.11	0.456
348L	C48B	C48	BELB	6580	SA106 B		1.643	STCK	1400.00	600.0		17999.98	8312.34	0.462
348W	C48B		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	8594.12	0.477
348R	C48B	97	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	7757.58	0.431
349	106	97	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	7681.04	0.427
350		97	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	7292.62	0.405
351		97	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	7133.37	0.396
352L	C49A	97	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	7153.79	0.397
352W	C49A		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	7779.00	0.432
352R	C49A	C49	BELB	6580	SA106 B		1.643	STCK	1400.00	600.0		17999.98	7560.41	0.420
353L	C49B	C49	BELB	6580	SA106 B		1.643	STCK	1400.00	600.0		17999.98	7449.02	0.414
353W	C49B		AWBW	AWBW			1.800	STCK	1400.00	600.0		17999.98	7648.18	0.425
353R	C49B	98	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	7056.03	0.392
354		98	STRP	6580	SA106 B		1.000	STCK	1400.00	600.0		17999.98	7183.69	0.399

RNTC (CONTD.)

BOX 100 ATW PATL *** CHICAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FIELD WATER PUMPS TO STEAM OPERATOR-1D *** REV-3A ** ** **
 PROJECT NO. -RCD-G-30-70 AUX-BLDG./TIGLIDE D.H. *** UNIT-1 ** ** **
 MT-1, TH-1, SAH-1, RSA-4, FHD(LFORC-A INSEL); ST, CK, RUPTURE APP SUPP SUMM

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOFT NO.	DCP NAME	COIF BARE	COIF TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
	357	C50A	98	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	7029.70	0.391
	358	C50A		AWBW	AMBW		1.800	STCK 1400.00	600.0	600.0		17999.98	7511.59	0.423
	359	C50A	C50	DFLB	6S80	SA106 B	1.643	STCK 1400.00	600.0	600.0		17999.98	7415.62	0.412
	360	C50D	C50	DFLB	6S80	SA106 B	1.643	STCK 1400.00	600.0	600.0		17999.98	7415.99	0.412
	361	C50B		AWBW	AMBW		1.600	STCK 1400.00	600.0	600.0		17999.98	7613.10	0.423
	362	C50B	99	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	7030.90	0.391
	363	T09	99	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	7057.20	0.394
	364	C51A	99	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	7321.83	0.407
	365	C51A	99	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	7752.79	0.432
	366	C51A		AWBW	AMBW		1.800	STCK 1400.00	600.0	600.0		17999.98	8620.15	0.479
	367	C51A	C51	DFLB	6S80	SA106 B	1.643	STCK 1400.00	600.0	600.0		17999.98	8343.41	0.464
	368	C51B	C51	DFLB	6S80	SA106 B	1.643	STCK 1400.00	600.0	600.0		17999.98	8548.37	0.475
	369	C51B		AWBW	AMBW		1.800	STCK 1400.00	600.0	600.0		17999.98	8952.83	0.492
	370	C51P	100	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	7949.23	0.442
	371	110	100	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	7921.28	0.440
	372	111	100	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	7615.60	0.434
	373		100	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	6786.32	0.374
	374	112	100	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	5851.69	0.325
	375	C52A	100	STRP	6S80	SA106 B	1.000	STCK 1400.00	600.0	600.0		17999.98	5865.23	0.326
	376	C52A		AWBW	AMBW		1.800	STCK 1400.00	600.0	600.0		17999.98	6039.44	0.336

RN10
(CONTD.)

11/15/79, AMMAN, B.V. J

BOX 100 AIR FUEL CHICAGO 9/ 13 12 *** C A F ***
 AUXILIARY FIELD VATER PERS TO STEAM CAPTAINOR 10 *** CIV-9A ***
 FUELER NO. - ECD-G-30 78 AUG. 1973 / 11-106 D.H. *** 011-1 ***
 WT. 1. 11-61 SA106A-1; FBDL (EPC-3, EPL); SL. CK.; RUPURE AND SUPP. SUPPL.

STRESS FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.25H UNLESS MODIFIED

UNIT NAME	COMP. NAME	COMP. TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
361R	C52A	C52	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	17999.98	5980.76	0.332
366L	C52B	C52	BELB	6S80	SA106 B	1.613	STCK	1400.00	600.0	17999.98	6264.85	0.349
367U	C52B	AMBW	AMBW			1.800	STCK	1400.00	600.0	17999.98	6372.62	0.354
368R	C52D	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	17999.98	6112.03	0.340
367	113	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	17999.98	6203.20	0.343
360		101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	17999.98	6024.85	0.335
369L	114	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	17999.98	5955.74	0.326
369PL	114		BRCH-R	6X2-S80	SA105	1.508	STCK	1400.00	600.0	20999.98	5932.29	0.282
369R	114		BRCH-R	6X2-S80	SA105	1.508	STCK	1400.00	600.0	20999.98	5929.27	0.282
370L	C52A	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	17999.98	5863.29	0.326
370W	C53A		AMBW	AMBW		1.800	STCK	1400.00	600.0	17999.98	5927.66	0.324
370R	C53A	C53	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	17999.98	5569.72	0.313
371L	C53R	C53	REFR	6S80	SA106 B	1.643	STCK	1400.00	600.0	17999.98	5934.47	0.330
371W	C53R		AMBW	AMBW		1.800	STCK	1400.00	600.0	17999.98	5929.29	0.332
371R	C53B	102	BRED-R	6X4-S80	SA106 B	1.800	STCK	1400.00	600.0	17999.98	5647.76	0.314
372L	113	102	BRED-R	6X4-S80	SA106 B	2.000	STCK	1400.00	600.0	17999.98	5479.59	0.315
372W	115		AWTT	AWTT		2.000	STCK	1400.00	600.0	17999.98	715.00	0.040
372R	115	103	SIRP	4S160	SA106 B	1.900	STCK	1400.00	600.0	17999.98	7035.63	0.391
373	116	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	17999.98	4165.47	0.231
						1.000	STCK	1400.00	600.0	17999.98	4285.61	0.244

END (CONTD.)

BOX 100 ADEL PATEL *** CNICAF30-W/ 23 HZ. *** C A F ** **
 AUXILIARY FIELD WATER PUMPS TO STEAM GENERATOR-1D ** ** ** ELV-3A ** **
 PUMPER NO. -RCO-6-30-78 AUX-BLDG./INSIDE D.H. ** ** ** UNIT-1 ** **
 HT-1, III-6, SAM-12, BSA-4, ENDR.(CORC. & DSPL); SL,CK.; RUPTURE AND SUPP. SUPPL.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SUP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CORRECTED STRESS (PSI)
374L	117	103	STRP	4S160	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	4283.16
374EL	117	120	BRCH-R	4X3/4160	SA105	SA105	1.000	STCK	1400.00	600.0		20999.98	4293.16
374BR	117	120	BRCH-R	4X3/4160	SA105	SA105	1.000	STCK	1400.00	600.0		20999.98	4204.43
374R	117	103	SIRE	4S160	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	4293.43
375L	118	103	STRP	4S160	SA106 B	SA106 B	1.000	STCK	1400.00	600.0		17999.98	4171.87
375W	118		AMBW	AMBW			1.000	STCK	1400.00	600.0		17999.98	4593.89
375R	118	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	4171.87
376	119	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	4095.61
377L	120	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	3930.47
377W	120		AMBW	AMBW			1.800	STCK	1400.00	600.0		19079.98	4200.50
377R	120	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	3800.47
378	120	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	3079.17
379	120	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	3419.31
380	120	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	3415.40
381	121	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	2980.14
382	122	104	STRP	4-PROCES	SA376 IP304	SA376 IP304	1.000	STCK	1400.00	600.0		19079.98	2966.10
382W	122		AMBW	AMBW			1.800	STCK	1400.00	600.0		19079.98	2966.10

MAXIMUM STRESS RATIO FOR THIS RUN = 0.516 AT 50F NO. 343W

RN10
(CONTD.)

BOX 100 ATUL PATE, CHICAGO W/ 33 IZ. *** C A F ** ** **
 ARCHITARY FIBO WATER PUMPS TO STEAM GENERATOR-ID ** ** ** REV-3A ** ** **
 PROGRAM NO. -RCD-6-20-70 AUX-BLEG./INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WF-1; TH-G; SAH-12; RSA-4; EHD; (EOPC & DSEL); SI, CK.; RUPTURE AND SUPP. SUPPL.

STRESSES FOR EQUATION 9 (CONTD.) OCCASIONAL LOADS. ALLOWABLE STRESS = 1.2SH UNLESS MODIFIED

RUN NAME	SOP NO.	DEP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	CUMULATED STRESS (PSI)	STRESS RATIO
RN11	383	119	105	STRP	B-GUARD	SA106 B	1.000	STCK	15.00	300.0		17999.98	248.23	0.014
	384	123	105	STRP	B-GUARD	SA106 B	1.000	STCK	15.00	300.0		17999.98	272.17	0.015
	385		105	STRP	B-GUARD	SA106 B	1.000	STCK	15.00	300.0		17999.98	342.19	0.019
	386	124	105	STRP	B-GUARD	SA106 B	1.000	STCK	15.00	300.0		17999.98	432.76	0.024
	387	124	105	STRP	B-GUARD	SA106 B	1.000	STCK	15.00	300.0		17999.98	1359.74	0.076
	388	125	105	STRP	B-GUARD	SA106 B	1.000	STCK	15.00	300.0		17999.98	661.93	0.037
	389	125	105	STRP	B-GUARD	SA106 B	1.000	STCK	15.00	300.0		17999.98	305.45	0.017
	390	126	105	STRP	B-GUARD	SA106 B	1.000	STCK	15.00	300.0		17999.98	37.22	0.002
	391R	126	106	FLXC	FLEX-COH		N/A							
	390	121	106	FLXC	FLEX-COH		N/A							

MAXIMUM STRESS RATIO FOR THIS RUN = 0.076 AT SOP NO. 386R

RN12	391	108	107	BRCH-B	6X3/4S80	SA105	1.000	STCK	1400.00	600.0		20999.98	9707.79	0.462
	392L	127	107	BRCH-B	6X3/4S80	SA105	N/A							
	392W	127		FILW	FILW		2.100	STCK	1400.00	600.0		17999.98	1400.47	0.779
	393R	127	108	SIRP	3/4S80	SA106 B	1.000	SICK	1400.00	600.0		17999.98	9779.45	0.543
	393L	128	108	STRP	3/4S80	SA106 B	1.000	SICK	1400.00	600.0		17999.98	9000.62	0.515
	393W	128		FILW	FILW		2.100	STCK	1400.00	600.0		17999.98	13225.92	0.735
	393R	126	109	SRED-E	1X3/4S80	SA105	2.250	STCK	1400.00	600.0		20999.98	14000.18	0.667
	394L	C54A	109	SRED-E	1X3/4S80	SA105	2.250	STCK	1400.00	600.0		20999.98	6529.26	0.406

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** ** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.P. ** ** ** UNIT-1 ** ** **
 WT-1. TH-6. SAM-12.RSA-4. ENDL(FORC. & DSPLE). SLCK. RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME NO.	SOP NAME	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
1	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	0.00	0.000	
2	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	29.76	0.001	
3	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	59.51	0.003	
4	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	89.27	0.004	
5	A2	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	119.02	0.005	
6	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	30.53	0.001	
7	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	180.09	0.008	
8	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	329.65	0.015	
9	A3	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	479.21	0.021	
10	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	93.18	0.004	
11	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	665.57	0.030	
12	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	1237.96	0.055	
13	A4	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	1810.34	0.080	
14	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	605.73	0.027	
15L	E01A	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	3011.78	0.134	
15W	E01A	AWBW	AWBW	AWBW	AWBW	1.800	STCK	1800.00	160.0	70.0	22499.98	5421.20	0.241	
15R	E01A	E01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	22499.98	3122.03	0.139	
16L	E01B	E01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	22499.98	2544.79	0.140	
16W	E01B	AWBW	AWBW	AWBW	AWBW	1.800	STCK	1800.00	160.0	70.0	22499.98	5808.01	0.258	
16R	E01B	1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	3226.67	0.143	
17	A6	1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	1631.10	0.072	

RUN1

BOX 100 ATUL PATEL *** CN1CAF30-W, 33 HZ ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 UNIT-1, IH-6; SAM-12;RSA-4; ENDFEORC & DSP1; ST-CK; RUPTURE AND SUPP. SUMM.

*** ** C A F ** **
 ** ** ** REV-3A ** **
 ** ** ** UNIT-1 ** **

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
18			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	376.36	0.017
19	A7		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	2247.00	0.100
20			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	1587.65	0.071
21			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	935.23	0.042
22			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	340.71	0.015
23	A8		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	489.60	0.022
24			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	496.33	0.022
25			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	584.50	0.026
26			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	724.68	0.032
27	1		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	892.68	0.040
28			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	341.78	0.015
29L	C01A		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	375.92	0.017
29W	C01A			AWBW			1.800	STCK	1800.00	160.0	70.0	22499.98	676.66	0.030
29R	C01A	C01		BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	22499.98	389.69	0.017
30L	C01B			BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	22499.98	443.89	0.020
30W	C01B			AWBW			1.800	STCK	1800.00	160.0	70.0	22499.98	770.79	0.034
30R	C01B		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	428.22	0.019
31	2		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	613.90	0.027
32L	C02A		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	22499.98	927.06	0.041
32W	C02A			AWBW			1.800	STCK	1800.00	160.0	70.0	22499.98	1668.70	0.074

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WI-1; IH-6; SAM-12; RSA-4; ENDRLEFORC & DSPLI.; ST.CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
32R	C02A	C02	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0	70.0	22499.98	960.99	0.043
33L	C02B	C02	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0	70.0	22499.98	1003.47	0.043
33W	C02B		AWBW				1.800	STCK	1800.00	160.0	70.0	22499.98	1742.45	0.077
33R	C02B	3	SIRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	968.03	0.043
34		3	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	1124.91	0.050
35L	C03A	3	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	1377.75	0.061
35W	C03A		AWBW				1.800	STCK	1800.00	160.0	70.0	22499.98	2479.95	0.110
35R	C03A	C03	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0	70.0	22499.98	1428.19	0.063
36L	C03B	C03	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0	70.0	22499.98	1414.14	0.063
36W	C03B		AWBW				1.800	STCK	1800.00	160.0	70.0	22499.98	2455.56	0.109
36R	C03B	4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	1364.20	0.061
37	3	4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	1270.40	0.056
38		4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	699.43	0.040
39		4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	580.57	0.026
40		4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	445.39	0.020
41		4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	626.63	0.028
42	4	4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	959.36	0.043
43	5	4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	861.74	0.038
44	6	4	SIRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	671.28	0.030
45		4	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	497.60	0.022

RUN1 (CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-70 AUX-BLDG./INSIDE O.H. *** UNIT-1 ** ** **
 WT-1; IH-6; SAM-12.RSA-4; ENDL(FORC. & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
46			4	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	352.21	0.016	
47		6A	4	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	283.12	0.013	
48L		C04A	4	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	254.30	0.011	
48W		C04A		AWBW			1.800	STCK 1800.00	160.0	70.0	22499.98	457.73	0.020	
48R		C04A	C04	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	160.0	70.0	22499.98	263.60	0.012	
49L		C04B	C04	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	160.0	70.0	22499.98	304.51	0.014	
49W		C04B		AWBW			1.800	STCK 1800.00	160.0	70.0	22499.98	528.77	0.024	
49R		C04B	5	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	293.76	0.013	
50		7	5	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	311.81	0.014	
51			5	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	708.39	0.031	
52			5	STRP	4S160-NI	SA10C B	1.000	STCK 1800.00	160.0	70.0	22499.98	1567.87	0.070	
53			5	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	2443.02	0.109	
54		8	5	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	3321.48	0.148	
55L		C05A	5	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	3545.95	0.156	
55W		C05A		AWBW			1.800	STCK 1800.00	160.0	70.0	22499.98	6382.71	0.284	
55R		C05A	C05	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	160.0	70.0	22499.98	3675.76	0.163	
56L		C05B	C05	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	160.0	70.0	22499.98	3663.87	0.163	
56W		C05B		AWBW			1.800	STCK 1800.00	160.0	70.0	22499.98	6362.07	0.283	
56R		C05B	6	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	3534.49	0.157	
57			6	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	160.0	70.0	22499.98	2791.56	0.124	

RUN1 (CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG / INSIDE D. H. *** UNIT-1 ** ** **
 WT-1; IH-6; SAM-12; RSA-4; ENDL(FORC. & DSPL); ST. CK.; RUPTURE AND SUPP. SUPPL.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
58			6	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	2048.64	0.091
59L	C06A		6	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	1305.73	0.058
59W	C06A			AWBW			1.800	STCK 1800.00	1800.00	160.0	70.0	22499.98	2350.32	0.104
59R	C06A	C06	BELB		4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0	70.0	22499.98	1353.53	0.060
60L	C06B		C06	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0	70.0	22499.98	1341.66	0.060
60W	C06B			AWBW			1.800	STCK 1800.00	1800.00	160.0	70.0	22499.98	2329.70	0.104
60R	C06B		7	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	1294.28	0.058
61	9		7	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	1818.10	0.081
62L	C07A		7	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	535.52	0.024
62W	C07A			AWBW			1.800	STCK 1800.00	1800.00	160.0	70.0	22499.98	963.94	0.043
62R	C07A	C07	BELB		4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0	70.0	22499.98	555.13	0.025
63L	C07B		C07	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0	70.0	22499.98	638.20	0.031
63W	C07B			AWBW			1.800	STCK 1800.00	1800.00	160.0	70.0	22499.98	1212.37	0.054
63R	C07B		8	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	673.54	0.030
64			8	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	370.02	0.016
65			8	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	1061.11	0.048
66L	C08A		8	STRP	4S160-NI	SA106 B	1.000	STCK 1800.00	1800.00	160.0	70.0	22499.98	1818.16	0.081
66W	C08A			AWBW			1.800	STCK 1800.00	1800.00	160.0	70.0	22499.98	3272.69	0.145
66R	C08A	C08	BELB		4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0	70.0	22499.98	1684.72	0.084
67L	C08B		C08	BELB	4S160-NI	SA106 B	1.037	STCK 1800.00	1800.00	160.0	70.0	22499.98	1501.30	0.067

RUN1
CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG /INSIDE D.H.
 UNIT-1 *** ** **
 HT-1; IH-6; SAM-12.RSA-4; ENDL(FORC & DSP) ; ST,CK,; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
67W	C08B		AWBW	AWBW			1.800	STCK	1800.00	160.0	70.0	22499.98	2606.91	0.116
67R	C08B	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	1448.29	0.064
68	10	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	929.33	0.041
69		9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	1345.75	0.060
70	11	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	3605.34	0.160
71L	C09A	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	4137.12	0.184
71W	C09A		AWBW	AWBW			1.800	STCK	1800.00	160.0	70.0	22499.98	7446.82	0.331
71R	C09A	C09	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0	70.0	22499.98	4288.57	0.191
72L	C09B	C09	BE1B	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0	70.0	22499.98	5006.61	0.223
72W	C09B		AWBW	AWBW			1.800	STCK	1800.00	160.0	70.0	22499.98	8693.65	0.386
72R	C09B	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	4829.60	0.215
73	12	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	5098.37	0.227
74		10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	4191.59	0.186
75		10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	3285.72	0.146
76L	13	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	22499.98	2385.55	0.106
76W	13		AWTT	AWTT			1.900	STCK	1800.00	160.0	70.0	22499.98	4532.54	0.201
76R	13	11	VALV	4S160	SA106 B		N/A							
77	14	11	VALV	4S160	SA106 B		N/A							
78L	15	11	VALV	4S160	SA106 B		N/A							
78W	15		AWTT	AWTT			1.900	STCK	1800.00	600.0	70.0	22500.00	3693.83	0.164

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** **
 PROBLEM NO. -KCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** **
 WT-1; TH-6; SA11-12;RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

ESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.05A UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
76R	15	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	22500.00	1944.12	0.086	
79	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	22500.00	1081.96	0.048		
80	16	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	22500.00	656.96	0.029	
81	16A	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	22500.00	852.78	0.038	
82L	17	12	STRP	4S160	SA106 B	1.000	STCK	1600.00	600.0	70.0	22500.00	1149.01	0.051	
82W	17		AWTT	AWTT	SA106 B	1.900	STCK	1800.00	600.0	70.0	22500.00	2183.13	0.097	
82R	17	13	VALV	4S160	SA106 B	N/A								
83	18	13	VALV	4S160	SA106 B	N/A								
84L	19	13	VALV	4S160	SA106 B	N/A								
84W	19		AWTT	AWTT	SA106 B	1.900	STCK	1800.00	600.0	70.0	22500.00	3228.43	0.143	
84R	19	14	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1699.18	0.076	
85L	20	14	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1917.81	0.085	
85W	20		AWTT	AWTT	SA106 B	1.900	STCK	1400.00	600.0	70.0	22500.00	5031.70	0.224	
85R	20	15	BTEE-R	4S80	SA106 B	N/A								
86BL	21	15	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	22500.00	3223.15	0.143	
86BR	21	15	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	22500.00	2427.85	0.108	
87L	22	15	BTEE-R	4S80	SA106 B	N/A								
87W	22		AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	22500.00	3586.05	0.159	
87R	22	16	SIRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1992.25	0.089	
88	16	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1023.30	0.045	

UNT
 (ITD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG / INSIDE D.H. ** ** **
 UNIT-1 ** ** **
 WT-1; TH-6; SA11-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DGP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
89	24	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1664.08	0.074	
90L	C10A	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2065.67	0.093	
90W	C10A		AMBW	AMBW		1.800	STCK	1400.00	600.0	70.0	22500.00	3754.22	0.167	
90R	C10A	C10	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	22500.00	3119.88	0.139	
91L	C10B	C10	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	22500.00	2910.61	0.129	
91W	C10B		AMBW	AMBW		1.800	STCK	1400.00	600.0	70.0	22500.00	3502.40	0.156	
91R	C10B	17	BTEE-R	4S80	SA106 B	N/A								
92BL	25	17	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	22500.00	2979.89	0.132	
92BR	25	17	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	22500.00	2453.37	0.109	
93L	20	17	BTEE-R	4S80	SA106 B	N/A								
93W	26		AWTT	AWTT		1.901	STCK	1400.00	600.0	70.0	22500.00	4314.00	0.192	
93R	26	18	VALV	4S80	SA106 B	N/A								
94	27	18	VALV	4S80	SA106 B	N/A								
95L	28	18	VALV	4S80	SA106 B	N/A								
95W	28		AWTT	AWTT		1.900	STCK	1400.00	600.0	70.0	22500.00	9196.46	0.409	
95R	28	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4840.24	0.215	
96	29	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5665.81	0.252	
97L	30	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4697.18	0.209	
97BL	30	74	FTEE-R	4X2-S160	SA105	3.030	STCK	1400.00	600.0	70.0	26250.00	14231.38	0.542	
97BR	30	74	FTEE-R	4X2-S160	SA105	3.030	STCK	1400.00	600.0	70.0	26250.00	14151.40	0.539	

RUN1
(CONTD.)

*** CNICAF30-W/33 HZ. ***
 *** ATUL PATEL ***
 *** AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ***
 *** PROBLEM NO. - RCD-6-30-7B. AUX-BLDG / INSIDE D.H. ***
 *** WT-1; IH-6; SAM-12; RSA-4; ENDL(FORC. R. DSFL); ST. CK.; RUPTURE AND SUPP. SUMM. ***
 C A F ** ** **
 REV-3A ** ** **
 UNIT-1 ** ** **

TRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION, ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
97R	30	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4670.79	0.208	
98	30A	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4900.94	0.218	
99L	31	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4651.64	0.207	
99W	31		AWTT	AWTT		1.900	STCK	1400.00	600.0	70.0	22500.00	8836.12	0.393	
99R	31	20	VALV	4S80	SA106 B	N/A								
100	32	20	VALV	4S80	SA106 B	N/A								
101L	C11A	20	VALV	4S80	SA106 B	N/A								
101W	C11A		AWTT	AWTT		1.900	STCK	1400.00	600.0	70.0	22500.00	9826.80	0.437	
101R	C11A	C11	BELB	4S80-FL	SA106 B	1.320	STCK	1400.00	600.0	70.0	22500.00	6627.05	0.303	
102L	C11B	C11	BELB	4S80-FL	SA106 B	1.320	STCK	1400.00	600.0	70.0	22500.00	7688.88	0.342	
102W	C11B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	10484.84	0.466	
102R	C11B	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5824.91	0.259	
103	33A	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	6016.26	0.267	
104L	C70A	21A	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4176.37	0.186	
104W	C70A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	7517.47	0.334	
104R	C70A	C70	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	22500.00	6247.28	0.278	
105L	C70B	C70	BELB	4S80	SA106 B	1.495	STCK	1400.00	600.0	70.0	22500.00	4978.36	0.221	
105W	C70B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	5990.56	0.266	
105R	C70B	21B	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	3328.09	0.148	
106		21B	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	3238.56	0.144	

(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG / INSIDE D.H. *** UNIT-1 ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
107L	C71A	21B	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	5710.50	0.254
107W	C71A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	10279.02	0.457
107R	C71A	C71	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	8542.22	0.380
108L	C71B	C71	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	9774.29	0.434
108W	C71B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	11761.60	0.523
108R	C71B	21C	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	6534.22	0.290
109	33B	21C	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	6540.32	0.291
110L	C72A	21C	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	6570.99	0.292
110W	C72A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	11827.79	0.528
110R	C72A	C72	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	9629.30	0.427
111L	C72B	C72	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	8504.27	0.378
111W	C72B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	10233.36	0.455
111R	C72B	21D	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	5685.19	0.253
112		21D	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	1303.90	0.059
113L	C73A	21D	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	5043.04	0.224
113W	C73A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	9031.07	0.404
113R	C73A	C73	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	7516.68	0.335
114L	C73B	C73	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	8666.05	0.386
114W	C73B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	10452.09	0.465
114R	C73B	21E	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	5866.72	0.258

RUN (CONTD.)

04/05/82

11/15/79, AMDAHL REV.1

*** C N1CAE30-W/ 33 HZ. ***
 BOX 100 ATUL PATEL
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 WT-1; IH-6; SAM-12;RSA-4, ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

DCP NAME	COMP TYPE	SECTION NAME	MATERIAL	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
33	21E	STRP	4S80	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00	5705.05	0.254
34	21E	STRP	4S80	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00	5671.27	0.249
C74A	21E	STRP	4S80	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00	5598.45	0.448
C74A	AWBW	AWBW	AWBW	SA106 B	1.800	STCK 1400.00	600.0	70.0	22500.00	10077.21	0.372
C74A	C74	BELB	4S80	SA106 B	1.496	STCK 1400.00	600.0	70.0	22500.00	8374.50	0.309
C74B	C74	BELB	4S80	SA106 B	1.496	STCK 1400.00	600.0	70.0	22500.00	6947.11	0.372
C74B	AWBW	AWBW	AWBW	SA106 B	1.800	STCK 1400.00	600.0	70.0	22500.00	8359.60	0.206
C74B	21F	STRP	4S80	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00	4644.22	0.128
C75A	21F	STRP	4S80	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00	2874.90	0.230
C75A	AWBW	AWBW	AWBW	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00	5174.83	0.191
C75A	C75	BELB	4S80	SA106 B	1.800	STCK 1400.00	600.0	70.0	22500.00	4300.46	0.156
C75B	C75	BELB	4S80	SA106 B	1.496	STCK 1400.00	600.0	70.0	22500.00	3507.49	0.188
C75B	AWBW	AWBW	AWBW	SA106 B	1.496	STCK 1400.00	600.0	70.0	22500.00	4220.64	0.104
C75B	21	STRP	4S80	SA106 B	1.800	STCK 1400.00	600.0	70.0	22500.00	2344.80	0.195
C75B	AWBW	AWBW	AWBW	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00	4388.36	0.351
C75B	21	STRP	4S80	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00	7899.06	0.292
C12A	21	STRP	4S80	SA106 B	1.800	STCK 1400.00	600.0	70.0	22500.00	6564.39	0.350
C12A	AWBW	AWBW	AWBW	SA106 B	1.496	STCK 1400.00	600.0	70.0	22500.00	7886.14	0.422
C12A	C12	BELB	4S80	SA106 B	1.496	STCK 1400.00	600.0	70.0	22500.00	9489.55	0.234
C12B	C12	BELB	4S80	SA106 B	1.800	STCK 1400.00	600.0	70.0	22500.00	5271.96	
C12B	AWBW	AWBW	AWBW	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00		
C12B	22	STRP	4S80	SA106 B	1.000	STCK 1400.00	600.0	70.0	22500.00		

BOX 100 ATUL PATEL *** C N I C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A ***
 PROBLEM NO. -RC9-6-30-78 AUX-BLDG. / INSIDE D.H. UNIT-1 ***
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUPPL.

STRESS: FOR LOCATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.05A UNLESS MODIFIED

RUN NO.	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
123	35	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5454.06	0.242	
124L	36	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5638.30	0.251	
124BL	36	60	TEE-R	4X2-S80	SA105	3.030	STCK	1400.00	600.0	70.0	26250.00	17082.74	0.651	
124BR	36	60	TEE-R	4X2-S80	SA105	3.030	STCK	1400.00	600.0	70.0	26250.00	13670.46	0.521	
124R	36	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4512.05	0.201	
125L	C13A	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5915.99	0.263	
125W	C13A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	10648.78	0.473	
125R	C13A	C13	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	22500.00	8849.50	0.393	
126L	C13B	C13	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	22500.00	9957.33	0.443	
126W	C13B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	11981.86	0.533	
126R	C13B	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	6656.59	0.296	
127	37	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	6650.75	0.296	
128	38	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	6654.99	0.296	
129		23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	7619.95	0.339	
130L	39	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	10215.53	0.454	
130W	39		AWBW	AWBW		1.900	STCK	1400.00	600.0	70.0	22500.00	18387.96	0.817	
130R	39	24	BRCH-B	16X4-S80	SA106 B	N/A								
131	40	24	BRCH-B	16X4-S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	10726.29	0.477	

MAXIMUM STRESS RATIO FOR THIS RUN = 0.817 AT SOP NO. 130W

BOX 100 ATUL PATEL *** CH1CAF30-W/ 33 HZ *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** ** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG / INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
294W	C64A		FILW	FILW	FILW		2.100	STCK	1400.00	600.0	70.0	22500.00	3908.01	0.174
294R	C64A	C64	SELB	2S80	SA105		1.786	STCK	1400.00	600.0	70.0	26250.00	3395.17	0.129
295L	C64B	C64	SELB	2S80	SA105		1.786	STCK	1400.00	600.0	70.0	26250.00	3972.67	0.151
295W	C64B		FILW	FILW			2.100	STCK	1400.00	600.0	70.0	22500.00	4672.13	0.208
295R	C64B	77	STRP	2S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	2172.10	0.097
296	93	77	STRP	2S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	2706.86	0.120

RUN9
(CONTD.)

MAXIMUM STRESS RATIO FOR THIS RUN = 0.535 AT SOP NO. 279W

RN10

297	25	78	BTEE-B	4S80	SA106 B		1.128	STCK	1400.00	600.0	70.0	22500.00	3420.22	0.152
298L	C36A	78	BTEE-B	4S80	SA106 B		N/A							
298W	C36A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	5245.98	0.233
298R	C36A	C36	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	4359.59	0.194
299L	C36B	C36	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	4197.95	0.187
299W	C36B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	5051.48	0.225
299R	C36B	79	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	2806.38	0.125
300L	E36A	79	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	2318.62	0.103
300W	E36A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	4173.52	0.185
300R	E36A	E36	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	3468.34	0.154
301L	E36B	E36	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	2667.96	0.119

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** ** REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./ INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
301W	E36B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	3210.41	0.143
301R	E36B	C37	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	2457.38	0.109
302L	C37B	C37	BELB	4S80	SA106 B		1.496	STCK	1400.00	600.0	70.0	22500.00	2435.47	0.108
302W	C37B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	2930.65	0.130
302R	C37B	80	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	1628.14	0.072
303		80	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	1695.24	0.075
304L	94A	80	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	2304.62	0.102
304W	94A		AWTT	AWTT			1.900	STCK	1400.00	600.0	70.0	22500.00	4378.78	0.195
304R	94A	81	STRP	4S160	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	1668.95	0.074
305L	94	81	STRP	4S160	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	1393.72	0.084
305W	94		AWTT	AWTT			1.900	STCK	1400.00	600.0	70.0	22500.00	3598.07	0.160
305R	94	82	NONS	4S160	SA105		N/A							
306	95	82	NONS	4S160	SA105		N/A							
307L	96	82	NONS	4S160	SA105		N/A							
307W	96		AWTT	AWTT			1.900	STCK	1400.00	600.0	70.0	22500.00	4409.33	0.196
307R	96	83	STRP	4S160	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	2249.73	0.100
308L	96A	83	STRP	4S160	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	2308.84	0.106
308W	96A		AWTT	AWTT			1.900	STCK	1400.00	600.0	70.0	22500.00	6267.54	0.279
308R	96A	84	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	3298.71	0.147
309	97	84	STRP	4S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	22500.00	3702.99	0.165

RN10
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 UNIT-1 *** ** **
 WT-1; SA112; RSA-4; ENDL(EORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0 SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
310	98	84	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4011.43	0.178	
311L	99	84	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1677.07	0.075	
311W	99		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	3018.72	0.134	
311R	99	85	BRED-E	6X4-S80	SA106 B	2.000	STCK	1400.00	600.0	70.0	22500.00	3354.13	0.149	
312L	100	85	BRED-E	6X4-S80	SA106 B	2.000	STCK	1400.00	600.0	70.0	22500.00	1296.02	0.058	
312W	100		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	1166.42	0.052	
312R	100	86	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	648.01	0.029	
313	100A	86	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	950.23	0.042	
314L	C38A	86	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1247.26	0.055	
314W	C38A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	2245.06	0.100	
314R	C38A	C38	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2049.01	0.091	
315L	C38B	C38	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2139.77	0.095	
315W	C38B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	2344.51	0.104	
315R	C38B	87	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1302.51	0.058	
316		87	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	829.19	0.037	
317L	C39A	87	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1030.11	0.046	
317W	C39A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	1854.20	0.082	
317R	C39A	C39	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	1692.28	0.075	
318L	C39B	C39	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	1608.59	0.071	
318W	C39B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	1762.51	0.078	

RN10
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** ** * * * * C A F * * * * *
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** * * * * REV-3A * * * * *
 PROBLEM NO. RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** * * * * UNIT-1 * * * * *
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NC.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
RN10 (CONTD.)														
318R	C39B	88	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	979.17	0.044	
319L	C40A	88	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	976.40	0.043	
319W	C40A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	1757.52	0.078	
319R	C40A	C40	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	1604.04	0.071	
320L	C40B	C40	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	923.38	0.041	
320W	C40B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	1011.73	0.045	
320R	C40B	89	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	562.07	0.025	
321		89	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	467.46	0.021	
322	10J	89	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1215.11	0.054	
323L	C41A	89	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1039.56	0.046	
323W	C41A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	1871.21	0.083	
323R	C41A	C41	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	1707.80	0.076	
324L	C41B	C41	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2134.10	0.095	
324W	C41B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	2338.29	0.104	
324R	C41B	90	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1299.05	0.058	
325L	C42A	90	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1302.87	0.058	
325W	C42A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	2345.17	0.104	
325R	C42A	C42	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2140.37	0.095	
326L	C42B	C42	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2683.41	0.128	
326W	C42B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	3159.30	0.140	

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F *** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A *** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** **
 WT-1, TH-6, SAM-12, RSA-4, ENDFORC & DSPL); ST, CK... RUPTURE AND SUPP. SUMM. *** **

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
326R	C42B	91	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1755.17	0.078
327L	C43A	91	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2764.22	0.123
327W	C43A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	4975.60	0.221
327R	C43A	C43	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	4541.09	0.202
328L	C43B	C43	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	4906.09	0.218
328W	C43B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	5375.52	0.239
328R	C43B	92	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2986.40	0.133
329		92	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2839.66	0.126
330	102	92	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2962.05	0.127
331L	C44A	92	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2859.01	0.127
331W	C44A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	5146.23	0.229
331R	C44A	C44	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	4696.82	0.209
332L	C44B	C44	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	4161.05	0.185
332W	C44B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	4559.20	0.203
332R	C44B	93	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2532.89	0.113
333	103	93	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2429.83	0.108
334	104	93	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2125.47	0.094
335	105	93	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1460.81	0.065
336L	C45A	93	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1427.48	0.063
336W	C45A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	2569.47	0.114

RN10 (CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-10 *** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG / INSIDE D.H. *** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST, CK, ; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
336R	C45A	C45	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2345.08	1.104
337L	C45B	C45	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2209.84	0.098
337W	C45B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	2421.29	0.108
337R	C45B	94	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1345.16	0.060
338		94	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1390.81	0.062
339L	C46A	94	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1532.84	0.068
339W	C46A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	2759.12	0.123
339R	C46A	C46	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2518.18	0.112
340L	C46B	C46	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2169.27	0.096
340W	C46B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	2376.83	0.106
340R	C46B	95	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1320.46	0.059
341		95	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	796.32	0.035
342		95	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1173.69	0.052
343L	C47A	95	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2013.87	0.090
343W	C47A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	3624.97	0.161
343R	C47A	C47	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	3308.41	0.147
344L	C47B	C47	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	3922.53	0.174
344W	C47B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	4297.85	0.191
344R	C47B	96	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2387.69	0.106
345	107	96	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2723.89	0.121

RNTO
CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 WT-1; TH-6; SAM-12; RSA-4; ENDLFORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
336R	C45A	C45	BELB	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2345.08	0.104
337L	C45B	C45	BELB	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2209.84	0.098
337W	C45B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	2421.29	0.108
337R	C45B	94	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1345.16	0.060
338		94	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1390.81	0.062
339L	C46A	94	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1532.84	0.068
339W	C45A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	2759.12	0.123
339R	C46A	C46	BELB	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2518.18	0.112
340L	C45B	C46	BELB	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	2169.27	0.096
340W	C46B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	2376.83	0.106
340R	C46B	95	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1320.46	0.059
341		95	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	796.32	0.035
342		95	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	1173.69	0.052
343L	C47A	95	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2013.87	0.090
343W	C47A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	3624.97	0.161
343R	C47A	C47	BELB	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	3308.41	0.147
344L	C47B	C47	BELB	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	3922.53	0.174
344W	C47B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	4297.85	0.191
344R	C47B	96	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2387.69	0.106
345	107	96	STRP	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2723.89	0.121

RNTD
(CONTD.)

NUCLEAR INC. 11/15/79, AMDAHL REV. 1
 ERPIPE VERS. BOX 100 ATUL PATEL *** CHN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-10 *** REV-3A ** ** **
 PROBLEM NO. -RCD-5-30-76 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WT-11, TH-6, SAM-12, RSA-4, ENDFORC & DSPPL, ST, OK, RUPTURE AND SUPP. SUMM.

RESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
	346L	108	96	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	3040.27	0.135
	346BL	108	107	BRCH-R	6X374580	SA106	1.000	STCK	1400.00	600.0	70.0	26250.00	3040.27	0.116
	346BR	108	107	BRCH-R	6X3/4580	SA106	1.000	STCK	1400.00	600.0	70.0	26250.00	3040.27	0.116
	346R	108	96	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	3040.27	0.135
	347L	C48A	96	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4252.32	0.189
	347W	C48A	96	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	7654.18	0.340
	347R	C48A	C48	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	6935.76	0.310
	348L	C48B	C48	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	8033.80	0.357
	348W	C48B	C48	BELB	6S80	SA106 B	1.800	STCK	1400.00	600.0	70.0	22500.00	6602.50	0.391
	348R	C48B	C48	BELB	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4890.28	0.217
	349	106	97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4819.24	0.214
	350		97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	3417.41	0.152
	351		97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	3611.88	0.161
	352L	C49A	97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5156.68	0.229
	352W	C49A	97	STRP	6S80	SA106 B	1.800	STCK	1400.00	600.0	70.0	22500.00	9282.04	0.413
	352R	C49A	C49	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	8471.46	0.377
	353L	C49B	C49	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	8172.12	0.363
	353W	C49B	C49	BELB	6S80	SA106 B	1.800	STCK	1400.00	600.0	70.0	22500.00	8954.05	0.398
	353R	C49B	98	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4974.48	0.221
	354		98	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	3657.25	0.163

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-ID REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG / INSIDE D.H. UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSP) L. ST. CK. . . RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SUP NO.	DCP NAME	COMP NAME	TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
355L	C50A	98	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5704.00	0.254	
355W	C50A		AWBW	AMBW		1.800	STCK	1400.00	600.0	70.0	22500.00	10267.21	0.456	
355R	C50A	C50	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	9370.60	0.416	
356L	C50B	C50	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	9819.21	0.436	
356W	C50B		AWBW	AMBW		1.800	STCK	1400.00	600.0	70.0	22500.00	10758.75	0.478	
356R	C50B	99	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5977.08	0.266	
357	T09	99	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5601.25	0.249	
358		99	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4871.24	0.216	
359L	C51A	99	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5771.56	0.257	
359W	C51A		AWBW	AMBW		1.800	STCK	1400.00	600.0	70.0	22500.00	10388.82	0.462	
359R	C51A	C51	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	9481.59	0.421	
360L	C51B	C51	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	9744.73	0.433	
360W	C51B		AWBW	AMBW		1.800	STCK	1400.00	600.0	70.0	22500.00	10677.14	0.475	
360R	C51B	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5931.74	0.264	
361	110	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5822.27	0.259	
362	111	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5595.62	0.249	
363		100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4220.06	0.188	
364	112	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4586.01	0.204	
365L	C52A	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4728.18	0.210	
365W	C52A		AWBW	AMBW		1.800	STCK	1400.00	600.0	70.0	22500.00	8510.72	0.378	

RNT0
(CONTD.)

BOX 100 ATUL PATEL
AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
PROBLEM NO. - RCD-6-30-78 AUX-BLDG./INSIDE D.H.
WT-1, TH-6, SAM-12, RSA-4, ENDFORC & DSPL); ST, CK, RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
RNT0 (CONTD.)														
365R	C52A	C52	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	7767.51	0.345
366L	C52B	C52	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	8395.21	0.373
366W	C52B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	9199.59	0.409
366R	C52B	101	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5110.88	0.227
367	113	101	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5069.54	0.225
368		101	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2432.89	0.108
369L	114	101	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2935.19	0.130
369BL	114		BRCH-R	6X2-S80	SA105	SA105	1.508	STCK	1400.00	600.0	70.0	26250.00	4428.90	0.169
369BR	114		BRCH-R	6X2-S80	SA105	SA105	1.508	STCK	1400.00	600.0	70.0	26250.00	3635.18	0.139
369R	114	101	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	2410.64	0.107
370L	C53A	101	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	3241.95	0.144
370W	C53A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	5835.51	0.259
370R	C53A	C53	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	22500.00	5307.57	0.236
371L	C53B	C53	BELB	6S80	SA106 B	SA106 B	1.543	STCK	1400.00	600.0	70.0	22500.00	5347.22	0.238
371W	C53B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	22500.00	5858.86	0.260
371R	C53B	102	BRED-R	6X4-S80	SA106 B	SA106 B	2.000	STCK	1400.00	600.0	70.0	22500.00	6509.84	0.289
372L	115	102	BRED-R	6X4-S80	SA106 B	SA106 B	2.000	STCK	1400.00	600.0	70.0	22500.00	15423.65	0.685
372W	115		AWTT	AWTT			1.900	STCK	1400.00	600.0	70.0	22500.00	14652.46	0.651
372R	115	103	STRP	4S160	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5584.71	0.248
373	116	103	STRP	4S160	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	5298.46	0.235

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** ** **
 UNIT-1 *** ** **
 WT-1; IH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTD.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
374L	117	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4939.11	0.220	
374BL	117	120	BRCH-R	4X3/4160	SA105	1.000	STCK	1400.00	600.0	70.0	26250.00	4939.11	0.188	
374BR	117	120	BRCH-R	4X3/4160	SA105	1.000	STCK	1400.00	600.0	70.0	26250.00	4944.90	0.188	
374R	117	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4944.90	0.220	
375L	118	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	4536.29	0.202	
375W	118		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	22500.00	8165.33	0.363	
375R	118	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	4655.68	0.169	
376L	119	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	4176.13	0.152	
376R	119	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	426.79	0.015	
377L	120	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	403.62	0.015	
377W	120		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	27474.99	726.52	0.026	
377R	120	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	403.62	0.015	
378		104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	302.67	0.011	
379		104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	201.71	0.007	
380		104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	100.76	0.004	
381		121	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	0.20	0.000
382		122	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	27474.99	0.00	0.000
382W	122		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	27474.99	0.00	0.000	

MAXIMUM STRESS RATIO FOR THIS RUN = 0.685 AT SOP NO. 372L

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** ** ** UNIT 1 ** ** **
 WT-1, TH-6, SAM-12, RSA-4, ENCL (FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 10 (CONTO.) THERMAL EXPANSION. ALLOWABLE STRESS = 1.0SA UNLESS MODIFIED

RUN NAME NO.	SOP NO.	DCP NAME	CORP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
383	110	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	22500.00	601.88	0.027
384	123	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	22500.00	599.30	0.027
385	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	15.00	300.0	70.0	22500.00	999.93	0.044
386L	124	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	22500.00	1622.70	0.072
386R	124	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	22500.00	38.96	0.002
387	125	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	22500.00	23.77	0.001
388	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	15.00	300.0	70.0	22500.00	11.90	0.001
389L	126	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	22500.00	0.03	0.000
389R	126	106	FLXC	FLEX-CGN	N/A								
390	121	106	FLXC	FLEX-CGN	N/A								

MAXIMUM STRESS RATIO FOR THIS RUN = 0.072 AT SOP NO. 386L

RN12	SOP NO.	DCP NAME	CORP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
391	108	107	BRCH-B	6X3/4S80	SA105	1.000	STCK	1400.00	600.0	70.0	26250.00	0.00	0.000
392L	127	107	BRCH-B	6X3/4S60	SA105	N/A							
392W	127	FILW	FILW										
392R	127	108	STRP	3/4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	0.00	0.000
393L	128	108	STRP	3/4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	22500.00	0.00	0.000
393W	128	FILW	FILW										
393R	128	109	SRED-E	1X3/4S80	SA105	2.250	STCK	1400.00	600.0	70.0	26250.00	0.00	0.000
394L	C54A	109	SRED-E	1X3/4S80	SA105	2.250	STCK	1400.00	600.0	70.0	26250.00	0.00	0.000

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

C A F ** ** **
 REV-3A ** ** **
 UNIT-1 ** ** **

STRESSES FOR EQUATION 11 SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
1	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	3813.56	0.102	
2	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1500.00	160.0	70.0	37499.98	4206.93	0.112	
3	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4262.95	0.114	
4	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	3981.63	0.106	
5	A2	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4502.20	0.120	
6	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	150.0	70.0	37499.98	3869.57	0.103	
7	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4174.95	0.111	
8	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4193.95	0.112	
9	A3	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4709.92	0.126	
10	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	3984.54	0.106	
11	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4714.53	0.126	
12	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5107.21	0.136	
13	A4	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	6085.28	0.162	
14	A1	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4461.72	0.119	
15	E01A	A1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5928.60	0.185	
15	E01A		AWBW			1.800	STCK	1800.00	160.0	70.0	37499.98	9374.16	0.250	
15	E01A	E01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	7038.85	0.188	
16	E01B	E01	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	7253.41	0.193	
16	E01B		AWBW			1.800	STCK	1800.00	160.0	70.0	37499.98	9749.90	0.260	
16	E01B	T	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	7135.29	0.190	
17	A6	I	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5733.75	0.153	

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-ID *** REV-3A ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. UN 1-1 ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SGP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
18			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4317.48	0.115
19	A7		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	6455.68	0.172
20			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5583.95	0.149
21			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5120.96	0.137
22			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4397.64	0.117
23	A8		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4568.85	0.122
24			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4405.35	0.117
25			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4546.54	0.121
26			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5099.16	0.136
27	1		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	6038.51	0.161
28			1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4585.72	0.122
29L	C01A		1	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4395.22	0.117
29W	C01A			AWBW										
29R	C01A	C01		BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	4408.98	0.118
30L	C01B	C01		BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	4514.52	0.120
30W	C01B			AWBW										
30R	C01B	2		STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4498.85	0.120
31	2		2	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4829.88	0.129
32L	C02A	2		STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5111.77	0.136
32W	C02A			AWBW										
			1.800	STCK	1800.00	160.0	70.0	37499.98	5983.32	0.160				

RUNT
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ***
 PROBLEM NO. -RCO-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ***
 WT-1, TH-6, SAM-12, RSA-4, ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
32R	C02A	C02	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	5145.71	0.137
33L	C02B	C02	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	5162.17	0.138
33W	C02B		AWBW				STCK	1800.00	160.0	70.0	37499.98	6021.96	0.161
33R	C02B	3	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5126.73	0.137
34		3	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5241.12	0.140
35L	C03A	3	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5815.13	0.155
35W	C03A		AWBW				STCK	1800.00	160.0	70.0	37499.98	7135.67	0.190
35R	C03A	C03	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	5865.57	0.156
36L	C03B	C03	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	5996.94	0.160
36W	C03B		AWBW				STCK	1800.00	160.0	70.0	37499.98	7307.60	0.195
36R	C03B	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5947.00	0.159
37	3	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5854.63	0.156
38		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.99	5307.62	0.142
39		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4812.92	0.128
40		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4502.51	0.120
41		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4513.65	0.120
42	4	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4869.58	0.130
43	5	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4610.81	0.128
44	6	4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4658.36	0.124
45		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4521.84	0.121

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A ** ** **
 PROBLEM NO. RCD-6-30-78 AUX-BLDG./INSIDE D.H. UNIT-1 ** ** **
 WI-1. TH-6. SAM-12;RSA-4. ENDL(FORC. & DSPLE). ST.CK. RIPIURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
46			4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4413.73	0.118
47	6A		4	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4382.00	0.117
48L	C04A		4	STRP	4S160-NI	SA106 B	1.030	STCK	1800.00	160.0	70.0	37499.98	4355.33	0.116
48W	C04A			AWBW			1.800	STCK	1800.00	160.0	70.0	37499.98	4659.38	0.124
49R	C04A		C04	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	4364.64	0.116
49L	C04B		C04	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	4755.09	0.127
49W	C04B			AWBW			1.800	STCK	1800.00	160.0	70.0	37499.98	5202.31	0.139
49R	C04B		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4744.34	0.127
50	7		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5232.27	0.140
51			5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4730.95	0.126
52			5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5615.50	0.150
53			5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	6460.07	0.172
54	8		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	7442.54	0.198
55L	C05A		5	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	7484.71	0.200
55W	C05A			AWBW			1.800	STCK	1800.00	160.0	70.0	37499.98	10365.30	0.276
55R	C05A		C05	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	7614.52	0.203
56L	C05B		C05	BELB	4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	7554.24	0.201
56W	C05B			AWBW			1.800	STCK	1800.00	160.0	70.0	37499.98	10279.34	0.274
56R	C05B		6	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	7424.86	0.198
57			6	STRP	4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	6977.02	0.186

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ***
 PROBLEM NO. - RCD-6-30-78 AUX. BLDG. / INSIDE D. H. *** UNIT-1 ***
 WT-1, TH-6, SAM-12, RSA-4; ENDLIFORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
58		6	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	6254.55	0.167
59L	C06A	6	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5236.72	0.140
59W	C06A		AWBW				1.800	STCK	1800.00	160.0	70.0	37499.98	6335.91	0.169
59R	C06A	C06	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	5294.52	0.141
60L	C06B	C06	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	5258.40	0.140
60W	C06B		AWBW				1.800	STCK	1800.00	160.0	70.0	37499.98	6282.56	0.168
60R	C06B	7	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5211.02	0.139
61	9	7	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	6198.02	0.165
62L	C07A	7	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4405.31	0.117
62W	C07A		AWBW				1.800	STCK	1800.00	160.0	70.0	37499.98	4853.41	0.129
62R	C07A	C07	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	4424.91	0.118
63L	C07B	C07	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	4675.12	0.125
63W	C07B		AWBW				1.800	STCK	1800.00	160.0	70.0	37499.98	5246.48	0.140
63R	C07B	8	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4650.47	0.124
64		8	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	4682.41	0.125
65		8	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	5488.41	0.146
66L	C08A	8	STRP		4S160-NI	SA106 B	1.000	STCK	1800.00	160.0	70.0	37499.98	6042.14	0.161
66W	C08A		AWBW				1.800	STCK	1800.00	160.0	70.0	37499.98	7640.32	0.204
66R	C08A	C08	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	6108.70	0.163
67L	C08B	C08	BELB		4S160-NI	SA106 B	1.037	STCK	1800.00	160.0	70.0	37499.98	5627.48	0.150

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WT-1, TH-6, SAM-12, RSA-4, ENDL(EORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
67W	C08B			AWBW	AWBW		1.800	STCK	1800.00	160.0	70.0	37499.98	6642.52	0.182
67R	C08B	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	5574.46	0.149
68	10	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	5060.70	0.135
69		9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	5701.05	0.152
70	11	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	8192.15	0.218
71L	C09A	9	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	8749.06	0.233
71W	C09A		AWBW	AWBW			1.800	STCK	1800.00	160.0	70.0	37499.98	12338.20	0.329
71R	C09A	C09	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0	70.0	37499.98	8900.51	0.237
72L	C09B	C09	BELB	4S160-NI	SA106 B		1.037	STCK	1800.00	160.0	70.0	37499.98	9625.84	0.257
72W	C09B		AWBW	AWBW			1.800	STCK	1800.00	160.0	70.0	37499.98	13594.87	0.363
72R	C09B	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	9449.04	0.252
73	12	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	9727.77	0.259
74		10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	9035.08	0.241
75		10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	8727.84	0.233
76L	13	10	STRP	4S160-NI	SA106 B		1.000	STCK	1800.00	160.0	70.0	37499.98	8211.25	0.219
76W	13		AWTT	AWTT			1.900	STCK	1800.00	160.0	70.0	37499.98	11213.40	0.299
76R	13	11	VALV	4S160	SA106 B		N/A							
77	14	11	VALV	4S160	SA106 B		N/A							
78L	15	11	VALV	4S160	SA106 B		N/A							
78W	15		AWTT	AWTT			1.900	STCK	1800.00	600.0	70.0	37500.00	9721.83	0.259

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ *** C A F *** ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A *** ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./ INSIDE D.H. *** UNIT-1 *** ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST_CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
78R	15	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	37500.00	7311.67	0.195	
79	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	37500.00	5821.15	0.155		
80	16	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	37500.00	7312.79	0.195	
81	16A	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	37500.00	6441.91	0.172	
82L	17	12	STRP	4S160	SA106 B	1.000	STCK	1800.00	600.0	70.0	37500.00	5904.98	0.157	
82W	17		AWTT	AWTT	SA106 B	1.900	STCK	1800.00	600.0	70.0	37500.00	7339.61	0.196	
82R	17	13	VALV	4S160	SA106 B	N/A								
83	18	13	VALV	4S160	SA106 B	N/A								
84L	19	13	VALV	4S160	SA106 B	N/A								
84W	19		AWTT	AWTT	SA106 B	1.900	STCK	1800.00	600.0	70.0	37500.00	8986.59	0.240	
84R	19	14	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6029.91	0.161	
85L	20	14	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6288.81	0.168	
85W	20		AWTT	AWTT	SA106 B	1.900	STCK	1400.00	600.0	70.0	37500.00	12469.79	0.333	
85R	20	15	BTEE-R	4S80	SA106 B	N/A								
86BL	21	15	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	37500.00	9869.28	0.263	
86BR	21	15	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	37500.00	8762.60	0.234	
87L	22	15	BTEE-R	4S80	SA106 B	N/A								
87W	22		AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	10468.89	0.279	
87R	22	16	STRP	4S80	SA106 B	1.000	SICK	1400.00	600.0	70.0	37500.00	6302.32	0.221	
88	16	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6976.68	0.186	

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** ** REV-3A ** ** **
 PROBLEM NO. RCD-6-30-78 AUX-BLDG./INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST,CK.; RUPTURE AND SUPP. SUMM.

JATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO	
24	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7951.76	0.212
24	16	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8078.97	0.215
24	16	AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	10209.41	0.272
24	16	PELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	9274.04	0.247
24	16	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	9151.92	0.244
24	16	AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	10062.45	0.268
24	16	BTEE-R	4S80	SA106 B	N/A							
25	17	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	37500.00	9094.45	0.243
25	17	BTEE-R	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	37500.00	8028.20	0.214
26	17	BTEE-R	4S80	SA106 B	N/A							
26	17	AWTT	AWTT	SA106 B	1.900	STCK	1400.00	600.0	70.0	37500.00	10207.79	0.272
26	18	VALV	4S80	SA106 B	N/A							
27	18	VALV	4S80	SA106 B	N/A							
28	18	VALV	4S80	SA106 B	N/A							
28	19	AWTT	AWTT	SA106 B	1.900	STCK	1400.00	600.0	70.0	37500.00	14127.39	0.377
28	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9694.42	0.259
29	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10700.10	0.285
30	19	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10226.40	0.273
30	74	FIEE-R	4X2-S160	SA105	3.030	STCK	1400.00	600.0	70.0	43750.00	20849.24	0.477
30	74	FTEE-R	4X2-S160	SA105	3.030	STCK	1400.00	600.0	70.0	43750.00	20769.36	0.475

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG / INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WT-1; IH-6; SAM-12, RSA-4; ENDL(FORC. & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
97R	30	19	STRP	4S80	SA106 B		1.000	STCK 1400.00	600.0	70.0	70.0	37500.00	10200.05	0.272
98	30A	19	STRP	4S80	SA106 B		1.000	STCK 1400.00	600.0	70.0	70.0	37500.00	11171.09	0.298
99L	31	19	STRP	4S80	SA106 B		1.000	STCK 1400.00	600.0	70.0	70.0	37500.00	10175.99	0.271
99W	31		AWTT	AWTT			1.900	STCK 1400.00	600.0	70.0	70.0	37500.00	14724.04	0.393
99R	31	20	VALV	4S80	SA106 B		N/A							
100	32	20	VALV	4S80	SA106 B		N/A							
101L	C11A	20	VALV	4S80	SA106 B		N/A							
101W	C11A		AWTT	AWTT			1.900	STCK 1400.00	600.0	70.0	70.0	37500.00	15250.67	0.407
101R	C11A	C11	BELB	4S80-FL	SA106 B		1.320	STCK 1400.00	600.0	70.0	70.0	37500.00	12027.15	0.321
102L	C11B	C11	BELB	4S80-FL	SA106 B		1.320	STCK 1400.00	600.0	70.0	70.0	37500.00	12895.83	0.344
102W	C11B		AWBW	AWBW			1.800	STCK 1400.00	600.0	70.0	70.0	37500.00	15878.46	0.423
102R	C11B	21A	STRP	4S80	SA106 B		1.000	STCK 1400.00	600.0	70.0	70.0	37500.00	11031.86	0.294
103	33A	21A	STRP	4S80	SA106 B		1.000	STCK 1400.00	600.0	70.0	70.0	37500.00	11532.82	0.308
104L	C70A	21A	STFF	4S80	SA106 B		1.000	STCK 1400.00	600.0	70.0	70.0	37500.00	9022.33	0.241
104W	C70A		AWBW	AWBW			1.800	STCK 1400.00	600.0	70.0	70.0	37500.00	12423.77	0.331
104R	C70A	C70	BELB	4S80	SA106 B		1.496	STCK 1400.00	600.0	70.0	70.0	37500.00	11114.25	0.296
105L	C70B	C70	BELB	4S80	SA106 B		1.496	STCK 1400.00	600.0	70.0	70.0	37500.00	9763.03	0.260
105W	C70B		AWBW	AWBW			1.800	STCK 1400.00	600.0	70.0	70.0	37500.00	10797.82	0.288
105R	C70B	21B	STRP	4S80	SA106 B		1.000	STCK 1400.00	600.0	70.0	70.0	37500.00	8100.69	0.216
106		21B	STRP	4S80	SA106 B		1.000	STCK 1400.00	600.0	70.0	70.0	37500.00	8001.20	0.213

RUN1
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAE30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WT-1, TH-6, SAM-12, RSA-4, ENDL(FORC & DSPL), ST, CK, RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
107L	C71A	21B	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10466.78	0.279
107W	C71A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	15064.15	0.402
107R	C71A	C71	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	13308.50	0.355
108L	C71B	C71	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	14542.60	0.388
108W	C71B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	16549.17	0.441
108R	C71B	21C	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11292.24	0.301
109	C3B	21C	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11314.71	0.302
110L	C72A	21C	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11381.18	0.303
110W	C72A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	16685.78	0.445
110R	C72A	C72	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	14656.12	0.391
111L	C72B	C72	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	13397.89	0.357
111W	C72B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	15171.72	0.405
111R	C72B	21D	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10554.91	0.281
112		21D	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6159.87	0.164
113L	C73A	21D	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9887.48	0.264
113W	C73A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	13982.61	0.373
113R	C73A	C73	BELB	4S80	SA106 B	SA106 B	1.436	STCK	1400.00	600.0	70.0	37500.00	12409.70	0.331
114L	C73B	C73	BELB	4S80	SA106 B	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	13852.18	0.369
114W	C73B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	15718.36	0.419
114R	C73B	21E	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10919.33	0.291

RUN (CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO - RCD-6-30-78 AUX-BLDG./INSIDE D.H.
 WT-1; TH-6; SAM-12, RSA-4; ENDL (FORC & DSPL); ST, CK... RUPTURE AND SUPP. SUMM.

** ** ** C A F ** ** **
 ** ** ** REV-3A ** ** **
 ** ** ** UNIT-1 ** ** **
 ** ** ** **

TRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
115	33	21E	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11027.96	0.294	
116	34	21E	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11103.48	0.296	
117L	C74A	21E	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10770.93	0.287	
117W	C74A		AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	15424.31	0.411	
117R	C74A	C74	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	13607.80	0.363	
118L	C74B	C74	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	11928.49	0.318	
118W	C74B		AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	13403.55	0.357	
118R	C74B	21F	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9592.15	0.256	
119L	C75A	21F	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7829.30	0.209	
119W	C75A		AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	10227.50	0.273	
119R	C75A	C75	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	9289.08	0.248	
120L	C75B	C75	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	8338.50	0.222	
120W	C75B		AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	9083.65	0.242	
120R	C75B	21	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7158.70	0.191	
121L	C12A	21	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9563.35	0.255	
121W	C12A		AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	13249.53	0.353	
121R	C12A	C12	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	11800.48	0.315	
122L	C12B	C12	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	13195.33	0.352	
122W	C12B		AWBW	AWBW	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	14927.97	0.398	
122R	C12B	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10512.10	0.280	

ROUT
CONTD.)

BOX 100 ATUP PATEL *** CHICAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-10 *** REV-3A ** **
 PROBLEM NO. - 3CD-6-30-78 AUX-BLDG. / INSIDE D.H. UNIT-1 ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	CORP NAME	CORP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
123	35	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10699.00	0.285	
124L	36	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10887.06	0.290	
124BL	36	60	FTEE-R	4X2-S80	SA105	3.030	STCK	1400.00	600.0	70.0	43750.00	23063.33	0.527	
124BR	36	60	FTEE-R	4X2-S80	SA105	3.030	STCK	1400.00	600.0	70.0	43750.00	19421.82	0.444	
124R	36	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9659.94	0.258	
125L	C13A	22	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11153.67	0.297	
125W	C13A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	16083.89	0.429	
125R	C13A	C13	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	14155.94	0.377	
125L	C13B	C13	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	15473.71	0.413	
126W	C13B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	17669.59	0.471	
126R	C13B	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	12061.39	0.322	
127	37	23	STRP	4S80	SA105 B	1.000	STCK	1400.00	600.0	70.0	37500.00	12074.86	0.322	
128	38	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	12078.87	0.322	
129		23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	13040.91	0.348	
130L	39	23	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	15533.79	0.417	
130W	39		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	24066.86	0.642	
130R	39	23	BRCH-B	18X4-S80	SA106 B	N7A								
131	40	24	BRCH-B	18X4-S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	16092.31	0.429	

MAXIMUM STRESS RATIO FOR THIS RUN = 0.642 AT SOP NO. 130W

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-ID ***
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./INSIDE U.H. ***
 WT-11 TH-61 SAM-12;RSA-4 ENDR(FORC DSPL); ST. CK. RUPTURE AND SUPP. SUMM. ***

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
294W	C64A		C64A	FILW	FILW		2.100	STCK	1400.00	600.0	70.0	37500.00	7988.16	0.213
294R	C64A		C64	SELB	2S80	SA105	1.786	STCK	1400.00	600.0	70.0	43750.00	7435.34	0.170
295L	C64B		C64	SELB	2S80	SA105	1.786	STCK	1400.00	600.0	70.0	43750.00	7845.09	0.179
295W	C64B			FILW	FILW		2.100	STCK	1400.00	600.0	70.0	37500.00	8555.00	0.228
295R	C64B		77	STRP	2S80	SA105 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6029.48	0.161
296	93		77	STRP	2S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7583.49	0.202

MAXIMUM STRESS RATIO FOR THIS RUN = 0.433 AT SOP NO. 279W

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
297	25		78	BTEE-B	4S80	SA106 B	1.128	STCK	1400.00	600.0	70.0	37500.00	8689.51	0.232
298L	C36A		78	BTEE-B	4S80	SA106 B	N/A							
298W	C36A			AMBW	AMBW		1.800	STCK	1400.00	600.0	70.0	37500.00	10691.84	0.285
298R	C36A		C36	BELB	4S80	SA106 B	1.436	STCK	1400.00	600.0	70.0	37500.00	9674.96	0.258
299L	C36B		C36	BELB	4S80	SA106 P	1.496	STCK	1400.00	600.0	70.0	37500.00	5479.30	0.253
299W	C36B			AMBW	AMBW		1.800	STCK	1400.00	600.0	70.0	37500.00	10456.40	0.279
299R	C36B		79	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8021.69	0.214
300L	F36A		79	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7500.88	0.200
300W	E36A			AMBW	AMBW		1.800	STCK	1400.00	600.0	70.0	37500.00	9533.81	0.254
300R	F36A		E36	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	8712.60	0.232
301L	E36B		E36	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	7894.30	0.211

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ** ** **
 PROBLEM NO -RCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WT-1, TH-6, SA1-12, RSA-4, ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	CORP NAME	CORP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
301W	E36B			AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	8549.13	0.228
301R	E36B		C37	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	7683.72	0.205
302L	C37B		C37	BELB	4S80	SA106 B	1.496	STCK	1400.00	600.0	70.0	37500.00	7668.37	0.204
302W	C37B			AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	8277.27	0.221
302R	C37B		80	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6800.27	0.181
303			80	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6781.65	0.181
304L	94A		80	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7268.94	0.194
304W	94A			AWTT	AWTT		1.900	STCK	1400.00	600.0	70.0	37500.00	9466.66	0.252
304R	94A		81	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	4845.59	0.129
305L	94		81	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	5104.90	0.136
305W	94			AWTT	AWTT		1.900	STCK	1400.00	600.0	70.0	37500.00	6913.41	0.184
305R	94		82	NONS	4S160	SA105	N/A							
306	95		82	NONS	4S160	SA105	N/A							
307L	96		82	NONS	4S160	SA105	N/A							
307W	96			AWTT	AWTT		1.900	STCK	1400.00	600.0	70.0	37500.00	8108.21	0.216
307R	96		83	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	5730.06	0.153
308L	96A		83	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6051.52	0.161
308W	96A			AWTT	AWTT		1.900	STCK	1400.00	600.0	70.0	37500.00	12311.82	0.328
308R	96A		84	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8934.18	0.238
309	97		84	STRP	4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9902.41	0.264

BOX 100 ATUL PAEL *** CHICAGO-4/ 33 HZ. *** C A F ***
 AUXILIARY FIELD WATER PUMPS TO STEAM GENERATOR-1D ***
 PROBLEM NO. -RCD-G-30-78 AUX BLDG./INSIDE D.H. ***
 UNIT-1 ***
 WT-1, TH-6, SAM-12, RSA-4, EMBL (FORC & DSFL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
310	98	84	STRP	4S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10661.29	0.284
311C	99	84	STRP	4S80	SAT06 B	SAT06 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6916.46	0.184
311W	99		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	8456.14	0.225
311R	99	85	BRED-E	6X4-S80	SA106 B	SA106 B	2.000	STCK	1400.00	600.0	70.0	37500.00	8876.43	0.237
312L	100	85	BRED-E	6X4-S80	SA106 B	SA106 B	2.000	STCK	1400.00	600.0	70.0	37500.00	7073.00	0.189
312W	100		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	6902.45	0.184
312R	100	86	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6288.49	0.168
313	100A	86	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6761.82	0.180
314L	C38A	86	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7159.01	0.191
314W	C38A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	8347.31	0.223
314R	C38A	C38	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	8087.09	0.216
315L	C38B	C38	BELB	6S80	SAT06 B	SAT06 B	1.643	STCK	1400.00	600.0	70.0	37500.00	8231.59	0.220
315W	C38B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	8505.64	0.227
315R	C38B	87	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7257.87	0.194
316		87	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6722.84	0.179
317L	C39A	87	STRP	6S80	SA106 B	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6872.98	0.183
317W	C39A		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	7863.46	0.210
317R	C39A	C39	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	7645.49	0.204
318L	C39B	C39	BELB	6S80	SA106 B	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	7504.90	0.200
318W	C39B		AWBW	AWBW			1.800	STCK	1400.00	600.0	70.0	37500.00	7709.41	0.206

RNTO (CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-10 *** REV-3A ** ** **
 PROBLEM NO. - CCD-6-30-78 AUX-BLDG./INSIDE D.H. *** UNIT-1 ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC. & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SQP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
318R	C39B	88	STRP	6S80	SA106 B	SA106 B	1.000	STCK 1400.00	600.0	600.0	70.0	37500.00	6775.86	0.181
319L	C40A	88	STRP	6S80	SA106 B	SA106 B	1.000	STCK 1400.00	600.0	600.0	70.0	37500.00	6772.82	0.181
319W	C40A		AWBW	AWBW			1.800	STCK 1400.00	600.0	600.0	70.0	37500.00	7704.07	0.205
319R	C40A	C40	BELB	6S80	SA106 B	SA106 B	1.643	STCK 1400.00	600.0	600.0	70.0	37500.00	7500.03	0.200
320L	C40B	C40	BELB	6S80	SA106 B	SA106 B	1.643	STCK 1400.00	600.0	600.0	70.0	37500.00	6705.70	0.179
320W	C40B		AWBW	AWBW			1.800	STCK 1400.00	600.0	600.0	70.0	37500.00	6833.74	0.182
320R	C40B	89	STRP	6S80	SA106 B	SA106 B	1.000	STCK 1400.00	600.0	600.0	70.0	37500.00	6266.24	0.167
321		89	STRP	6S80	SA106 B	SA106 B	1.000	STCK 1400.00	600.0	600.0	70.0	37500.00	6315.96	0.168
322	101	89	STRP	6S80	SA106 B	SA106 B	1.000	STCK 1400.00	600.0	600.0	70.0	37500.00	7708.90	0.206
323L	C41A	89	STRP	6S80	SA106 B	SA106 B	1.000	STCK 1400.00	600.0	600.0	70.0	37500.00	6779.96	0.181
323W	C41A		AWBW	AWBW			1.800	STCK 1400.00	600.0	600.0	70.0	37500.00	7742.14	0.206
323R	C41A	C41	BELB	6S80	SA106 B	SA106 B	1.643	STCK 1400.00	600.0	600.0	70.0	37500.00	7534.76	0.201
324L	C41B	C41	BELB	6S80	SA106 B	SA106 B	1.643	STCK 1400.00	600.0	600.0	70.0	37500.00	7975.96	0.213
324W	C41B		AWBW	AWBW			1.800	STCK 1400.00	600.0	600.0	70.0	37500.00	8225.55	0.219
324R	C41B	90	STRP	6S80	SA106 B	SA106 B	1.000	STCK 1400.00	600.0	600.0	70.0	37500.00	7051.55	0.188
325L	C42A	90	STRP	6S80	SA106 B	SA106 B	1.000	STCK 1400.00	600.0	600.0	70.0	37500.00	7058.35	0.188
325W	C42A		AWBW	AWBW			1.800	STCK 1400.00	600.0	600.0	70.0	37500.00	8236.45	0.220
325R	C42A	C42	BELB	6S80	SA106 B	SA106 B	1.643	STCK 1400.00	600.0	600.0	70.0	37500.00	7985.91	0.213
326L	C42B	C42	BELB	6S80	SA106 B	SA106 B	1.643	STCK 1400.00	600.0	600.0	70.0	37500.00	8947.80	0.239
326W	C42B		AWBW	AWBW			1.800	STCK 1400.00	600.0	600.0	70.0	37500.00	9290.37	0.248

RNTO
(CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ***
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG./INSIDE D. H. *** UNIT-1 ***
 WT-1 TH-6; SAM-12, RSA-4; ENDL(FORC. & DSP); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
326R	C42B	91	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7686.27	0.205	
327L	C43A	91	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8554.63	0.228	
327W	C43A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	10914.04	0.291	
327R	C43A	C43	BELB	6S90	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	10429.67	0.278	
328L	C43B	C43	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	10819.76	0.289	
328W	C43B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	11341.46	0.302	
328R	C43B	92	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8797.18	0.235	
329		92	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8715.10	0.232	
330	102	92	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8647.43	0.231	
331L	C44A	92	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8626.69	0.230	
331W	C44A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	11053.97	0.295	
331R	C44A	C44	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	10557.39	0.282	
332L	C44B	C44	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	10126.50	0.270	
332W	C44B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	10581.86	0.282	
332R	C44B	93	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8385.68	0.224	
333	103	93	STRP	6S80	SA106 R	1.000	STCK	1400.00	600.0	70.0	37500.00	8332.95	0.222	
334	104	93	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8204.15	0.219	
335	105	93	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6918.31	0.184	
336L	C45A	93	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	6848.06	0.183	
336W	C45A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	8008.64	0.214	

RNT0
(CONTD.)

BOX 100 ATUL PATEL *** C N I C A F 30-W/ 33 HZ. *** ** ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** ** ** **
 PROBLEM NO. - RCD-6-30-78 AUX-BLDG. / INSIDE D.H. *** ** ** **
 UNIT-1 *** ** ** **
 MT-1; TH-6; SAM-12; RSA-4; ENDL(FORC. & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
336R	C45A	C45	BELB	6S80	SA106 B		1.643	STCK	1400.00	600.0	70.0	37500.00	7777.99	0.207
337L	C45B	C45	BELB	6S80	SA106 B		1.643	STCK	1400.00	600.0	70.0	37500.00	7720.97	0.206
337W	C45B		AMBW	AMBW			1.800	STCK	1400.00	600.0	70.0	37500.00	7946.16	0.212
337R	C45R	94	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	6829.23	0.182
338		94	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	6955.35	0.185
339L	C46A	94	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	7052.04	0.188
339W	C46A		AMBW	AMBW			1.600	STCK	1400.00	600.0	70.0	37500.00	8331.41	0.222
339R	C46A	C46	BELB	6S80	SA106 B		1.643	STCK	1400.00	600.0	70.0	37500.00	8072.58	0.215
340L	C46B	C46	BELB	6S30	SA106 B		1.643	STCK	1400.00	600.0	70.0	37500.00	7818.56	0.208
340W	C46B		AMBW	AMBW			1.800	STCK	1400.00	600.0	70.0	37500.00	8053.09	0.215
340R	C46B	95	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	6916.66	0.184
341		95	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	6374.70	0.170
342		95	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	6789.55	0.181
343L	C47A	95	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	7703.80	0.205
343W	C47A		AMBW	AMBW			1.800	STCK	1400.00	600.0	70.0	37500.00	9427.75	0.251
343R	C47A	C47	BELB	6S80	SA106 B		1.643	STCK	1400.00	600.0	70.0	37500.00	9073.18	0.242
344L	C47B	C47	BELB	6S80	SA106 B		1.643	STCK	1400.00	600.0	70.0	37500.00	9598.05	0.256
344W	C47B		AMBW	AMBW			1.800	STCK	1400.00	600.0	70.0	37500.00	10002.84	0.267
344R	C47B	96	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	8005.18	0.213
345	107	96	STRP	6S80	SA106 B		1.000	STCK	1400.00	600.0	70.0	37500.00	9521.97	0.254

RNTO
 (CONTD.)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** ** * * * C A F ** * * *
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** * * * REV-3A ** * * *
 PROBLEM NO. -RCD-G-30-78 AUX-BLDG./INSIDE D.H. ** * * * UNIT-1 ** * * *
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	STF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
RNTD (CONTD.)														
346L	108	96	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9508.97	0.254	
346BL	108	107	BRCH-R	6X3/4S80	SA105	1.000	STCK	1400.00	600.0	70.0	43750.00	9508.97	0.217	
346BR	108	107	BRCH-R	6X3/4S80	SA105	1.000	STCK	1400.00	600.0	70.0	43750.00	9490.64	0.217	
346R	108	96	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9493.64	0.253	
347L	C48A	96	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9982.27	0.266	
347W	C48A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	13511.00	0.360	
347R	C48A	C48	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	12799.84	0.341	
348L	C48B	C48	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	13600.76	0.363	
348W	C48B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	14388.54	0.384	
348R	C48B	97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10419.65	0.278	
349	106	97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10344.32	0.276	
350		97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8924.05	0.238	
351		97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9100.05	0.243	
352L	C49A	97	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10626.60	0.283	
352W	C49A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	14787.80	0.394	
352R	C49A	C49	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	13965.15	0.372	
353L	C49B	C49	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	13601.85	0.363	
353W	C49B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	14389.74	0.384	
353R	C49B	98	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10392.47	0.277	
354		98	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9237.76	0.246	

MONSWEILL PAGE PRINTING SYSTEM - P1185-02

04/05/82

EDS NUCLEAR INC.
SUPERLIFE VERS. 11/15/79. ANDAHL REV. 1

BOX 100 ATUL PATEL *** C N I C A F ***
AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ***
PROBLEM NO. - RCD-6-30-78 AUX-BLDG./INSIDE O.H. ***
WT-1, TH-6, SAN-12, RSA-4, FNDL (FORC. & D5PL), ST. CK., RUPTURE AND SUPP. SUMM. ***

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO	DCP NAME	COMP NAME	CONF TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
355L	C50A	98	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11165.18	0.298	
355W	C50A		AMBW	6S80	SA106 B	1.600	STCK	1400.00	600.0	70.0	37500.00	15761.19	0.420	
355R	C50A	C50	BELB	6S80	SA106 B	1.343	STCK	1400.00	600.0	70.0	37500.00	14853.53	0.396	
356L	C50B	C50	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	15277.67	0.407	
356W	C50B		AMBW	6S80	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	16225.90	0.433	
356R	C50B	99	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11418.39	0.304	
357	T09	99	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11130.44	0.297	
358		99	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10283.55	0.274	
359L	C51A	99	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11183.37	0.298	
359W	C51A		AMBW	6S80	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	15816.14	0.422	
359R	C51A	C51	BELB	6S80	SA106 B	1.543	STCK	1400.00	600.0	70.0	37500.00	14903.69	0.397	
360L	C51B	C51	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	15211.52	0.406	
360W	C51B		AMBW	6S80	SA106 B	1.800	STCK	1400.00	600.0	70.0	37500.00	16153.42	0.431	
360R	C51B	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11379.81	0.303	
361	110	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11292.17	0.301	
362	111	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	11092.50	0.296	
363		100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9698.68	0.259	
364	112	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10065.66	0.268	
365L	C52A	100	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10190.96	0.272	
365W	C52A		AMBW	6S80	SA106 B	1.600	STCK	1400.00	600.0	70.0	37500.00	14006.86	0.374	

RNTO
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 IZ *** C A F 1 * * * * *
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A * * * * *
 PROBLEM NO. - RCD-6-3C-78 AUX-BLDG., INSIDE D.H. *** UNIT-1 * * * * *
 WT-1: TH-6; SAH-12; RSA-4; FHD (FORC. & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SGP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
365R	C52A	C52	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	13252.41	0.353	
366L	C52B	C52	BELB	6S90	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	13778.48	0.367	
366W	C52B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	14583.27	0.389	
366R	C52B	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10490.36	0.280	
367	113	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	10442.73	0.278	
368		101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	7928.51	0.211	
369L	114	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8558.00	0.228	
369BL	114		BRCH-R	6X2-S80	SA105	1.508	STCK	1400.00	600.0	70.0	43750.00	10084.10	0.230	
369BR	114		BRCH-R	6X2-S80	SA105	1.508	STCK	1400.00	600.0	70.0	43750.00	9289.80	0.212	
369R	114	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8031.06	0.214	
370L	C53A	101	STRP	6S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8896.32	0.237	
370W	C53A		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	11590.29	0.309	
370R	C53A	C53	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	11028.53	0.294	
371L	C53B	C53	BELB	6S80	SA106 B	1.643	STCK	1400.00	600.0	70.0	37500.00	10835.18	0.289	
371W	C53B		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	11358.34	0.303	
371R	C53B	102	BRED-R	6X4-S80	SA106 B	2.000	STCK	1400.00	600.0	70.0	37500.00	12024.00	0.321	
372L	115	102	BRED-R	6X4-S80	SA106 B	2.000	STCK	1400.00	600.0	70.0	37500.00	21693.41	0.578	
372W	115		AWTT	AWTT		1.900	STCK	1400.00	600.0	70.0	37500.00	20842.41	0.556	
372R	115	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9321.42	0.249	
373	116	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	9193.61	0.245	

RNTO
(CONTD.)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D REV-3A ** ** **
 PROBLEM NO. - RCD-6-30-78 ADJ-BLDG./INSIDE D.H. UNIT-1 ** ** **
 VT-1, TH-6, SAM-12, RSA-4, ENDL(FORC. & D:FL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION. ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP NAME	COMP TYPE	SECTION NAME	MATERIAL NAME	STF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
374L	117	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8697.55	0.232	
374R	117	120	BRCH-R	4X3/4160	SA105	1.000	STCK	1400.00	600.0	70.0	43750.00	8697.55	0.199	
374R	117	120	BRCH-R	4X3/4160	SA105	1.000	STCK	1400.00	600.0	70.0	43750.00	8703.23	0.199	
374R	117	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8703.23	0.232	
375L	118	103	STRP	4S160	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	8119.43	0.217	
375W	118		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	37500.00	11964.44	0.319	
375R	118	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	43374.98	8238.62	0.190	
376L	119	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	43374.98	7431.58	0.171	
376R	119	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	43374.98	4338.71	0.100	
377L	120	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	43374.98	4097.54	0.094	
377W	120		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	43374.98	4675.17	0.106	
377R	120	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	43374.98	4097.54	0.094	
378	104	STRP	4-PROCES	SA376 TP304		1.000	STCK	1400.00	600.0	70.0	43374.98	3273.79	0.075	
379	104	STRP	4-PROCES	SA376 TP304		1.000	STCK	1400.00	600.0	70.0	43374.98	3527.42	0.081	
380	104	STRP	4-PROCES	SA376 TP304		1.000	STCK	1400.00	600.0	70.0	43374.98	3423.47	0.079	
381	121	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	43374.98	2977.14	0.069	
382	122	104	STRP	4-PROCES	SA376 TP304	1.000	STCK	1400.00	600.0	70.0	43374.98	2966.10	0.068	
382W	122		AWBW	AWBW		1.800	STCK	1400.00	600.0	70.0	43374.98	2966.10	0.068	

MAXIMUM STRESS RATIO FOR THIS RUN = 0.578 AT SOP NO. 372L

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ *** C A F ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D *** REV-3A ***
 PROBLEM NO - RCD-6-30-76 AUX-BLDG./INSIDE D.H. *** UNIT-1 ***
 VI-1, II-6, SAM-12, RSA-4, ENDL (FORC. & DSPL); ST. CK.; RUPTURE AND SUPP. SUMM.

STRESSES FOR EQUATION 11 (CONTD.) SUSTAINED LOADS AND THERMAL EXPANSION, ALLOWABLE STRESS = 1.0(SH+SA) UNLESS MODIFIED

RUN NAME	SOP NO.	DCP NAME	COMP PLATE	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
RNT1														
383	119	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	37500.00	743.21	0.020	
384	123	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	37500.00	744.94	0.020	
385	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	37500.00	1107.09	0.030		
386L	124	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	37500.00	1716.87	0.046	
386R	124	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	37500.00	1142.95	0.030	
387	125	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	37500.00	540.07	0.014	
388	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	37500.00	244.50	0.007		
389L	126	105	STRP	8-GUARD	SA106 B	1.000	STCK	15.00	300.0	70.0	37500.00	37.19	0.001	
389R	126	106	FLXC	FLEX-CON		N/A								
390	121	106	FLXC	FLEX-CON		N/A								

MAXIMUM STRESS RATIO FOR THIS RUN = 0.046 AT SOP NO. 386L

RUN NAME	SOP NO.	DCP NAME	COMP PLATE	COMP TYPE	SECTION NAME	MATERIAL NAME	SIF	LOAD SET	PRESS (PSI)	SH TEMP	SC TEMP	ALLOW. STRESS (PSI)	COMPUTED STRESS (PSI)	STRESS RATIO
RNT2														
391	108	107	BRCH-B	6X3/4S80	SA105	1.000	STCK	1400.00	600.0	70.0	43750.00	4337.22	0.099	
392L	127	107	BRCH-B	6X3/4S60	SA105	N/A								
392W	127	FILW	FILW			2.100	STCK	1400.00	600.0	70.0	37500.00	5883.76	0.157	
392R	127	108	STRP	3/4S60	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	4606.93	0.123	
393L	128	108	STRP	3/4S80	SA106 B	1.000	STCK	1400.00	600.0	70.0	37500.00	4606.93	0.123	
393W	128	FILW	FILW			2.100	STCK	1400.00	600.0	70.0	37500.00	5883.76	0.157	
393R	128	109	SRED-E	1X3/4S80	SA105	2.250	STCK	1400.00	600.0	70.0	43750.00	6133.58	0.140	
394L	C54A	109	SRED-E	1X3/4S80	SA105	2.250	STCK	1400.00	600.0	70.0	43750.00	4561.41	0.104	

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. *** ** ** ** C A F ** ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** ** REV-3A ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG / INSIDE D.H. ** ** ** UNIT-1 ** ** **
 WT-1; JH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); SI, CK... RUPTURE AND SUPP. SUMM.

SUPPORT LOAD SUMMARY (CONTD.)

SUPP NAME	SUPP LOCN	SUPP TYPE	DIRN CODE	RESULT TYPE	UNIT	AXIS TYPE	X-AXIS SET	Y-AXIS SET	Z-AXIS SET	LOAD SET	
101X	101	SNGL	X	DISP	(IN)	GLOB	0.067 0.057 0.057 0.010 -0.010 -0.366 -0.371 -0.376	FLTD(M+) UPST COLD HOT SSE SSE HOT UPST FLTD(M-)	-1275.19 -1445.59 -1594.69	HOT UPST FLTD(M-)	
101X	101	SNGL	X	FORC	(LB)	GLOB	360.85 273.04 104.64 -87.81 -87.81 -236.92 -360.85 -429.37 -597.77	SSE(M+) FLTD UPST HOT COLD HOT SSE UPST FLTD(M-)	0.441 0.432 0.422 0.018 0.003 0.003 -0.006 -0.019 -0.018	FLTD(M+) UPST HOT SSE COLD HOT UPST FLTD SSE(M-)	
101Y	101	SNGL	Y	DISP	(IN)	GLOB					
101Y	101	SNGL	Y	FORC	(LB)	GLOB					
										507.53 190.67 -46.18 -316.87	SSE(M+) FLTD UPST HOT
										0.999 0.984 0.966 0.032 0.007 0.007 -0.011 -0.026 -0.032	FLTD(M+) UPST HOT SSE COLD HOT UPST FLTD SSE(M-)

BOX 100 ATUL PATEL *** CN1CAF30-W/ 33 HZ. ***
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG / INSIDE D.H.
 WT-1; IH-6; SAM-12,RSA-4; ENDR(FORC. & DSPL); SI,CK...RUPTURE AND SUPP. SUMM.

SUPPORT LOAD SUMMARY (CONTD.)

SUPP NAME	SUPP LOCN	SUPP TYPE	DIRN CODE	RESULT TYPE	RESULT UNIT	AXIS TYPE	LOAD SET	X-AXIS	Y-AXIS	Z-AXIS	LOAD SET
103Z	103	SNUB	Z	FORC	(LB)	GLOB					
								771.57			SSE(M+)
								411.50			FLTD
								-411.50			UPST
								-771.57			FLTD
								-771.57			SSE(M-)
								1.351			HOT (M+)
								1.351			UPST
								1.351			FLTD
								0.002			HOT
								0.002			COLD
								0.002			FLTD
								0.002			UPST
								0.002			SSE
								-0.054			FLTD(M-)
104Y	104	SNGL	Y	FOFC	(LB)	GLOB					
								230.86			SSE(M+)
								-230.86			SSE
								-337.76			FLTD
								-445.49			UPST
								-568.62			COLD
								-568.62			HOT
								-751.38			HOT
								-874.50			UPST
								-982.23			FLTD(M-)
								0.203			FLTD(M+)
								0.169			UPST
								0.130			HOT
								0.073			SSE
								-0.007			COLD
								-0.007			HOT
								-0.045			UPST
								-0.073			SSE
								-0.079			FLTD(M-)
								1.367			FLTD(M+)
								1.337			UPST
								1.303			HOT
								0.064			SSE
								0.006			COLD
								0.006			HOT
								-0.028			UPST
								-0.058			FLTD
								-0.064			SSE(M-)

BOX 100 ATUL PATEL *** CNICAF30-W/ 33 HZ. *** C A F ** **
 AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D ** ** **
 PROBLEM NO. -RCD-6-30-78 AUX-BLDG./INSIDE G.H. ** ** **
 WT-1; TH-6; SAM-12; RSA-4; ENDL(FORC & DSPL); ST.CK.; RUPTURE AND SUPP. SUMM. ** ** **

SUPPORT LOAD SUMMARY (CONTD.)

SUPP NAME	SUPP LOCN	SUPP TYPE	DIRN CODE	RESULT TYPE	UNIT	AXIS TYPE	LOAD SET	X-AXIS	Y-AXIS	Z-AXIS	LOAD SET
107Z	107	SNGL	Z	FORC	(LB)	GLOB					
								595.79			FLTD(M+)
								562.40			SSE
								333.33			UPST
								33.39			HOT
								33.39			COLD
								-260.92			HOT
								-560.77			UPST
								-562.40			SSE
								-823.23			FLTD(M-)

DISP	(IN)	GLOB	FLTD(M+)
0.062			FLTD
0.062			SSE
0.034			UPST
-0.062			SSE
-0.100			HOT
-0.133			UPST
-0.161			FLTD(M-)

SUPP NAME	SUPP LOCN	SUPP TYPE	DIRN CODE	RESULT TYPE	UNIT	AXIS TYPE	LOAD SET	X-AXIS	Y-AXIS	Z-AXIS	LOAD SET
109Y	109	SNGL	Y	FORC	(LB)	GLOB					
								329.92			SSE(M+)
								-10.11			FLTD
								-164.08			UPST
								-329.92			SSE
								-340.04			COLD
								-340.04			HOT
								-361.83			HOT
								-557.79			UPST
								-711.75			FLTD(M-)

DISP	(IN)	GLOB	FLTD(M+)
0.021			FLTD(M+)
0.021			SSE
0.011			UPST
-0.021			SSE
-0.222			HOT
-0.233			UPST
-0.243			FLTD(M-)

SUPP NAME	SUPP LOCN	SUPP TYPE	DIRN CODE	RESULT TYPE	UNIT	AXIS TYPE	LOAD SET	X-AXIS	Y-AXIS	Z-AXIS	LOAD SET
								0.667			FLTD(M+)
								0.542			UPST
								0.398			HOT
								0.269			SSE
								0.002			COLD
								0.002			HOT
								-0.141			UPST
								-0.269			FLTD
								-0.269			SSE(M-)

EDS NUCLEAR INC.
SUPERPIPE VERS. 11/15/79, AMDAHL REV. 1

BOX 100 ATUL PATEL
AUXILIARY FEED WATER PUMPS TO STEAM GENERATOR-1D
PROBLEM NO. RCD-6-30-78 AUX-BLDG./INSIDE D.H.
WT-1, TH-5, SAM-12, RSA-4, ENDL(FORC & DSPL), SLCK, RUPTURE AND SUPP. SUMM.

SUPPORT LOAD SUMMARY (CONTD.)

SUPP NAME	SUPP LOCN	SUPP TYPE	DIRN CODE	RESULT UNIT	AXIS TYPE	X-AXIS LOAD SET	Y-AXIS LOAD SET	Z-AXIS LOAD SET
113Z (CONTD.)								
				DISP (IN)	GLOB	0.002 0.002	0.326 0.323 0.002 -0.002	-5.77 -5.77 -625.20 -1161.43
							FLTD(M+) UPST HOT SSE	COLD HOT UPST SSE
116Y	116	SNGL	Y			-0.002 -0.036 -0.038 -0.039	0.003 0.003 0.003 0.004 -0.605	-0.002 -0.003 -0.003 -0.004 -0.605
							FLTD(M-) UPST HOT SSE	FLTD(M-) UPST HOT SSE
				FORC (LB)	GLOB	522.71 -389.11 -522.71 -633.04 -911.82 -1406.79 -1685.57 -1929.50	SSE(M+) FLTD UPST HOT SSE COLD HOT UPST FLTD(M-)	
							FLTD(M+) SSE	
				DISP (IN)	GLOB	0.002 0.002	0.002 0.002	0.037 0.032 0.010
							FLTD(M+) HOT SSE	FLTD(M+) UPST HOT SSE
M457	124	ANCH	GLOB			-0.002 -0.268 -0.269	0.005 0.010 -0.010	-0.005 -0.010 -0.010
							FLTD(M-) UPST HOT SSE	FLTD(M-) UPST HOT SSE
				FORC (LB)	GLOB	2227.26 1815.73 1345.42	SSE(M+) FLTD UPST HOT	475.76 473.67 254.71
							FLTD(M+) UPST HOT SSE FLTD	FLTD(M+) UPST SSE UPST

Item 55 - 3.7.3.8.3, page 3.7-32 and Table 3.7.3-1

Provide a detailed example of the "Alternate Analysis of Flexible Piping" including the evaluation of Seismic Anchor Motion. Explain the use of the 15/8 factor and the 2g and 3g limits on page 3.7-33.

Response:

A presentation during the meeting explained Alternate Analysis Criteria design basis and user actions to the satisfaction of the staff. The 15/8 factor is the ratio of Safe Shutdown earthquake acceleration value of .15g to the Operating Basis earthquake acceleration value of .08g. These values were chosen for the foundation at Catawba as provided for in 10CFR Part 100, Appendix A and explained in Section 2.5.2.6 of the FSAR. The .08g value for OBE is conservative and is slightly more than 1/2 the SSE.

Concentrated weights within the Alternate Criteria are assumed to be mechanical equipment, particularly valves. In Section 3.9.22, the seismic qualification by analysis of safety related mechanical equipment, including its supports, includes the consideration of two mutually orthogonal components of horizontal seismic motion occurring simultaneously with the vertical motion as recommended in Reg. Guide 1.92. The 2g and 3g SSE acceleration limits were used in the Westinghouse Pump and Valve Operability Program (Section 3.9.3.2) for static shaft deflection analysis of pump rotors and static valve qualification. It also required the piping designer to maintain the acceleration to these limits. The 3g and 2g limits are conservative and the Alternate Criteria has taken these limits and conservatively applied them to determine spans and loading regardless of the type of concentrated weight or class of pipe.

This item was closed.

Item 56 - 3.7.3.9, page 3.7-33

The method for analyzing multiply-supported components is unacceptable. The appropriate method was either a response spectrum that envelopes the response spectra at all support elevations or multiple response spectra inputs. Provide a commitment to this method of analysis.

Response:

We will revise page 3.7-33 (as attached) to provide the following information:

3.7.3.9 Multiply - Supported Equipment Components with Distinct Inputs

For seismic piping (other than NSSS), analysis includes earthquake loads represented by horizontal earthquake response spectra at the various floor elevations in the Category I structures.

For a piping system spanning between two or more elevations (spectra) the response spectrum analysis is performed using an envelope of all appropriate floor response spectras through which the pipe passes. The spectrum used to represent the vertical seismic accelerations is two-thirds of the horizontal ground spectrum where no vertical floor spectra is developed.

For the evaluation of relative support motions in the seismic analysis of piping systems interconnecting two or more primary structures, the maximum relative movement between structures is assumed, and the piping system is subjected to these movements through the piping system supports and restraints using a static analysis. Separate cases for N-S earthquake and E-W earthquake are considered. Support movements are based on the maximum of the floor movements immediately above and below the support location, with the interpolation optional. The stresses in the piping resulting from these imposed restraint movements are considered to act concurrently with other seismic and thermal stresses; however, these stresses are considered to be secondary stresses and as such are combined directly with the stresses resulting from thermally induced movement.

No separate evaluation is made for the stress requirement of the Faulted Condition because it is covered by the stress requirement of the Upset Condition if only pressure, gravity and earthquake loadings are considered as they were in the subject analysis. For the Faulted Condition only the seismic (SSE) contribution to the total stress is increased over the seismic (OBE) contribution to the total stress for the Upset Condition with the gravity and pressure stresses being equivalent for both design conditions. The stress (displacement, reaction) effect of a SSE is taken to be 15/8 that of the corresponding OBE. Since the allowable stress for the Faulted Condition is double that of the Upset Condition, the evaluation of earthquake stress limit is based on the Upset Condition only.

Spans with concentrated weights are evaluated against the displacement and stress criteria described above; in addition, acceleration limits are imposed assuming that concentrated weights are usually valves. The limits are 2 g (SSE) in the vertical direction and 3 g (SSE) in each of two mutually perpendicular horizontal directions. All three of these acceleration components may occur simultaneously, but resultant combinations of these components are not used as acceleration limits. The limits are independent of the orientation of a valve.

3.7.3.9 Multiply - Supported Equipment Components with Distinct Inputs

For seismic piping (other than NSSS), analysis includes earthquake loads represented by horizontal earthquake response spectra at the various floor elevations in the Category I structures. For a piping system spanning between two or more elevations (spectra), ~~the spectrum curve associated with the elevation closest to, or higher than, the center of mass of the piping system is used. In establishing the response spectra used for a particular analysis problem the underlying philosophy is that the spectrum selected is representative of the input motion to which the major portion of the pipe is subjected. This generally corresponds to the spectrum associated with the elevation of the center of mass of the pipe. Each analysis problem is evaluated individually so that the input spectrum used is equal to or more conservative than the spectrum associated with the elevation of the major portion of the pipe.~~ The spectrum used to represent the vertical seismic accelerations is two-thirds of the horizontal ground spectrum where no vertical floor spectra is developed.

For the evaluation of relative support motions in the seismic analysis of piping systems interconnecting two or more primary structures, the maximum relative movement between structures is assumed, and the piping system is subjected to these movements through the piping system supports and restraints using a static analysis. Separate cases for N-S earthquake and E-W earthquake are considered. Support movements are based on the maximum of the floor movements immediately above and below the support location, with the interpolation optional. The stresses in the piping resulting from these imposed restraint movements are considered to act concurrently with other seismic and thermal stresses; however, these stresses are considered to be secondary stresses and as such are combined directly with the stresses resulting from thermally induced movement.

The response spectrum analysis is performed using an envelope of all appropriate floor response spectra through which the pipe passes.

Item 57 - 3.7.3.9, page 3.7-34

The stresses caused by differential seismic motion of piping are secondary stresses for piping, but are primary stresses for pipe supports. They are not secondary stresses as noted. Provide a commitment that your analysis reflects this.

Response:

Duke will revise FSAR page 3.7-34 (as attached) so that the third sentence of the third paragraph will read as follows:

Per ASME Code rules, the stress caused by differential seismic motion is clearly secondary for piping (NB-3650).

Additionally a sentence will be added at the end of section 3.7.3.9 as follows:

All analyzed piping stresses are considered primary stresses for the purpose of pipe support design.

This item was closed.

When response spectrum methods are used to evaluate Reactor Coolant System primary components interconnected between floors, the procedures of the following paragraphs are used. There are no components in Westinghouse scope of analysis which are connected between buildings. The primary components of the Reactor Coolant System are supported at no more than two floor elevations.

A dynamic response spectrum analysis is first made assuming no relative displacement between support points. The response spectra used in this analysis is the most severe floor response spectra.

Secondly, the effect of differential seismic movement of components interconnected between floors is considered statically in the integrated system analysis and in the detailed component analysis. The results of the building analysis are reviewed on a mode-by-mode basis to determine the differential motion in each mode. Per ASME Code rules, the stress caused by differential seismic motion is clearly secondary for piping (NB-3650) ~~and component supports (NF-3231)~~. For components, the differential motion will be evaluated as a free end displacement, since, per NB-3213.19, examples of a free end displacement are motions "that would occur because of relative thermal expansion of piping, equipment, and equipment supports, or because of rotations imposed upon the equipment by sources other than the piping". The effect of the differential motion is to impose a rotation on the component from the building. This motion, then, being a free end displacement and being similar to thermal expansion loads, will cause stresses which will be evaluated with ASME Code methods including the rules of NB-3227.5 used for stresses originating from restrained free end displacements. *All analysed piping stresses are considered primary stresses for pipe support design.*

The results of these two steps, the dynamic inertia analysis and the static differential motion analysis, are combined absolutely with due consideration for the ASME classification of the stresses.

3.7.3.10 Use of Constant Vertical Static Factors

For seismic piping subsystems, the simultaneous three-directional excitation used in the analysis does not involve constant vertical static factors.

3.7.3.11 Torsional Effects of Eccentric Masses

For seismic piping, significant masses offset from the pipe centerline are specifically included in the seismic math model. Therefore, any forces or moments, including torsion, due to these eccentric masses appear in the results of the analysis. Typical examples of such masses are remote-actuated valve operators and local bypass piping.

3.7.3.12 Buried Seismic Category I Piping Systems and Tunnels

The Nuclear Service Water System includes buried seismic piping connecting various safety-related structures. Due to its early position in the procurement and erection schedules, the Nuclear Service Water System piping is designed in accordance with the 1971 (rather than 1974) edition of the ASME Code. The seismic analysis performed on this pipe considers:

Item 58 - 3.7.3.13, page 3.7-55

Provide an example of how the seismic boundary is protected in cases where the seismic and non-seismic piping connect.

Response:

When an anchor is used to separate a seismic boundary non-seismic boundary, a plastic hinge calculation is performed. All the non-seismic supports are assumed to fail and a plastic hinge is formed. The loads developed are absolute summed with the seismic analyzed side. As per Regulatory Guide 1.29, the interface between seismic Category I and non-seismic system is designated as seismic Category I. An example of a plastic hinge calculated for anchor I-R-BW-1547, shown in figure 3.9.3-1, is attached.

Dev./Station CATAWBAAttachment - Item 58Subject LOADS ON ANCHOR AT SEISMIC & NON-SEISMIC PIPING Unit | File No.INTERFACE FOR PROBLEM - CAF & BWBSheet No. 18 of 40 Problem No. RCD-6-30-78 By ACP Date 12-20-80Checked By AWD Date 12-29-80

THIS PAGE ADDED @ REV-2

PURPOSE :-

TO DETERMINE THE MAX. FORCES & MOMENTS REQUIRED TO DESIGN AN ANCHOR WHICH INTERFACE SEISMIC (RIGOROUS) AND NON-SEISMIC (NON-RIGOROUS) PIPING.

ASSUMPTIONS:-

- (1) ASSUME THAT FAILURE OF NON-RIGOROUS PIPING (SEISMICLY NOT-SUPPORTED) WILL BE BY MOMENT AND TORSIONAL LOADS ONLY.
- (2) ASSUME THAT DESIGN STRESS IN PIPE WILL BE YIELD STRESS.
- (3) IT IS ASSUMED THAT EACH DIRECTIONAL MOMENT AND TORSION INDEPENDENTLY CAUSES YIELDING OF COMPLETE CROSS-SECTION OF THE NON-RIGOROUS PIPING AT AN ANCHOR.

REFERENCE:-

- (1) PROBLEM-CAC ; UNIT-1 ; REV-2 . SH.# 30 to 39 of 50.
- (2) R.J. ROARK & W.C. YOUNG. FORMULAS FOR STRESS & STRAIN ; 5TH EDITION
- (3) AISC MANUAL OF STEEL CONSTRUCTION ; 7TH EDITION

THEORY:-

CALCULATE THE REQUIRED FORCES AND MOMENTS TO FORM A PLASTIC HINGE AT THE ANCHOR POINT ON THE NON-SEISMIC PIPING. THIS IS DONE TO ENSURE THAT DURING SEISMIC EVENT THE PIPING ON THE NON-SEISMIC SIDE OF THE ANCHOR WILL YIELD BEFORE IT CAN SIGNIFICANTLY AFFECT THE ANCHOR AND RIGOROUS PIPING.

Dev./Station CATAWBA Unit 1 File No.
 Subject LOADS ON ANCHOR AT SEISMIC & NON-SEISMIC PIPING
INTERFACE FOR PROBLEM-CAF & 3WB By AP Date 12-20-80
 Sheet No. 19 of 40 Problem No. RCD-6-30-78 Checked By KVJ Date 12-29-80
 THIS PAGE ADDED @ REV-2

$$M_p = \sigma_y Z / 12 \quad (\text{FT-LBS})$$

REF-2 PAGE NO. -199 & 202

$$T = \sigma_y J / 24 R_i \quad (\text{FT-LBS})$$

REF-1 PAGE NO. -

WHERE:

M_p = PLASTIC MOMENT. MOMENT REQUIRED TO PRODUCE YIELDING OF
 THE COMPLETE SECTION OF PIPE (FT-LBS)

σ_y = YIELD STRESS

= 35000 PSI FOR SA-106, GRD-B

Z = PLASTIC SECTION OF MODULUS (in^3)

= $1/6 (OD^3 - ID^3)$ in^3

OD = OUT-SIDE DIA. OF PIPE (in)

ID = INSIDE DIA. OF PIPE (in)

T = TORSIONAL MOMENT (FT-LBS)

J = POLAR MOMENT OF INERTIA (in^4)

= $\pi/32 (OD^4 - ID^4) = .098175 (OD^4 - ID^4)$

FOR 2" SCH.-40 ; SA-106 GRD-B

$$M_p = \sigma_y Z / 12 =$$

$$= 35000 \times .7609 / 12$$

$$= 2219. \text{ FT-LBS.}$$

$$T = \sigma_y J / 24 R_i$$

$$= 35000 \times 1.3315 / 24 \times 1.0335$$

$$= 1878.8 \approx 1879.$$

$$OD = 2.375'' ; ID = 2.067'' ; R_i = 1.0335$$

$$Z = 1/6 (2.375^3 - 2.067^3) = .7609$$

$$J = \pi/32 (2.375^4 - 2.067^4) = 1.3315$$

Dev./Station CATAWBAUnit 1 File No. _____Subject LOADS ON ANCHOR AT SEISMIC & NON-SEISMIC PIPING INTERFACE
FOR PROBLEM - CAF & BWBBy ACP Date 12-20-80Sheet No. 20 of 40 Problem No. RCD-6-30-76 Checked By AKD Date 12-29-80

THIS PAGE ADDED @ REV-2

REF. DWG. CN-1491-BW013 REV-5

WT. OF 2" SCH-40 PIPE WITH WATER

IS 5.11 lbs/ft.

$$\therefore M_1 = 16.9271 \times 5.11 \approx 87. \text{ lbsm}$$

$$M_2 = 1.9167 \times 5.11 \approx 10. \text{ lbsm}$$

USING RESPONSE SPECTRA @ 577.0'

AUX. BLD. AND 595.0' R.B. WALL AND

VERT. RS. (ALL 1% DMP) THE

MAX. ACCELERATION USED ARE AS FOLLO

$$A_x = X(N-5) = 2.165 \text{ g.}$$

$$A_y = Y(\text{VERT}) = 0.41 \text{ g.}$$

$$A_z = Z(\text{E-W}) = 2.165 \text{ g.}$$

$$F = M \times A$$

$$F_{1x} = M_1 \times A_x = 87 \times 2.165 = 188. = F_{1z}; \quad F_{1y} = M_1 \times A_y = 87 \times 0.41 \approx 36.0$$

$$F_{2x} = M_2 \times A_x = 10 \times 2.165 = 22. = F_{2z}; \quad F_{2y} = M_2 \times A_y = 10 \times 0.41 \approx 4.0$$

CALCULATION OF F_{Ax} ANCHOR FORCE

$$\sum M_y = 0 = F_{1x} \times 8.4635 + F_{2x} \times 16.9271 + M_3 \times A_x \times 16.9271 - M_p$$

$$\therefore M_3 = (M_p - 1591. - 372.4) / A_x \times 16.9271$$

$$\therefore M_3 = 6.97$$

$$\sum F_x = 0 \therefore F_{Ax} = F_{1x} + F_{2x} + M_3 \times A_x = 188 + 22 + 15 = 225. \text{ lbsf}$$

CALCULATION OF F_{Az} ANCHOR FORCE.

$$\sum M_y = 0 = F_{1z} \times 0 + F_{2z} \times 9.584 + F_{3z} \times 1.9167 - M_p$$

$$\therefore F_{3z} = (2219 - 22) / 1.9167 = 1146 \text{ lbsf}$$

$$\sum F_z = 0 \therefore F_{Az} = F_{2z} + F_{3z} = 22 + 1146 = 1168. \text{ lbs.f}$$

CALCULATION OF F_{Ay} ANCHOR FORCE.

$$\sum M_x = 0 = F_{1y} \times 8.4635 + F_{2y} \times 16.9271 + F_{3y} \times 16.9271 - M_p$$

$$\therefore F_{3y} = (2219 - 305 - 68) / 16.9271 = 108.6 \approx 109$$

$$\sum F_y = 0 \therefore F_{Ay} = F_{1y} + F_{2y} + F_{3y} = 37 + 4 + 109 = 150$$

$$\sum M_z = 0 = F_{2y} \times 9.584 + F_{3y} \times 1.9167 - 1879$$

$$\therefore F_{3y} = (1879 - 38) / 1.9167 = 978.$$

$$\sum F_y = 0 \therefore F_{Ay} = F_{2y} + F_{3y} = 4 + 978 = 982.$$

$$\therefore F_{Ay} = 982 \text{ lbsf } (\because 982 > 150)$$

SO LOADS FOR ANCHOR
ON NON-SEISMIC SIDE
OF THE ANCHOR ARE

$$F_{Ax} = 225 \text{ lbs.}$$


$$F_{Ay} = 982. \text{ lbs.}$$

$$F_{Az} = 1168 \text{ lbs.}$$

$$M_{Ax} = M_p = 2219 \text{ ft-lbs.}$$

$$M_{Ay} = M_p = 2219 \text{ ft-lbs.}$$

$$M_{Az} = T = 1879 \text{ ft-lbs.}$$




Dev./Station CATAWBA Catawba Unit File No.
 Subject ANCHOR LOAD SUMMARY
 PROBLEM- CAF & BWB By Date
 Sheet No. 21 of 40 Problem No. RLD-G-30-78 Checked By Date

SUPPORT (ANCHOR) NO. I-R-BW-1547 PIPE SIZE & SCH. - 2" SCH 40

LOAD NO.	PROBLEM NAME	DCP. NO.	COMPUTER OUTPUT ID NO.	Design temp. of the pipe = <u>275</u> °F
1	BWB	49	3-3-81; 21:8:36	
2	BWB	49	SEE CALCULATED LOADS ON SH#20	
3	CAF	140	4-16-81; 14:08:51	

LOAD CONDITION	LOAD ID. NO.	LOADS (LBS) AND MOMENTS IN GLOBLE COORDINATES					
		Fx	Fy	Fz	Mx	My	Mz
COLD	1	0.	- 46	- 2	- 117	- 4	- 45
	3	- 6.	- 33	12	49	- 9	- 3
	TOTAL	- 6	- 79	10	- 68	- 13	- 48
HOT (+)	1	0.	- 46	- 83.	- 117	185.	- 44
	3	- 6	149	262	49	- 9	34
	TOTAL	0	149	345	49	185	34
HOT (-)	1	- 12	- 46	- 2	- 117	- 4	- 45
	3	- 254	- 33	- 2	- 365	- 641	- 3
	TOTAL	- 266	- 79	- 4	- 482	- 645	- 48
UPSET (+)	2	225	982	1168.	2219	2219	1879
	3	8	159	286	67	15	39
	TOTAL	233	1141	1454	2286	2234	1918
UPSET (-)	2	- 225.	- 982	- 1168	- 2219	- 2219	- 1879
	3	- 267	- 42	- 25	- 383	- 665	- 8
	TOTAL	- 492	- 1024	- 1193	- 2602	- 2884	- 1887
FAULTED (+)	2	225	982	1168	2219	2219	1879
	3	20	167	306	88	37	44
	TOTAL	245	1149	1474	2301	2256	1923
FAULTED (-)	2	- 225	- 982	- 1168	- 2219	- 2219	- 1879
	3	- 279	- 50	- 45	- 399	- 687	- 13
	TOTAL	- 504	- 1032	- 1213	- 2618	- 2906	- 1892
SSE (±)	2	± 225	± 982	± 1168	± 2219	± 2219	± 1879
	3	± 26	± 17	± 43	± 34	± 46	± 10
	TOTAL	± 251	± 999	± 1211	± 2253	± 2265	± 1889

No.	Revision	By/Date	Ckd/Date
3	This page separated from 2 page	ACP. 4/17/81	CEP 4/21/81



AUXILIARY BUILDING
 AUXILIARY FEEDWATER SYSTEM
 CATAWBA NUCLEAR STATION
 Figure 3.9.3-1
 Rev. 2

Item 59 - 3.7.3.4, page 3.7-29

The applicant states that rigid equipment/support systems have natural frequencies greater than 33 Hz as noted in Section 3.7.3.1. Is this a correct reference?

Response:

Page 3.7-29 will be revised (as attached) to read as follows:

Also, rigid equipment/support systems have natural frequencies greater than 33 Hz.

CNS

In all cases, equipment under earthquake loadings is designed to be within code allowable stresses.

Also, ~~as noted in Section 3.7.2.5~~ rigid equipment/support systems have natural frequencies greater than 33 Hz.

3.7.3.5 Use of Equivalent Static Load Method of Analysis

For seismic piping, the equivalent static load method involves the multiplication of the total weight of the equipment or component member by the specified seismic acceleration coefficient. The magnitude of the expected dynamic response coefficient is established on the basis of the Westinghouse scope which characteristics of the component. Components within Westinghouse scope which can be adequately characterized as a single degree of freedom systems are considered to have a modal participation factor of one. Seismic acceleration coefficients for multi-degree of freedom systems which may be in the resonance region of the amplified response spectra curves are increased by 50 percent to account conservatively for the increased modal participation.

3.7.3.6 Three Components of Earthquake Motion

Methods used to account for three components of earthquake motion for Westinghouse subsystems are given in Section 3.7.2.6.

For seismic piping other than NSSS, analysis is performed using simultaneous three-direction excitation. Directional responses are combined into a total response by taking the square root of the sum of the squares (SRSS) of individual responses. This method conforms fully to the recommendations of Regulatory Guide 1.92.

3.7.3.7 Combination of Modal Responses

Methods used to combine modal responses for subsystems in Westinghouse's scope of responsibility are given in Section 3.7.2.7.

For seismic piping other than the NSSS, modal responses are combined into a total response by taking the square root of the sum of the squares (SRSS) of individual responses. The responses from groups of closely spaced modes, defined as having frequencies between the lowest frequency in the group and a frequency ten percent higher, are combined by absolute summation; the resulting response for each group is then combined by SRSS with the remaining responses from the modes which are not closely spaced. This method conforms fully to the recommendations of Regulatory Guide 1.92.

3.7.3.8 Analytical Procedures for Piping

The criteria for determining which piping is to be seismic are discussed in Section 3.2.1. All seismic piping is classified Seismic Category I. The specific analytical procedures used in qualifying the pipe depend on its size, temperature, structural frequency, and other factors as discussed in this section.

Item 60 - 3.9.1.1, page 3.9-1

Emergency conditions are omitted here. Does this mean that the Small Steam Break and Small LOCA in Table 3.9.1-1 (page 2) are evaluated using faulted limits?

Response:

The design basis for the Catawba plant did not include emergency limits. Specifically, the ASME Code and internal Westinghouse design requirements did not address emergency conditions in the design basis. Consequently, it is not necessary to define emergency conditions in Section 3.9.1.

The definition of a small LOCA and a small steamline break as emergency conditions in Table 3.9.1-1 was also discussed. It was pointed out that these transients were inappropriately identified as emergency conditions for the Catawba plant and should be deleted from Table 3.9.1-1. Small break design transients for the Catawba plant are enveloped by upset and faulted condition limits. Specifically, fatigue considerations for small breaks are enveloped by upset condition transients. Structurally, small breaks are enveloped by large breaks considered under faulted condition limits.

Based on the above discussion and the attached revision to Table 3.9.1-1, this item was resolved.

ATTACHMENT TO ITEM 60

Table 3.9.1-1 (page 2)
Design Transients for ASME Code Class I Piping

(1) SIGN TRANSIENTS	(2) CONDITION	(3) OCCURRENCES	(4) RESIDUAL HEAT REMOVAL SYSTEM	SAFETY INJECTION SYSTEM	CHEMICAL AND VOLUME CONTROL SYSTEM	PRESSURIZER SURGE LINE	PRESSURIZER RELIEF	PRESSURIZER SPRAY	RID BYPASS	REACTOR COOLANT DRAIN LINES	UPPER HEAD INJECTION LINES
Loss of load without Immediate Turbine or Reactor Trip	Upset	80	X	X	X	X	X NOTES 4, 5	X	X	X	X
Loss of Flow in One Loop and Inadvertent SFS Actuation	Upset	80	X	X	X	X	X	X	X	X	X
Inadvertent RCS Depressurization	Upset	20	X	X	X	X	X	X	X	X	X
Inadvertent SI Accumulator Blowdown during Plant Shutdown	Upset	4	-	X	X	X	X	X	X	X	X
High Head Safety Injection on Injection	Upset	22	-	X	-	-	-	-	X	X	X
High Head Safety Injection on Injection	Upset	48	-	X	-	-	-	-	-	-	-
High Steam Break	Emergency	5	-	X	-	-	-	-	-	-	-
High Steam Break	Emergency	6	-	X	-	-	-	-	-	-	-
Large Steam Break	Faulted	1	X	X	X	X	X	X	X	X	X
High Head Safety Injection on Injection	Faulted	1	X	X	X	X	X	X	X	X	X
	Faulted	2	-	X	X	X	X	X	X	X	X
	Faulted	2	-	X	X	X	X	X	X	X	X
Line Roll Test	Test	10	X	X	X	X	X	X	X	X	X
Stochastic Test	Test	5	X	X	X	X	X	X	X	X	X
Primary Side Leak Test	Test	50	X	X	X	X	X	X	X	X	X
Inadvertent Auxiliary Spray	Test	1	-	X	X	X	X	X	X	X	X

9

N 16
Duke item
Catawba - 60

Portion of piping analyzed for 10 upset occurrences, remainder for 9 upset and 1 test occurrences.
Pressurizer surge line is analyzed for 80 occurrences of transient C-7, the final cooldown spray.
Pressurizer surge line is analyzed for 150,000 initial fluctuations and 3,000,000 random fluctuations.
These transients are conditions which can cause the PORV's to open. Although a total of 320 such transients are shown, the PORV inlet lines are analyzed for 100 such occurrences.
Analysis of the safety valves 40 occurrences were assumed.
Number of occurrences is 20,000,000.

X NOTE 1b

X NOTE 12

Item 61 - 3.9.1.1, page 3.9-7

How many cycles of OBE earthquake are used in the analysis?

Response:

See Items 49 and 51 for a discussion of the duration of the OBE. Based on Items 49 and 51, this item was resolved.

Item 62 - 3.9.1.1, page 3.9-8

The first paragraph lists conservative assumptions. Assumption a) is that "the reactor is initially in a hot, zero-power condition." Is this actually conservative?

Response:

For a steamline break transient the hot, zero power condition is a conservative assumption relative to thermal transients and control of the reactor coolant system. It was also noted that this assumption does not apply to structural and pipe break considerations for the main steamline and associated accident analyses(e.g., containment temperature).

Based on the above discussion, this item was resolved.

Item 64 - 3.9.1.2.1, page 3.9-9

This section states that "analyses must be in accordance with the functional and structural analysis requirements set forth in the applicable Duke specifications." Provide an example of the functional and structural analysis requirements set forth in applicable Duke specifications.

Response:

Duke will revise FSAR page 3.9-9 as attached. This item was closed.

psig coincident with steam generator secondary side pressure of 0 psig. The RCS is designed for 5 cycles of these hydrostatic tests, which are performed prior to plant startup. The number of cycles is independent of other operating transients.

Additional hydrostatic tests will be performed to meet the inservice inspection requirements of ASME Section XI Subarticle IS5-20. A total of four such tests is expected. The increase in the fatigue usage factor caused by these tests is easily covered by the conservative number (50) of primary side leakage tests that are considered for design.

3. Primary Side Leakage Test

Subsequent to each time the primary system has been opened, a leakage test will be performed. During this test the primary system pressure is, for design purposes, raised to 2500 psia, with the system temperature above the minimum temperature imposed by reactor vessel material ductility requirements, while the system is checked for leaks. In actual practice, the primary system is pressurized to approximately 2400 psia as measured at the pressurizer, to prevent the pressurizer safety valves from lifting during the test.

During this leakage test, the secondary side of the steam generator must be pressurized so that the pressure differential across the tube sheet does not exceed 1600 psi. This is accomplished with the steam, feedwater, and blowdown lines closed off. For design purposes, it is assumed that 50 cycles of this test will occur during the 40 year life of the plant.

3.9.1.2 Computer Programs Used in Analysis

3.9.1.2.1 Components and Equipment

In the qualification of specific components or equipment provided to Duke, vendors may use computer methods of analysis. These analyses must be in qualified accordance with the functional and structural analysis requirements set forth in the applicable Duke specification. *criteria*

3.9.1.2.2 Piping Systems

Static and dynamic analyses of Catawba piping systems are performed using the computer program SUPERPIPE which is owned and maintained by EDS Nuclear, Inc., 220 Montgomery Street, San Francisco, California 94104.

SUPERPIPE is a general purpose piping program which performs comprehensive structural analyses of linear elastic piping systems for dead weight, thermal expansion, seismic spectra or time history, arbitrary force time history and other loading conditions. Analyses are performed to ASME requirements for Class 1, 2 and 3 systems.

A piping system is idealized as a mathematical model consisting of lumped masses connected by mass elastic members. The location of lumped masses is chosen to accurately represent the dynamic characteristics of the system for a dynamic analysis. Adequately represent the weight distribution of

Item 65 - 3.9.1.4.3, page 3.9-14

The applicant states that "The component upper and lower lateral supports are inactive during plant heatup, cooldown and normal plant operating conditions. However, these restraints become active when the plant is at power and under the rapid motions of the reactor coolant loop components that occur from the dynamic loadings and are represented by stiffness matrices and/or individual tension or compression spring members in the dynamic model. The analyses are performed at the full power condition."

What component does this paragraph refer to? Is the full power condition a normal operating condition?

Response:

It was pointed out that the subject paragraph refers to the steam generator supports. Clarification was provided for the subject FSAR paragraph by pointing out that inactive refers to the fact that these supports are not in contact with the steam generator during normal heatup. During power operation the supports are shimmed to zero gap and become active relative to dynamic loading conditions such as LOCA and SSE. It was agreed that the FSAR should be revised to clarify the subject paragraph. The clarification to FSAR Section 3.9.1.4.3 is attached.

Based on the above discussion and the attached FSAK revision, this item was resolved.

ATTACHMENT TO ITEM 65

CNS

After all the sections have been defined in this matter, the overall stiffness matrix and associated load vector to suppress the deflection of all the network points is determined. By inverting the stiffness matrix, the flexibility matrix is determined. The flexibility matrix is multiplied by the negative of the load vector to determine the network point deflections due to the thermal and boundary force effects. Using the general transfer relationship, the deflections and internal forces are then determined at all node points in the system.

The static solutions for deadweight, thermal, and general pressure loading conditions are obtained by using the WESTDYN-7 computer program. The derivation of the hydraulic loads for the loss of coolant accident analysis of the loop is covered in Section 3.6.2.

Seismic

The model used in the static analysis is modified for the dynamic analysis by including the mass characteristics of the piping and equipment. The effect of the equipment motion on the reactor coolant loop/supports system is obtained by modeling the mass and the stiffness characteristics of the equipment in the overall system model.

The steam generator is represented by three discrete masses. The lower mass is located at the intersection of the centerlines of the inlet and outlet nozzles of the steam generator. The middle mass is located at the steam generator upper support elevation and the third mass is located at the top of the steam generator.

The reactor coolant pump is represented by a two discrete mass model. The lower mass is located at the intersection of the centerlines of the pump suction and discharge nozzles. The upper mass is located near the center of gravity of the motor.

The reactor vessel and core internals are represented by approximately 13 discrete masses. The masses are lumped at various locations along the length of the vessel and along the length of the representation of the core internals.

STEAM GENERATOR

The ~~component~~ upper and lower lateral supports are inactive during plant heatup, cooldown and normal plant operating conditions. ~~However, these restraints become active when the plant is at power and under the rapid motions of the~~ *(i.e. do not provide support)* reactor coolant loop components that occur from the dynamic loadings and are represented by stiffness matrices and/or individual tension or compression spring members in the dynamic model. The analyses are performed at the full power condition. *(They)*

(i.e. provide support only)

The response spectra method employs the lumped mass technique, linear elastic properties, and the principle of modal superposition. Floor response spectra are generated for two perpendicular horizontal directions and the vertical direction. The floor response spectra are applied along each horizontal axis simultaneously with the vertical axis.

subject to dynamic loads from events such as S.W.A.

Item 66 - 3.9.1.4.3, page 3.9-15

The applicant states that "The modal amplitudes are then converted to displacements in the global coordinate system and applied to the corresponding mass point. From these data the forces, moments, deflections, rotations, support reactions and piping stresses are calculated for all significant modes." What criteria is used to determine the significant modes?

Response:

For the reactor coolant system Westinghouse indicated that all modes with a corresponding displacement greater than 0.001 inch are considered in the analysis up to a frequency of 200 cps.

Based on the above discussion, this item was resolved.

Item 67 - 3.9.1.4.3, page 3.9-15

Justify the use of 4% critical damping for the loss of coolant accident?

Response:

Westinghouse utilizes 4% critical damping for the evaluation of the reactor coolant system for a loss of coolant accident. Justification of this damping value is provided in WCAP 7921AR which has been approved by the NRC. This topical report has been included in the FSAR and added to the list of references contained in Section 3.9. Based on the above discussion and the attached FSAR revision, this item was resolved.

ATTACHMENT TO ITEM 67

CNS

From the mathematical description of the system, the overall stiffness matrix K is developed from the individual element stiffness matrices using the transfer matrix method. After deleting the rows and columns representing rigid restraints, the stiffness matrix is revised to obtain a reduced stiffness matrix (K_R associated with mass degrees of freedom only). From the mass matrix and the reduced stiffness matrix, the natural frequencies and the normal modes are determined. The modal participation factor matrix is computed and combined with the appropriate response spectra value to give the modal amplitude for each mode. The total modal amplitude is obtained by computing the absolute sum of the contributions for each direction.

The modal amplitudes are then converted to displacements in the global coordinate system and applied to the corresponding mass point. From these data the forces, moments, deflections, rotations, support reactions and piping stresses are calculated for all significant modes.

The total seismic response is computed by combining the contributions of the significant modes by using the methods described in Section 3.7.

Loss of Coolant Accident

The mathematical model used in the static analyses is modified for the loss of coolant accident analyses to represent the severance of the reactor coolant loop piping at the postulated break location. Modifications include addition of the mass characteristic of the piping and equipment. To obtain the proper dynamic solution, two masses, each containing six dynamic degrees of freedom and located on each side of the break, are included in the mathematical model. The natural frequencies and eigenvectors are determined from this broken loop model.

The dynamic structural solution for the loss of coolant accident is obtained by using a modified-predictor-corrector-integration technique and normal mode theory.

When elements of the system can be represented as single acting members (tension or compression members), they are modelled as nonlinear elements, which are represented mathematically by the combination of a gap, a spring, and a viscous damper. The force in this nonlinear element is treated as an externally applied force in the overall normal mode solution. Multiple non-linear elements can be applied at the same node, if necessary.

The time-history solution is performed in subprogram FIXFM3. The input to this subprogram consists of the natural frequencies, normal modes, applied forces and nonlinear elements. The natural frequencies and normal modes for the modified reactor coolant loop dynamic model are determined with the WESTDYN-7 program. To properly simulate the release of the strain energy in the pipe, the internal forces in the system at the postulated break location due to the initial steady-state hydraulic forces, thermal forces, and weight forces are determined. The release of the strain energy is accounted for by applying the negative of these internal forces as a step function loading. The initial conditions are equal to zero because the solution is only for the transient problem (the dynamic response to the system from the static equilibrium position). The time history displacement solution of all dynamic degrees of freedom is obtained using subprogram FIXFM3 and employing 4 percent critical damping. (DAMPING VALUES - SEE 14)

ATTACHMENT TO ITEM 67

CNS

REFERENCES FOR SECTION 3.9

1. "Documentation of Selected Westinghouse Structural Analysis Computer Codes," WCAP-8252, Revision 1, May 1977.
2. "Benchmark Problem Solutions Employed for Verification of WECAN Computer Program," WCAP-8929, June 1977.
3. "Sample Analysis of a Class 1 Nuclear Piping System," prepared by ASME Working Group on Piping, AMSE Publication, 1972.
4. Witt, F.J., Bamford, W.H., Esselman, T.C., "Integrity of Primary Piping Systems of Westinghouse Nuclear Power Plants During Postulated Seismic Events," WCAP-9283, March 1978.
5. Bogard, W.T., Esselman, T.C., "Combination of Safe Shutdown Earthquake and Loss-of-Coolant Accident Responses for Faulted Condition Evaluation of Nuclear Power Plants," WCAP-9279, March 1978.
6. Bloyd, C.N., Ciarametars, W., and Singleton, N.R., "Verification of Neutron Pad and 17 x 17 Guide Tube Designs by Preoperational Tests on the Trojan I Power Plant," WCAP-8780, May 1976.
7. Lee, H., "Prediction of the Flow-Induced Vibration of Reactor Internals by Scale Model Test", WCAP-8317-A, July 1975.
8. Bloyd, C.N., Singleton, N.R., "UHI Plant Internals Vibration Measurement Program and Pre- and Post-Hot Functional Examinations", WCAP-8517, March 1975.
9. Bohm, G.J. and LaFaille, J.P., "Reactor Internals Response Under a Blowdown Accident", First Intl. Conf. on Structural Mechanics in Reactor Technology, Berlin, September 20-24, 1971.
10. "Documentation of Selected Westinghouse Structural Analysis Computer Codes", WCAP-8252, April 1974, Section VI.
11. Cooper, F.W., Jr., "17 x 17 Drive Line Components Tests - Phase 1B 11, 111, D-Loop-Droop and Deflection", WCAP-8446 (Westinghouse Proprietary Class 2), WCAP-8449 (Westinghouse Non-Proprietary) December, 1974.
12. Kraus, S., "Neutron Shielding Pads", WCAP-7870, May, 1972.
13. "MULTIFLEX, A FORTRAN IV Computer Program for Analyzing Thermal-Hydraulic Structures System Dynamics," WCAP-8709, February 1976 (Proprietary), and WCAP-8709, February 1976 (Non-Proprietary).
14. CLOUD, R.L., "DAMPING VALUES OF NUCLEAR PLANT COMPONENTS", WCAP-7921 - AR - MAY 1974

Item 68 - 3.9.1.4.3, page 3.9-16

The last paragraph refers to Figure 3.9.1-2. Provide this figure.

Response:

The figure is already provided.

Item 69 - 3.9.1.4.4, page 3.9-19

The third paragraph says that seismic analyses are performed individually for the reactor coolant pump, the pressurizer and the steam generator. How is the connected piping handled for these components?

Response:

Westinghouse discussed how RCS piping effects are included in the analysis of the steam generator, reactor coolant pump, and pressurizer. Details of this discussion for each component is as follows:

- Steam Generator - A generic analysis of this component is performed taking into account the upper and lower bound stiffness of the component supports and the stiffness of the RCS piping. Several combinations of stiffnesses are analyzed. This generic analysis envelopes the Catawba plant.
- Reactor Coolant Pump - For this component a specific plant analysis was performed taking into account the stiffness of the supports and piping for the Catawba plant.
- Pressurizer - The effects of piping on the pressurizer are negligible and the piping stiffness is ignored. The pressurizer analysis is controlled by the support stiffness. The pressurizer nozzle is qualified to generic loads. These nozzle allowables are provided to Duke for consideration in their piping analysis.

Based on the above discussions, this item was resolved.

Item 70 - 3.9.1.4.4, page 3.9-19

The last sentence of the third paragraph says that qualification of the reactor pressure vessel is by a "static stress analysis based on loads that have been derived from dynamic analysis." Provide details of this analysis and justify its use.

Response:

The discussion focused on the reference to the static stress analyses for the reactor vessel. It was pointed out that this reference was only intended to cover inertial loads. It was pointed out that the Westinghouse RV vendor performs a static stress analysis utilizing generic loads specified by Westinghouse. Such loads include nozzle loads and internal loads on the vessel. The generic loads specified by Westinghouse are generated from dynamic systems analysis. Westinghouse also indicated that the RV vendor also performs transient analysis on the vessel but the subject FSAR paragraph was not intended to address this analysis. It was agreed that the methods discussed by Westinghouse were acceptable but the subject FSAR paragraph required clarification. The clarification to Section 3.9.1.4.4 has been made consistent with the above discussion.

Based upon the above discussion and the attached revision to the FSAR, this item was resolved.

ATTACHMENT TO ITEM 70

CNS

3.9.1.4.4 Analysis of Primary Components

Equipment which serves as part of the pressure boundary in the reactor coolant loop include the steam generators, the reactor coolant pumps, the pressurizer, and the reactor vessel. This equipment is ANS Safety Class 1 and the pressure boundary meets the requirements of the ASME Boiler and Pressure Vessel Code, Section III, Subsection NB. This equipment is evaluated for the loading combinations outlined in Table 3.9.1-2. The equipment is analyzed for 1) the normal loads of dead-weight, pressure and thermal, 2) mechanical transients of OBE, SSE, and pipe ruptures, including the effects of asymmetric pressurization, and 3) pressure and temperature transients outlined in Section 3.9.1.1.

The results of the reactor coolant loop analysis are used to determine the loads acting on the equipment nozzles and the support/component interface locations. These loads are supplied for all loading conditions on an "umbrella" load basis. That is, on the basis of previous plant analyses, a set of loads are determined which should be larger than those seen in any single plant analysis. The umbrella loads represent a conservative means of allowing detailed component analysis prior to the completion of the system analysis. Upon completion of the system analysis, conformance is demonstrated between the actual plant loads and the loads used in the analyses of the components. Any deviations where the actual load is larger than the umbrella load will be handled by individualized analysis.

Seismic analyses are performed individually for the reactor coolant pump, the pressurizer, and the steam generator. Detailed and complex dynamic models are used for the dynamic analyses. The response spectra corresponding to the building elevation at the highest component/building attachment elevation is used for the component analysis. Seismic analyses for the steam generator and pressurizer are performed using 2 percent damping for the OBE and 4 percent damping for the SSE. The analysis of the reactor coolant pump for determination of loads on the motor, main flange, and pump internals is performed using the damping for bolted steel structures, that is, 2 percent for the OBE and 5 percent for the SSE (0.5 percent for OBE and 1.0 percent for SSE is used in the system analysis). This damping is applicable to the reactor coolant pump since the main flange, motor stand, and motor are all bolted assemblies (See Section 5.4). The reactor pressure vessel is qualified by ~~static stress analysis based on loads that have been derived from dynamic analysis.~~ *Seismically* the reactor vessel vendor in accordance with the ASME Code.

The pressure boundary portions of Class 1 valves in the RCS are designed and analyzed according to the requirements of NB-3500 of ASME III.

Valves in sample lines connected to the RCS are not considered to be ANS Safety Class 1 nor ASME Class 1. This is because the nozzles where the line connect to the primary system piping are orificed to a 3/8 inch hole. This hole restricts the flow such that loss through a severance of one of these lines can be made up by normal charging flow.

The loadings used in this analysis are supplied by Westinghouse and are based on loads generated by a dynamic systems analysis.

Item 71 - 3.9.1.4.4, page 3.9-19

In the third paragraph, the applicant states that the "Seismic analyses for the steam generator and pressurizer are performed using 2 percent damping for the OBE and 4 percent damping for the SSE." Justify the use of 4% critical damping for the SSE.

Response:

Westinghouse utilizes 4% damping in the analysis of primary components for the SSE. Justification for the 4% damping is provided in WCAP 7921AR which has been approved by the NRC. As identified in Item 67, revisions have been made to the FSAR to incorporate this topical report as Reference 14. Additionally, reference has been made in Section 3.9.1.4.4 to WCAP 7921AR.

Based upon the above discussion, Item 67, and the attached FSAR change, this item is resolved.

ATTACHMENT TO ITEM 71

CNS

3.9.1.4.4 Analysis of Primary Components

Equipment which serves as part of the pressure boundary in the reactor coolant loop include the steam generators, the reactor coolant pumps, the pressurizer, and the reactor vessel. This equipment is ANS Safety Class 1 and the pressure boundary meets the requirements of the ASME Boiler and Pressure Vessel Code, Section III, Subsection NB. This equipment is evaluated for the loading combinations outlined in Table 3.9.1-2. The equipment is analyzed for 1) the normal loads of dead-weight, pressure and thermal, 2) mechanical transients of OBE, SSE, and pipe ruptures, including the effects of asymmetric pressurization, and 3) pressure and temperature transients outlined in Section 3.9.1.1.

The results of the reactor coolant loop analysis are used to determine the loads acting on the equipment nozzles and the support/component interface locations. These loads are supplied for all loading conditions on an "umbrella" load basis. That is, on the basis of previous plant analyses, a set of loads are determined which should be larger than those seen in any single plant analysis. The umbrella loads represent a conservative means of allowing detailed component analysis prior to the completion of the system analysis. Upon completion of the system analysis, conformance is demonstrated between the actual plant loads and the loads used in the analyses of the components. Any deviations where the actual load is larger than the umbrella load will be handled by individualized analysis.

(REFERENCE 14) Seismic analyses are performed individually for the reactor coolant pump, the pressurizer, and the steam generator. Detailed and complex dynamic models are used for the dynamic analyses. The response spectra corresponding to the building elevation at the highest component/building attachment elevation is used for the component analysis. Seismic analyses for the steam generator and pressurizer are performed using 2 percent damping for the OBE and 4 percent damping for the SSE. The analysis of the reactor coolant pump for determination of loads on the motor, main flange, and pump internals is performed using the damping for bolted steel structures, that is, 2 percent for the OBE and 5 percent for the SSE (0.5 percent for OBE and 1.0 percent for SSE is used in the system analysis). This damping is applicable to the reactor coolant pump since the main flange, motor stand, and motor are all bolted assemblies (See Section 5.4). The reactor pressure vessel is qualified by static stress analysis based on loads that have been derived from dynamic analysis.

The pressure boundary portions of Class 1 valves in the RCS are designed and analyzed according to the requirements of NB-3500 of ASME III.

Valves in sample lines connected to the RCS are not considered to be ANS Safety Class 1 nor ASME Class 1. This is because the nozzles where the line connect to the primary system piping are orificed to a 3/8 inch hole. This hole restricts the flow such that loss through a severance of one of these lines can be made up by normal charging flow.

Item 72 - 3.9.1.4.5, page 3.9-20

The applicant states "Pipe displacement restraints installed in the primary shield wall limit the break opening area of the vessel nozzle pipe breaks. An upper bound break area of 85 square inches was determined, taking into account the primary shield wall pipe restraints and vessel and pipe relative motions from similar plant analyses. Detailed studies have shown that pipe breaks at the hot or cold leg reactor vessel nozzles, even with a limited break area, would give the highest reactor vessel support loads and the highest vessel displacements, primarily due to the influence of reactor cavity pressurization."

Provide supporting evidence for an upper bound break area of 85 square inches. Were the detailed studies which showed that pipe breaks at reactor vessel nozzles give highest vessel support loads and displacement performed for the Catawba plant? If performed for a similar plant, show that they are indeed similar to Catawba.

Response:

As discussed in Item 12 and 14, analyses were performed to demonstrate that the break opening area of 85 square inches is conservative. Westinghouse has performed specific plant analyses for plants such as SNUPPS (Callaway, Wolf Creek) as well as generic analyses which demonstrate that breaks at the RV nozzles result in the highest loads and displacements on the vessel supports. Although no such comparative analysis was performed for Catawba, previous analysis results apply because of the similarities in Westinghouse plant designs. The major similarity is the configuration of the reactor cavity annulus which is the governing factor in determining RV support loads and displacements.

Based on the above discussion and the information provided for Item 12, this item was resolved.

Item 73 - 3.9.1.4.6, page 3.9-23

The first paragraph of item 1 identifies stress limit criteria which are not in compliance with Appendix F of the ASME Code. Provide a commitment to the stress limit criteria of Appendix F of the ASME Code.

Response:

Westinghouse indicated that this method was only used for the reactor coolant pump feet. A generic analysis was used to qualify the pump feet, however, the specific stresses were not available. Westinghouse indicated that the analysis did demonstrate compliance with the 90% ultimate stress as specified in the FSAR. It was agreed that the subject paragraph in the FSAR would satisfy Appendix F requirements if the 90% criteria were deleted. Westinghouse indicated that they would review the analysis further to determine if Appendix F criteria could be satisfied. Based on this review, it has been determined that Appendix F criteria have been satisfied for the reactor coolant pump feet. As a result of this review, the 90% criteria has been deleted from the FSAR.

Based on the above information and the attached FSAR revision, this item is resolved.

ATTACHMENT TO ITEM 73

CNS

even though the time history results show that these loads occur neither simultaneously nor on the same support.

The largest vertical loads are produced on the support, opposite the broken nozzle. The largest horizontal loads are produced on the supports which are perpendicular to the broken nozzle horizontal centerline. Note that the peak loads are conservative values since the break opening area for the vessel inlet nozzle break (as obtained from the dynamic loop analysis) is actually less than the estimated 85 square inch area used to generate the applied loads. If additional analysis was performed using the lower break opening area, the loads would be considerably reduced.

3.9.1.4.6 Stress Criteria for Class 1 Components and Component Supports

All Class 1 components and supports are designed and analyzed for the design, normal, and upset conditions to the rules and requirements of the ASME Code Section III. The design analysis or test methods and associated stress or load allowable limits that will be used in evaluation of faulted conditions are those that are defined in Appendix F of the ASME Code with supplementary options outlined below:

1. Elastic System Analysis and Component Inelastic analysis

This is an acceptable method of evaluation for Faulted Conditions if primary stress limits for components are taken as greater of $0.70 S_u$ or $S_y + 1/3$

$(S_u - S_y)$ for membrane stress and greater of $0.70 S_{ut}$ or $S_y + 1/3 (S_{ut} - S_y)$ for membrane plus-bending stress, where material properties are taken at appropriate temperature, and the maximum stress is limited to ~~90% of the material stress~~

If plastic component analysis is used with elastic system analysis or with plastic system analysis, the deformations and displacements of the individual system members will be shown to be no larger than those which can be properly calculated by the analytical methods used for the system analysis.

2. Elastic/Inelastic System Analysis and Component/Test Load Method

The test load method given in F-1370(d) is an acceptable method of qualifying components in lieu of satisfying the stress/load limits established for the component analysis.

If the component/test load method is used with elastic or plastic system analysis, the deformations and displacements of the individual component members taken from the test load method data at the loads resulting from the system analysis will be shown to be no larger than those which can be properly calculated by the analytical methods used for the system analysis.

A list of seismic Category I equipment and the method of qualification used is provided in Table 3.2.1-1, 3.2.1-2, 3.2.2-2, and 3.2.3.-1.

Item 74 - 3.9.1.4.6, page 3.9-23

The applicant states "If plastic component analysis is used with elastic system analysis or with plastic system analysis, the deformations and displacements of the individual system members will be shown to be no larger than those which can be properly calculated by the analytical methods used for the system analysis." Indicate when this has been used.

Response:

The test load method is used by Westinghouse for the reactor vessel pads. This item has been discussed in other meetings and has been justified based on one-eighth scale model tests.

Based on the above discussions, this item was resolved.

Item 75 - 3.9.1.4.7, page 3.9-24

The first paragraph indicates that elastically determined stresses will be compared against inelastic limits. This approach is not one of the methods listed in Appendix F of the ASME Code. Provide an example of the analyses and provide assurance that this method is at least as conservative as those in Appendix F.

Editorial Comment

The applicant states "Dynamic Seismic analysis for the SSE is performed on this piping utilizing the response spectrum method in accordance with USNRC Regulatory Guide 1.92." Is this a correct reference?

Response:

Page 3.9-24 will be revised (as attached).

CNS

Loading combinations and allowable stresses for ASME III Class 1 components and supports are given in Tables 3.9.1-2 and 3.9.1-3. For Faulted condition evaluations, the effects of the safe shutdown earthquake (SSE) and loss-of-coolant accident (LOCA) are combined using the square root of the sum of the squares (SRSS) method. Justification for this method of load combination is contained in References 4 and 5. The responses to other loading combinations defined in Table 3.9.1-2 are combined using the absolute sum method.

3.9.1.4.7 Balance-of-Plant Components, Piping and Supports

Seismic category I piping other than NSSS is analyzed for the faulted condition utilizing elastically-determined stresses compared against ~~inelastic limits~~. This is in accordance with applicable sections of the ASME Code or ANSI B31.1 as appropriate. Load combinations and allowable stresses for faulted and other plant conditions are discussed in Section 3.9.3.

Dynamic seismic analysis for the SSE is performed on this piping utilizing the ~~response spectrum~~ *model combination* method in accordance with USNRC Regulatory Guide 1.92.

All seismic Category 1 supports are designed and analyzed for the Normal, Upset, Faulted and Test Conditions. The stress limits for normal and upset conditions are as presented in ASME III Subsection NF and Subsection NA Appendix XVII for the portion of the support within the NF boundary. The stress limit for the faulted load combination is as specified in Subsection NF with the exception that to avoid column buckling in compression, for members subject to local instability associated with compression flange buckling in flexural members and web buckling in plate guides, the allowable stress has been limited to 2/3 of the critical buckling stress. For support design there is no inelastic analysis. Temperature effects for material properties are considered. For the portion of the support not within the NF boundary and for supports for B31.1 piping, stress limits are as provided in MSC-SP58 or the AISC Manual.

For integral attachments to the pressure boundary the rules of ASME Section III, Subsection NB, NC, ND are used as applicable.

3.9.2 DYNAMIC TESTING AND ANALYSIS

3.9.2.1 System Operational Test Program

3.9.2.1.1 System Vibration Testing

ASME III requires that piping design minimize vibration and that piping systems be observed under startup or initial operating conditions to insure that steady state vibration in piping systems is not excessive. As part of the preoperational test program described in Chapter 14, steady state piping vibration and transient response of piping due to valve closures, pump starts, and other changing configurations are observed. Details of the tests are given in Table 14.2.12-1.

Duke Class A, B, C, and F systems satisfy the criteria of Regulatory Guide 1.68, Revision 2 for systems to be included in the vibration test program. Systems

*allowables provided in
Table F-1322.2-1 of Appendix
F of the ASME Code Section III.*

Provide your interpretation of jurisdictional boundaries as they pertain to IIF supports. Justify your position.

Response:

Subsection NF of the ASME Boiler and Pressure Vessel Code defines requirements for structural elements for both component supports and piping supports. In reviewing application of this subsection to structural elements of pipe supports Duke Power Company has defined jurisdictional boundaries to be within the scope of subsection NF when the ASME code provisions are clearly applicable and result in rational structural requirements for design and construction. Many aspects of structural steel design have a long and established history of adequate and reasonable application by structural engineers. For this reason, Duke Power Company uses applicable codes and standards other than ASME standards for the majority of structural steel design associated with pipe supports. Boundaries between items designed and fabricated to Subsection NF and those designed and fabricated to codes and standards applicable to building structural items are clearly designated on all drawings released for construction. Guidelines for defining these standard boundaries are provided in Duke specification CNS-1206.00-04-0001 Design Specification For Nuclear Safety Related Component Supports (QA Condition 1). A copy of this document has been previously provided to NRC representatives.

As justification for our position we have been asked by the staff to show approximate equivalence across jurisdictional boundaries for several specific items.

1. Presence of clearly defined structural requirements on both sides of the jurisdictional boundary.

The Design Specification clearly defines design criteria to be followed on both sides of the NF boundary. For both normal and upset conditions, structural steel is designed to normal allowable limits per AISC requirements, regardless of boundary. For the faulted condition, additional conservatism over and above that required by Appendix F is provided by limiting steel stress to 1.33 x AISC allowables within the NF boundary and to 1.5 x AISC allowables outside the NF boundary. This is consistent with allowable values used for building structural steel. Limiting stresses under faulted conditions to the elastic stress range as provided by these measures provides that the structure performs as predicted by elastic analysis procedures that are well documented and provides a degree of conservatism due to additional capacity in the inelastic range of materials which is not utilized.

2. Consideration of the relevance of buckling as a factor in support design.

For normal and upset conditions, use of AISC allowable stresses results in appropriate safety factors against buckling for these conditions.

Use of the 1.5 factor on AISC allowable stresses for the faulted condition subsequently reduces the safety factor against buckling but maintains adequate margins for this condition. In the region of "short column" buckling (for $f_y=36$, $\frac{kL}{r} < 126$) formulas presented by AISC

and use of the 1.5 factor allows values of allowable stress to approach 0.9 x yield strength. Critical buckling as presented by the Euler approach is not the predominant failure mode in this region. For KL/r values above the critical buckling coefficient, AISC limits stresses to 12/23 x critical buckling stress. Use of the 1.5 for faulted loading increases this limit to 18/23 x critical buckling stress. This value is slightly higher than the 2/3 value proposed by the staff.

In actuality, buckling strength is seldom the controlling factor in structural steel or pipe support design. Bending and shear forces are the predominant limiting stress considerations. Coupling these limits with deflection limitations imposed on the supports, required to make the supports relatively stiff compared to the piping for stress analysis validation, removes most consideration of buckling from the analytical approach to pipe support design. Predominance of tube steel in support design, primarily due to superior properties for torsional resistance, provides relatively low L/r ratios for design, further obviating the need for a stringent review of buckling as a critical factor. However, changing the design specification to account for a 2/3 factor on buckling rather than 18/23 would require individual review of each of more than 20,000 calculations already completed for Nuclear Safety Related pipe supports at the Catawba Station. In short, we feel the slight difference in buckling limits has little, if any, relevance in support design and the methods and allowable stresses used for Catawba present a safe and adequate situation.

3. Use of initial overdesign as an added conservatism.

Beginning in December 1979, new support designs initiated for Catawba Nuclear Station were conservatively designed by incorporation of an additional 25% of piping loads supplied into design loads for the support. Rational for this conservatism included reduction of changes due to revised loadings by reanalysis and increased margin available when field conditions would not allow all elements of the design drawing to be fabricated per drawing requirements. Although such changes have resulted in encroachment into the margin in many cases, for an even greater number of cases, the margin is now increased as piping loads have decreased. Coupled with the fact that the full capacity of a member is seldom used when structural engineers provide a design which is limited only by a maximum criteria, pipe support designs for the Catawba Station are certainly conservative and provide high confidence that adequate structures for pipe supports are produced.

4. Materials control and mill test certification reports.

Materials purchased for Catawba Nuclear Station are classified on site as either safety related or non-safety related. Materials used within the NF jurisdictional boundary which are not "bulk stock" items, such as component standard supports are purchased from an authorized supplier per Subsection NA-3700 and NCA-3800. Certified mill test reports in accordance with NF-2130(a) are obtained showing compliance with Section III Subsection NF requirements for Class I materials. Traceability of

component standard supports are maintained for Class A supports. Bulk stock items, such as miscellaneous steel are received on site with certified mill test reports. Tube steel inside the NF boundary is purchased to requirements of Code Case N-71-8.

Design drawings define materials specifications inside the NF jurisdictional boundary as SA/A showing that the appropriate ASTM specification and ASME specification are equivalent. Tube steel furnished per Design drawings reference Code Case N-71-8. Material furnished on Design drawings outside the NF boundary reference the appropriate ASTM specification. Both material inside and outside the NF boundary for structural items other than component standard supports are furnished from Nuclear Safety Related field bulk stock and are equivalent as certified mill test reports are furnished as previously mentioned. Receipt of CMTR's are part of initial receiving inspection procedures.

5. Weld inspection and NDE requirements.

Weld inspection inside the NF boundary is performed per Duke Power Company QA requirements for ASME Code work and meets requirements of Subsection NF, Article NF-5000. An Authorized Nuclear Inspector, independent of Duke Power Company, reviews each support package prior to fabrication. The ANI has authority to add inspection hold points and additional NDE requirements appropriate.

All welders utilized for supports on ASME Code piping are qualified for both requirements of AWS D1.1 and ASME Section IX.

Predominant weld types on welds within and outside the NF boundary are fillet and partial penetration welds. Visual inspection is performed by qualified QC inspectors for all welds with other NDE requirements specified where appropriate.

6. Duke Power Company control of design and construction and resultant "reasonableness" of job.

Duke Power Company designs, fabricates and erects the supports for Catawba Nuclear Station. This provides unique advantages in the enforcement of requirements both within the NF jurisdictional boundary and outside that boundary. The intent of specification requirements is maintained throughout the design and construction process through direct communication between designer, fabricator and erector. This close interface is not always possible when design, fabrication and erection are contracted to different companies.

Item 79 3.9.2.3, page 3.9-32

The first full paragraph mentions three plants which provide prototypical data. Which of the three plants --Indian Point 2, Trojan or Sequoyah 1-- is the valid prototype for Catawba?

Response:

The prototype plant for Catawba is Indian Point Unit 2. The IPP-2 plant was fully instrumented and tested during hot functional and pre-operational testing. Additionally, available test data on the Trojan 1 and Sequoyah 1 plants together with the prototype IPP-2 results can be used to characterize vibrational characteristics of 4-loop internals. The significant differences between Catawba and IPP-2 internals are the replacement of the annular thermal shield with neutron panels, modifications resulting from the use of 17x17 fuel and the change to UHI-style inverted top hat upper internals.

Upper Internals

The upper internals of Catawba and that of the tested Sequoyah 1 unit are similar with the UHI-style inverted top hat configuration. The upper internals adequacy of Sequoyah 1 has been established by the plant tests and supplemented with the scale model tests of similar configurations. The results of testing at Sequoyah 1 show that components are excited by flow-induced and pump related excitations. Analyses of the data indicate that the instrumented components have adequate factors of safety and that the vibration behavior is well characterized. A specific comparison of the Sequoyah upper head characteristics with the Catawba plant is provided in the response to Item 80. This information demonstrates that appropriate safety margins exist for the upper internals. In summary, structural adequacy and vibratory behavior of the Catawba upper internals configuration has been established by testing at the Sequoyah 1 plant.

Neutron Panels (Core Barrel)

Scale model tests indicate significantly lower vibrational levels for internals

with neutron panels than for internals with annular thermal shields. Test results from Trojan 1 (neutron panels similar to Catawba) show lower vibration levels than on IPP-2. The primary source of excitation of the core barrel is flow turbulence generated at the inlet nozzles and in the downcomer. Since both Catawba and Trojan 1 have neutron panels, the vibration levels are similar. The coolant inlet temperature and flow rate of Catawba are slightly higher than Trojan 1. Scale model tests show that the core barrel vibration levels vary as the velocity raised to a small power. The differences in fluid density and flow rate result in an approximately 5.8% higher core barrel vibrations for Catawba when compared with Trojan 1. This correlation and the fact that the scale model tests and plant tests show that vibration levels are lower with neutron panels than annular thermal shields leads to the conclusion that stresses less than or approximately equal to IPP-2 will result on the Catawba internals.

17x17 Fuel

Fuel assembly masses and stiffnesses remain relatively unchanged, and so no significant change in internals vibration is expected.

With the inclusion of data relative to the Sequoyah/Catawba upper internals comparison in Item 80 and the minor revision to FSAR Section 3.9.2.3.3 (attached to Item 80), this item is resolved.

Item 80 3.9.2.3, page 3.9-33

Item 3 discusses vibration of the upper internals. The second to the last sentence says that "Applying a 5% increase in level to the high factors of safety deduced from Sequoyah 1 data results in adequate margins for Catawba upper internals." What are the margins for the upper internals?

Response:

Portions of Section 3.9.2.2.2 will be changed to read:

". . . The vibration of the upper internals due to flow turbulence is approximately proportional to the product of density, and velocity, V , squared (reference 8). This product is approximately 5% higher in Catawba than Sequoyah 1. By applying the 5% increase in the quantity ρV^2 (i.e., density times velocity squared) to the high factors of safety deduced from the Sequoyah 1 data, the minimum factor of safety for the Catawba upper internals is 1.80 (reference 14). The changes in the fluid . . . frequencies."

It was pointed out that the 1.8 safety factor refers to margin relative to the endurance limit. It was also noted that Reference 14 will be added to the FSAR.

Based on the above discussion and the attached FSAR change, this item was resolved.

* By applying the 5% increase in the quantity ρV^2 (i.e., density times velocity squared) to high factors of safety deduced from the Sequoyah 1 data, the minimum factor of safety for the Catawba upper internals is 1.8 (Reference 14).

CNS

3. UHI Inverted Top Hat Upper Support Configuration

The components of the upper internals are excited by turbulent forces due to axial and cross flows in the upper plenum (Reference 8) and pump speed related components. Sequoyah and Catawba have the same upper internals configuration; therefore, the general vibration behavior is not changed. Data on upper internals vibration have been obtained during hot functional testing at Sequoyah 1. A preliminary report on analysis of the data has been submitted. A final report including measurements with the core in place is in preparation. Reduction of the data and the post hot functional inspection results provide assurance of the design adequacy. The increased flow rate of Catawba with respect to Sequoyah is reflected in upper internals vibrations primarily as a change in fluid velocity. The vibration of the upper internals due to flow turbulence is approximately proportional to the product of density and velocity squared (Reference 8). This product is approximately 5% higher in Catawba than Sequoyah 1. ~~*Applying a 5% increase in level to the high factors of safety deduced from Sequoyah 1 data results in adequate margins for Catawba upper internals.~~ The change in fluid density and elastic modulus due to outlet temperature differences results in a very small change in structural natural frequencies.

Further data have been obtained during initial startup testing of Sequoyah-1. These data indicate lower vibration levels (and consequently higher factors of safety) than those deduced from hot functional data.

The original test and analysis of the four-loop configuration is augmented by (References 6, 7, and 8) to cover the effects of successive hardware modifications.

3.9.2.4 Preoperation Flow-Induced Vibration Testing of Reactor Internals

Because the Catawba reactor internals design configuration is well characterized, as was discussed in Section 3.9.2.3, it is not considered necessary to conduct instrumented tests of the Catawba plant hardware. The recommendations of Regulatory Guide 1.20 are satisfied by conducting the confirmatory pre- and post-hot functional examination for integrity. This examination will include in excess of 30 features (illustrated in Figure 3.9.2-1) with special emphasis on the following areas:

1. All major load-bearing elements of the reactor internals relied upon to retain the core structure in place.
2. The lateral, vertical and torsional restraints provided within the vessel.
3. Those locking and bolting devices whose failure could adversely affect the structural integrity of the internals.
4. Those other locations on the reactor internal components which are similar to those which are examined on the prototype designs.
5. The inside of the vessel will be inspected before and after the hot functional test, with all the internals removed, to verify that no loose

Item 81 3.9.2.4, page 3.9-33

Provide Figure 3.9.2-1.

Response:

Figure 3.9.2-1 is already provided.

Item 82 3.9.2.5, page 3.9-35

The first full paragraph states that "For faulted conditions, stresses are above yield in a few locations. For these cases only, some inelastic stress limits are applied." Define the inelastic stress limits and indicate where these limits have been applied.

Response:

As discussed in Item 7, the reactor internals were procured prior to implementation of sub-section NG of the ASME Code. However, the reactor internals for the Catawba plant satisfy ASME Code design and fabrication requirements. Additionally, faulted condition stresses satisfy the limits defined in Appendix F of the ASME Code and are combined in accordance with NUREG-0484. Section 3.9.2.5 of the FSAR has been revised to state that faulted condition stresses for the reactor internals satisfy limits defined in Appendix F of the ASME Code. Based on the above discussions and the attached FSAR changes, this item was resolved.

3.9.2.5 Dynamic System Analysis of the Reactor Internals Under Faulted Conditions

1. Loss of coolant accident (LOCA). Both cold leg and hot leg breaks are considered.
2. Safe shutdown earthquake (SSE).

Maximum stresses for SSE and LOCA are obtained and combined.

Maximum stress intensities are compared to allowable stresses for each of the above conditions. Elastic analysis is used to obtain the response of the structure and the stress analysis on each component is performed according to ASME Code approved techniques. For faulted conditions, stresses are ~~above~~ ~~the~~ ~~allowable~~ ~~limits~~ ~~and~~ ~~are~~ ~~not~~ ~~permitted~~.

Compared to meet the Code allowable design limits provided in Table F-1322.2-1 of Appendix F of the ASME Code.

Item 83 3.9.2.5

Previous analysis for other nuclear plants have shown that certain reactor system components and their supports may be subjected to previously underestimated asymmetric loads under the conditions that result from the postulation of ruptures of the reactor coolant piping at various locations.

The applicant has described the design of the reactor internals for blowdown loads only. The applicant should also provide information on asymmetric loads. It is, therefore, necessary to reassess the capability of these reactor system components to assure that the calculated dynamic asymmetric loads resulting from these postulated pipe ruptures will be within the bounds necessary to provide high assurance that the reactor can be brought safely to a cold shutdown condition. The reactor system components that require reassessment shall include:

- a. Reactor pressure vessel.
- b. Core supports and other reactor internals.
- c. Control rod drives.
- d. ECCS piping that is attached to the primary coolant piping.
- e. Primary coolant piping.
- f. Reactor vessel supports.

The following information should be included in the FSAR about the effects of postulated asymmetric LOCA loads on the above mentioned reactor system components and the various cavity structures.

1. Provide arrangement drawings of the reactor vessel support systems in sufficient detail to show the geometry of all principal elements and materials of construction.
2. If a plant-specific analysis will not be submitted for your plant, provide supporting information to demonstrate that the generic plant analysis under consideration adequately bounds the postulated accidents at your facility. Include a comparison of the geometric, structural, mechanical, and thermal-hydraulic similarities between your facility and the case analyzed. Discuss the effects of any differences.
3. Consider all postulated breaks in the reactor coolant piping system, including the following locations:
 - a. Steam line nozzles to piping terminal ends.
 - b. Feedwater nozzle to piping terminal ends.
 - c. Recirculation inlet and outlet nozzles to recirculation piping terminal ends.
4. Provide an assessment of the effects of asymmetric pressure differentials* on the systems and components listed above in combination with all external

* Blowdown jet forces at the location of the rupture (reaction forces), transient differential pressures in the annular region between the component and the wall, and transient differential pressures across the core barrel within the reactor vessel.

loadings including safe shutdown earthquake loads and other faulted condition loads for the postulated breaks described above. This assessment may utilize the following mechanistic effects as applicable:

- a. Limited displacement break areas.
 - b. Fluid-structure interaction.
 - c. Actual time-dependent forcing function.
 - d. Reactor support stiffness.
 - e. Break opening times.
5. If the results of the assessment on Item 3 above indicate loads leading to inelastic actions of these systems or displacement exceeding previous design limits, provide an evaluation of the inelastic behavior (including strain hardening) of the material used in the system design and the effect of the load transmitted to the backup structures to which these systems are attached.
 6. For all analyses performed, include the method of analysis, the structural and hydraulic computer codes employed, drawings of the models employed and comparisons of the calculated to allowable stresses and strains or deflections with a basis for the allowable values.
 7. Demonstrate that safety-related components will retain their structural integrity when subjected to the combined loads resulting from the loss-of-coolant accident and the safe shutdown earthquake.
 8. Demonstrate the functional capability of any essential piping when subjected to the combined loads resulting from the loss-of-coolant accident and the safe shutdown earthquake.

Response: (Item 83, reference Item 115)

These questions are in reference to asymmetric LOCA loads. Westinghouse, in its analyses of reactor system components and their supports, has considered asymmetric LOCA loadings. Description of the asymmetric LOCA loads is given in detail in Catawba FSAR Sections 3.9.1.4.3; 3.9.1.4.4; 3.9.1.4.5; 3.9.1.4.5.1; 3.9.1.4.5.2; 3.9.1.4.5.3; 3.9.1.4.5.4; 3.9.1.4.6; 3.9.1.4.7; 3.9.2.5; and updated sections 3.9.1.2.3; 3.9.1.4.2; 3.9.4.2; 3.9.4.3.4; 3.9.4.4.

It should also be recognized that this item was discussed on other plant dockets and that since asymmetric LOCA loadings were identified during the North Anna licensing review Westinghouse has routinely considered such loads in the design basis.

Additionally, it should be pointed out that the methods used by Westinghouse are consistent with NUREG-0609.

In performing the asymmetric LOCA load evaluation design interface information was routinely exchanged between Westinghouse and Duke. For example, Duke provided Westinghouse with cavity pressure loads which are incorporated in the Westinghouse analysis. Additionally, since Duke is responsible for the design of primary component supports information was provided across this design interface relative to support stiffnesses, gaps, and actual calculated loads. This design interface assumed that all elements of the plant design were incorporated in the asymmetric LOCA load evaluation.

Based upon the above discussions and the attached FSAR changes, this item was resolved.

CNS

4. STHRUST - hydraulic loads on loop components from blowdown information.
5. WECAN - finite element structural analysis.
6. DARI - WOSTAS - dynamic transient response analysis of reactor vessel and internals.

→ 7. (see N4)

3.9.1.3 Experimental Stress Analysis

No experimental stress analysis methods have been used for the Catawba project.

3.9.1.4 Considerations for the Evaluation of the Faulted Condition

3.9.1.4.1 Loading Conditions

The reactor coolant loop piping is evaluated in accordance with the criteria of ASME III, NB-3650 and Appendix F. The loads included in the evaluation result from the SSE, deadweight, pressure, and LOCA loadings (loop hydraulic forces, asymmetric subcompartment pressurization forces, and reactor vessel motion).

The structural stress analyses performed on the reactor coolant system consider the loadings specified as shown in Table 3.9.1-2. These loads result from thermal expansion, pressure, dead weight, Operating Basis Earthquake (OBE), Safe Shutdown Earthquake (SSE), design basis loss of coolant accident, and plant operational thermal and pressure transients.

3.9.1.4.2 Analysis of the Reactor Coolant Loop

The loads used in the analysis of the reactor coolant loop piping are described in detail below.

Pressure

Pressure loading is identified as either membrane design pressure or general operating pressure, depending upon its application. The membrane design pressure is used in connection with the longitudinal pressure stress and minimum wall thickness calculations in accordance with the ASME Code.

The term operating pressure is used in connection with determination of the system deflections and support forces. The steady-state operating hydraulic forces based on the system initial pressure are applied as general operating pressure loads to the reactor coolant loop model at change in direction or flow area.

Dead Weight

A dead weight analysis is performed to meet Code requirements by applying a 1.0 g load downward on the complete piping system. The piping is assigned a distributed mass or weight as a function of its properties. This method provides a distributed loading to the piping system as a function of the weight of the pipe and contained fluid during normal operating conditions.

ATTACHMENT TO ITEM 83

CNS

Latch Assembly - Thermal Clearances

The magnetic jack has several clearances where parts made of Type 410 stainless steel fit over parts made from Type 304 stainless steel. Differential thermal expansion is therefore important. Minimum clearances of these parts at 68°F is 0.011 inches. At the maximum design temperature of 650°F minimum clearance is 0.0045 inches and at the maximum expected operating temperatures of 550°F is 0.0057 inches.

Latch Arm - Drive Rod Clearances

The control rod drive mechanism incorporates a load transfer action. The movable or stationary gripper latch are not under load during engagement, as previously explained, due to load transfer action.

Figure 3.9.4-3 shows latch clearance variation with the drive rod as a result of minimum and maximum temperatures. Figure 3.9.4-4 shows clearance variations over the design temperature range.

Coil Stack Assembly - Thermal Clearances

The assembly clearances of the coil stack assembly over the latch housing was selected so that the assembly could be removed under all anticipated conditions of thermal expansion.

At 70°F the inside diameter of the coil stack is 7.308/7.298 inches. The outside diameter of the latch housing is 7.260/7.270 inches.

Thermal expansion of the mechanism due to operating temperature of the control rod drive mechanism result in minimum inside diameter of the coil stack being 7.310 inches at 222°F and the maximum latch housing diameter being 7.302 inches at 532°F.

Under the extreme tolerance conditions listed above it is necessary to allow time for a 70°F coil housing to heat during a replacement operation.

Four coil stack assemblies were removed from four hot control rod drive mechanisms mounted on 11.035 inch centers on a 550° test loop, allowed to cool, and then placed without incident as a test to prove the preceding.

Coil Fit in Core Housing

Control rod drive mechanism and coil housing clearances are selected so that coil heat up results in a close to tight fit. This is done to facilitate thermal transfer and coil cooling in a hot control rod drive mechanism.

3.9.4.4 CRDS Performance Assurance Program

Evaluation of Material's Adequacy

The ability of the pressure housing components to perform throughout the design lifetime as defined in the equipment specification is confirmed by the stress analysis report required by the ASME Boiler and Pressure Vessel Code, section III.

ATTACHMENT TO ITEM 83

INSERT A

3.9.4.3.4 Evaluation of Control Rod Drive Mechanisms and Supports

The control rod drive mechanisms (CRDMs) and CRDM support structures are evaluated for the loading combinations outlined in Table 3.9(N)-2.

A detailed finite element model of the CRDMs and CRDM supports is constructed using the WECAN computer program with beam, pipe, and spring elements. For the LOCA analysis, nonlinearities in the structure are represented. These include RPI plate impact, tie rods, and lifting leg clevis/RPV head interface. The time history motion of the reactor vessel head, obtained from the RPV analysis described in 3.9(N).1.4.6, is input to the dynamic model. Maximum forces and moments in the CRDMs and support structure are then determined. For the seismic analysis, the structural model is linearized and the floor response spectra corresponding to the CRDM tie rod elevation is applied to determine the maximum forces and moments in the structure.

The bending moments calculated for the CRDMs for the various loading conditions are compared with maximum allowable moments determined from a detailed finite element stress evaluation of the CRDMs. Adequacy of the CRDM support structure is verified by comparing the calculated stresses to the criteria given in ASME III, Subsection NF.

The highest loads occur at the head adaptor, the location where the mechanisms penetrate the vessel head. The bending moments at this location are presented in Table 3.9N-20 for the longest and shortest CRDM.

ATTACHMENT TO ITEM 83

CNS

Internal components subjected to wear will withstand a minimum of 3,000,000 steps without refurbishment as confirmed by life tests (Reference 11). Latch assembly inspection is recommended after 2.5 E6 steps have been accumulated on a single control rod drive mechanism.

To confirm the mechanical adequacy of the fuel assembly, the control rod drive mechanism, and rod cluster control assembly, functional test programs have been conducted on a full scale 12 foot control rod. The 12 foot prototype assembly was tested under simulated conditions of reactor temperature, pressure, and flow for approximately 1000 hours. The prototype mechanism accumulated about 3,000,000 steps and 600 trips. At the end of the test the control rod drive mechanism was still operating satisfactorily. A correlation was developed to predict the amplitude of flow excited vibration of individual fuel rods and fuel assemblies. Inspection of the drive line components did not reveal significant fretting.

These tests include verification that the trip time achieved by the full length control rod drive mechanisms meet the design requirement of 2.2 seconds from start of rod cluster control assembly motion to dashpot entry. This trip time requirement will be confirmed for each control rod drive mechanism prior to initial reactor operation and at periodic intervals after initial reactor operation as required by the proposed Technical Specifications.

There are no significant differences between the prototype control rod drive mechanisms and the production units. Design materials, critical tolerances and fabrication techniques (Section 4.2.3.3.2) are the same.

The dynamic behavior of the reactivity control components has been studied using experimental test data and experience from operating reactors.

These tests have been reported in Reference 11. It is expected that all control rod drive mechanisms will meet specified operating requirements for the duration of plant life with normal refurbishment. However, a technical specification pertaining to an inoperable rod cluster control assembly has been set. Latch assembly inspection is recommended after 2.5 E6 steps have been accumulated on a single control rod drive mechanism.

If a rod cluster control assembly cannot be moved by its mechanism, adjustments in the boron concentration ensure that adequate shutdown margin would be achieved following a trip. Thus, inability to move one rod cluster control assembly can be tolerated. More than one inoperable rod cluster control assembly could be tolerated, but would impose additional demands on the plant operator. Therefore, the number of inoperable rod cluster control assemblies has been limited to one as discussed in the Technical Specifications.

In order to demonstrate proper operation of the Control Rod Drive Mechanism and to ensure acceptable core power distributions during rod cluster control assembly partial-movement checks are performed on the rod cluster control assemblies. (Refer to Technical Specifications.) In addition, periodic tests of the rod cluster control assemblies are performed at each refueling shutdown to demonstrate continued ability to meet trip time requirements, to ensure core subcriticality after reactor trip, and to limit potential reactivity insertions from a hypothetical rod cluster control assembly ejection. During these tests the acceptable drop time of each assembly is not greater than 2.2 seconds, at full flow and operating temperature, from the beginning of motion to dashpot entry.

ATTACHMENT TO ITEM 83

INSERT B

In addition, dynamic testing programs have been conducted by Westinghouse and Westinghouse Licensees to demonstrate that control rod scram time is not adversely affected by postulated seismic events. Acceptable scram performance is assured by also including the effects of the allowable displacements of the driveline components in the evaluation of the test results.

ATTACHMENT TO ITEM 83

CNS

Control Rod Drive Mechanisms

The control rod drive mechanisms (CRDM's) pressure housings are Class I components designed to meet the stress requirements for normal operating conditions of Section III of the ASME Boiler and Pressure Vessel Code. Both static and alternating stress intensities are considered. The stresses originating from the required design transients are included in the analysis.

ACCEPT → A dynamic seismic analysis is required on the CRDM's when a seismic disturbance has been postulated to confirm the ability of the pressure housing to meet ASME Code, Section III allowable stresses and to confirm its ability to trip when subjected to the seismic disturbance.

Full Length Control Rod Drive Mechanism Operational Requirements

The basic operational requirements for the full length CRDM's are:

1. 5/8 inch step,
2. Approximately 144 inch,
3. 360 pound maximum load,
4. Step in or out at 45 inches/minute (72 steps/minute),
5. Electrical power interruption shall initiate release of drive rod assembly,
6. Trip delay time of less than 150 milliseconds - Free fall of drive rod assembly shall begin less than 150 milliseconds after power interruption no matter what holding or stepping action is being executed with any load and coolant temperature of 100 F to 550 F,
7. 40 year design life with normal refurbishment.

3.9.4.3 Design Loads, Stress Limits, and Allowable Deformations

3.9.4.3.1 Pressure Vessel

The pressure retaining components are analyzed for loads corresponding to normal, upset, and faulted conditions. The analysis performed depends on the mode of operation under consideration.

The scope of the analysis requires many different techniques and methods, both static and dynamic.

Some of the loads that are considered on each component where applicable are as follows:

1. Control Rod Trip (equivalent static load)
2. Differential Pressure
3. Spring Preloads

ATTACHMENT TO ITEM 83

INSERT C

The control rod drive mechanisms (CRDMs) are evaluated for the effects of postulated reactor vessel inlet nozzle and outlet nozzle limited displacement breaks. A time history analysis of the CRDMs is performed for the vessel motion discussed in Section 3.9.1.4.5. A model of the CRDMs is formulated with gaps at the upper CRDM support modeled as nonlinear elements. The CRDMs are represented by beam elements with lumped masses. The translation and rotation of the vessel head is applied to this model. The resulting loads and stresses are compared to allowables to verify the adequacy of the system.

Item 84 3.9.3, page 3.9-40 and 41

The third paragraph on page 3.9-40 and the second full paragraph on 3.9-41 refers to Section 4.5.2 for design loading conditions for core support structures. This section discussed Reactor Internals Materials. Provide the appropriate reference.

Response:

The reference to Section 4.5.2 for the design loading conditions for core support structures is incorrect. The correct reference should be FSAR Section 3.9.5.2. The FSAR has been revised to incorporate the current reference. Based on the attached FSAR change, this item was resolved.

ATTACHMENT TO ITEM 84

CNS

The results obtained from linear analyses indicate that the relative displacement between the components will close the gaps and consequently the structures will impinge on each other. Linear analysis will not provide information about the impact forces generated when components impinge on each other; however, in some instances, linear approximations can, and are applied prior to and after gap closure. The effects of the gaps that could exist between vessel and barrel, between fuel assemblies, between fuel assemblies and baffle plates, and between the control rods and their guide paths were considered in the analysis using both linear approximations and non-linear techniques. Both static and dynamic stress intensities are within acceptable limits.

Even though control rod insertion is not required for plant shutdown, this analysis shows that most of the guide tubes will deform within the limits established experimentally to assure control rod insertion. For the guide tubes deflected above the no loss of function limit, it must be assumed that the rods will not drop. However, the core will still shut down due to the negative reactivity insertion in the form of core voiding. Shutdown will be aided by the great majority of rods that do drop. Seismic deflections of the guide tubes are generally negligible by comparison with the no loss of function limit.

3.9.2.6 Correlations of Reactor Internals Vibration Tests With the Analytical Results

As stated in Section 3.9.2.3, it is not considered necessary to conduct instrumented tests of the Catawba reactor vessel internals. Adequacy of these internals will be verified by use of the Sequoyah and Trojan results.

3.9.3 ASME CODE CLASS 1, 2 AND 3 COMPONENTS, COMPONENT SUPPORTS AND CORE SUPPORT STRUCTURES

The ASME Code Class components are constructed in accordance with the ASME Boiler and Pressure Vessel Code, Section III.

Detailed discussion of ASME Code Class I components is provided in Sections 3.9.1 and 5.4.

For core support structures, design loading conditions are given in Section ~~3.9.2~~ 3.9.5.2. N35

In general, for reactor internals components and for core support structures the criteria for acceptability in regard to mechanical integrity analyses are that adequate core cooling and core shutdown must be assured. This implies that the deformation of the reactor internals must be sufficiently small so that the geometry remains substantially intact. Consequently, the limitations established on the internals are concerned principally with the maximum allowable deflections and stability of the parts in addition to a stress criterion to assure integrity of the components.

For the loss of coolant plus the safe shutdown earthquake condition, deflections of critical internal structures are limited. In a hypothesized downward vertical

ATTACHMENT TO ITEM 84

CNS

displacement of the internals, energy absorbing devices limit the displacement after contacting the vessel bottom head, ensuring that the geometry of the core remains intact.

The following mechanical functional performance criteria apply:

1. Following the design basis accident, the functional criterion to be met for the reactor internals is that the plant shall be shutdown and cooled in an orderly fashion so that fuel cladding temperature is kept within specified limits. This criterion implies that the deformation of critical components must be kept sufficiently small to allow core cooling.
2. For large breaks, the reduction in water density greatly reduces the reactivity of the core, thereby shutting down the core whether the rods are tripped or not. The subsequent refilling of the core by the Emergency Core Cooling System uses borated water to maintain the core in a subcritical state. Therefore, the main requirement is to assure effectiveness of the Emergency Core Cooling System. Insertion of the control rods, although not needed, gives further assurance of ability to shut the plant down and keep it in a safe shutdown condition.
3. The inward upper barrel deflections are controlled to insure no contacting of the nearest rod cluster control guide tube. The outward upper barrel deflections are controlled in order to maintain an adequate annulus for the coolant between the vessel inner diameter and core barrel outer diameter.
4. The rod cluster control guide tube deflections are limited to insure operability of the control rods.
5. To insure no column loading of rod cluster control guide tubes, the upper core plate deflection is limited.

Methods of analysis and testing for core support structures are discussed in Sections 3.9.2.3, 3.9.2.5, and 3.9.2.6. Stress limits ~~and deformation criteria~~ are given in Sections ~~4.5.2~~ 3.9.5.4. *Deformation criteria is given in Sections 3.9.2.5 and 3.9.5.3.*

3.9.3.1 Loading Combinations Design Transients, and Stress Limits (For ASME Code Class 2 and 3 Components)

Design pressure, temperature, and other loading conditions that provide the bases for design of fluid systems Code Class 2 and 3 components are presented in the sections which describe the systems.

3.9.3.1.1 Design Loading Combinations and Design Stress Limits for Westinghouse Equipment

The design loading combinations for ASME Code Class 2 and 3 components and supports are given in Table 3.9.3-1. The design loading combinations are categorized with respect to Normal, Upset, Emergency, and Faulted Conditions. Stress

Item 85 - 3.9.3.1.1, page 3.9-41

The first paragraph refers to the Emergency Condition in Table 3.9.3-1 and to the stress limits for each loading combination in Tables 3.9.3-2, -3, -4, -5, and -6. The Emergency Condition is missing from Table 3.9.3-1 and no stress limits are given for the Emergency Conditions. Provide the missing information.

Response:

As discussed in Item 60, emergency conditions were not applicable for the Catawba plant. Therefore, the reference to emergency conditions in Section 3.9.3.1.1 has been deleted. Additionally, it is not appropriate to define emergency condition limits in the stress limit tables provided in Section 3.9. Based on the above discussion, the information provided in Item 60, and the attached FSAR revision, this item was resolved.

ATTACHMENT TO ITEM 85

CNS

displacement of the internals, energy absorbing devices limit the displacement after contacting the vessel bottom head, ensuring that the geometry of the core remains intact.

The following mechanical functional performance criteria apply:

1. Following the design basis accident, the functional criterion to be met for the reactor internals is that the plant shall be shutdown and cooled in an orderly fashion so that fuel cladding temperature is kept within specified limits. This criterion implies that the deformation of critical components must be kept sufficiently small to allow core cooling.
2. For large breaks, the reduction in water density greatly reduces the reactivity of the core, thereby shutting down the core whether the rods are tripped or not. The subsequent refilling of the core by the Emergency Core Cooling System uses borated water to maintain the core in a subcritical state. Therefore, the main requirement is to assure effectiveness of the Emergency Core Cooling System. Insertion of the control rods, although not needed, gives further assurance of ability to shut the plant down and keep it in a safe shutdown condition.
3. The inward upper barrel deflections are controlled to insure no contacting of the nearest rod cluster control guide tube. The outward upper barrel deflections are controlled in order to maintain an adequate annulus for the coolant between the vessel inner diameter and core barrel outer diameter.
4. The rod cluster control guide tube deflections are limited to insure operability of the control rods.
5. To insure no column loading of rod cluster control guide tubes, the upper core plate deflection is limited.

Methods of analysis and testing for core support structures are discussed in Sections 3.9.2.3, 3.9.2.5, and 3.9.2.6. Stress limits and deformation criteria are given in Sections 4.5.2.

3.9.3.1 Loading Combinations Design Transients, and Stress Limits (For ASME Code Class 2 and 3 Components)

Design pressure, temperature, and other loading conditions that provide the bases for design of fluid systems Code Class 2 and 3 components are presented in the sections which describe the systems.

3.9.3.1.1 Design Loading Combinations and Design Stress Limits for Westinghouse Equipment

The design loading combinations for ASME Code Class 2 and 3 components and supports are given in Table 3.9.3-1. The design loading combinations are categorized with respect to Normal, Upset, ~~Emergency~~, and Faulted Conditions. Stress

DELETE

Item 87 - 3.9.3.1, pages 3.9-40 to 43

This section does not cover bolts. Provide service limits for bolts.

Response:

Attached are changes to FSAR Tables 3.9.3-7 and 3.9.3-8 which address the stress limits for flange bolts.

TABLE 3.9.3-7

Stress Criteria and Load Combination Requirements for Duke Class A Piping

<u>Condition</u>	<u>Load Combination</u>	<u>Applicable Stress Criteria</u>
Design	Pressure +Weight +OBE	ASME III NB-3652 $\Sigma(\text{Primary}) \leq 1.5 S_m$
Normal, Upset	Pressure +Weight +Thermal +Thermal transients +OBE (incl. anchor motions) +Relief Valve (as applicable) +Fluid dynamic effects	ASME III NB-3653 & 3654 $\Sigma(\text{Primary} + \text{Secondary}) \leq 3.0 S_m$ $\Sigma(\text{Primary}) \leq 1.5 S_m$
Faulted	Pressure +Weight +SSE +Pipe Rupture +Relief Valve (as applicable) +Fluid dynamic effects	ASME III Appendix F (F-1360) $\Sigma(\text{Primary}) \leq 3.0 S_m$
Faulted	Pressure +Weight +Pipe Rupture +Relief Valve (as applicable) +Fluid dynamic effects	ASME III Appendix F (F-1360) $\Sigma(\text{Primary}) \leq 3.0 S_m$

NOTE:
 (1) Refer to Section 3.9.3.1.2 for load combination method
 (2) Flange bolts are High Strength SA 193-B7. High strength bolts SA 193-B7 meet the stress limit requirements specified in ASME SECTION III NB 3230 as verified in ORNL/sub/2913-5

NOTE:

(1) Refer to Section 3.9.3.1.2 for load combination method

TABLE 3.9.3-8

Stress Criteria and Load Combination Requirements for Duke Class B, C, and F Piping

<u>Condition</u>	<u>Load Combination</u>	<u>Applicable Stress Criteria</u>
Normal	Pressure +Weight +Thermal	ASME III NC- or ND-3652 $\Sigma(\text{Primary} + \text{Secondary}) \leq (S_h + S_a)$
Upset	Pressure +Weight +Thermal +OBE (incl. anchor motions) +Valve thrust +Fluid dynamic effects	ASME III NC- or ND-3652 $\Sigma(\text{Secondary}) \leq S_a$ $\Sigma(\text{Primary}) \leq 1.2 S_h$
Faulted	Pressure +Weight +SSE +Valve thrust +Fluid dynamic effects +Pipe rupture	ASME Code Case 1606 $\Sigma(\text{Primary}) \leq 2.4 S_h$
Faulted	Pressure +Weight +Valve thrust +Fluid dynamic effects +Pipe rupture	ASME Code Case 1606 $\Sigma(\text{Primary}) \leq 2.4 S_h$
Faulted	Pressure +Weight +Tornado	ASME Code Case 1606 $\Sigma(\text{Primary}) \leq 2.4 S_h$

NOTE:
 (1) Refer to Section 3.9.3.1-3 for load combination method
 (2) Flange bolts are High Strength SA 193-B7. High strength bolts SA 193-B7 meet the stress limit requirements specified in ASME SECTION III NB 3230 as verified in ORNL/Sub/2913-3

NOTE:

(1) Refer to Section 3.9.3.1-3 for load combination method.

Item 88 - 3.9.3.1.5, page 3.9-43

The first paragraph refers to Tables 3.9.3-11 and 3.9.3-12 for load combinations for supports, restraints, anchors, and snubbers. However, these tables are indicated as only being applicable for Duke Class A, B, C, and F items.

Provide the load combinations for Westinghouse items.

Response:

The load combination tables in Section 3.9 were reviewed. It was agreed that the tables were acceptable with the following exceptions:

- a. Table 3.9.1-3 (attached) would be revised to delete Class 1 valves and component supports since neither type of equipment was supplied by Westinghouse. Also, the note on the test method would be clarified.
- b. A table will be added for Class 2 and 3 component supports. However, as a result of investigating this time further, it was determined that a change to Section 3.9.3.4 is required in lieu of the addition of a table for Class 2 and 3 component supports. The revision to Section 3.9.3.4 is attached.

It was also noted that Westinghouse combines loads defined in the load combination tables in accordance with NUREG-0484.

Based on the above discussions and the attached FSAR changes, this item was resolved.

ATTACHMENT TO ITEM 88 88

Table 3.9.1-3

Allowable Stresses for ASME Section III Class 1 Components*

<u>Operating Condition Classification</u>	<u>Vessels/Tanks</u>	<u>Piping</u>	<u>Pumps</u>	<u>Valves</u>	<u>Component Supports</u>
Normal	ASME Section III NB 3222	ASME Section III NB 3653	ASME Section III NB 3222	ASME Section III	ASME Section III Subsection NF
Upset	ASME Section III NB 3223	ASME Section III NB 3654	ASME Section III NB 3223	ASME Section III	ASME Section III Subsection NF
Faulted	ASME Section III NB 3225 F1323.1 See Section 3.9.1.4	ASME Section III NB 3652 F1360 See Section 3.9.1.4	ASME Section III NB3225 F1323.1 See Section (No active class 1 pump used)	See Note 1. ASME Section III See Section 3.9.3.2	ASME Section III Subsection NF See Section 3.9.1.4

$P_e, P_m, P_b, Q_t, C_p, S_n$ & S_m as defined by Section III ASME Code

*A test of the components ^{is} may be performed in lieu of analysis.
for the reactor vessel pads as discussed in Section 3.9.1.4.6.

ATTACHMENT TO ITEM 88

CNS

To assure an accurate assessment of the Pressurizer Relief System structural response during and following the actuation of the safety and relief valves, detailed thermal-hydraulic and structural dynamic time-history analyses are performed. To obtain maximum loadings during the valve discharge transients, it is assumed that all safety and relief valves commence opening simultaneously. The thermal hydraulic dynamic analyses are performed using the RELAP computer code.

The flow induced force time-histories are then used in a dynamic time-history structural analysis of the entire Pressurizer Relief System using the computer program SUPERPIPE. The structural analysis results in the determination of time-histories of displacements, stresses and support reaction forces throughout the Pressurizer Relief System. For conservatism in combination with other loading conditions, the maximum stresses and reaction forces determined from this analysis are combined without regard to sign or differences in time of occurrence.

Normal operating conditions for the Pressurizer Relief System consist of internal pressure, dead weight, transient and steady state thermal loads and the system transient response to valve operation.

To assure compliance with the stress limits of the ASME Code for the Class 1 and 2 components of the Pressurizer Relief System, the following operating conditions, in addition to the normal operating conditions noted above are evaluated:

Upset Condition: Normal Condition Loads and Operating Basis Earthquake (OBE).

Faulted Conditions: Normal Condition Loads and Safe Shutdown Earthquake (SSE).

Stress computations and stress limit evaluations are performed in accordance with the ASME Code requirements. Design and analysis iterations of the Pressurizer Relief System are conducted, as necessary, to ensure compliance with the ASME Code limits.

3.9.3.4 Component Supports

balance of plant

Loading combinations, design transients, and stress limits for component supports are discussed in Section 3.9.3.1. The use of these criteria provide a conservative basis for assuring no loss of structural integrity to supports and restraints, even under adverse loading conditions.

→ INSERT A

3.9.4 CONTROL ROD DRIVE SYSTEM (CRDS)

3.9.4.1 Descriptive Information of CRDS

Control Rod Drive Mechanism

Control rod drive mechanisms are located on the dome of the reactor vessel.

ATTACHMENT TO ITEM 88

Insert A

For Westinghouse supplied Class 2 and 3 component supports leading combinations are defined in Table 3.9.3-1. The stress limits applicable for Class 2 and 3 component supports are as follows:

a) Linear Supports for Tanks and Heat Exchangers

- 1) Normal - The allowable stresses of A.I.S.C.-69 Part 1 are employed for normal condition allowables.
- 2) Upset - Stress limits for upset conditions are 33 percent higher than those specified for normal conditions. This is consistent with Paragraph 1.5.6 of A.I.S.C.-69 Part 1 which permits one-third increase in allowable stresses for wind or seismic loads.
- 3) Faulted - Stress limits for faulted condition are the same as for the upset condition.

b) Plate and Shell Supports for Tanks and Heat Exchangers

- 1) Normal - Normal condition limits are those specified in ASME Sec. VIII, Division 1 or A.I.S.C.-69 Part 1.
- 2) Upset - Stress limits for upset condition are 33 percent higher than those specified for normal conditions. This is consistent with Paragraph 1.5.6 of A.I.S.C.-69 Part 1 which permits one-third increase in allowable stresses for wind or seismic loads.
- 3) Faulted - Stress limits for faulted condition are the same as for the upset condition.

ATTACHMENT TO ITEM 88

Insert - (Continued)

- c) Plate and Shell Supports for Pumps - The stress limits used for ASME Code Class 2 and 3 plate and shell component supports are identical to these used for the supported component. These allowable stresses are such that the design requirements for the components and system assume that structural integrity is maintained.

Item 89 - 3.9.3-1

Sections 3.9.3.1.5 (page 3.9-43) and 3.9.3.4 (page 3.9-51), while discussing supports and restraints, do not provide sufficient information with respect to snubbers. Provide the basis for selecting the location, the required load capacity, and the structural and mechanical performance parameters of safety-related snubbers (mechanical and hydraulic) and the method of achieving a high level of operability assurance including:

1. A description of the analytical and design methodology utilized to develop the required snubber locations and characteristics.
2. A discussion of design specification requirements to assure that required structural and mechanical performance characteristics and product quality are achieved.
3. Procedures, controls to assure correct installation of snubbers and checking and checking the hot and cold settings during plant startup tests.
4. Provisions for accessibility for inspection, testing and repair or replacement of snubbers.

Response:

Parts 1 & 2

Per discussion during the meetings snubbers are used to restrain seismic motion while allowing thermal movement based upon analysed piping during seismic events. The staff rephrased the snubber question presented to be limited to operational vibration damping. To date no snubbers have been used to mitigate operational piping vibration. If snubbers are employed in this manner in the future, the analytical and design methodology utilized, as well as design specification requirements to assure that structural and mechanical performance characteristics and product quality are achieved will be submitted for review.

Section 3.9.3.1.5 of the FSAR will be revised as attached.

Insert A

If snubbers are used to mitigate effects of operational vibration, the analytical and design methodology utilized as well as design specification requirements to assure that structural and mechanical performance characteristics and product quality are achieved will be developed and available for review.

Part 3

Refer to the attached Test Abstract for Pre-service and Pre-Operational Testing of Snubbers.

Part 4

Refer to the attached Test Abstract for Pre-service and Pre-Operational Testing of Snubbers.

CNS

A typical piping analysis problem, with representative math model, is shown in Figure 3.9.3-1. The results of this analysis are given in Table 3.9.3-10.

3.9.3.1.4 Design Loading Combinations and Design Stress Limits for Mechanical Equipment Furnished by Duke

The load combinations and corresponding stress criteria for Duke Mechanical equipment and valves are presented in Table 3.9.3-9.

3.9.3.1.5 Piping Supports and Restraints

The design loading combination associated with each component operating condition is given in Table 3.9.3-11 for supports, restraints, and anchors and in Table 3.9.3-12 for mechanical or hydraulic snubbers.

Loads for each loading combination are combined algebraically except that components which contain positive and negative values are combined to assemble the worst case load combination.

Design stress limits for each component operating condition are in accordance with Subsection NF of the ASME Boiler and Pressure Vessel Code for those portions of supports and restraints within the NF jurisdictional boundary. Stress limits for Normal and Upset Conditions are in accordance with Article XVII-2000. For Faulted Condition, design stress limits for manufacturer's standard support components are in accordance with the requirements of Appendix F. Emergency Condition stress limits, as specified in Article XVII-2000 are used for the design of all other components for Faulted Condition. Stresses for those portions of supports and restraints outside the NF jurisdictional boundary are limited to the allowable values in Table 3.9.3-11.

Snubbers are used at locations where restraints are necessary based on piping stress analysis, but thermal movement of the pipe must not be constrained. Performance selection is based on manufacturer's load capacity data and the requirement that the allowable travel of the snubber exceed the calculated pipe thermal travel. The midpoint of pipe thermal travel is set at the midpoint of the snubber travel range with hot and cold settings established accordingly. ← - INSERT A *Insert A*

Each snubber assembly is accessible after installation and all adjustment features are unobstructed and visible where possible. The manufacturer's figure number, size, stroke, and load rating is mounted on each snubber.

The loading combinations for Westinghouse items are given on Table 3.9.1-2.

3.9.3.2 Pump and Valve Operability Program

3.9.3.2.1 Westinghouse Pump and Valve Operability Program

Mechanical equipment classified as safety-related must be capable of performing its function under postulated plant conditions. Equipment with faulted condition

DUKE POWER COMPANY
CATAWBA NUCLEAR STATION
PROPOSED TEST ABSTRACT FOR PRE-SERVICE
AND PRE-OPERATIONAL TESTING OF SNUBBERS

1.0 SCOPE

1.1 This abstract details the general requirements for the pre-service and pre-operational examinations of installed snubbers.

2.0 PRE-SERVICE EXAMINATION

2.1 A pre-service examination shall be made on all snubbers. This examination shall be conducted after installation, but not more than six months prior to system pre-operational testing. The examination shall verify the following:

2.1.1 There are no visible signs of damage or required clearances as a result of storage, handling, or installation.

2.1.2 The snubber installation is in a condition similar to the manufacturer's specifications. Installation procedures including the snubbers were installed according to Design drawings and specifications shall be acceptable.

2.1.3 Snubber is not rusted, frozen, or damaged.

2.1.4 Adequate wire clearance is provided to allow snubber movement.

2.1.5 Structural connections such as pins, bearings, studs, fasteners, and other connecting hardware such as lock nuts, tabs, wire and other outer pins are installed correctly.

2.2 If the period between the pre-service examination and system pre-operational test exceeds 6 months, due to unexpected situations, re-examination of 2.1.1 shall be performed. This re-examination may be accomplished in conjunction with 3.0.

2.3 Snubbers which fail to meet the requirements of 2.1 shall be corrected, repaired, or replaced. The corrected, repaired, or replaced snubber shall be examined in accordance with 2.1.

3.0 PRE-OPERATIONAL EXAMINATION

3.1 A pre-operational examination shall be conducted on each snubber whose system operating temperature equals or exceeds 250°F. This examination shall be conducted during system pre-operational testing. Snubber thermal movement shall be verified as follows:

3.1.1 During initial system startup and cooldown, at specified temperature intervals for any system which attains operating temperature, verify the snubber expected thermal movement.

- 3.1.2 For those systems which do not attain operating temperature, verify by observation and/or calculation that the snubber will accommodate the projected thermal movement.
 - 3.1.1 Verify the snubber swing clearance at specified heatup and cooldown plateaus.
 - 3.2 Any discrepancies or inconsistencies between the actual and design range of thermal movement shall be evaluated to determine the cause prior to proceeding to the next specified temperature interval.

Item 90 - 3.9.3.1.5, page 3.9-43


The second paragraph says that "loads for each loading combination are combined algebraically except that components which contain positive and negative values are combined to assemble the worst case load combination." Provide an example of what is done here.

Response:

The requested example is attached.

ITEM #90 Attachment

ITEM NO.	NO. REQ'D	SIZE	DESCRIPTION	ASTM	LOT NUMBER	BY
1	4	1" ϕ PHILLIPS CONC. FAST. CAT. # WS 10090		—		
2	1	R 1 x 12 x 1'-9" LG.		A36		
3	2	TS 4 x 4 x .375 x 1'-8 1/2" LG.		A500GRB		
4	2	TS 3 x 3 x .250 x 0'-10 13/16" LG.		A500GRB		
5	4	R 1/2 x 3 x 0'-3 1/2" LG. STIFFENER		A36		
6	2	R 1/2 x 3 x 1'-6 13/16" LG. STIFFENER		A36		



FOR INFORMATION ONLY

DIRECTION	MVMT.	HOT LD.	COLD LD.	UPSET	HYDRO	FAULTED	ALLOW LD	—
VERTICAL	0.00 / 3.00	1958#	1796#	— / 2.98#	1796#	— / 2220#	—	—
N-S	—	—	—	—	—	—	—	—
E-W	0.00 / 0.00	6#W	6#W	257#E	262#W	473#E / 484#W	—	—

ANALYSIS PROBLEM NO. RNN	10/12/79	DATA PT.	11	CALC. NO.	—	DP. CO. CLASS	C
DESIGNER/DATE	<i>John P. ...</i> 2/16/82	INSPECTED/DATE	WAIVED	QA CONDITION <u>1</u>			
DRAWN/DATE	<i>Steve Nichols</i> 2/26/82	INSPECTED/DATE	WAIVED				
CHECKED/DATE	<i>F. ...</i> 3/1/82	APPROVED/DATE	<i>...</i> 3/1/82				
DUKE POWER COMPANY							
PROJECT CATAWBA NUCLEAR STATION				UNIT <u>1</u>			
REV.	BY	OK	DATE	DESCR.	APPROV.	DATE	
0	TXN		2/1/82	RELEASED FOR CONST.	...	2/1/82	

REFERENCE DRAWINGS		
PIPE	150: CN-1506-RN-001R	REV. —
CIVIL	CN-1231-1	REV. —
ELECT	CN-1899-01	REV. —
HVAC	CN-1522-04.40-00	REV. —
MARK NO.	1-R-RN-0612	REV. 0
SHEET	1	OF 1

CATAWBA NUCLEAR STATION UNIT-1
DIESEL GENERATOR BUILDING NUCLEAR SERVICE WATER SYSTEM
PROBLEM-RVN
STATIC + DYNAMIC SUPP SUM + STRESS CHECK

SUPPORT LOAD SUMMARY (CONTD.)

SUPP NAME	SUPP LOCN	SUPP TYPE	UNIV TYPE	RESULT	AXIS	FORC (LB)	GLDB	FLTD(M+)
7A	7	SINGL	A					
I-E-EN-COIL						1480.64		
						187.36		
						897.68		
						231.38		
						8.53		
						-568.01		
						-1234.31		
						-1247.32		
						-1817.32		

DISP (IN) GLDB

11Y 11 MANG Y

I-E-EN-COIL

SUPP NAME	SUPP LOCN	SUPP TYPE	UNIV TYPE	RESULT	AXIS	FORC (LB)	GLDB	FLTD(M+)
						201.78		
						-261.78		
						1483.70		
						903.86		
						745.48		
						1725.64		
						1937.85		
						2097.43		
						-2219.59		

DISP (IN) GLDB

0.44 FLTD(M+)
0.43 UPST
0.43 HOT
-0.120 HOT

Y-AXIS LOAD SET

-0.026 HOT
-0.032 UPST
-0.038 FLTD(M-)

0.075 FLTD(M+)
0.059 UPST
0.062 HOT
0.012 SSE
0.003 COLD
-0.012 SSE
-0.026 HOT
-0.032 UPST
-0.038 FLTD(M-)

201.78 SSE (M+)
-261.78 SSE

1483.70 FLTD
903.86 UPST
745.48 HOT
1725.64 COLD
1937.85 HOT
2097.43 UPST
-2219.59 FLTD(M-)

DURE POWER CO.

GALEBOR NUCLEAR REACTOR UNIT-1
DIFFERENTIAL MODELS FOR NUCLEAR SERVICE WATER SYSTEM
PROGRAM-414
STATIC & DYNAMIC SUPP SUM & STRESS CHECK

SUPPORT LOAD SUMMARY (CONTD.)

SUPP NAME	SUPP LUCN	SUPP TYPE	DIRY CDE	RESLT TYPE	RESJLT UNIT	WATS TIME
-----------	-----------	-----------	----------	------------	-------------	-----------

111 (CONTD.)

112	11	SNGL	7	FORC	(LB)	6L-9
-----	----	------	---	------	------	------

1-R-21-612

DISP	(IN)	6L03
------	------	------

.043	UPST	FLTD(M-)
.043	MOT	
-.120	MOT	
-.120	UPST	FLTD(M-)

131	11	MARG	1	FORC	(LB)	6L09
-----	----	------	---	------	------	------

1-R-21-613

DISP	(IN)	6L09
------	------	------

.037	FLTD(M-)	
.085	UPST	
.085	MOT	
-.240	MOT	
-.240	UPST	FLTD(M-)

Y-AXIS	LOAD SET	Z-AXIS	LOAD SET
--------	----------	--------	----------

478.41	SSE	478.41	FLTD(M-)
475.70	UPST	475.70	SSE
256.42	MOT	256.42	UPST
3.11	COLD	3.11	MOT
-5.07	MOT	-5.07	COLD
-7.74	UPST	-7.74	MOT
-291.44	SSE	-291.44	UPST
-483.43	FLTD(M-)	-483.43	SSE

255.41	SSE	255.41	FLTD(M-)
-1164.13	FLTD	-1164.13	SSE
-1303.56	UPST	-1303.56	FLTD
-1440.05	MOT	-1440.05	UPST
-1522.57	COLD	-1522.57	MOT
-1549.01	MOT	-1549.01	COLD
-1687.50	UPST	-1687.50	MOT
-1803.53	FLTD(M-)	-1803.53	UPST

Item 91 - 3.9.4.3.1, page 3.9-58

The first full paragraph says that "the dynamic behavior of the reactivity control components has been studied using experimental test data and experience from operating reactors." Provide details of the tests and data.

Response:

The statement relative to the reactivity control components is currently inappropriately located in Section 3.9N.4. It was agreed that this statement should be incorporated in another portion of Section 3.9.4. An FSAR change has been made to correct this deficiency. It was also pointed out that test data and operating experience data for reactivity control components is provided in Reference 11.

Based on the above discussion and the attached FSAR changes, this item was resolved.

N40

ATTACHMENT TO ITEM 91

CNS



4. Coolant Flow Forces (static)
5. Temperature Gradients
6. Differences in thermal expansion
 - a. Due to temperature differences
 - b. Due to expansion of different materials
7. Interference between components
8. Vibration (mechanically or hydraulically induced)
9. All operational transients listed in Table 3.9.1-1
10. Pump Overspeed
11. Seismic Loads (operation basis earthquake and design basis earthquake)
12. Blowdown Forces (due to cold and hot leg break)

The main objective of the analysis is to satisfy allowable stress limits, to assure an adequate design margin, and to establish deformation limits which are concerned primarily with the functioning of the components. The stress limits are established not only to assure that peak stresses will not reach unacceptable values, but also limit the amplitude of the oscillatory stress component in consideration of fatigue characteristics of the materials. Standard methods of strength of materials are used to establish the stresses and deflections of these components. The dynamic behavior of the reactivity control components has been studied using experimental test data and experience from operating reactors.

Move to pag
3.9-60

3.9.4.3.2 Drive Rod Assembly

All postulated failures of the drive rod assemblies either by fracture or uncoupling lead to a reduction in reactivity. If the drive rod assembly fractures at any elevation, that portion remaining coupled falls with, and is guided by the rod cluster control assembly. This always results in reactivity decrease.

3.9.4.3.3 Latch Assembly and Coil Stack Assembly

Results of Dimensional and Tolerance Analysis

With respect to the control rod drive mechanism system as a whole, critical clearances are present in the following areas:

1. Latch assembly (Diametral clearances)
2. Latch arm-drive rod clearances
3. Coil stack assembly-thermal clearances
4. Coil fit in coil housing

The following write-up defines clearances that are designed to provide reliable operation in the control rod drive mechanism in these four critical areas. These clearances have been proven by life tests and actual field performance at operating plants.



ATTACHMENT TO ITEM 91

CNS

Internal components subjected to wear will withstand a minimum of 3,000,000 steps without refurbishment as confirmed by life tests (Reference 11). Latch assembly inspection is recommended after 2.5×10^6 steps have been accumulated on a single control rod drive mechanism.

To confirm the mechanical adequacy of the fuel assembly, the control rod drive mechanism, and rod cluster control assembly, functional test programs have been conducted on a full scale 12 foot control rod. The 12 foot prototype assembly was tested under simulated conditions of reactor temperature, pressure, and flow for approximately 1000 hours. The prototype mechanism accumulated about 3,000,000 steps and 600 trips. At the end of the test the control rod drive mechanism was still operating satisfactorily. A correlation was developed to predict the amplitude of flow excited vibration of individual fuel rods and fuel assemblies. Inspection of the drive line components did not reveal significant fretting.

These tests include verification that the trip time achieved by the full length control rod drive mechanisms meet the design requirement of 2.2 seconds from start of rod cluster control assembly motion to dashpot entry. This trip time requirement will be confirmed for each control rod drive mechanism prior to initial reactor operation and at periodic intervals after initial reactor operation as required by the proposed Technical Specifications.

There are no significant differences between the prototype control rod drive mechanisms and the production units. Design materials, critical tolerances and fabrication techniques (Section 4.2.3.3.2) are the same.

The dynamic behavior of the ... (REFERENCE from page 3.9-53) ... reactors. These tests have been reported in Reference 11.

FSAR Change here

It is expected that all control rod drive mechanisms will meet specified operating requirements for the duration of plant life with normal refurbishment. However, a technical specification pertaining to an inoperable rod cluster control assembly has been set. Latch assembly inspection is recommended after 2.5×10^6 steps have been accumulated on a single control rod drive mechanism.

If a rod cluster control assembly cannot be moved by its mechanism, adjustments in the boron concentration ensure that adequate shutdown margin would be achieved following a trip. Thus, inability to move one rod cluster control assembly can be tolerated. More than one inoperable rod cluster control assembly could be tolerated, but would impose additional demands on the plant operator. Therefore, the number of inoperable rod cluster control assemblies has been limited to one as discussed in the Technical Specifications.

In order to demonstrate proper operation of the Control Rod Drive Mechanism and to ensure acceptable core power distributions during rod cluster control assembly partial-movement checks are performed on the rod cluster control assemblies. (Refer to Technical Specifications.) In addition, periodic tests of the rod cluster control assemblies are performed at each refueling shutdown to demonstrate continued ability to meet trip time requirements, to ensure core subcriticality after reactor trip, and to limit potential reactivity insertions from a hypothetical rod cluster control assembly ejection. During these tests the acceptable drop time of each assembly is not greater than 2.2 seconds, at full flow and operating temperature, from the beginning of motion to dashpot entry.

Item 92 - 3.9.5.1, page 3.9-62

The first full paragraph refers to Figure 3.9.5-1. Provide this figure.

Response:

Figure 3.9.5-1 is already provided.

Item 93 - 3.9.5.1, page 3.9-63

The third paragraph discusses the energy absorbers. Provide details of the analysis. What do they look like? How much deflection is there?

Response:

The main purpose of the energy absorber is to absorb impact loads of the core and the supporting structure during a postulated core drop accident. The energy of the impact is absorbed by an energy absorbing mechanism which consist of a "necked-down" portion as shown in Figure 3.9.5-1A. Using energy principles the total potential energy of the system is absorbed by the strain energy of the energy-absorbing devices.

The maximum deformations of the energy absorbing assemblies during the core drop accident remain well within the functional limits so as not to affect the RCC Scram Function.

The strain limits for the energy absorbers was also discussed and Westinghouse indicated that appropriate strain limits had been satisfied. The NRC also indicated that these limits also satisfied SRP requirements. Westinghouse agreed to make FSAR changes (attached) to clarify this item including the definition of the strain limits which were met.

Based on the above discussion and the attached FSAR changes, this item was resolved.

ATTACHMENT
TO ITEM 93




FIGURE 3.9.5-1A ENERGY ABSORBING ASSEMBLY

ATTACHMENT TO ITEM 93

CNS

The main radial support system of the lower end of the core barrel is accomplished by "key" and "keyway" joints to the reactor vessel wall. At equally spaced points around the circumference, an Inconel clevis block is welded to the vessel inner diameter. Another Inconel insert block is bolted to each of these blocks and has a "keyway" geometry. Opposite each of these is a "key" which is attached to the internals. At assembly, as the internals are lowered into the vessel, the keys engage the keyways in the axial direction. With this design, the internals are provided with a support at the furthest extremity, and may be viewed as a beam fixed at the top and simply supported at the bottom.

Radial and axial expansions of the core barrel are accommodated but transverse movement of the core barrel is restricted by this design. With this system, cyclic stresses in the internal structures are within the ASME Section III limits. In the event of an abnormal downward vertical displacement of the internals following a hypothetical failure, energy absorbing devices limit the displacement after contacting the vessel bottom head. The load is then transferred through the energy absorbing devices of the internals to the vessel.

The energy absorbers, cylindrical in shape, are contoured on their bottom surface to the reactor vessel bottom head geometry. ~~* Assuming a downward vertical displacement the potential energy of the system is absorbed mostly by the strain energy of the energy absorbing devices.~~ (* INSERT - A)

Upper Core Support Assembly

The upper core support assembly, shown in Figures 3.9.5-2 and 3.9.5-3 consists of the top support plate assembly, and the upper core plate between which are contained support columns and guide tube assemblies. The support columns establish the spacing between the top support plate assembly and the upper core plate and are fastened at top and bottom to these plates. The UHI support columns transmit the mechanical loadings between the two plates and serve the supplementary function of supporting thermocouple guide tubes. They position the upper core plate and upper support which act as the boundaries for the flow plenum at the outlet of the core. Additionally each UHI column has a central axial flow passage full length for conveying core cooling water to the core when it is injected into the vessel head. The water enters the flow passage through a small hole on the side of the top of the UHI support column. A support column is provided at each fuel assembly position that does not contain accommodation for a control rod with the exception of the peripheral low power fuel assembly locations. The fuel assemblies which do not have a support column above them are located in front of the inlet and outlet nozzles of the vessel. The UHI support columns also contain thermocouple supports.

The guide tube assemblies shield and guide the control rod drive shafts and control rods. They are fastened to the top support plate and are restrained by pins in the upper core plate for proper orientation and support. Additional guidance for the control rod drive shafts is provided by the upper guide tube which is attached to the upper support plate and guide tube. In the UHI system, the guide tubes also serve to transport UHI water from the vessel head region to the area directly above the fuel assemblies. All units having UHI have the maximum number of guide tubes independent of other RCC requirements.

ATTACHMENT TO ITEM 93

INSERT A

The main purpose of the energy absorber is to absorb impact loads of the core and the supporting structure during a postulated core drop accident. The energy of the impact is absorbed by an energy absorbing mechanism which consists of a "necked-down" portion as shown in Figure 3.9.5-1A. Using energy principles the total potential energy of the system is absorbed by the strain energy of the energy-absorbing devices.

The maximum deformations of the energy absorbing assemblies during the core drop accident remain well within the functional limits so as not to affect the RCS Scram Function. It should also be noted that the maximum strains undergone by the energy absorbers ($\leq 15\%$ strains, hot condition) during the core drop accident are well below the fracture limits (62% strains for 304 stainless steel at 600°F) and satisfy the SRP requirements.

Item 94 - 3.9.6, page 3.9-68

The applicant must provide a commitment that the inservice testing of ASME Class 1, 2, and 3 components will be in accordance with the revised rules of 10 CFR, Part 50, Section 50.55a, paragraph (g).

Response:

The inservice test program will be in accordance with 10 CFR, part 50, Section 50.55a, paragraph (g). This item was closed.

Item 95 - 3.9.6, page 3.9-68

Any requests for relief from ASME Section XI should be submitted as soon as possible.

Response:

Duke will submit requests as soon as possible. This item was closed.

Item 97 - Table 3.9.1-1, page 1

Explain Note 1a as it refers to the Inadvertent Auxiliary Spray transient.

Response:

Westinghouse indicated that the design requirement for the inadvertent auxiliary spray transient was ten occurrences under upset conditions. The basis for notes 1a and 1b was not apparent from the above stated design requirement.

Therefore, it was agreed that notes 1a and 1b would be deleted from Table 3.9.1-1.

Based upon the attached FSAR revision, this item was resolved.

ATTACHMENT TO ITEM 97

Table 3.9.1-1 (page 2)
Design Transients for ASME Code Class I Piping

(1) DESIGN TRANSIENTS	(2) CONDITION	(3) OCCURRENCES	(4) RESIDUAL HEAT REMOVAL SYSTEM	SAFETY INJECTION SYSTEM	CHEMICAL AND VOLUME CONTROL SYSTEM	PRESSURIZER SURGE LINE	PRESSURIZER RELIEF	PRESSURIZER SPRAY	RID BYPASS	REACTOR COOLANT DRAIN LINES	UPPER HEAD INJECTION LINES
Loss of Load without Immediate Turbine or Reactor Trip	Upset	80	X	X	X	X	X NOTES 4, 5	X	X	X	X
Loss of Flow in One Loop	Upset	80	X	X	X		X	X	X	X	X
Reactor Trip with Cooldown and Inadvertent SIS Actuation	Upset	10	X	X	X	X	X	X	X	X	X
Inadvertent RCS Depressurization	Upset	20	X	X	X	X	X	X	X	X	X
Inadvertent SI Accumulator Blowdown during Plant Cooldown	Upset	4	-	X	-	-	-	-	-	-	-
High Head Safety Injection	Upset	22	-	X	-	-	-	-	-	-	-
Boron Injection	Upset	48	-	X	-	-	-	-	-	-	-
Small Steam Break	Emergency	5									X
Small LOCA	Emergency	5									X
Large Steam Break	Faulted	1	X	X	X	X	X	X	X	X	X
Large LOCA	Faulted	1	X	X	X	X	X	X	X	X	X
High Head Safety Injection	Faulted	2	-	X	-	-	-	-	-	-	-
Boron Injection	Faulted	2	-	X	-	-	-	-	-	-	-
Turbine Roll Test	Test	10	X	X	X	X	X	X	X	X	X
Hydrostatic Test	Test	5	X	X	X	X	X	X	X	X	X
Primary Side Leak Test	Test	50	X	X	X	X	X	X	X	X	X
Inadvertent Auxiliary Spray	Test	1	-	-	X	-	-	X	-	-	-

NOTE 12
Delete

NOTE 16
DELETE

NOTES: *Delete*

1. a) Portion of piping analyzed for 10 upset occurrences, remainder for 9 upset and 1 test occurrences.
 b) Piping analyzed for 9 upset and 1 test condition.

X. Pressurizer surge line is analyzed for 80 occurrences of transient C-7, the final cooldown spray.

X. Pressurizer surge line is analyzed for 150,000 initial fluctuations and 3,000,000 random fluctuations.

X. These transients are conditions which can cause the PORV's to open. Although a total of 320 such transients are shown, the PORV inlet lines are analyzed for 100 such occurrences.

f. For analysis of the safety valve 40 occurrences were assumed.

5. Number of occurrences is 20,000,000.

ATTACHMENT 97

Item 98 - Table 3.9.1-3

The footnote indicates that a test may be performed in lieu of an analysis to determine ASME Code compliance. Provide the criteria for such tests.

Response:

This item was resolved under Item 88.

Item 99 - Tables 3.9.1-3, 3.9.3-7, and 3.9.3-8

What are the allowable stresses?

Response:

Tables 3.9.1-3, 3.9.3-7, and 3.9.3-8 will be revised.

Revised tables 3.9.3-7 and 3.9.3-8 are attached. Revised table 3.9.1-3 is attached as response to item 88.

TABLE 3.9.3-7

Stress Criteria and Load Combination Requirements for Duke Class A Piping

<u>Condition</u>	<u>Load Combination</u>	<u>Applicable Stress Criteria</u>
Design	Pressure +Weight +OBE	ASME III NB-3652 $\Sigma(\text{Primary}) \leq 1.5 S_m$
Normal, Upset	Pressure +Weight +Thermal +Thermal Transients +OBE (incl. anchor motions) +Relief Valve (as applicable) +Fluid dynamic effects	ASME III NB-3653 & 3654 $\Sigma(\text{Primary} + \text{Secondary}) \leq 3.0 S_m$
Faulted	Pressure +Weight +SSE +Pipe Rupture +Relief Valve (as applicable) +Fluid dynamic effects	ASME III Appendix F (F-1360) $\Sigma(\text{Primary}) \leq 3.0 S_m$
Faulted	Pressure +Weight +Pipe Rupture +Relief Valve (as applicable) +Fluid dynamic effects	ASME III Appendix F (F-1360) $\Sigma(\text{Primary}) \leq 3.0 S_m$

NOTE:

(1) Refer to Section 3.9.3.1.2 for load combination method.

TABLE 3.9.3-8

Stress Criteria and Load Combination Requirements for Duke Class B, C, and F Piping

<u>Condition</u>	<u>Load Combination</u>	<u>Applicable Stress Criteria</u>
Normal	Pressure +Weight +Thermal	ASME III NC- or ND-3652
Upset	Pressure +Weight +Thermal +OBE (incl. anchor motions) +Valve thrust +Fluid dynamic effects	$\Sigma(\text{Primary} + \text{Secondary}) \leq (S_h + S_a)$ ASME III NC- or ND-3652
Faulted	Pressure +Weight +SSE +Valve thrust +Fluid dynamic effects +Pipe rupture	$\Sigma(\text{secondary}) \leq S_a$ $\Sigma(\text{Primary}) \leq 1.2 S_h$ ASME Code Case 1606
Faulted	Pressure +Weight +Valve thrust +Fluid dynamic effects +Pipe rupture	ASME Code Case 1606 $\Sigma(\text{Primary}) \leq 2.4 S_h$
Faulted	Pressure +Weight +Tornado	ASME Code Case 1606 $\Sigma(\text{Primary}) \leq 2.4 S_h$

NOTE:

(1) Refer to Section 3.9.3.1-3 for load combination method.

Item 100 - Table 3.9.3-6

Note 4 to Table 3.9.3-6 indicates that the design requirements are not applicable to parts contained within the valve or which are not part of the pressure boundary.

It is the staff's position that the valve disc is a part of the pressure boundary. Therefore, indicate the design criteria for valve discs when subject to " P_{max} "

Response:

The requirements implemented by Westinghouse for valve discs were discussed. Westinghouse indicated that the design requirement for valve discs was 110 percent of the maximum differential operating pressure. It was agreed that footnote 4 to Table 3.9.3-6 (attached) would be revised to reflect the design criteria utilized by Westinghouse.

Based on the above discussion and the attached FSAR change, this item was resolved.

ATTACHMENT TO ITEM 100

TABLE 3.9.3-6 (Page 2)

Stress Criteria for Safety Related ASME Code Class 2 and Class 3 Valves

NOTES:

2. Casting quality factor of 1.0 shall be used.
3. These stress limits are applicable to the pressure retaining boundary, and include the effects of loads transmitted by the extended structures, when applicable.
4. Design requirements listed in this Table are not applicable to valve ~~discs~~, stems, seat rings, or other parts of valves which are contained within the confines of the body and bonnet, ~~or otherwise not part of the pressure boundary.~~ *Value discs are designed to 110 percent of the maximum differential operating pressure.*
5. The maximum pressure resulting from upset, emergency or faulted conditions shall not exceed the tabulated factors listed under P_{max} times the design pressure. If these pressure limits are met, the stress limits in Table 3.9.3-6 are considered to be satisfied.
6. Refer to Table 3.9.3-1 for Load Combinations.

Item 101 - 3.2.2, page 3.2-1

Are the safety and relief valve piping on the main steam line classified as safety-related? Are there any other piping > 2½" connected to the main steam line up to the outermost containment isolation valve? If so, what is its safety classification?

Explain the design of these portions of structures and systems that form an interface between Seismic Category I and non-Seismic Category I features. What QA requirements are applied to those systems, structures, and components?

(Q210.1) Provide a discussion of your compliance W/R.G. 1.29.

Response:

Page 10.3-1 will be revised as attached.

Piping up to and including main safeties is Duke Class B. Safety valve outlet pipes and vent stacks are Duke Class F so that a seismic event cannot damage the outlet pipes and/or vent stacks in such a manner as to impair valve operation.

The following piping is greater than 2½" and connected to the main steam lines upstream of the main steam isolation valves. All the listed piping is Duke Class B.

- a) Condensate drain drip legs
- b) Lines to PORV's and safeties
- c) Lines to auxiliary FWP turbine.

10.3 MAIN STEAM SUPPLY SYSTEM

10.3.1 DESIGN BASES

The Main Steam Supply System is designed to achieve the following:

1. Provide steam flow requirements at main turbine inlet design conditions.
2. Dissipate heat from the Reactor Coolant System following a turbine and/or reactor trip by dumping steam to the condenser and atmosphere.
3. Provide steam as required for:
 - a. Main and auxiliary feedwater pump turbines.
 - b. Condenser steam air ejectors.
 - c. Main and feedwater pump turbine seals.
 - d. Miscellaneous auxiliary equipment.
4. Conform to applicable design codes presented in Table 3.2.2-2.
5. Allow visual in-service inspection.
6. Protect adjacent equipment against heat damage.

10.3.2 DESCRIPTION

Main steam is generated in the four steam generators by feedwater absorbing heat from the Reactor Coolant System. Main steam is conveyed by four lines, one per steam generator, to the turbine inlet valves. A pressure equalization and steam distribution header is connected to each main steam line upstream of the turbine inlet valves. A flow restrictor is provided in each steam generator outlet nozzle to limit maximum flow and the resulting thrust forces caused by a steam line rupture. The steam generators and all main steam piping and valves to the outer doghouse walls are Duke Safety Class B. Main steam piping across the yard to the Turbine Building wall is Duke Safety Class F. All other piping is Duke Class G. See Figures 10.3.2-1, -2, -3, -4, -5, -6, -7, and -8.

Five self-actuated safety valves are located on each main steam line (a total of twenty) in the doghouses to prevent overpressurization of the Main Steam System under all conditions. The valves are designed to pass 105 percent of the Engineered Safeguard Design (ESD) steam flow at a pressure not exceeding 110 percent of the system design pressure (1200 psia). See Tables 3.2.2-1 and 3.2.2-2 for applicable codes.

All piping up to the condenser inlet valves is Duke Safety Class B. The safety valves are designed to pass 105 percent of the ESD steam flow at a pressure not exceeding 110 percent of the system design pressure (1200 psia). See Tables 3.2.2-1 and 3.2.2-2 for applicable codes.

Item 102 - 3.6.1.1.1, page .36-1

The FSAR stated that "reactor coolant piping is restrained such that the lateral displacements of the broken ends of the pipe are less than the pipe wall thickness."

Provide the assumptions and the analytical results to verify this statement.

The FSAR states that system response due to breaks in the RCS are "accommodated directly by the supporting structures of the reactor vessel, the steam generator, and the reactor coolant pumps including two additional pipe supports." Provide the assumptions and analytical results to justify the statement.

Response:

Based on the discussions relative to Items 12 and 72 on break sizes, the criteria relative to pipe displacement and wall thickness is not pertinent to any of the criteria specified or analyses performed for the Catawba plant. Consequently, it was agreed that the reference to lateral displacements of RCS piping be deleted from the FSAR.

This item also refers to two pipe whip restraints in the RCS. This should be changed to seven to correctly reflect the restraint configuration of each RCS loop.

Based on the above discussion and the attached FSAR revisions, this item was resolved.

ATTACHMENT TO ITEM 102

CNS

3.6 PROTECTION AGAINST DYNAMIC EFFECTS ASSOCIATED WITH THE POSTULATED RUPTURE OF PIPING

General Design Criterion 4 of Appendix A to 10CFR50 required that structures, systems, and components important to safety be protected from the dynamic effects of pipe failure. This section describes the design bases and design measures to ensure that the containment vessel and all essential equipment inside or outside the containment, including components of the reactor coolant pressure boundary, have been adequately protected against the effects of blow-down jet and reactive forces and pipe whip resulting from postulated rupture of piping.

Criteria presented herein regarding break size, shape, orientation, and location are in accordance with the guidelines established by NRC Regulatory Guide 1.46, and include considerations which are further clarified in NRC Branch Technical Positions MEB 3-1 and APCS 3-1 where appropriate. These criteria are intended to be conservative and allow a high margin of safety. For those pipe failures where portions of these criteria lead to unacceptable consequences, further analyses will be performed. However, any less conservative criteria will be adequately justified and fully documented.

3.6.1 POSTULATED PIPING FAILURES IN FLUID SYSTEMS INSIDE AND OUTSIDE CONTAINMENT

3.6.1.1 Design Bases

3.6.1.1.1 Reactor Coolant System

The Reactor Coolant System, as used in Section 3.6 of the Safety Analysis Report, is limited to the main coolant loop piping and all branch connection nozzles out to the first butt weld. The particular arrangement of the Reactor Coolant System, building structures, and mechanical restraints preclude the formation of plastic hinges for breaks postulated to occur in the Reactor Coolant System. Consequently, pipe whip and jet impingement effects of the postulated pipe break will not result in unacceptable consequences to essential components. ~~Reactor coolant loop piping is restrained such that the lateral displacements of the broken ends of the pipe are less than the pipe wall thickness.~~ This restraint configuration, along with the particular arrangement of the Reactor Coolant System and building structures, mitigates the effects of the jet from the given break such that no unacceptable consequences to essential components are experienced.

The application of criteria for protection against the effects of postulated breaks in the Reactor Coolant System in accordance with Reference 1 results in a system response which can be accommodated directly by the supporting structures of the reactor vessel, the steam generator, and the reactor coolant pumps including ~~two~~ additional pipe supports. The design bases for postulated breaks in the Reactor Coolant System are discussed in Section 3.6.2.1.

SEVEN

Item 103 - 3.6.2.1.1, page 3.6-7

Describe the analysis performed to verify the integrity and operability of the isolation valves for a pipe break beyond the restraint.

Response:

The integrity and operability of the isolation valves is insured by the standard analyses for any pipe rupture event. An occurrence that would affect the design function of the double isolation valves, inclusive of a single active failure, will be reviewed and protection provided for a break downstream of the restraint. With the crane wall as a guide, the restraint will resist loading that would affect the valves, and the power cables will be protected if they are targets of the subject break. The break is 182 linear pipe feet away from the closest valve and is 43 arch feet away from the closest valve. The above analysis is consistent and sufficient to insure the integrity and operability of the double isolation valves.

The attached revision to FSAR page 3.6-29 provides Duke's commitment to supply a list of postulated pipe break locations.

CNS

3.6.2.4.3 Residual Heat Removal Recirculation Line Penetration

Residual heat removal recirculation line penetrations are of the cold-penetration type. (See Figure 3.6.2-6)

Design requirements for these penetrations are as follows:

- a) The recirculation line is an extension of Containment up through the first valve.
- b) These valves are Safety Class 2 and are conservatively designed (600 psig design pressure) to withstand the Containment design pressure of 15 psig.
- c) Valves are located in an accessible area for maintenance during the post-accident period.
- d) Expansion joints are utilized in the penetration design.

3.6.2.4.4 Access for Periodic Examination

A description of the method of providing access to permit periodic examinations of process pipe welds within the protective assembly as required by the plant inservice inspection program is discussed in Section 6.6.

3.6.2.5 Summary of Dynamic Analyses Results

A summary of the dynamic analyses, resulting from postulated pipe breaks in high-energy piping systems, is presented for a typical high-energy system. The analyses summary of the example system (Safety Injection, NI) is comprised of the following information:

- a) System pipe routing - Figures 3.6.2-9 thru 3.6.2-36
- b) Location of postulated breaks - Figures 3.6.2-9 thru 3.6.2-36
- c) Location of postulated pipe rupture restraints - Figures 3.6.2-9 thru 3.6.2-36 (Jet barriers are located near target to intercept jet)
- d) Summary of protection requirements - Tables 3.6.2-7 and 3.6.2-8
- e) Summary of combined stresses at break locations - Tables 3.6.2-4 thru 3.6.2-6
- f) Plans of plant layout at various elevations - Figures 3.6.2-37 thru 3.6.2-41

A summary of postulated circumferential and longitudinal break locations are shown on Figures (later).

Item 104 - 3.6.2.1.1.1, page 3.6-9


Show locations of pipe whip restraints on the reactor coolant piping and for which breaks in the RCS they are designed.

Response:

It was agreed that Figure 3.6.2-4 would be revised to indicate the location of pipe breaks and restraints for the RCS.

Based on the attached FSAR revision, this item was resolved.

ATTACHMENT TO ITEM 104



Reactor Coolant Loop Model

Item 105 - 3.6.2.1.1.2, page 3.6-10

A longitudinal break (Break 7) at 50° elbow on the Intrados assumes a break area less than the cross-sectional area of the pipe. Provide the analytical and experimental bases for the limited break. (Reference 1 does not contain the assumptions).

Response:

The longitudinal break at the 50° elbow in the RCS was assumed to be one full break area. The FSAR has been revised to reflect this break size and "less" will be deleted.

Based on the above discussion and the attached FSAR change, this item was resolved.

ATTACHMENT TO ITEM 105

CNS

- c) Damage to the high head safety injection lines connected to the other leg of the affected loop or to the other loops is prevented.
- d) Propagation of the break to high head safety injection line connected to the affected leg is prevented if the line break results in a loss of core cooling capability due to a spilling injection line.

3.6.2.1.1.1 Postulated Piping Break Locations and Orientations

In each leg of the Reactor Coolant System, a minimum of three postulated rupture locations shall be selected in the following manner:

Breaks shall be postulated at the terminal end points and at all locations in a run or branch in which the cumulative usage factor exceeds 0.2 for normal and upset operating conditions or in which the range of primary plus secondary stress intensity for normal and upset operating conditions exceeds 80 percent of the ASME Section III Code allowable on an elastic basis (2.4 S_u). In the event that a location between the terminal end points cannot be chosen in this manner, the point of highest fatigue usage shall be used to obtain a total of three break locations.

At each possible break location, consideration must be given to the occurrence of either a circumferential or longitudinal break. As discussed in Reference 1, a circumferential rupture is more likely than a longitudinal rupture for reactor coolant piping. Only in the case of one elbow is a longitudinal rupture postulated.

Circumferential breaks are perpendicular to the longitudinal axis of the pipe.

Longitudinal breaks are parallel to the longitudinal axis of the pipe. Certain longitudinal break orientations may be excluded on the basis of the state of stress at the location considered.

For the main reactor coolant piping system, eleven discrete break locations were determined by stress and fatigue analyses. The locations are given in Table 3.6.2-1 and shown in Figure 3.6.2-2. The postulated locations conform to the criteria stated above and are discussed in Reference 1.

Break type at each discrete break location are presented in Table 3.6.2-1. The results of the analyses which lead to the break orientations are discussed in Reference 1.

3.6.2.1.1.2 Postulated Piping Break Sizes

For a circumferential break, the break area is the cross-sectional area of the pipe at the break location, unless pipe displacement is shown to be limited by analysis, experiment or physical restraint.

For a longitudinal break, the break area is the cross sectional area of the pipe at the break location unless analytically or experimentally shown otherwise. A longitudinal break area ~~less than~~ the cross sectional area of the

EQUAL TO

Item 106 - 3.6.2.2.2.3, page 3.6-24

In the equation used to calculate jet impingement loads, explain the use of "cos θ ."
Explain how the total cross-sectional area of the jet at the target structure (A_j) is calculated.

Response:

When determining a jet load on an object which is not perpendicular to the axis of the jet, the term cos θ is used to determine the resultant jet load to which the object will be subjected. The total cross-sectional area of the jet (A_j) is calculated by the equation:

$$A_j = A_e \left(1 + \frac{2X}{D_e} \tan 10^\circ \right)^2$$

where: A_e = break area

D_e = diameter of the break

X = distance from the source to target

the 10° angle is the half angle of expansion of the jet, for an expanding jet.

Item 107 - 3.6.2.3.3, page 3.6-36

Describe what buckling criteria and limits are used in the design of pipe whip restraints.


Response:

The allowable stress in compression is limited to 1.5 times the AISC allowable.

This item is closed.

Table 3.6.2-3

Stress Allowables for Design of Pipe Rupture Restraints¹

Stress	Allowable
1. Tension	
a. On the net section, except at pinholes	$f_t = .90F_y$
b. On the net section at pinholes in eye-bars pin connected plates of builtup members	$f_t = .66F_y$
2. Shear	$f_v = .55F_y$
3. Compression	$f_a = 1.5 \times (\text{AISC formula 1.5-1})$ but not to exceed $f_a = \frac{23}{18} \times (\text{AISC formula 1.5-2})$
4. Bending	$f_b = 1.33 \times (\text{AISC Section 1.5.1.4})$
5. Combined Stresses	per AISC Section 1.6 with F_t, F_v, F_a and F_b as modified above. F_e may be modified by $\frac{23}{18} \times (\text{AISC formula})$
6. Bolts 	
a. Tension	60.0 ksi
b. Shear	22.5 ksi
7. Welds	
a. full penetration	equal to base material allowable
b. fillet partial penetration	1.5 x (AISC code)
c. fillet	

1.5 x (allowable stress from AISC manual)

¹Rupture restraints may also be designed to F-1300 of Appendix F to Section III of the ASME code. Also see Sections 3.6.2.3.2 and 3.6.2.3.3.

²For ~~A193 bolts 1-1/8 inches in diameter and greater, a larger allowable shear and tensile value may be used, provided the factor of safety of slip, calculated in accordance with Commentary Section C4 of the Specification for Structural Joints is equal to, or greater than, that for A325 bolts.~~

³~~Anchor bolts which are drilled through a wall of floor and are pretensioned may be pretensioned with a value less than the proof load, provided the allowable shear is reduced in accordance with the formulas in AISC Section 1.6.3.~~

8. Crushing strength of crush pads are designed and purchased in accordance with individual device requirements shown on applicable drawings.

9. Crush pipes are designed using yield strength per actual mill test reports.

Item 108 - 3.6.2.5, page 3.6-29

Item c) - The locations of pipe whip restraints are not shown in the Figures 3.6.2-9 thru 3.6.2-36. Provide locations of all pipe whip restraints, jet barriers, and enclosures.

Response:

To determine the location of the restraint, you must identify the particular restraint used for a particular break, reference Table 3.6.2-7 and 3.6.2-8 (Summary of protection requirements). Then refer back to the figures (3.6.2-9 thru 3.6.2-36) showing the location of the break and find that particular restraint.

Jet barriers cannot be shown on the piping isometric drawings because jet barrier location can be anywhere between the source break and the target.

Item 109 - 3.7.2.14, page 3.7-36 (Proprietary version sent under separate letter)

Provide justification that for the Catawba SSE, the fuel assembly displacements are large enough to result in no damping values less than 10%.

Response:

The fuel assembly damping values are measured from mechanical tests in both air and still water environments which envelop specific Catawba plant conditions. The measured damping characteristics indicated that the damping value tends to increase as a result of increasing fuel assembly deflection amplitude. The fuel assembly damping value measured in the submerged flow conditions are much higher than that obtained in air. Furthermore, the in-core neutron detector results indicated a very high fuel assembly damping value due to hydrodynamic effects and inter-fuel assembly rubbing in a closely packed reactor core.

Under a postulated faulted condition transient such as an SSE or LOCA, the fuel assembly deflection amplitude generally reaches the physical limit imposed by accumulated inter-fuel assembly gaps. In order to accurately predict the fuel assembly dynamic responses under the postulated transients, a uniform [] +(a,b,c) damping value was imposed for all modes as a result of mechanical damping. An additional []+(a,b,c) was included for the fuel assembly fundamental mode to account for the hydrodynamic effects; the damping combination for the fuel assembly model was calculated using the method of combining mass and stiffness damping coefficients. These damping values used for the fuel assembly analysis are conservatively justified, based on the measured results from in-core neutron detectors.

Additionally, Westinghouse has monitored in plant vibration of fuel assemblies. This data indicates that fuel assembly displacements in the range of .001 inch results in damping value in excess of []^{a,b,c}. The results of this study have been published in an ASME paper (79-DET-43) entitled, "In-Core Detection of Nuclear Fuel Assembly Vibration."

Based upon the information provided above a fuel assembly damping value of []^{a,b,c} is conservative over the entire range of fuel assembly displacements which could be postulated for the Catawba plant.

In conjunction with this item, Reference 4 in Section 3.7 (pg. 3.7-36) should be revised as follows:

Beaumont, M. D. (et.al.) Ed., "Verification Testing and Analyses of the 17x17 Optimized Fuel Assembly, "WCAP-9401-P-A/WCAP-9402-A dated August, 1981.

Based upon the above discussion and the attached FSAR changes, this item was resolved.



an ASME
publication

\$3.00 PER COPY
5 TO ASME MEMBERS

ATTACHMENT TO ITEM 109

In-Core Detection of Nuclear Fuel Assembly Vibration

W. L. BRYAN

Senior Engineer
Westinghouse Electric Corp.,
Nuclear Fuel Division,
Pittsburgh, Pa.
Mem. ASME

In order to monitor in-plant vibrations of Westinghouse pressurized water reactor nuclear fuel assemblies, neutron flux variations were measured at fuel rod support locations. Fuel assemblies were monitored at various core locations in two operating nuclear power plants. The monitored assemblies produced frequencies and mode shapes which closely matched out-of-core test results. Digital analysis techniques described in this report can be applied to many other testing situations.

Contributed by the Design Engineering Division of the American Society of Mechanical Engineers for presentation at the Design Engineering Technical Conference, St. Louis, Mo., September 10-12, 1979. Manuscript received at ASME Headquarters May 29, 1979.

Copies will be available until June 1, 1980.

In-Core Detection of Nuclear Fuel Assembly Vibration

W. J. BRYAN

ABSTRACT

In order to monitor in-plant vibrations of Westinghouse pressurized water reactor nuclear fuel assemblies, neutron flux variations were measured at fuel rod support locations. Fuel assemblies were monitored, at various core locations, in two operating nuclear power plants. The monitored assemblies produced frequencies and mode shapes which closely matched out-of-core test results. Digital analysis techniques described in this report can be applied to many other testing situations.

NOMENCLATURE

Applied force	= $f(t)$
critical damping coefficient	= C_c
damping constant	= c
Fourier transform function	= $X(j\omega)$
Fourier transform of output	= $O(j\omega)$
Fourier transform of input	= $I(j\omega)$
frequency	= ω
frequency response	= $H(j\omega)$
fuel assembly frequency measured divided by the fuel assembly calculated frequency	= θ
function in the time domain	= $x(t)$
Laplace variable	= s
Laplace transformed function	= $X(s)$
Laplace transform of output	= $O(s)$
Laplace transform of input	= $I(s)$
mass	= m
Modal damping coefficient	= ξ
natural frequency	= ω_m
resultant displacement	= x

rms value of vibration components between two frequencies	= σ
spring constant	= k
time	= t
transfer function	= $G(s)$

INTRODUCTION

To monitor nuclear fuel assembly vibrations within a Westinghouse pressurized water reactor core, a program employing movable in-core neutron detectors within the instrument tube of fuel assemblies was initiated. Neutron flux measurements were taken from two operating nuclear cores. Flux measurements, within selected fuel assemblies, were made at each fuel rod support (grid) location. The data was recorded on magnetic tape and analyzed with a fast Fourier transform analyzer. In this manner, a comparison of relative grid-to-grid displacement was made for a given fuel assembly, thereby, establishing its dynamic characteristics. A typical fuel assembly is shown in Figure 1.

DETERMINATION OF FUEL ASSEMBLY DYNAMIC CHARACTERISTICS

Fuel assembly vibrational characteristics during in-core tests were determined using modal analysis techniques. Modal analysis is a process of characterizing the dynamic properties of an elastic structure by identifying its modes of vibration. That is, each mode has a specific natural frequency and damping factor which can be identified from almost any point on the fuel assembly. In addition, the mode has a particular shape which defines it spatially over the entire assembly.

The tests consisted of recording time history neutron flux variations on magnetic tape and then reducing them via Fourier and Laplace transforms on a digital Fourier analyzer. The Fourier transforms were used for computing frequency response, power spectrum, and coherence functions. The Laplace transform was employed to compute analytical expressions for transfer functions from frequency response measurements. In the past, the disadvantage of transformation analysis was in the solving of the resulting




Fig. 1 Typical Fuel Assembly

integral equation, this was especially true for experimental data. However, with the advent of the digital computer and related transformation algorithms, experimental data is now quite easily handled. In fact, the relationships between the time, frequency, and Laplace domains are well defined quantities in today's digital Fourier analyzers, making them perfect analysis tools.

The Fourier and Laplace transforms are mathematical methods that allow data to be transformed from one independent variable to another: Fourier transforms time to frequency; Laplace transforms time to the Laplace s-variable. The Fourier transformation pair is defined as:

$$X(j\omega) = \int_{-\infty}^{\infty} x(t)e^{-j\omega t} dt \quad (1)$$

and

$$x(t) = \int_{-\infty}^{\infty} X(j\omega) e^{j\omega t} d\omega \quad (2)$$

where equation (1) is the forward transformation and equation (2) is the inverse transformation.

$X(j\omega)$ also contains the amplitude and phase information at every frequency present in $x(t)$ without stipulating $x(t)$ to be periodic.

In the same manner, the Laplace transform pair is defined as:

$$X(s) = \int_0^{\infty} x(t)e^{-st} dt \quad (3)$$

and

$$x(t) = \frac{1}{2\pi j} \int_{\sigma_1 - j\infty}^{\sigma_1 + j\infty} X(s) e^{st} ds \quad (4)$$

where equation (3) is forward transformation and equation (4) the inverse transformation.

The frequency response of the system is defined as the Fourier transform of the r input divided by the Fourier transform of the input, or:

$$H(j\omega) = \frac{O(j\omega)}{I(j\omega)} \quad (5)$$

In the same manner, the transfer function is defined as the Laplace transform of the output divided by the Laplace transform of the input, or:

$$G(s) = \frac{O(s)}{I(s)} \quad (6)$$

In these processes of signal transformation, information is gained or lost as it is transformed from one domain to another. An example of presenting the same information in three different domains is shown in Figure 2. In the time domain, the transform function is the unit impulse response; in the frequency domain, it is the frequency response function; and in the Laplace or s-domain, it is the transfer function. Table 1 summarizes the transfer functions in their different forms.

The dynamic or apparent stiffness, impedance or mechanical impedance, and dynamic or apparent mass are all ratios of input force excitation to response motion and identify resonant frequencies by minimum values, or valleys in the graphic presentation. The dynamic compliance or compliance, mobility, and inertance are reciprocal relationships of the previous transforms, thus, resonant frequencies are identified as maximum values, or peaks, in the graphic presentations.

TABLE 1
DIFFERENT FORMS OF THE TRANSFER FUNCTION FOR MECHANICAL SYSTEMS

$$\frac{\text{Displacement}}{\text{Force}} = \text{Dynamic Compliance or Compliance}$$

$$\frac{\text{Force}}{\text{Displacement}} = \text{Dynamic Stiffness or Apparent Stiffness}$$

$$\frac{\text{Velocity}}{\text{Force}} = \text{Mobility}$$

$$\frac{\text{Force}}{\text{Velocity}} = \text{Mechanical Impedance or Impedance}$$

$$\frac{\text{Acceleration}}{\text{Force}} = \text{Inertance}$$

$$\frac{\text{Force}}{\text{Acceleration}} = \text{Dynamic Mass or Apparent Mass}$$

It can be shown that for a simple single degree-of-freedom system the Laplace transform equation can be written as:

$$X(s) = \frac{F(s)}{ms^2 + cs + k} \quad (7)$$

The denominator is called the characteristic equation, since the roots of the equation determine the character of the time response. The roots of the characteristic equation are known as poles or singularities of the system, and the function becomes zero at their locations. The roots of the numerator polynomial are called the zeroes of the system. These poles and zeroes are located at critical frequencies of the system. Therefore, the transfer function of a dynamic system is defined as the ratio of the output of the system to the input to the s-domain. It is, by definition, a function of the complex variable s. If a system has m inputs and n resultant outputs, then the system has mn transfer functions.

The transfer function which relates the displacement to the force is referred to as the compliance transfer function and is expressed as:

$$H(s) = \frac{X(s)}{F(s)} \quad (8)$$

Therefore, for the single degree of freedom system

$$H(s) = \frac{1}{ms^2 + cs + k} \quad (9)$$

Since s is complex, the transfer function has a real and an imaginary part, and it can be represented by points in a plane. This plane is referred to as the s-plane. Any complex value of s may be located by plotting its real component on one axis and its imaginary component on the other. The magnitude of the function can be plotted as a surface above the plane. If the frequency response function of the system was measured using a Fourier transform, the function frequency would be complex-valued. It would be represented by its real and imaginary parts, or equivalently, by its magnitude and phase. The Fourier transform, as seen previously, is obtained by merely substituting $j\omega$ for s. This special case of the transfer function is called the frequency response function, and it is the basic concept used in spectrum analyzers. Hence, the Fourier transform is merely the Laplace transform evaluated along the $j\omega$, or frequency axis, of the complex Laplace plane.

The analytical form of the frequency response function is found, therefore, by letting $s = j\omega$:

$$H(j\omega) = \frac{1}{-m\omega^2 + jc\omega + k} \quad (10)$$

Substituting ω_n and ξ , and letting $F(j\omega) = kf(j\omega)$ then, $H(j\omega)$ becomes

$$\frac{X(j\omega)}{F(j\omega)} = H(j\omega) = \frac{1}{1 + 2\xi j \left(\frac{\omega}{\omega_n} \right) - \frac{\omega^2}{\omega_n^2}} \quad (11)$$

This equation is the classical form of the frequency response function.

The equation of motion of an n degree-of-freedom system and its Fourier and Laplace transforms can be set up in the same fashion incorporating matrix methods. In matrix form $H(s)$ is defined as the inverse of the system matrix and completely defines the dynamics of the system. The residues from any row or column of $[H(s)]$ define the system mode shapes for the natural frequencies which are determined from the system poles. The poles also determine the system damping values. The n global system values for the pole locations will be the same for all transfer functions in the system because the modes of vibration of an elastic system are global properties. However, the value for the residues depend on the particular terms of the

function and are unique for each system. In addition, values of the residues determine the amplitude of the resonance in each transfer function. Therefore, the four properties of any vibration can be determined, namely, its natural frequency, damping, magnitude, and phase. Except for positions at node points, these model parameters can be identified from any row or column of the transfer function matrix $[H]$. Therefore, from a testing point of view, these techniques offer important time saving advantages.

In a reactor core, nuclear fuel assemblies are subjected to pressure fluctuations caused by high-speed coolant flow. These pressure fluctuations cause flow-induced vibrations in the assemblies. The identification of the coolant flow pressure fluctuations, as well as their effects on the operation and life of the fuel assembly, is paramount. To determine these effects, the dynamic characteristics of the assemblies must be determined, however, before statistical methods used to determine these effects can be employed, data must be categorized. In particular, the excitation and response must be tested for randomness and whether they are stationary or nonstationary. Additional tests can divide stationary data, placing them into ergodic or non-ergodic categories. Data distribution must be known, so that proper error formulas are used. All data can be analyzed using specialized techniques, however, this paper presents only random, stationary data. For any real system, random, stationary data can not be collected and, therefore, judgment must be used when evaluating analytical results.

Because $F(t)$ is assumed to be random and stationary in nature, the probability distribution for vibrational amplitude, in a given direction, is Gaussian, and it can be written about a zero mean, as:

$$P_Y(y) = \frac{1}{\sqrt{2\pi}\sigma} \exp \left[-1/2 \left(\frac{y}{\sigma} \right)^2 \right] \quad (12)$$

which implies that σ , the standard deviation, for a zero mean value, is equal to the rms value. The probability that an observed value of displacement will range between $-y_0$ and y_0 , or cumulative distribution, is determined by the integration:

$$P[-y_0 \leq y \leq y_0] =$$

$$\int_{-y_0}^{y_0} P_Y(y) dy = \frac{1}{\sqrt{2\pi}\sigma} \int_{-y_0}^{y_0} \exp \left[-1/2 \left(\frac{y}{\sigma} \right)^2 \right] dy \quad (13)$$

The normal probability integral or cumulative distribution, has been evaluated and is tabulated in various sources. Several values are listed below:

n	P(-n ≤ y ≤ n)
0.5	0.383
1.0	0.683
1.5	0.866
2.0	0.954
2.5	0.988
3.0	0.997

Therefore, vibrational amplitude 0 to peak will be greater than 3σ for 0.3 percent of the time.

From this probabilistic view, σ , defined as the rms value of vibration amplitude components between two given frequency limits is obtained directly from the power spectrum as:

$$\sigma = \left[\int_{f_1}^{f_2} \rho^2 df \right]^{1/2} \quad (14)$$

which is the square root of the area under the power spectral density curve.

In addition to this information, the power spectral density curve can be used to obtain a damping value for a lightly damped system, i.e., ($\xi \ll 1$) $= \sqrt{1 - \xi^2} \approx 1$. The mean squared response was equal to:

$$\bar{x}^2 = \frac{1}{2\pi} \int_0^{\infty} |H(j\omega)|^2 d\omega \quad (15)$$

where $H(j\omega) = f$, a constant power spectral density function for white noise.

Substituting, the mean square response becomes

$$\bar{x}^2 = \frac{1}{2\pi} \int_0^{\infty} \frac{1}{\left[1 - \left(\frac{\omega}{\omega_n}\right)^2\right]^2 + 4\xi^2 \frac{\omega^2}{\omega_n^2}} d\omega \quad (16)$$

The integral can be evaluated by the method of residues to obtain:

$$\bar{x}^2 = \frac{f}{2\pi} \left(\frac{\pi}{4} \frac{\omega_n}{\xi}\right) = \frac{f\omega_n}{8\xi} \quad (17)$$

The value of the integral $\int_0^{\infty} |H(j\omega)|^2 d\omega$ is equal to

$$\frac{\pi \omega_n}{4\xi}$$

From these equations, it follows that the peak value of $|H(j\omega)|$ occurs at the natural frequency of the system ω_n .

$$|H(j\omega_n)| = \frac{1}{2\xi} \quad (18)$$

In Figure 3, the frequencies ω_1 and ω_2 are called the half power points. The frequency difference ($\omega_2 - \omega_1$) is referred to as the bandwidth of the complex frequency response function $|H(j\omega)|$ and the modal damping coefficient can be determined by:

$$\xi = \frac{|\omega_1 - \omega_2|}{2\omega_n} \quad (19)$$

To obtain the data for analysis, movable in-core neutron flux detectors were used. These detectors move vertically in the instrumentation tube of the fuel assemblies. The detectors measure the horizontal variation of neutron flux attenuation by changing current in its ion chamber. Thus, with the correct proportionality constant, the variations in neutron flux provide relative amplitudes of vibration between grid locations, absolute amplitudes, frequency, and damping content. To assure the relative amplitude of one grid motion to another, the neutron flux detector was positioned vertically at the minimum instrument signal within the grid. This was then checked by the insertion length of the neutron flux detector into the core.

Nuclear noise data was recorded on magnetic analog tape during start-up data collection periods at two nuclear plant sites. During data collection, reactor power levels were held at 30 percent, 32.5 percent, and 100 percent at full flow conditions. Fuel assemblies which were monitored were located such that all the possible core baffle boundary conditions present in the reactors were analyzed. These conditions were adjacent to two fuel assemblies and two baffle walls, adjacent to three fuel assemblies and one baffle wall, and adjacent to four fuel assemblies.

The following assumptions were made in the data reduction processes: 1) Fuel assembly vibrations were linear, 2) Random forcing function was used to excite fuel assembly vibrations. The first assumption was confirmed by the small assembly vibrational amplitudes. The second assumption was confirmed by the normal distribution of the neutron flux data.

To obtain frequencies, pikes were located on the spectral plots and their corresponding frequencies recorded. These plots were calculated in the frequency range of 0-50 Hz with a spectral resolution of 0.125 Hz and a noise bandwidth of 0.198 Hz. For each spectrum, sixty-four continuous spectral averages were performed. To normalize the spectrum, the results were divided by the measured dc level, which is proportional to the steady state flux. The error of the spectral density was approximately ± 10 percent. The first three frequencies of a typical fuel assembly are presented in terms of β , the test frequency measured divided by the calculated frequency, in Figure 4. Test frequencies compared well to analytically calculated frequencies.

Fuel assembly motion was determined by the integration of the spectrum between frequency limits of interest (equation 14). This was accomplished by the use of a fast Fourier transform analyzer and a post-processing minicomputer. A transformation of neutron flux to displacement was performed and then normalized on a per mode basis. Typical fuel assembly mode shapes are shown in Figure 4. These values are presented next to analytical results determined by use of finite element methods and confirmed by out-of-core testing. Both methods showed good agreement with in-core test results. A typical σ displacement was found to be 0.1 mm and occurred in modes 1 and 2. This displacement was found to be higher than that obtained in out-of-core test results but not high enough to cause assembly rubbing or impacting. The assembly which showed the largest amplitude of vibration, in one of the plants, was examined after its first cycle of use. No scuffing marks on any of its grids were observed, thus, further verifying the assumption of a linear fuel assembly vibration.

The best estimate damping curve for the fuel assemblies is presented in Figure 5. The damping coefficients were obtained by use of equation (19). These coefficients were found to be higher than those measured in air bench tests.

CONCLUSIONS

The in-core neutron flux detection tests demonstrated:

- 1) A movable neutron detector can be used to measure fuel assembly vibration characteristics during reactor operations.
- 2) The fuel assemblies which were monitored generally produced frequencies and mode shapes which matched out-of-core test and analytical results.
- 3) The damping coefficients obtained under reactor conditions are greater than those measured in air in bench tests.
- 4) The use of digital analyzer techniques greatly reduces the time and effort required to analyze the test data. These time-saving techniques can be applied to many similar test situations.

ACKNOWLEDGEMENTS

The work of K. L. Schmugar for initiating the program and setting up the data collection procedures, and the efforts of R. Gopal and W. Ciaramitaro for directing of the recording and reduction of neutron flux data to spectrum plots are acknowledged.

REFERENCES

1. Bryan, W. J., "Digital Analysis Techniques Used in Nuclear Fuel Vibration Analysis," ASME Symposium on Flow-Induced Vibration, 1979.
2. Crandall, S. H. and Mark, W. D., Random Vibration in Mechanical Systems, Academic Press, New York, 1963.
3. Crandall, S. H., Random Vibration, Vol. 2, 2nd ed., M.I.T. Press, Cambridge, Mass., 1963.
4. Lyon, R. H., Statistical Energy Analysis of Dynamic Systems: Theory and Applications, M.I.T. Press, Cambridge, Mass., 1975.

5. Thomas, W. T., Vibration Theory and Applications, Prentice-Hall, Englewood Cliffs, N. J., 1972.

6. Hurty, W. C. and M. F. Rubinstein, Dynamics of Structures, Prentice-Hall, Englewood Cliffs, N. J., 1964.

7. Ramsey, K. A., "Effective Measurements for Structural Dynamic Testing," Sound and Vibration 9, pp. 24-35 (1975).




Figure 2. A Mechanical System Can Be Described In: (A) The Time Domain, (B) The Frequency Domain or (C) The Laplace Domain. (7)




Figure 3. A Plot of $H(j\omega)$ vs. ω for a Single Degree of Freedom (1)




Figure 5. Best Estimate Damping Curve for the Assembly, In-Core Conditions (1)





Figure 4. Typical Fuel Assembly Mode Shapes and θ Factor (1)

Item 110 - 3.9.3.3, page 3.9-32

The applicant states that "since Catawba has a slightly higher flow rate than Trojan, vibration levels due to the core barrel excitation are expected to be somewhat greater than those of Trojan." Provide assurance that the vibration levels in the reactor will not cause failure of the reactor neutron shield boltings which might result in the dropping of the neutron shielding pads.

Response:

The neutron shield pad is fastened to the core barrel using 16, 7/8 inch, bolts. Due to the preload of the neutron pad bolts, a high friction force exists between the neutron pad and the core barrel. The analysis shows that this friction force is more than sufficient to eliminate any relative motion between the neutron pad and the core barrel, i.e., cyclic loading of the neutron pad bolts due to dead weight, seismic, hydraulic and vibratory loads. Thus, the vibratory loads will not cause fatigue failure of the neutron pad bolts.

The neutron shield pad is also secured to the core barrel using 3, 2 3/8 in. dia., steel pins which provides added assurance that the neutron pad will not drop off the core barrel.

The properties of these bolts were also discussed. Westinghouse indicated that the subject bolts were 316 stainless steel with a minimum yield strength of 65,000 psi and a minimum tensile strength of 90,000 psi. The preload on these bolts is 70% of the minimum yield strength.

Based upon the above discussion, this item was resolved.

Item 111 - Unit 1 incorporates a Model D3 steam generator. Unit 2 incorporates a Model D5 steam generator. Provide assurance that the Model D3 S/G tubes are adequately designed to prevent failure and adverse secondary side leakage.

Response:

Model D3 steam generators for Catawba Unit 1 and Model D5 steam generators for Unit 2 are designed and manufactured in accordance with the ASME Code Section III Class 1 requirements. Tube degradation mechanisms encountered on steam generators are addressed here.

Tube Thinning - Tube thinning occurred with the use of phosphate chemistry secondary side water treatment. The Catawba units will utilize an all volatile type (AVT) chemistry treatment program and such tube thinning susceptibility should not be a concern.

Tubesheet Crevice Corrosion - The tubes in these steam generators are expanded full depth in the tubesheet. Full depth expansion eliminates the tubesheet crevice and, therefore, crevice corrosion should not occur in these steam generators.

Denting - The first line of defense for susceptibility to denting is the use of AVT chemistry control from initial operation of the plant. The Catawba units are equipped with full flow condensate polishers to help control and maintain the secondary chemistry and utilize fresh water for condenser circulating water. Should there be an inleakage to the condensate and steam generator feedwater through the condensers, the chemical makeup of the circulation water would be less severe than if the plant used sea water or brackish water. Also, the large capacity continuous blowdown system contributes to maintaining the AVT chemistry program. The prevention of denting is predicated on maintaining the chemistry program and reducing to a minimum any periods of operation with off-normal chemistry.

Row 1 "U" Bend Cracking - Row one "U" bend cracking has only occurred in some plants with Model 51 steam generators. The cracking has been attributed to the small bend radius of the row one U bend and the residual stresses in the tube. The steam generators for the Catawba Units are Model D type with different size tubing and a larger row one "U" bend radius, which contribute to lower bending and residual stresses. Row one cracking is not expected to be a concern for these steam generators.

Tube Corrosion in Sludge - The sludge management program is expected to reduce the amount of sludge in the generators to a minimum. The AVT chemistry program reduces or should eliminate deposit of hard sludge so that tube corrosion in sludge should not be a concern in these steam generators. Additionally, the Catawba steam generators are designed to allow sludge lancing during outages to further reduce any sludge inventory that remains in the steam generator.

Flow Induced Vibration at Feed Inlet

Please refer to Duke Power Co., February 23, 1982, letter ⁽¹⁾ response to NRC letter of January 22, 1982, regarding possible tube damage due to flow induced vibrations.

⁽¹⁾Duke letter, W. O. Parker, Jr., to H. R. Denton, NRC, dated February 23, 1982.

Item 112 - 3.7.3.6, page 3.7-29

This section refers to 3.7.2.6 for a discussion of the method Westinghouse uses to account for three components of earthquake motion. For the NSSS piping, how are the three components of earthquake motion handled in the seismic analysis?

Response:

Westinghouse performed a two-dimensional seismic analysis for the Catawba plant. The directional inputs were combined algebraically. The components in the N-S and vertical directions were combined. The components in the E-W and vertical directions were also combined. The two resultants were compared and the larger magnitude used in the analysis.

Based on the above discussion, this item was resolved.

Item 113 - 3.9.3.1

A table of stress criteria and design loading combinations similar to Tables 3.9.3-1 and Table 3.9.3-1 and Table 3.9.3-2 is required for core support structures and component supports.

Response:

The loading combinations for core support structures were discussed and Westinghouse agreed to provide a new table (attached) in the FSAR to address this item. As identified in Item 7, it was pointed out that the core support structures were procured prior to implementation of Subsection NG of the Code. Thus it was agreed to add a footnote to the table indicating how the core support structures compared with ASME Code requirements. It was also agreed that the content of the footnote would also be incorporated in the FSAR text.

Attachment to Item 113

Table 3.9.3-1(A)

Design Loading Combinations for ASME Code Core Support Structures*

<u>Condition Classification</u>	<u>Loading Combination</u>
Design	Design Pressure, Design Temperature, Deadweight
Normal	Normal Condition Pressure, Normal Condition Metal Temperature, Deadweight, Nozzle Loads
Upset	Upset Condition Pressure, Upset Condition Metal Temperature, Deadweight, Nozzle Loads, Operating Basis Earthquake
Faulted	Faulted Condition Pressure, Faulted Condition Metal Temperature, Deadweight, Nozzle Loads, Safe Shutdown Earthquake

*By contract, this plant preceeded the application of Subsection NG of Section III of the ASME Code. Therefore, these internals are not "stamped" and no specific stress report is required. Nonetheless, the internals are designed to meet the intent of the code.

ATTACHMENT TO ITEM 113

CNS

The results obtained from linear analyses indicate that the relative displacement between the components will close the gaps and consequently the structures will impinge on each other. Linear analysis will not provide information about the impact forces generated when components impinge on each other; however, in some instances, linear approximations can, and are applied prior to and after gap closure. The effects of the gaps that could exist between vessel and barrel, between fuel assemblies, between fuel assemblies and baffle plates, and between the control rods and their guide paths were considered in the analysis using both linear approximations and non-linear techniques. Both static and dynamic stress intensities are within acceptable limits.

Even though control rod insertion is not required for plant shutdown, this analysis shows that most of the guide tubes will deform within the limits established experimentally to assure control rod insertion. For the guide tubes deflected above the no loss of function limit, it must be assumed that the rods will not drop. However, the core will still shut down due to the negative reactivity insertion in the form of core voiding. Shutdown will be aided by the great majority of rods that do drop. Seismic deflections of the guide tubes are generally negligible by comparison with the no loss of function limit.

3.9.2.6 Correlations of Reactor Internals Vibration Tests With the Analytical Results

As stated in Section 3.9.2.3, it is not considered necessary to conduct instrumented tests of the Catawba reactor vessel internals. Adequacy of these internals will be verified by use of the Sequoyah and Trojan results.

3.9.3 ASME CODE CLASS 1, 2 AND 3 COMPONENTS, COMPONENT SUPPORTS AND CORE SUPPORT STRUCTURES

The ASME Code Class components are constructed in accordance with the ASME Boiler and Pressure Vessel Code, Section III.

Detailed discussion of ASME Code Class 1 components is provided in Section 3.9.1 and 5.4.

For core support structures, design loading conditions are given in Section

3.9.5.2. (~~3.9.5.2.~~ * Insert a)

In general, for reactor internals components and for core support structures the criteria for acceptability in regard to mechanical integrity analyses are that adequate core cooling and core shutdown must be assured. This implies that the deformation of the reactor internals must be sufficiently small so that the geometry remains substantially intact. Consequently, the limitations established on the internals are concerned principally with the maximum allowable deflections and stability of the parts in addition to a stress criterion to assure integrity of the components.

For the loss of coolant plus the safe shutdown earthquake condition, deflections of critical internal structures are limited. In a hypothesized downward vertical

Item 113

ATTACHMENT TO ITEM 113

INSERT A

The design loading combinations for the ASME Code case support structures are given in Table 3.9.3-1(A). It is to be noted that the reactor internals of this plant are not "stamped" and no specific stress report is required. Nonetheless, the internals are designed to meet the intent of the ASME Code.

Item 114 - 3.9.3.3.1, page 3.9-50

The ASME Code is referenced several times. Any reference to the ASME Code should specify the part of the code being referenced.

Response:

Section 3.9.3.3.1, page 3.9-50 discusses overpressure protection for the Main Steam System. This section references Chapter 10 for further description of ASME Code requirements. Section 10.3.1 references Table 3.2.2-2 which presents the design codes applicable to the Main Steam Supply System. The SM (Main Steam) System and SV (Main Steam Vent) System listed in Table 3.2.2-2 (page 8) indicate the applicable code is ASME Boiler and Pressure Vessel Code-Section III, Class 2.

Whenever practical, FSAR revisions referencing the ASME Code will include the applicable ASME section.

Item 115 - 3.9.5.2, page 3.9-52

The applicant has not included asymmetric loads in the list of design loading conditions for the reactor internals. Assurances must be provided the reactor internals have been analyzed for asymmetric loads.

Response:

See Item 83 for a discussion of asymmetric LOCA loads.

Item 116 - Table 3.9.2-2

Table 3.9.2-2 lists the maximum deflections for reactor internal support structures. The allowable and the no-loss-of function deflections are the same for the upper barrel (radial) component. Provide assurances that this provides for an adequate margin of safety.

Response:

The actual deflections on reactor internals were presented to the Staff and found to be acceptable. Westinghouse agreed to revise the FSAR to indicate that all deflections were acceptable. However, in reviewing the FSAR (attached) it was determined that the appropriate information is already contained in Section 3.9.4. The attached information is similar to those resulting from other MEB review meetings.

Based upon the information presented to the Staff and the attached FSAR material, this item was resolved.

ATTACHMENT TO ITEM 116

CNS

2. The barrel with the core is analyzed as a beam elastically supported at the top and at the lower radial support and the dynamic response is obtained.

Guide Tubes - The dynamic loads on rod cluster control guide tubes are more severe for a loss of coolant accident caused by hot leg rupture than for an accident by cold leg rupture since the cold leg break leads to much smaller changes in the transverse coolant flow over the rod cluster control guide tubes. The guide tubes in closest proximity to the ruptured outlet nozzle are the most severely loaded. The transverse guide tube forces during a blowdown decrease with increasing distance from the ruptured nozzle location.

A detailed structural analysis of the rod cluster control guide tubes is performed to establish the equivalent cross section properties and elastic end support conditions. An analytical model is verified by subjecting the control rod cluster guide tube to a concentrated force applied at the midpoint of the lower guide tube. In addition, the analytical model has been previously verified through numerous dynamic and static tests performed on the 17 x 17 guide tube design.

The response of the guide tubes to the transient loading from blowdown is found by representing the guide tube as an equivalent single degree of freedom system and assuming the slope of the time dependent load to be a step function with constant slope front end.

Upper Support Columns - Upper support columns located close to the broken nozzle during hot leg break will be subjected to transverse loads due to cross flow. The loads applied to the columns are computed with a method similar to the one used for the guide tubes, i.e., by taking into consideration the increase in flow across the column during the accident. The columns are studied as beams with variable section and the resulting stresses are obtained using the reduced section modulus and appropriate stress risers for the various sections.

Results of Reactor Internals Analysis

Maximum stresses due to the safe shutdown earthquake (vertical and horizontal components) and a loss of coolant accident (hot leg or cold leg break) were obtained and combined. All core support structure components were found to be within acceptable stress and deflection limits for a loss of coolant accident occurring simultaneously with the safe shutdown earthquake; the stresses and deflections which would result following a faulted condition are less than those which would adversely affect the integrity of the core support structures. For the transverse excitation, it is shown that the barrel does not buckle during a hot leg break and that it meets the allowable stress limits during all specified transients.

Also, the natural and applied frequencies are such that resonance problems will not occur.

Item
116

Item 122

The Post Accident Hydrogen Recombiner Package is incorrectly classified as Safety Class NA. To be acceptable this component should be classified Safety Class 2.

Response:

The post accident hydrogen recombinder package is safety Class 2, subject to QA requirements, and seismically designed. Table 3.2-2 (attached) has been revised to reflect this classification. It should be noted that this item was received after the MEB review meeting and, as such, was not discussed at the meeting.

Based on the attached FSAR revision, this item was resolved.

ATTACHMENT TO ITEM 122

Table 2-2-2 (Page 10)

Summary of Critical Mechanical System Components

(9)
Tornado
Missile

System Component or System	(2) Scope	(3) Safety Class	(4) Code	(5) QA Req'd	(6) Location	(7) Rad Source	(8) Systems OBI DBI	(9) Tornado Missile
<u>VII Diesel Generator Engine Air and Exhaust System</u>								
Intake Filter	D	HA	-	-	DB	-	-	X
Intake Silencers	D	HA	-	-	DB	-	-	X
Exhaust Silencers	D	HA	-	-	DB	-	-	X
Valves	D	J	111-3	X	DB	-	X	X
<u>VI Containment Purge and Containment Ventilation System</u>								
Containment Purge Air Handling Units	D	HHS	-	-	AB	P	-	X
Containment Purge Air Exhaust Fans	D	HHS	-	-	"	P	-	X
Containment Purge Air Exhaust Filters	D	HHS	-	-	"	P	-	X
Incore Instr. Room Purge Exhaust Air Handling Unit	D	HHS	-	-	AB	P	-	X
Incore Instr. Purge Supply Air Handling Unit	D	HRS	-	-	AB	P	-	X
Valves	D	2	111-2	X	AB, C	P	X	X
<u>VQ Containment Air Release and Addition System</u>								
Filters	D	HNS	-	-	AB	P	-	X
Valves	D	2	111-2	X	AB, C	P	X	X
Fans	D	HA	-	-	AB	P	-	X
<u>VV Containment Ventilation System</u>								
Upper Containment Ventilation Units	D	HNS	-	-	C	P	-	X
Upper Containment Return Air Fans	D	HNS	-	-	C	P	-	X
CRDM Vent Fans	S	HNS	-	-	C	P	-	X
Lower Containment Vent Units	D	HNS	-	-	C	P	-	X
Containment Aux. Charcoal Filter Units	D	HNS	-	-	C	P	-	X
Containment Aux. Charcoal Filter Unit Fans	D	HNS	-	-	C	P	-	X
Incore Instr. Room Ventilation Units	D	HNS	-	-	C	P	-	X
<u>VX Containment Air Return and Hydrogen Skimmer System</u>								
Air Return Fans	D	2	MR/A(12)	X	C	-	X	X
Hydrogen Skimmer Fans	D	2	MR/A(14)	X	C	-	X	X
Valves	D	2	111-2	X	C	-	X	X
<u>VI Containment Hydrogen Sample & Purge System</u>								
Containment Hydrogen Purge Inlet Blower	D	HNS	(10)	-	MB	-	-	X
Containment Sample Blower	D	HNS	(10)	-	AB	X	-	X
Post Accident Elec. Hydrogen Re-combiner Pkg.	W	MR 2	(20)	X	C	-	X	X