

ILLINOIS POWER COMPANY



U-0553

L30-82(09-28)-L

500 SOUTH 27TH STREET, DECATUR, ILLINOIS 62525

September 28, 1982

Mr. Cecil O. Thomas, Chief
Standardization & Special Projects Branch
Division of Licensing
Office of Nuclear Reactor Regulation
U.S. Nuclear Regulatory Commission
Washington, D.C. 20555

Reference: IP letter 6/23/82, U-0508, G. E. Wuller to
H. Bernard, NRC

Dear Mr. Thomas:

Clinton Power Station Unit 1
Docket No. 50-461
Common Vessel Reference Level

In the referenced letter, it was stated that Illinois Power Company would revise its operator training and maintenance procedures to include the fuel zone common vessel reference level. This letter is to confirm that we are adding the further commitment to revise the Clinton Power Station emergency operating procedures so that they properly address the common vessel reference level for the fuel zone level meter.

Since the use of the common vessel reference level only impacts the fuel zone level meter, which is not used during normal plant operations, the only operating procedures which require revision are the emergency operating procedures.

It is our understanding that this information should close out SER confirmatory item #39.

Sincerely,

A handwritten signature in cursive script that reads 'G. E. Wuller'.

G. E. Wuller
Supervisor-Licensing
Nuclear Station Engineering

GEW/lt

cc: Ann M. Ramey-Smith, NRC HFEB
J. H. Williams, NRC Clinton Project Manager
H. H. Livermore, NRC Resident Inspector
Illinois Department of Nuclear Safety

Boo1

8210050289 820928
PDR ADOCK 05000461
E PDR