VERMONT YANKEE NUCLEAR POWER CORPORATION



P.O. Box 157, Governor Hunt Road Vernon, Vermont 05354-0157 (802) 257-7711

> April 10, 1994 VY-RCE-94-009 BVY 94-39

U.S. Nuclear Regulatory Commission Washington, D.C. 20555

Attn:

Document Control Desk

Reference:

a) License No. DPR-28 (Docket No. 50-271)

Dear Sir:

Submitted herewith is the Monthly Statistical Report for the Vermont Yankee Nuclear Power Station for the month of March, 1994.

Very truly yours,

Vermont Yankee Nuclear Power Corp.

Donald A. Reid

Vice President, Operations

cc: USNRC, Region I

USNRC Resident Inspector, VYNPS

180006 9404150252 940331 PDR ADDCK 05000271 JE24

VERMONT YANKEE NUCLEAR POWER STATION

MONTHLY STATISTICAL REPORT 94-03 FOR THE MONTH OF MARCH 1994

OPERATING DATA REPORT

DOCKET NO.50-271

DATE 940410

COMPLETED BY G.A. WALLIN

TELEPHONE (802)257-7711

OPERATING STATUS 1. Unit Name: Vermont Yankee						
2. Reporting Period: March	Reporting Period: March NOTES:					
3. Licensed Thermal Power(MWt):1593						
4. Nameplate Rating (Gross MWe): 540						
5. Design Electrical Rating(Net MWe):	514(oc) 504(cc)				
6. Maximum Dependable Capacity(Gross MW	e): <u>535</u>					
7. Maximum Dependable Capacity(Net MWe)	: 504					
8. If changes, occur in capacity rating last report, give reasons:	s(Items Numb	er 3 through	7) since			
9. Power level to which restricted, if . 0. Reasons for restrictions, if any:	any(Net MWe)					
1. Hours in Reporting Period 2. Number Of Hours Reactor was Critical 3. Reactor Reserve Shutdown Hours 4. Hours Generator On-Line 5. Unit Reserve Shutdown Hours 6. Gross Thermal Energy Generated (MWH) 7. Gross Electrical Energy Generated 8. Net Electrical Energy Generated (MWH) 9. Unit Service Factor 1. Unit Availability Factor 1. Unit Capacity Factor (Using MDC Net) 2. Unit Capacity Factor (Using DER Net) 3. Unit Forced Outage Rate 4. Shutdowns scheduled over next 6 mont Each: N/A	395437.00 380313.00 100.00 100.00 101.42 99.45 1.51	2160.00 0.00 2154.35 0.00 3399641.00 1151755.00 1107360.00 99.74 99.74 101.72 99.74 0.79	186984.00 153377.41 0.00 150269.97 0.00 224105312.50 74671137.00 70954384.00 79.64 79.64 74.61 73.16			
5. If shut down at end of report period 6. Units In Test Status(prior to commer INITIAL CRITICALITY INITIAL ELECTRICITY COMMERCIAL OPERATION		on): N/A	tup:N/A			

VYDPF 0411.01 DP 0411 Rev. 5 Page 1 of 1 RT No. 13.F01.19F

AVERAGE DAILY UNIT POWER LEVEL

DOCKET NO. 50-271
UNIT Vermont Yankee
DATE 940410
COMPLETED BY G.A. WALLIN
TELEPHONE (802)257-7711

MONTH	March		
DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)	DAY	AVERAGE DAILY POWER LEVEL (MWe-Net)
1.	519	17.	494
2.	519	18.	490
3.	519	19.	519
4.	520	20.	520
5.	519	21.	519
6.	519	22.	519
7.	519	23.	519
8.	519	24.	519
9.	519	25.	520
10.	519	26.	520
11.	519	27.	519
12.	519	28.	519
13.	519	29.	519
14.	519	30.	519
15.	333	31.	519
16.	514		

INSTRUCTIONS:

On this format, list the average daily unit power level in MWE-Net for each day in the reporting month. Compute to the nearest whole megawatt.

VYDPF 0411.02 DP 0411 Rev. 5 Page 1 of 1 RT No. 13.F01.18V

UNIT SHUTDOWNS AND POWER REDUCTIONS

REPORT MONTH MARCH

DOCKET NO 50-271 UNIT NAME Vermont Yankee DATE 940410 COMPLETED BY G.A. Wallin

TELEPHONE (802)257-7711

No.	Date	1 Type	Duration (hours)	2 Reason	3 Method of Shutting Down Reactor	License Event Report #	4 System Code	5 Component Code	Cause and Corrective Action to Prevent Recurrence
94-03	940315	S	0.00	В,Н*	4 Power Reduction	N/A	RB	CONROD	Surveillance testing and a Rod Pattern Exchange
94-03	940315	F	11.42	А	4 Power Reduction	N/A	CD	VALVOP	MSIV-80B closure timing out of specification. Speed adjustment made to correct deficient time

1 F: Forced

VYDPF 0411.03

DP 0411 Rev. 5

Page 1 of 1

S: Scheduled

2 Reason:

A-Equipment Failure (Explain) 1 - Manual

B-Maintenance or Test

C-Refueling

D-Regulatory Restriction

E-Operator Training and License Examination

F-Administrative

G-Operational Error (Explain)

*H-(Explain) - Control Rod Pattern Exchange

3 Method:

2 - Manual Scram

4 - Other (Explain)

4 Exhibit G- Instructions for Preparation of Data Entry Sheets for License 3 - Automatic Scram Event Report (LER) File

(NUREG 0161)

5 Exhibit I - Same Source

DOCKET NO. 50-271
DATE 940410
COMPLETED BY G.A. WALLIN
TELEPHONE (802)257-7711

REPORT MONTH March

SUMMARY OF OPERATING EXPERIENCES

Highlights

Vermont Yankee operated at 99.5% of rated thermal power for the month. Gross electrical generation was 395.437 MWHe or 98.4% design electrical capacity.

Operating Summary

The following is a chronological description of plant operations including other pertinent items of interest for the month:

At the beginning of the reporting period the plant was operating at 99.9% of rated thermal power.

- 940315 At 0405 hours, initiated a power reduction to minimum recirculation flow to perform surveillance testing, and a rod pattern exchange.
- 940315 At 0430 hours, initiated turbine bypass valve testing. (See Unit Shutdowns and Power Reductions)
- 940315 At 0533 hours, completed turbine bypass valve testing.
- 940315 At 0601 hours, at minimum recirculation flow, initiated MSIV testing.
 MSIV-80B closure time was not within specification. (See Unit
 Shutdowns and Power Reductions)
- 940315 At 0620 hours, initiated a rod pattern exchange. (See Unit Shutdowns and Power Reductions)
- 940315 At 0715 hours, completed the rod pattern exchange.
- 940315 At 1448 hours, and 40% power, initiated a drywell entry to perform a speed adjustment on MSIV-80B.
- 940315 At 1840 hours, completed speed adjustment to MSIV-80B.
- 940315 At 1858 hours, completed MSIV testing and began a return to full power.

At the end of the reporting period the plant was operating at 99.9% of rated thermal power.

VYDPF 0411.04 DP 0411 Rev. 5 Page 1 of 1 RT No. 13.F01.18X