

April 7, 1994

Docket No. 50-302

Mr. Percy M. Beard, Jr.
Senior Vice President,
Nuclear Operations
Florida Power Corporation
ATTN: Manager, Nuclear
Licensing (NA2I)
Crystal River Energy Complex
15760 W Power Line Street
Crystal River, Florida 34428-6708

Dear Mr. Beard:


SUBJECT: CRYSTAL RIVER NUCLEAR GENERATING PLANT UNIT 3 - RESPONSE TO GENERIC LETTER (GL) 89-19 (USI A-47), STEAM GENERATOR OVERFILL PROTECTION, MPA B-113 (TAC NO. M74933)

GL 89-19 described the staff's concerns regarding steam generator overfill events as a result of control system failures, and concluded that pressurized water reactor (PWR) plants should provide automatic steam generator overfill protection with associated technical specifications. GL 89-19 requested that each licensee provide a plan and schedule for implementing GL 89-19 recommendations, or appropriate justification for not implementing them. By letters dated March 19, 1990, and July 6, 1993, you responded to GL 89-19. You did not propose to implement the GL 89-19 recommendations and provided justification for your proposal.

We have reviewed your responses to GL 89-19. Based on our evaluation, we conclude that the installation of an automatic steam generator overfill protection system for Crystal River Unit 3 (CR-3) is not justified from a cost/benefit standpoint. Our Safety Evaluation is enclosed.

This completes our action on GL 89-19, MPA B-113 for Crystal River Unit 3 and TAC No. M74933 is closed.

Sincerely,



L. Raghavan, Project Manager
Project Directorate II-2
Division of Reactor Projects - I/II
Office of Nuclear Reactor Regulation

9404180095 940407
PDR ADOCK 05000302
P PDR

cc w/enclosure:
See next page

Enclosure:
Safety Evaluation

Distribution
Docket File
NRC & Local PDRs
PDII-2 RF
SVarga

GLainas
HBerkow
ETana
LRaghavan

KJabbour, PDII-3
OGC
ACRS (10)
DVerelli, RII
JWermiel, HICB

Office	LA: PDII2	PM: PDII2	PD: PDII2	HICB	
Name	E.Tana <i>ETT</i>	L.Raghavan <i>LR</i>	H.Berkow <i>HB</i>	JWermiel <i>JW</i>	
Date	04/7/94	04/4/94	04/7/94	04/5/94	

OFFICIAL RECORD COPY - DOCUMENT NAME: G:\CRYSTAL\GL89-19.SER

130097
NRC FILE CENTER COPY

DF01/0