

8-4-78

PRELIMINARY NOTIFICATION

No.: PN-III-78-62
Date: August 4, 1978

Facility: Union Electric Company, Callaway Unit 1
(DN 50-483), Callaway County, MO

Subject: CONSTRUCTION ACCIDENT

Two workers at the Callaway site were seriously injured at about 11:00 a.m., on August 4, 1978, when a support girder for the polar crane rail fell on them. The support girder had just been placed on the brackets, the rigging had been disconnected and was being raised up when it caught on the support girder and knocked it off of the brackets.

Local press interest is anticipated.

OSHA has been notified.

RIII received notification of the event at 2:00 p.m., on August 4, 1978. The above information is current as of 2:00 p.m., on August 4, 1978. The State of Missouri is being notified.

Contact: E. R. Schweibinz, D. W. Hayes, R. F. Heishman.
Prepared By Section Chief Branch Chief